

September 27, 2001

Mr. W. R. McCollum, Jr.
Vice President, Oconee Site
Duke Energy Corporation
7800 Rochester Highway
Seneca, SC 29672

SUBJECT: REVISION TO TECHNICAL SPECIFICATION BASES B 3.7.16 - OCONEE
NUCLEAR STATION, UNITS 1, 2, AND 3

Dear Mr. McCollum:

By letter dated September 4, 2001, you informed the staff of a change to the Oconee Nuclear Station, Units 1, 2, and 3 Technical Specifications that only affects the Bases of TS 3.7-16, "Control Room Area Cooling Systems (CRACS)." The change clarifies the Control Room Ventilation System and the Chilled Water System descriptions by replacing the reference to water cooled condensing units with water cooled chillers and adding a description of the condenser service water pumps to the description of what constitutes a train.

The purpose of this letter is to distribute the enclosed List of Effective Page and TS page to the appropriate TS manual holders.

Sincerely,

/RA/

David E. LaBarge, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

Enclosure: List of Effective Page and Revised Bases Page

cc w/encl: See next page

Mr. W. R. McCollum, Jr.
Vice President, Oconee Site
Duke Energy Corporation
7800 Rochester Highway
Seneca, SC 29672

September 27, 2001

SUBJECT: REVISION TO TECHNICAL SPECIFICATION BASES B 3.7.10 - OCONEE
NUCLEAR STATION, UNITS 1, 2, AND 3

Dear Mr. McCollum:

By letter dated September 4, 2001, you informed the staff of a change to the Oconee Nuclear Station, Units 1, 2, and 3 Technical Specifications that only affects the Bases of TS 3.7-16, "Control Room Area Cooling Systems (CRACS)." The change clarifies the Control Room Ventilation System and the Chilled Water System descriptions by replacing the reference to water cooled condensing units with water cooled chillers and adding a description of the condenser service water pumps to the description of what constitutes a train.

The purpose of this letter is to distribute the enclosed List of Effective Page and TS page to the appropriate TS manual holders.

Sincerely,
/RA/

David E. LaBarge, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

Enclosure: List of Effective Page and Revised Bases Page

cc w/encl: See next page

Distribution:

PUBLIC
PDII-1 RF (paper copy)
RidsNrrDlpmLpdii
RidsNrrDlpmLpdii1
RidsNrrPMDLaBarge
RidsNrrLAHawes
RidsOgcRp
G. Hill (6 paper copies)

RidsNRRWBeckner
RidsAcrcAcrcnwMail Center
RidsRegionIIMailCenter

Document Name: G:\PDII-1\OCONEE\BAS CHG0904 OCO.WPD

To receive a copy of this document, indicate in the box:

"C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

Accession Number ML

OFFICE	PM:PDII/S1	<input checked="" type="checkbox"/> c	LA:PDII/S1	<input type="checkbox"/>	ASC:PDII/1	<input type="checkbox"/>
NAME	DLaBarge		CHawes		RLaufer	
DATE	09/27/01		09/26/01		09/27/01	

OFFICIAL RECORD COPY

Oconee Nuclear Station

cc:

Ms. Lisa F. Vaughn
 Legal Department (PBO5E)
 Duke Energy Corporation
 422 South Church Street
 Charlotte, North Carolina 28201-1006

Anne W. Cottingham, Esquire
 Winston and Strawn
 1400 L Street, NW
 Washington, DC 20005

Manager, LIS
 NUS Corporation
 2650 McCormick Drive, 3rd Floor
 Clearwater, Florida 34619-1035

Senior Resident Inspector
 U. S. Nuclear Regulatory
 Commission
 7812B Rochester Highway
 Seneca, South Carolina 29672

Mr. Henry Porter, Director
 Division of Radioactive Waste Management
 Bureau of Land and Waste Management
 Department of Health and Environmental
 Control
 2600 Bull Street
 Columbia, South Carolina 29201-1708

Mr. Michael A. Schoppman
 Framatome ANP
 1911 North Ft. Myer Drive
 Suite 705
 Rosslyn, VA 22209

Mr. L. E. Nicholson
 Compliance Manager
 Duke Energy Corporation
 Oconee Nuclear Site
 7800 Rochester Highway
 Seneca, South Carolina 29672

Ms. Karen E. Long
 Assistant Attorney General
 North Carolina Department of
 Justice
 P. O. Box 629
 Raleigh, North Carolina 27602

Mr. C. Jeffrey Thomas
 Manager - Nuclear Regulatory
 Licensing
 Duke Energy Corporation
 526 South Church Street
 Charlotte, North Carolina 28201-1006

Mr. Richard M. Fry, Director
 Division of Radiation Protection
 North Carolina Department of
 Environment, Health, and
 Natural Resources
 3825 Barrett Drive
 Raleigh, North Carolina 27609-7721

Mr. Peter R. Harden, IV
 VP-Customer Relations and Sales
 Westinghouse Electric Company
 5929 Carnegie Blvd.
 Suite 500
 Charlotte, North Carolina 28209