April 18, 1996

Mr. J.P. O'Hanlon Senior Vice President - Nuclear Virginia Electric and Power Company 5000 Dominion Blvd. Glen Allen, Virginia 23060

DISTRIBUTION:

See next page

SUBJECT: SURRY UNITS 1 AND 2 - ISSUANCE OF AMENDMENTS RE: 10 CFR PART 50, APPENDIX J OPTION B PERFORMANCE BASED CONTAINMENT LEAKAGE RATE TESTING (TAC NOS. M94079 AND M94080)

Dear Mr. O'Hanlon:

The Commission has issued the enclosed Amendment No. 208 to Facility Operating License No. DPR-32 and Amendment No. 208 to Facility Operating License No. DPR-37 for the Surry Power Station, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications (TS) in response to your application transmitted by letter dated November 20, 1995, as supplemented March 14, 1996.

These amendments would permit the use of 10 CFR Part 50 Appendix J, Option B, performance-based containment leakage rate testing.

A copy of the Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by:

Bart C. Buckley, Senior Project Manager Project Directorate II-1 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 208 to DPR-32
- 2. Amendment No. 208 to DPR-37
- Safety Evaluation 3.

7604250365 960418

ADOCK 05000280

PNR

PDR

cc w/enclosures: See next page

Document Name - G:\SURRY\SU94079.AMD

CP-1

To rece attach	eive a copy of tl nent/enclosure	nis "E	<pre>document, indic " = Copy with at</pre>	cate in the box: ctachment/enclose	" C " = Copy without ure " N " = N g /copy	CHB
OFFICE	LA:PDII-1:DRPE	٤	PM:PDII-1:DRPE) ~D	E D:PDII-1	OGC 40 W	SCSB
NAME	EDunnington STD		BBuckley	Elmbro	CHOULER	CBerlinger
DATE	419196		4111 196	4118196	4 1 6 96	04/11/96
			OFFICIAL REC	CORD COPY		BW

OFFICIAL RECORD COPY

NRC FILE CENTER COPY

AMENDMENT NO. 208 TO FACILITY OPERATING LICENSE NO. DPR-32 - SURRY UNIT 1 AMENDMENT NO. 208 TO FACILITY OPERATING LICENSE NO. DPR-37 - SURRY UNIT 2 Distribution Docket File PUBLIC PDII-1 RF S. Varga J. Zwolinski E. Dunnington B. Buckley OGC G. Hill (4), TWFN, 5/C/3 C. Grimes, 11/F/23 ACRS

Dhoj

Mr. J. P. O'Hanlon Virginia Electric and Power Company

cc:

Mr. Michael W. Maupin, Esq. Hunton and Williams Riverfront Plaza, East Tower 951 E. Byrd Street Richmond, Virginia 23219

Mr. David Christian, Manager Surry Power Station Virginia Electric and Power Company 5570 Hog Island Road Surry, Virginia 23883

Senior Resident Inspector Surry Power Station U. S. Nuclear Regulatory Commission 5850 Hog Island Road Surry, Virginia 23883

Chairman Board of Supervisors of Surry County Surry County Courthouse Surry, Virginia 23683

Dr. W. T. Lough Virginia State Corporation Commission Division of Energy Regulation P. O. Box 1197 Richmond, Virginia 23209

Regional Administrator, Region II U. S. Nuclear Regulatory Commission 101 Marietta Street N.W., Suite 2900 Atlanta, Georgia 30323

Robert B. Strobe, M.D., M.P.H. State Health Commissioner Office of the Commissioner Virginia Department of Health P.O. Box 2448 Richmond, Virginia 23218 Surry Power Station

Office of the Attorney General Commonwealth of Virginia 900 East Main Street Richmond, Virginia 23219

Mr. M. L. Bowling, Manager Nuclear Licensing & Operations Support Innsbrook Technical Center Virginia Electric and Power Company 5000 Dominion Blvd. Glen Allen, Virginia 23060

Mr. Al Belisle U.S. Nuclear Regulatory Commission 101 Marietta Street, N.W. Suite 2900 Atlanta, Georgia 30323-0199



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

VIRGINIA ELECTRIC AND POWER COMPANY

DOCKET NO. 50-280

SURRY POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 208 License No. DPR-32

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company (the licensee) dated November 20, 1995 as supplemented March 14, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.



- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-32 is hereby amended to read as follows:
 - (B) <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. 208, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

EV Ambio

Eugene V. Imbro, Director Project Directorate II-1 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: April 18, 1996



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

VIRGINIA ELECTRIC AND POWER COMPANY

DOCKET NO. 50-281

SURRY POWER STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 208 License No. DPR-37

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company (the licensee) dated November 20, 1995 as supplemented March 14, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission:
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-37 is hereby amended to read as follows:
 - (B) <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. 208 , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

EVAmbro

Eugene V. Imbro, Director Project Directorate II-1 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: April 18, 1996

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 208 TO FACILITY OPERATING LICENSE NO. DPR-32 AMENDMENT NO. 208 TO FACILITY OPERATING LICENSE NO. DPR-37

DOCKET NOS. 50-280 AND 50-281

Revise Appendix A as follows:

<u>Remove Pages</u>	<u>Insert Pages</u>
TS 4.4 -1	TS 4.4-1
TS 4.4-2	TS 4.4-2
TS 4.4-3	
TS 6.6-11	TS 6.6-11
TS 6.6-12	

4.4 <u>CONTAINMENT TESTS</u>

Applicability

Applies to containment leakage testing.

Objective

To assure that leakage of the primary reactor containment and associated systems is held within allowable leakage rate limits; and to assure that periodic surveillance is performed to assure proper maintenance and leak repair during the service life of the containment. Specification

- A. Periodic and post-operational integrated leakage rate tests of the containment shall be performed in accordance with the requirements of 10 CFR 50, Appendix J, "Reactor Containment Leakage Testing for Water Cooled Power Reactors."
- B. Containment Leakage Rate Testing Requirements
 - The containment and containment penetrations leakage rate shall be demonstrated by performing leakage rate testing as required by 10 CFR 50 Appendix J, Option B, as modified by approved exemptions, and in accordance with the guidelines contained in Regulatory Guide 1.163, dated September, 1995. Leakage rate acceptance criteria are as follows:
 - a. An overall integrated leakage rate of less than or equal to La, 0.1 percent by weight of containment air per 24 hours, at calculated peak pressure (Pa).
 - b. A combined leakage rate of less than or equal to 0.60 La for all penetrations and valves subject to Type B and C testing when pressurized to Pa.

Prior to entering an operating condition where containment integrity is required the as-left Type A leakage rate shall not exceed 0.75 La and the combined leakage rate of all penetrations subject to Type B and C testing shall not exceed 0.6 La.

2. The provisions of Specification 4.0.2 are not applicable.

Basis

The leak tightness testing of all liner welds was performed during construction by welding a structural steel test channel over each weld seam and performing soap bubble and halogen leak tests.

Amendment Nos. 208 and 208

The containment is designed for a maximum pressure of 45 psig. The containment is maintained at a subatmospheric air partial pressure consistent with TS Figure 3.8-1 depending upon the cooldown capability of the Engineered Safeguards and will not rise above 45 psig for any postulated loss-of-coolant accident.

The initial test pressure for the Type A test is 47.0 psig to allow for containment expansion and equalization. A review was performed to determine the effects of pressurizing containment above its design pressure of 45.0 psig. This review was based on the original containment test at 52 psig. During that test, the calculated stresses were found to be well within the allowable yield strength of the structural reinforcing bars, therefore performance of the Type A test at 47 psig will have no detrimental effect on the containment structure.

All loss-of-coolant accident evaluations have been based on an integrated containment leakage rate not to exceed 0.1% of containment volume per 24 hr.

The above specification satisfies the conditions of 10 CFR 50.54(o) which stated that primary reactor containments shall meet the containment leakage test requirements set forth in Appendix J.

The limitations on closure and leak rate for the containment airlocks are required to meet the restrictions on containment integrity and containment leak rate. Surveillance testing of the airlock seals provides assurance that the overall airlock leakage will not become excessive due to seal damage during the intervals between airlock leakage tests.

References

UFSAR Section 5.4	Design Evaluation of Containment Tests and Inspections of			
	Containment			
UFSAR Section 7.5.1	Design Bases of Engineered Safeguards Instrumentation			
UFSAR Section 14.5	Loss of Coolant Accident			
10 CFR 50 Appendix J	"Primary Reactor Containment Leakage Testing for Water Cooled Power Reactors"			

Amendment Nos. 208 and 208

I

1

C. Special Reports

In the event that the Reactor Vessel Overpressure Mitigating System is used to mitigate a RCS pressure transient, submit a Special Report to the Commission within 30 days. The report shall describe the circumstances initiating the transient, the effect of the PORVs or the administrative controls on the transient and any corrective action necessary to prevent recurrence.

FOOTNOTES

- 1. A single submittal may be made for a multiple unit station. The submittal should combine those sections that are common to all units at the station.
- 2. This tabulation supplements the requirements of Section 20.2206 of 10 CFR Part 20.
- 3. A single submittal may be made for a multi-unit station. The submittal should combine those sections that are common to all units at the station; however, for units with separate radwaste systems, the submittal shall specify the releases of radioactive material from each unit.

Amendment Nos. 208 and 208



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION RELATED TO AMENDMENT NO. 208 TO FACILITY OPERATING LICENSE NO. DPR-32 AND AMENDMENT NO. 208 TO FACILITY OPERATING LICENSE NO. DPR-37 VIRGINIA ELECTRIC AND POWER COMPANY SURRY POWER STATION, UNIT NOS. 1 AND 2 DOCKET NOS. 50-280 AND 50-281

1.0 INTRODUCTION

On September 12, 1995, the U.S. Nuclear Regulatory Commission (NRC) approved issuance of a revision to 10 CFR Part 50, Appendix J, "Primary Reactor Containment Leakage Testing for Water-Cooled Power Reactors" which was subsequently published in the <u>Federal Register</u> on September 26, 1995, and became effective on October 26, 1995. The NRC added Option B, "Performance-Based Requirements," to allow licensees to voluntarily replace the prescriptive testing requirements of 10 CFR Part 50 Appendix J with testing requirements based on both overall performance and the performance of individual components.

By letters dated November 20, 1995, and March 14, 1996, Virginia Electric and Power Company, the licensee for Surry Power Station Units 1 and 2, applied for amendments to Facility Licenses DPR-32 and DPR-37. The proposed changes would permit implementation of 10 CFR Part 50 Appendix J, Option B. The licensee has proposed changes to the technical specifications (TS) which include a reference to Regulatory Guide 1.163, "Performance-Based Containment Leak Test Program," dated September 1995, which specifies a method acceptable to the NRC for complying with Option B.

The March 14, 1996, letter provided clarifying information that did not change the scope of the November 20, 1995, submittal and the proposed no significant hazards consideration.

2.0 BACKGROUND

Compliance with Appendix J provides assurance that the primary containment, including those systems and components which penetrate the primary containment, do not exceed the allowable leakage rate specified in the TS and bases. The allowable leakage rate is determined so that the leakage assumed in the safety analyses is not exceeded.

On February 4, 1992, the NRC published a notice in the <u>Federal Register</u> (57 FR 4166) discussing a planned initiative to begin eliminating requirements

9604250373 960418 PDR ADOCK 05000280 P PDR marginal to safety which impose a significant regulatory burden. 10 CFR Part 50, Appendix J, "Primary Containment Leakage Testing for Water-Cooled Power Reactors," was considered for this initiative and the staff undertook a study of possible changes to this regulation. The study examined the previous performance history of domestic containments and examined the effect on risk of a revision to the requirements of Appendix J. The results of this study are reported in NUREG-1493, "Performance-Based Leak-Test Program."

Based on the results of this study, the staff developed a performance-based approach to containment leakage rate testing. On September 12, 1995, the NRC approved issuance of this revision to 10 CFR Part 50, Appendix J, which was subsequently published in the <u>Federal Register</u> on September 26, 1995, and became effective on October 26, 1995. The revision added Option B, "Performance-Based Requirements," to Appendix J to allow licensees to voluntarily replace the prescriptive testing requirements of Appendix J with testing requirements based on both overall and individual component leakage rate performance.

Regulatory Guide 1.163, "Performance-Based Containment Leak Test Program," dated September 1995, was developed as a method acceptable to the NRC staff for implementing Option B. This regulatory guide states that the Nuclear Energy Institute (NEI) guidance document NEI 94-01, Rev. 0, "Industry Guideline for Implementing Performance-Based Option of 10 CFR Part 50, Appendix J," provides methods acceptable to the NRC staff for complying with Option B with four exceptions which are described therein.

Option B requires that the regulatory guide, or other implementation document used by a licensee to develop a performance-based leakage testing program, must be included, by general reference, in the plant TS. The licensee has referenced Regulatory Guide 1.163, dated September 1995, in the Surry TS.

Regulatory Guide 1.163, dated September 1995, specifies an extension in Type A test frequency to at least one test in 10 years based upon two consecutive successful tests. Type B tests may be extended up to a maximum interval of 10 years based upon completion of two consecutive successful tests and Type C tests may be extended up to 5 years based on two consecutive successful tests.

By letter dated October 20, 1995, NEI proposed TS to implement Option B. After some discussion, the staff and NEI agreed on final TS which were transmitted to NEI in a letter dated November 2, 1995. These TS are to serve as a model for licensees to develop plant specific TS in preparing amendment requests to implement Option B.

In order for a licensee to determine the performance of each component, factors that are indicative of or affect performance, such as an administrative leakage limit, must be established. The administrative limit is selected to be indicative of the potential onset of component degradation.

2

Although these limits are subject to NRC inspection to assure that they are selected in a reasonable manner, they are not TS requirements. Failure to meet an administrative limit requires the licensee to return to the minimum value of the test interval.

Option B requires that the licensee maintain records to show that the criteria for Type A, B, and C tests have been met. In addition, the licensee must maintain comparisons of the performance of the overall containment system and the individual components to show that the test intervals are adequate. These records are subject to NRC inspection.

3.0 EVALUATION

The licensee's November 20, 1995, and March 14, 1996, letters to the NRC proposed TS changes to permit the use of Option B of the revised 10 CFR Part 50, Appendix J. Option B permits a licensee to choose Type A; or Type B and C; or Type A, B and C; testing to be done on a performance basis. The licensee has elected to perform Type A, B, and C testing on a performance basis. The TS changes refer to Regulatory Guide 1.163, "Performance-Based Containment Leak Test Program," dated September 1995, which specifies methods acceptable to the NRC for complying with Option B. This requires changes to existing TS 4.4.B, 4.4.F, and 6.6.B.4.

These TS changes replace specific surveillance requirements related to containment leakage rate testing and the corresponding acceptance criteria and test methods with a requirement to perform the required testing as required by 10 CFR Part 50, Appendix J, Option B, as modified by approved exemptions, and in accordance with the guidelines contained in Regulatory Guide 1.163, dated September 1995. The licensee chose not to include its performance-based testing program in the TS as an administrative program, as was proposed in the November 2, 1995, letter to NEI discussed above. The November 2, 1995, letter provided guidance to licensees but is not an NRC requirement. The staff has reviewed the licensee's proposed TS changes and finds them consistent with the requirements of 10 CFR Part 50, Appendix J, Option B, in that the changes include general reference in the TS to the regulatory guide used by the licensee to develop the performance-based leakage-testing program for Surry Units 1 and 2. The staff therefore concludes that the licensee's request to implement 10 CFR Part 50, Appendix J, Option B, is acceptable.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Virginia State official was notified of the proposed issuance of the amendments. The State official had no comment.

5.0 ENVIRONMENTAL CONSIDERATION

These amendments change a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no

significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that these amendments involve no significant hazards consideration and there has been no public comment on such finding (60 FR 65686). Accordingly, these amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of these amendments.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: J. Pulsipher

Date: April 18, 1996