

OCONEE NUCLEAR STATION
 TECHNICAL SPECIFICATIONS - BASES
 LIST OF EFFECTIVE PAGES

<u>PAGE</u>	<u>AMENDMENT</u>	<u>REVISION DATE</u>
B 3.7.12-2	BASES REVISION	01/31/00
B 3.7.13-1	300/300/300	12/16/98
B 3.7.13-2	300/300/300	12/16/98
B 3.7.14-1	300/300/300	12/16/98
B 3.7.14-2	300/300/300	12/16/98
B 3.7.14-3	300/300/300	12/16/98
B 3.7.15-1	300/300/300	12/16/98
B 3.7.15-2	300/300/300	12/16/98
B 3.7.15-3	300/300/300	12/16/98
B 3.7.16-1	300/300/300	12/16/98
B 3.7.16-2	300/300/300	12/16/98
B 3.7.16-3	BASES REVISION	08/23/01
B 3.7.16-4	BASES REVISION	01/31/00
B 3.7.16-5	300/300/300	12/16/98
B 3.7.17-1	300/300/300	12/16/98
B 3.7.17-2	BASES REVISION	03/27/99
B 3.7.17-3	300/300/300	12/16/98
B 3.8.1-1	300/300/300	12/16/98
B 3.8.1-2	300/300/300	12/16/98
B 3.8.1-3	BASES REVISION	03/27/99
B 3.8.1-4	300/300/300	12/16/98
B 3.8.1-5	300/300/300	12/16/98
B 3.8.1-6	300/300/300	12/16/98
B 3.8.1-7	300/300/300	12/16/98
B 3.8.1-8	300/300/300	12/16/98
B 3.8.1-9	300/300/300	12/16/98
B 3.8.1-10	300/300/300	12/16/98
B 3.8.1-11	BASES REVISION	01/31/00
B 3.8.1-12	BASES REVISION	03/27/99
B 3.8.1-13	300/300/300	12/16/98
B 3.8.1-14	BASES REVISION	01/31/00
B 3.8.1-15	300/300/300	12/16/98
B 3.8.1-16	300/300/300	12/16/98

BASES (continued)

LCO Two redundant trains of the CRACS and WC Systems train are required to be OPERABLE to ensure that at least one train in each system is available, assuming a single active failure disables the other train in one or both systems. Total system failure could result in the equipment operating temperature exceeding limits. A Train of CRVS consists of one of the redundant AHUs specified in Table B 3.7.16-1 for each of the three portions of the control area for an Oconee unit and associated ducts, dampers, instrumentation and controls. A single AHU can function as a component in more than one train on an Oconee unit and can function as a component on trains in multiple Oconee units. For example AHU-34, and its associated ducts, damper, instrumentation and controls, can simultaneously function as the AHU for a train of CRVS serving the Unit 1 cable room, the Unit 1 equipment room as well as the Unit 2 cable room. The combination of AHU-34 and either AHU-11 or AHU-12 along with their associated equipment constitutes a combination of equipment which can satisfy the requirement for one train of CRVS for Unit 1. Additionally, AHU-34 can simultaneously serve as the AHU for the portion of a Unit 2 CRVS train serving the Unit 2 cable room. AHU-35 in combination with either AHU-11 or AHU-12 along with their associated equipment constitutes a combination of equipment which can satisfy the requirement for one train of CRVS for Unit 2.

The CRACS is considered OPERABLE when the individual components that are necessary to maintain control area temperature are OPERABLE in both trains of CRVS and WC System. Each CRVS train listed in Table B 3.7.16-1 includes the associated ductwork, instrumentation, and air handling unit, which includes the fan, fan motor, cooling coils, and isolation dampers. Each WC train consists of a chiller, chilled water pump, condenser service water pump, and associated controls. Although each chilled water pump is normally associated with, and aligned to, a specific chiller, any OPERABLE chilled water pump maybe aligned to any OPERABLE chiller to maintain one OPERABLE train when a component has been removed from service. The two redundant trains can include a temporarily installed full-capacity control area cooling train. Any temporary cooling train shall have a power source with availability equivalent to the source of the permanently installed train. In addition, the CRACS must be OPERABLE to the extent that air circulation can be maintained.

APPLICABILITY In MODES 1, 2, 3, and 4 the CRACS must be OPERABLE to ensure that the control area temperature will not exceed equipment OPERABILITY requirements.