

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS																
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD																				
				1	2	3	4	1	2	3	4	1	2	3	4																	
105800	8-SJ-1162-13 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	C	-	-	-	X	-	-	-	**CALIBRATION BLOCK** LIMITATION: EXAMINED (PT) 99.1% & (UT) 94.1% OF THE CODE REQUIRED SURFACE & VOLUME, DUE TO AN OBSTRUCTION FROM THE BRANCH CONNECTION AT THE TOP CENTER LINE OF THE PIPE. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **8-SS-XX-.860-23-SAM**
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE. LIMITATION: EXAMINED (PT) 99.1% & (UT) 94.1% OF THE CODE REQUIRED SURFACE & VOLUME, DUE TO AN OBSTRUCTION FROM THE BRANCH CONNECTION AT THE TOP CENTER LINE OF THE PIPE.																																
105900	8-SJ-1162-14 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	-	-	-	-	LIMITED UT FROM DOWNSTREAM SIDE DUE TO WELD 8-SJ-1162-15. **8-SS-XX-.860-23-SAM**				
106000	8-SJ-1162-15 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	-	-	-	-	LIMITED UT FROM UPSTREAM SIDE DUE TO WELD 8-SJ-1162-14. **8-SS-XX-.860-23-SAM**				
106100	8-SJ-1162-16 PIPE TO TEE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	-	-	-	-	LIMITED UT FROM DOWNSTREAM SIDE DUE TO PERMANENT PIPE SUPPORT INTERFERENCE. **8-SS-XX-.860-23-SAM**				

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**				
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD								
				1	2	3	4	1	2	3	4	1	2	3	4					
106200	8-SJ-1162-17 TEE TO 4" CAP	B-J B9.11	PT UT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NOTE: ID/OD RATIO REQUIRES THE USE OF A <30 DEGREE TRANSDUCER (REF. AR#990423129, CRCA# 01). (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-XX-.689-27-SAM**
89 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																				
106300	8-SJ-1162-18 TEE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**
106400	8-SJ-1162-19 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**
106500	8-SJ-1162-20 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**
106600	8-SJ-1162-21 PIPE TO PIPE	B-J B9.11	PT UT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **8-SS-XX-.860-23-SAM**
89 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																				
106700	8-SJ-1162-22 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**
106800	8-SJ-1162-22A PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
8-SJ-1162 (REF. DWG. NO. A-59)																		
106900	8-SJ-1162-23 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **8-SS-XX-.860-23-SAM**
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																		
8-SJ-1162 (REF. DWG. NO. A-58, A-59)																		
107000	8-SJ-1162-24 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	LIMITED UT FROM DOWNSTREAM SIDE AND NO UT ON WELD DUE TO PIPE SUPPORT INTERFERENCE. **8-SS-XX-.860-23-SAM**
107100	8-SJ-1162-25 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	LIMITED UT FROM UPSTREAM SIDE DUE TO ADJACENT PIPE. LIMITED UT FROM DOWNSTREAM SIDE DUE TO "I" BEAM. **8-SS-XX-.860-23-SAM**
107200	8-SJ-1162-26 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	LIMITED UT FROM UPSTREAM SIDE DUE TO ADJACENT PIPE. LIMITED UT FROM DOWNSTREAM SIDE DUE TO PIPE SUPPORT. **8-SS-XX-.860-23-SAM**
107300	8-SJ-1162-27 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
107400	8-SJ-1162-28 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	C	-	-	-	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **8-SS-XX-.860-23-SAM**
92 - UT45 INDICATIONS 1, 2, 4 AND 5 ARE GEOMETRIC REFLECTORS FROM THE WELD ROOT. INDICATIONS 3 AND 6 ARE CROWN GEOMETRY.																	
107500	8-SJ-1162-29 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**
107600	8-SJ-1162-30 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**
107700	8-SJ-1162-30PS PIPE TO PENETRATION	B-K B10.20	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 506885 (1C-12SIA-019). UT BASELINE EXAMINATION PERFORMED.
107800	8-SJ-1162-31 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO PIPE SUPPORT. **8-SS-XX-.860-23-SAM**
107900	8-SJ-1162-32 PIPE TO ELBOW	B-J B9.11	PT UT	1	C	-	-	-	-	-	-	-	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **8-SS-XX-.860-23-SAM**
91 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																	
108000	8-SJ-1162-33 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**								
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD												
				1	2	3	4	1	2	3	4	1	2	3	4									
108100	8-SJ-1162-34 PIPE TO TEE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO TEE CONFIGURATION. **8-SS-XX-.860-23-SAM**
108200	8-SJ-1162-35 TEE TO REDUCER	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO REDUCER CONFIGURATION. LIMITED UT FROM UPSTREAM SIDE DUE TO INNER RADIUS OF TEE. **8-SS-XX-.860-23-SAM**
108300	8-SJ-1162-36 TEE TO REDUCER	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	LIMITED UT FROM UPSTREAM SIDE DUE TO INNER RADIUS OF TEE. NO UT FROM DOWNSTREAM SIDE DUE TO REDUCER CONFIGURATON. **8-SS-XX-.860-23-SAM**
108400	8-SJ-1152-1 VALVE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO VALVE CONFIGURAION. **8-SS-XX-.860-23-SAM**
108500	8-SJ-1152-1PL-1 THRU 6 PIPE LUG	B-K B10.20	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	REF. SUM# 507250 (1P-11SIH-016). REDEFINED AS 1PL-1 THRU 6. SEE SUMMARY NUMBERS 108500, 108600, 108700, 108800, 108900 & 109000. **8-SS-XX-.860-23-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**				
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD								
				1	2	3	4	1	2	3	4	1	2	3	4					
109100	8-SJ-1152-2 PIPE TO ELBOW	B-J B9.11	PT UT	1 C	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **8-SS-XX-.860-23-SAM**
89 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																				
109200	8-SJ-1152-3 ELBOW TO PIPE	B-J B9.11	PT UT	1 -	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **8-SS-XX-.860-23-SAM**
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																				
109300	8-SJ-1152-3PS-1 & 2 PIPE SUPPORT	B-K B10.20	PT	1 -	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 507240 (1P-11SIG-034). REDEFINED AS 3PS-1 & 2. SEE SUMMARY NOS. 109300 & 109400.
109500	8-SJ-1152-4 PIPE TO PIPE	B-J B9.11	PT UT	1 -	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO PIPE CONFIGURAION. **8-SS-XX-.860-23-SAM**
109510	8-SJ-1152-4PL-1 THRU 4 PIPE LUGS	B-K B10.20	PT	1 -	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	REF. NON-IWF SUM# 505285 (1P-SIG-PS10). INACCESSIBLE, DO NOT SELECT.
109550	B8-SJ-1152-4PS-1 PIPE SUPPORT	B-K B10.20	PT	1 -	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NON LOAD BEARING MEMBER.

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
109600	8-SJ-1152-4PS-2 PENETRATION TO PIPE	B-K B10.20	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 507280 (1P-SIA-PS10). NO UT FROM UPSTREAM SIDE DUE TO PENETRATION CONFIGURATION. NO UT FROM DOWNSTREAM SIDE DUE TO PIPE CONFIGURATION.
93 - W.O.#931121035 TO PERFORM NDE.																	
109700	8-SJ-1152-5 PIPE TO PIPE	B-J B9.11	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO PIPE CONFIGURATION. **8-SS-XX-.860-23-SAM**
93 - W.O.#931121035 TO PERFORM NDE. THE UT45 INDICATIONS ARE GEOMETRIC INDICATIONS FROM THE WELD ROOT AND COUNTERBORE.																	
109900	8-SJ-1152-6 PIPE TO ELBOW	B-J B9.11	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **8-SS-XX-.860-23-SAM**
93 - W.O.#931121035 TO PERFORM NDE. THE UT45 INDICATIONS ARE GEOMETRIC INDICATIONS FROM THE WELD ROOT AND COUNTERBORE.																	
110000	8-SJ-1152-7 ELBOW TO PIPE	B-J B9.11	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**
110100	8-SJ-1152-8 PIPE TO ELBOW	B-J B9.11	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**
110200	8-SJ-1152-9 ELBOW TO PIPE	B-J B9.11	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**
99RF	FTI UNDER W.O.#50000402 TO PERFORM NDE. THIS SUM# REPLACES SUM# 110100 , DUE TO A SUPPORT OBSTRUCTION. THE SURFACE EXAM REVEALED A PT INDICATION, WHICH WAS UT EVAL. AS ACCEPTABLE (IWB-3514.3(B)) REF. NOT# 20008522.																

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
8-SJ-1152 (REF. DWG. NO. A-61)																		
110300	8-SJ-1152-10 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	LIMITED UT FROM UPSTREAM SIDE DUE TO PIPE SUPPORT. LIMITED UT FROM DOWNSTREAM SIDE DUE TO 8-SJ-1163-11. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **8-SS-XX-.860-23-SAM**
				2	-	-	-	-	-	-	-	-	-	R	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
99RF - THIS SUM# WAS REPLACED BY SUM# 110200 IN 2/3/1, DUE TO THE LACK OF SCAFFOLDING SUPPORT.																		
8-SJ-1152 (REF. DWG. NO. A-60, A-61)																		
110400	8-SJ-1152-11 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	LIMITED UT FROM UPSTREAM SIDE DUE TO PIPE SUPPORT AND WELD 8-SJ-1152-10. **8-SS-XX-.860-23-SAM**	
				2	-	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-	-		-
-----																		
110500	8-SJ-1152-12 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**	
				2	-	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-	-		-
-----																		
110600	8-SJ-1152-13 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CONFIGURATION. **8-SS-XX-.860-23-SAM**	
				2	-	-	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-	-		-
-----																		
110700	8-SJ-1152-14 ELBOW TO PIPE	B-J B9.11	PT UT	1	C	-	-	-	-	-	-	-	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **8-SS-XX-.860-23-SAM**	
				2	C	-	-	-	-	-	-	-	-	-	-	-		
				3	X	-	-	-	-	-	-	-	-	-	-	-		-

89 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
110800	8-SJ-1152-15 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	**8-SS-XX-.860-23-SAM**
110900	8-SJ-1152-16 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO WALL INTERFERENCE. **8-SS-XX-.860-23-SAM**
111000	8-SJ-1152 (REF. DWG. NO. A-61) 8-SJ-1152-16PS PENETRATION TO PIPE	B-K B10.20	PT UT	1	-	C	-	-	2	-	-	-	-	3	-	-	-	-	REF SUM# 507260 (1C-11SIA-003A). UT PERFORMED DURING FIRST INTERVAL.
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																			
111100	8-SJ-1152 (REF. DWG. NO. A-60, A-61) 8-SJ-1152-17 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO PROXIMITY OF WELD 8-SJ-1152-16PS. **8-SS-XX-.860-23-SAM**
111200	8-SJ-1152-18 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	**8-SS-XX-.860-23-SAM**
111300	8-SJ-1152-19 PIPE TO TEE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	R	3	-	-	-	X	LIMITED UT FROM DOWNSTREAM SIDE, DUE TO INNER RADIUS OF TEE. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **8-SS-XX-.860-23-SAM**
93	DEFERRED TO SIRFO#12.																		
95	W.O.#950526019 TO PERFORM NDE. LIMITED EXAMINATION FROM THE DOWNSTREAM SIDE, DUE TO TEE CONFIGURATION.																		

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**								
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD												
				1	2	3	4	1	2	3	4	1	2	3	4									
111400	8-SJ-1152-20 TEE TO REDUCER	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	LIMITED UT FROM UPSTREAM SIDE DUE TO INNER RADIUS OF TEE. NO UT FROM DOWNSTREAM SIDE DUE TO REDUCER CONFIGURATION. **8-SS-XX-.860-23-SAM**
111500	8-SJ-1152-21 TEE TO REDUCER	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	LIMITED UT FROM UPSTREAM SIDE DUE TO INNER RADIUS OF TEE. NO UT FROM DOWNSTREAM SIDE DUE TO REDUCER CONFIGURATION. **8-SS-XX-.860-23-SAM**
111600	8-SJ-1145-1 TEE TO VALVE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO TEE CONFIGURATION. NO UT FROM DOWNSTREAM SIDE DUE TO VALVE CONFIGURATION. **8-SS-XX-.860-23-SAM**
111700	8-SJ-1145-2 VALVE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO VALVE CONFIGURATION. **8-SS-XX-.860-23-SAM**
111800	8-SJ-1145-3 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	C	3	-	-	-	X	4	-	-	-	-	LIMITED UT FROM DOWNSTREAM SIDE DUE TO HANGER. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **8-SS-XX-.860-23-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**									
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD													
				1	2	3	4	1	2	3	4	1	2	3	4										
111900	8-SJ-1145-3/2-SJ-1147 2 IN. BRANCH CONNECTION	B-J B9.32	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
112000	8-SJ-1145-4 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**
112100	8-SJ-1145-5 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**
112150	8-SJ-1145-5PS PIPE SUPPORT	B-K B10.20	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	REF. SUM# 505480 (1C-14RHG-005).
112200	8-SJ-1145-6 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**
112300	8-SJ-1145-7 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**
112400	8-SJ-1145-8 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	C	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **8-SS-XX-.860-23-SAM**
99RF -	FTI UNDER W.O.#50000402 TO PERFORM NDE.																								
112500	8-SJ-1145-9 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**8-SS-XX-.860-23-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**								
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD												
				1	2	3	4	1	2	3	4	1	2	3	4									
112600	8-SJ-1145-10 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	**8-SS-XX-.860-23-SAM**
112700	8-SJ-1145-11 PIPE TO REDUCER	B-J B9.11	PT UT	1	C	-	-	-	2	C	-	-	-	3	X	-	-	-	4	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **8-SS-XX-.860-23-SAM**
89 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																								
8-SJ-1135 (REF. DWG. NO. A-63)																								
112750	8-SJ-1135-1 REDUCER TO VALVE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO REDUCER CONFIGURATION. NO UT FROM DOWNSTREAM SIDE DUE TO VALVE CONFIGURATION. **8-SS-XX-.860-23-SAM**
112800	8-SJ-1135-2 VALVE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO VALVE CONFIGURATION. **8-SS-XX-.860-23-SAM**
113000	8-SJ-1135-2PS-1 & 2 PIPE SUPPORT	B-K B10.20	PT	1	C	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	REF. SUM# 505430 (1C-13RHG-014). REDEFINED AS 2PS-1 & 2. SEE SUMMARY NUMBERS 113000 & 113050.
113100	8-SJ-1135-3 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	**8-SS-XX-.860-23-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
113300	8-SJ-1135-4 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**8-SS-XX-.860-23-SAM**
113400	8-SJ-1135-5 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	**8-SS-XX-.860-23-SAM**
99RF -	FTI UNDER W.O.#50000402 TO PERFORM NDE. THIS SUM# REPLACES SUM# 113600 IN 2/3/1, DUE TO THE LACK OF SCAFFOLDING SUPPORT.																		
113500	8-SJ-1135-5/2-SJ-1137 2 IN. BRANCH CONNECTION	B-J B9.32	PT	1	C	-	-	-	2	C	-	-	-	3	X	-	-	-	
113600	8-SJ-1135-6 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **8-SS-XX-.860-23-SAM**
99RF -	THIS SUM# WAS REPLACED BY SUM# 113400, DUE TO THE LACK OF SCAFFOLDING SUPPORT.																		
113700	8-SJ-1135-7 ELBOW TO REDUCER	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO REDUCER CONFIGURATION. **8-SS-XX-.860-23-SAM**
113800	6-SJ-1142 (REF. DWG. NO. A-64) REDUCER TO ELBOW	B-J B9.11	PT UT	1	K	C	-	-	2	-	C	-	-	3	-	X	-	-	LIMITED UT FROM UPSTREAM SIDE DUE TO REDUCER CONFIGURATION. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
91 -	EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																		

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
113850	6-SJ-1142-2 ELBOW TO VALVE	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CONFIGURATION. NO UT FROM DOWNSTREAM SIDE DUE TO VALVE CONFIGURATION. **6-SS-160-.764-25-SAM**
113900	6-SJ-1142-3 VALVE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO VALVE CONFIGURATION. **6-SS-160-.764-25-SAM**
114100	6-SJ-1142-3/2-SJ-1149 2 IN. BRANCH CONNECTION	B-J B9.32	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
114200	6-SJ-1142-4 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	LIMITED UT FROM UPSTREAM SIDE DUE TO BRANCH CONNECTION INTERFERENCE. **6-SS-160-.764-25-SAM**
114300	6-SJ-1142-5 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	C	3	-	-	-	X	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
92 -	EXAMINED PER IEB 76-06. UT45 INDICATIONS 1 AND 3 ARE GEOMETRIC REFLECTORS FROM THE WELD ROOT. INDICATION 2 IS A GEOMETRIC REFLECTOR FROM THE COUNTER BORE.																		

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
114400	6-SJ-1142-6 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
114500	6-SJ-1142-7 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
114600	6-SJ-1142-8 ELBOW TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	NO UT FROM UPSTREAM OR DOWNSTREAM SIDES DUE TO ELBOW CURVATURES. **6-SS-160-.764-25-SAM**
114700	6-SJ-1142-9 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
114800	6-SJ-1142-10 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	C	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
99RF -	FTI UNDER W.O.#50000402 TO PERFORM NDE.																		
114900	6-SJ-1142-11 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	C	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
99RF -	FTI UNDER W.O.#50000402 TO PERFORM NDE.																		

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**								
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD												
				1	2	3	4	1	2	3	4	1	2	3	4									
115000	6-SJ-1142-12 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
115100	6-SJ-1142-13 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
115200	6-SJ-1142-14 PIPE TO TEE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO TEE CONFIGURATION. **6-SS-160-.764-25-SAM**
115300	6-SJ-1141 (REF. DWG. NO. A-65) 6-SJ-1141-1 REDUCER TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO REDUCER CONFIGURATION. NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
92 -	EXAMINED PER IEB 76-06. ONE LINEAR INDICATION. SEE CNF SAM1-9. REEXAM AFTER WELD PREPARATION REVEALED NO RECORDABLE INDICATIONS.																							
115350	6-SJ-1141-2 ELBOW TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM UPSTREAM OR DOWNSTREAM SIDES DUE TO ELBOW CURVATURES. **6-SS-160-.764-25-SAM**
115400	6-SJ-1141-3 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**					
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD									
				1	2	3	4	1	2	3	4	1	2	3	4						
115600	6-SJ-1141-4 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
115700	6-SJ-1141-5 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. LIMITED UT FROM DOWNSTREAM SIDE DUE TO ANGLE IRON. **6-SS-160-.764-25-SAM**
115800	6-SJ-1141-6 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	C	-	-	-	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																					
115900	6-SJ-1141-7 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
115950	6-SJ-1141-7PS PIPE SUPPORT	B-K B10.20	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
116000	6-SJ-1141-8 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
116100	6-SJ-1141-9 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. LIMITED UT FROM DOWNSTREAM SIDE DUE TO PIPE HANGER. **6-SS-160-.764-25-SAM**
116200	6-SJ-1141-10 PIPE TO ELBOW	B-J B9.11	PT UT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	-	**6-SS-160-.764-25-SAM**
91 -	EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																		
116300	6-SJ-1141-11 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
116400	6-SJ-1141-12 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
92 -	EXAMINED PER IEB 76-06. UT45 INDICATIONS ARE GEOMETRIC REFLECTORS FROM THE WELD ROOT AND INSIDE SURFACE COUNTER BORE AREA.																		
116500	6-SJ-1141-13 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. NO UT FROM DOWNSTREAM SIDE DUE TO WELDED SUPPORT. **6-SS-160-.764-25-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
116600	6-SJ-1141-14 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
116700	6-SJ-1141-15 ELBOW TO VALVE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. NO UT FROM DOWNSTREAM SIDE DUE TO VALVE CONFIGURATION. **6-SS-160-.764-25-SAM**
116800	6-SJ-1141-16 VALVE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO VALVE CONFIGURATION. **6-SS-160-.764-25-SAM**
116900	6-SJ-1141-17 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
117000	6-SJ-1141-18 ELBOW TO BRANCH CONNECTION	B-J B9.11	PT UT	1	C	-	-	-	2	-	C	-	-	3	-	X	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. NO UT FROM DOWNSTREAM SIDE DUE TO BRANCH CONNECTION CONFIGURATION. REL. REQ. NO. 1. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**

91 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS. PT EXAM REVEALED FIVE LINEAR INDICATIONS. SEE CNF 8. ALL INDICATIONS ARE ALLOWABLE BY CODE. ACCEPTED "AS IS" BY PSE&G PERSONNEL.

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
	6-SJ-1132 (REF. DWG. NO. A-66)																	
117050	6-SJ-1132-1 REDUCER TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO REDUCER CONFIGURATION. NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
117100	6-SJ-1132-2 ELBOW TO VALVE	B-J B9.11	PT UT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. NO UT FROM DOWNSTREAM SIDE DUE TO VALVE CONFIGURATION. **6-SS-160-.764-25-SAM**
117200	6-SJ-1132-3 VALVE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO VALVE CONFIGURATION. **6-SS-160-.764-25-SAM**
117400	6-SJ-1132-3/2-SJ-1139 2 IN. BRANCH CONNECTION	B-J B9.32	PT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	
99RF -	FTI UNDER W.O.#50000402 TO PERFORM NDE.																	
117500	6-SJ-1132-4 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	**6-SS-160-.764-25-SAM**
117600	6-SJ-1132-5 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
117700	6-SJ-1132-6 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	**CALIBRATION BLOCK** (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																		
117800	6-SJ-1132-7 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	**6-SS-160-.764-25-SAM**
117900	6-SJ-1132-7A PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	**6-SS-160-.764-25-SAM**
118000	6-SJ-1132-7B PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	**6-SS-160-.764-25-SAM**
118100	6-SJ-1132-8 PIPE TO ELBOW	B-J B9.11	PT UT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
89 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																		
118200	6-SJ-1132-9 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
118300	6-SJ-1132-10 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
118400	6-SJ-1132-11 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	C	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
93 -	DEFERRED TO SIRFO#12.																	
95 -	W.O.#950526019 TO PERFORM NDE.																	
118500	6-SJ-1132-12 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
118600	6-SJ-1132-13 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
118700	6-SJ-1132-14 PIPE TO TEE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO TEE CONFIGURATION. **6-SS-160-.764-25-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
	6-SJ-1131 (REF. DWG. NO. A-67)																	
118800	6-SJ-1131-1 REDUCER TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO REDUCER CONFIGURATION. **6-SS-160-.764-25-SAM**
118900	6-SJ-1131-2 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	C	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																		
119000	6-SJ-1131-3 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
119100	6-SJ-1131-4 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
119200	6-SJ-1131-5 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**





SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
119800	6-SJ-1131-10 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	C	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
92 - EXAMINED PER IEB 76-06. UT45 INDICATIONS ARE GEOMETRIC REFLECTORS FROM THE WELD ROOT.																	
119900	6-SJ-1131-11 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
120000	6-SJ-1131-12 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
120100	6-SJ-1131-13 ELBOW TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM OR DOWNSTREAM SIDES DUE TO ELBOW CURVATURES. **6-SS-160-.764-25-SAM**
120200	6-SJ-1131-14 ELBOW TO PIPE	B-J B9.11	PT UT	1	C	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO PIPE SUPPORT. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**

89 - LIMITED EXAMINATION DUE TO ADJACENT PIPE. EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
120300	6-SJ-1131-15 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
120400	6-SJ-1131-16 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
120500	6-SJ-1131-17 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
120600	6-SJ-1131-18 ELBOW TO VALVE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	C	3	-	-	-	X	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. NO UT FROM DOWNSTREAM SIDE DUE TO VALVE CONFIGURATION. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
92 -	EXAMINED PER IEB 76-06.																		
120700	6-SJ-1131-19 VALVE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO VALVE CONFIGURATION. **6-SS-160-.764-25-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
120800	6-SJ-1131-20 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
120850	6-SJ-1131-21 ELBOW TO BRANCH CONNECTION	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. NO UT FROM DOWNSTREAM SIDE DUE TO BRANCH CONNECTION CONFIGURATION. **6-SS-160-.764-25-SAM**
	6-SJ-1122 (REF. DWG. NO. A-68)																		
120900	6-SJ-1122-1 REDUCER TO VALVE	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO REDUCER CONFIGURATION. NO UT FROM DOWNSTREAM SIDE DUE TO VALVE CONFIGURATION. **6-SS-160-.764-25-SAM**
121000	6-SJ-1122-2 VALVE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO VALVE CONFIGURATION. **6-SS-160-.764-25-SAM**
121200	6-SJ-1122-3 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**

99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS								
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD												
				1	2	3	4	1	2	3	4	1	2	3	4									
121300	6-SJ-1122-4 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	**CALIBRATION BLOCK** NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
121400	6-SJ-1122-5 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	**6-SS-160-.764-25-SAM**
121500	6-SJ-1122-6 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	**6-SS-160-.764-25-SAM**
121600	6-SJ-1122-7 PIPE TO ELBOW	B-J B9.11	PT UT	1	C	-	-	-	2	-	C	-	-	3	-	X	-	-	4	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
91 -	EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																							
121700	6-SJ-1122-8 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
121800	6-SJ-1122-9 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
121900	6-SJ-1122-10 ELBOW TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM UPSTREAM OR DOWNSTREAM SIDES DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**																		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD																						
				1	2	3	4	1	2	3	4	1	2	3	4																			
121950	6-SJ-1122-11 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**															
122100	6-SJ-1122-12 PIPE TO TEE	B-J B9.11	PT UT	1	-	-	-	-	C	-	-	-	-	2	-	-	-	-	C	-	-	-	-	3	-	-	-	-	X	-	-	-	-	NO UT FROM THE DOWNSTREAM SIDE DUE TO TEE CONFIGURATION. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
92 -	EXAMINED PER IEB 76-06. NO UT FROM THE DOWNSTREAM SIDE DUE TO TEE CONFIGURATION.																																	
122200	6-SJ-1121-1 REDUCER TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	2	-	-	-	-	-	-	-	-	-	3	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO REDUCER CONFIGURATION. NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
122300	6-SJ-1121-2 ELBOW TO VALVE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	2	-	-	-	-	-	-	-	-	K	3	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. NO UT FROM DOWNSTREAM SIDE DUE TO VALVE CONFIGURATION. LIMITATION: EXAMINED (UT) 63.9% OF THE CODE REQUIRED VOLUME, DUE TO THE VALVE CONFIGURATION. **6-SS-160-.764-25-SAM**
99RF -	FTI UNDER W.O.#50000402 TO PERFORM NDE. ENGR'G A-E EXAM (PT & UT) IAW PR#971001364, CRCA#4, ONE TIME ONLY. LIMITATION: EXAMINED (UT) 63.9% OF THE CODE REQUIRED VOLUME, DUE TO THE VALVE CONFIGURATION.																																	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**								
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD												
				1	2	3	4	1	2	3	4	1	2	3	4									
122400	6-SJ-1121-3 VALVE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO VALVE CONFIGURATION. **6-SS-160-.764-25-SAM**
122500	6-SJ-1121-4 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																								
122600	6-SJ-1121-5 ELBOW TO BRANCH CONNECTION	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. NO UT FROM DOWNSTREAM SIDE DUE TO BRANCH CONNECTION CONFIGURATION. **6-SS-160-.764-25-SAM**
122700	6-SJ-1112 (REF. DWG. NO. A-70) 6-SJ-1112-1 REDUCER TO VALVE	B-J B9.11	PT UT	1	C	-	-	-	2	C	-	-	-	3	X	-	-	-	4	-	-	-	-	LIMITED UT FROM DOWNSTREAM SIDE DUE TO VALVE CONFIGURATION. **6-SS-160-.764-25-SAM**
89 -	EXAMINATION PERFORMED PER 76-06 REQUIREMENTS. EXAMINED 100% OF CODE REQUIRED AREA.												EXAMINED 63% OF CODE REQUIRED VOLUME.											
122800	6-SJ-1112-2 VALVE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO VALVE CONFIGURATION. **6-SS-160-.764-25-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**								
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD												
				1	2	3	4	1	2	3	4	1	2	3	4									
122900	6-SJ-1112-2/2-SJ-1119 2 IN. BRANCH CONNECTION	B-J B9.32	PT METH	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	
123000	6-SJ-1112-3 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																								
123100	6-SJ-1112-4 ELBOW TO PIPE	B-J B9.11	PT UT	1	C	-	-	-	2	C	-	-	-	3	X	-	-	-	4	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
89 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																								
123200	6-SJ-1112-5 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
123300	6-SJ-1112-6 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
123400	6-SJ-1112-7 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
123500	6-SJ-1112-8 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
123600	6-SJ-1112-9 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **6-SS-160-.764-25-SAM**
92 -	EXAMINED PER IEB 76-06. UT45 INDICATIONS ARE GEOMETRIC REFLECTORS FROM THE WELD ROOT.																		
123700	6-SJ-1112-10 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
123800	6-SJ-1112-11 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
123900	6-SJ-1112-12 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO ELBOW CURVATURE. **6-SS-160-.764-25-SAM**
124000	6-SJ-1112-13 PIPE TO TEE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO TEE CONFIGURATION. **6-SS-160-.764-25-SAM**



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
6-SJ-1111 (REF. DWG. NO. A-88)																
124100	6-SJ-1111-1 REDUCER TO VALVE	B-J B9.11	PT UT	1	-	-	-	-	C	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO REDUCER CONFIGURATION. NO UT FROM DOWNSTREAM SIDE DUE TO VALVE CONFIGURATION. **6-SS-160-.764-25-SAM**
92 -	EXAMINED PER IEB 76-06. UT45 INDICATIONS ARE GEOMETRIC REFLECTORS FROM THE WELD ROOT. NO UT ON DOWNSTREAM SIDE DUE TO VALVE CONFIGURATION. LIMITED UT FROM THE UPSTREAM SIDE DUE TO REDUCER. 100% COVERAGE OBTAINED.															
6-SJ-1111 (REF. DWG. NO. A-71)																
124200	6-SJ-1111-2 VALVE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	NO EXAMINATION FROM UPSTREAM SIDE DUE TO VALVE CONFIGURATION. **6-SS-160-.764-25-SAM**
124300	6-SJ-1111-3 PIPE TO BRANCH CONNECTION	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO BRANCH CONNECTION CONFIGURATION. **6-SS-160-.764-25-SAM**
4-SJ-1195 (REF. DWG. NO. A-72)																
124400	4-SJ-1195-1 VALVE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO VALVE CONFIGURATION. **4-SS-160-.533-28-SAM-R **

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
124500	4-SJ-1195-2 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	LIMITED UT FROM DOWNSTREAM SIDE DUE TO SUPPORT INTERFERENCE. **4-SS-160-.533-28-SAM-R **
124600	4-SJ-1195-3 PIPE TO REDUCING ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	LIMITED UT FROM UPSTREAM SIDE DUE TO ANGLE IRON INTERFERENCE. **4-SS-160-.533-28-SAM-R **
4-SJ-1194 (REF. DWG. NO. A-73)																			
124700	4-SJ-1194-1 VALVE TO PIPE	B-J B9.11	PT UT	1	C	-	-	-	1	C	-	-	-	1	C	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO VALVE CONFIGURATION. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
89 -	NO UT FROM THE UPSTREAM SIDE DUE TO VALVE CONFIGURATION. EXAMINATION PERFORMED PER 76-06 REQUIREMENTS. EXAMINED 100% OF CODE REQUIRED AREA. EXAMINED 33% OF CODE REQUIRE VOLUME.																		
124800	4-SJ-1194-2 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**4-SS-160-.533-28-SAM-R **
124900	4-SJ-1194-3 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**4-SS-160-.533-28-SAM-R **

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**										
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD														
				1	2	3	4	1	2	3	4	1	2	3	4											
125000	4-SJ-1194-4 ELBOW TO PIPE	B-J B9.11	PT UT	1	C	-	-	-	-	1	-	-	-	-	-	-	-	1	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **
125100	4-SJ-1194-5 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	C	2	-	-	-	-	C	-	-	3	-	-	-	-	X	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
92 -	EXAMINED PER IEB 76-06. UT45 INDICATION IS A GEOMETRIC REFLECTOR FROM THE WELD ROOT.																									
125200	4-SJ-1194-6 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	2	-	-	-	-	-	-	C	3	-	-	-	-	-	-	X	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
99RF -	FTI UNDER W.O.#50000402 TO PERFORM NDE.																									
125300	4-SJ-1194-7 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	2	-	-	-	-	-	-	-	3	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **
125310	4-SJ-1194-7PL-1 THRU 4 PIPE LUGS	B-K B10.20	PT	1	-	-	-	-	-	2	-	-	-	-	-	-	-	3	-	-	-	-	-	-	-	REF NON-IWF SUM# 507185 (1P-SIG-PS41). INACCESSIBLE, DO NOT SELECT.
125400	4-SJ-1194-7PS-1 PIPE TO PENETRATION	B-K B10.20	PT	1	-	-	-	-	-	2	-	-	-	-	-	-	-	3	-	-	-	-	-	-	-	NON LOAD BEARING MEMBER.

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
125500	4-SJ-1194-7PS-2 PENETRATION TO PIPE	B-K B10.20	PT UT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	REF SUM# 507180 (1P-SIA-PS41). NO UT FROM UPSTREAM SIDE DUE TO PENETRATION CONFIGURATION.
125600	4-SJ-1194-8 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																		
125700	4-SJ-1194-9 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
92 - EXAMINED PER IEB 76-06. UT45 INDICATION IS A GEOMETRIC REFLECTOR FROM THE WELD ROOT.																		
125800	4-SJ-1194-10 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **
125900	4-SJ-1194-11 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **
126000	4-SJ-1194-12 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**				
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD								
				1	2	3	4	1	2	3	4	1	2	3	4					
126100	4-SJ-1194-13 PIPE TO ELBOW	B-J B9.11	PT UT	1 C	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
89 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																				
126200	4-SJ-1194-14 ELBOW TO PIPE	B-J B9.11	PT UT	1 -	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **
126300	4-SJ-1194-15 PIPE TO ELBOW	B-J B9.11	PT UT	1 -	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	LIMITED UT FROM DOWNSTREAM SIDE DUE TO WELDED PIPE SUPPORT. **4-SS-160-.533-28-SAM-R **
126400	4-SJ-1194-16 ELBOW TO ELBOW	B-J B9.11	PT UT	1 -	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **
126500	4-SJ-1194-17 ELBOW TO PIPE	B-J B9.11	PT UT	1 -	-	-	-	C	-	-	-	-	-	-	-	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
92 - EXAMINED PER IEB 76-06.																				
126600	4-SJ-1194-18 PIPE TO ELBOW	B-J B9.11	PT UT	1 -	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
126700	4-SJ-1194-19 ELBOW TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**4-SS-160-.533-28-SAM-R **
126800	4-SJ-1194-20 ELBOW TO TEE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO TEE CONFIGURATION. **4-SS-160-.533-28-SAM-R **
126900	4-SJ-1194-21 TEE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	C	-	-	-	3	X	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
89 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																			
127000	4-SJ-1194-22 PIPE TO TEE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO TEE CONFIGURATION. **4-SS-160-.533-28-SAM-R **
127100	4-SJ-1194-23 TEE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO TEE CONFIGURATION. **4-SS-160-.533-28-SAM-R **

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
127200	4-SJ-1194-24 PIPE TO TEE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO TEE CONFIGURATION. **4-SS-160-.533-28-SAM-R**
127300	4-SJ-1194-25 TEE TO REDUCING ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO TEE CONFIGURATION. **4-SS-160-.533-28-SAM-R**
127400	4-SJ-1193 (REF. DWG. NO. A-72) 4-SJ-1193-1 VALVE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO VALVE CONFIGURATION. **4-SS-160-.533-28-SAM-R**
127500	4-SJ-1193-2 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	**4-SS-160-.533-28-SAM-R**
127600	4-SJ-1193-3 PIPE TO REDUCING ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	LIMITED UT FROM DOWNSTREAM SIDE DUE TO PIPE SUPPORT. **4-SS-160-.533-28-SAM-R**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
4-SJ-1182 (REF. DWG. NO. A-74)																
127700	4-SJ-1182-1 VALVE TO PIPE	B-J B9.11	PT UT	1	C	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO VALVE CONFIGURATION. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
89 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																
127800	4-SJ-1182-2 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **
127900	4-SJ-1182-3 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **
128000	4-SJ-1182-4 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	C	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																
128100	4-SJ-1182-5 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	LIMITED UT FROM DOWNSTREAM SIDE DUE TO BRANCH CONNECTION. **4-SS-160-.533-28-SAM-R **



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
128200	4-SJ-1182-6 PIPE TO ELBOW	B-J B9.11	PT UT	1 C	-	-	-	-	2 C	-	-	-	-	3 X	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
89 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																			
128300	4-SJ-1182-7 ELBOW TO PIPE	B-J B9.11	PT UT	1 -	-	-	-	-	2 -	-	-	-	-	3 -	-	-	-	-	**4-SS-160-.533-28-SAM-R **
128400	4-SJ-1182-8 PIPE TO ELBOW	B-J B9.11	PT UT	1 -	-	-	-	-	2 -	-	-	-	-	3 -	-	-	-	-	**4-SS-160-.533-28-SAM-R **
128500	4-SJ-1182-9 ELBOW TO PIPE	B-J B9.11	PT UT	1 -	-	-	-	-	2 -	-	-	-	-	3 -	-	-	-	-	LIMITED UT FROM DOWNSTREAM SIDE DUE TO WALL INTERFERENCE. **4-SS-160-.533-28-SAM-R **
128600	4-SJ-1182-10 PIPE TO ELBOW	B-J B9.11	PT UT	1 -	-	-	-	-	2 -	-	-	-	-	3 -	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																			
128700	4-SJ-1182-11 ELBOW TO PIPE	B-J B9.11	PT UT	1 -	-	-	-	-	2 -	-	-	-	-	3 -	-	-	-	-	**4-SS-160-.533-28-SAM-R **

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
128800	4-SJ-1182-12 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **
128900	4-SJ-1182-13 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																			
129000	4-SJ-1182-14 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
93 - W.O.#931121035 TO PERFORM NDE. THE UT45 INDICATIONS ARE GEOMETRIC REFLECTORS FROM THE WELD ROOT.																			
129100	4-SJ-1182-15 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **
129200	4-SJ-1182-16 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **
129300	4-SJ-1182-17 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS															
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD																			
				1	2	3	4	1	2	3	4	1	2	3	4																
129400	4-SJ-1182-18 PIPE TO ELBOW	B-J B9.11	PT UT	1	C	-	-	-	-	2	-	-	-	-	-	-	-	3	-	X	-	-	-	-	-	-	-	-	-	-	**CALIBRATION BLOCK** LIMITED UT FROM UPSTREAM SIDE DUE TO BRANCH CONNECTION CONFIGURATION. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
91 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																															
129500	4-SJ-1182-19 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	2	-	-	-	-	-	-	-	3	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **	
129600	4-SJ-1182-20 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	2	-	-	-	-	-	-	-	3	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **		
129700	4-SJ-1182-21 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	2	-	-	-	-	-	-	-	3	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **		
129710	4-SJ-1182-21PL-1 THRU 4 PIPE LUGS	B-K B10.20	PT	1	-	-	-	-	-	2	-	-	-	-	-	-	-	3	-	-	-	-	-	-	-	-	-	-	REF NON-IWF SUM# 506850 (1P-SIG-PS70). INACCESSIBLE, DO NOT SELECT.		
129800	4-SJ-1182-21PS-1 PIPE TO PENETRATION	B-K B10.20	PT	1	-	-	-	-	-	2	-	-	-	-	-	-	-	3	-	-	-	-	-	-	-	-	-	-	UT BASELINE EXAMINATION PERFORMED. NON LOAD BEARING MEMBER.		

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**					
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD									
				1	2	3	4	1	2	3	4	1	2	3	4						
129900	4-SJ-1182-21PS-2 PENETRATION TO PIPE	B-K B10.20	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	REF SUM# 506855 (1P-SIA-PS70). UT BASELINE EXAMINATION PERFORMED.
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																					
130000	4-SJ-1182-22 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																					
130100	4-SJ-1182-23 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **
130200	4-SJ-1182-24 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	LIMITED UT FROM UPSTREAM SIDE DUE TO PIPE HANGER. **4-SS-160-.533-28-SAM-R **
130300	4-SJ-1182-25 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**						
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD										
				1	2	3	4	1	2	3	4	1	2	3	4							
130400	4-SJ-1182-26 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	X	-	-	-	LIMITATION: EXAMINED (UT) 96.7% OF THE CODE REQUIRED VOLUME, DUE TO THE OBSTRUCTION FROM AN ADJACENT BRANCH CONNECTION. **4-SS-160-.533-28-SAM-R**
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE. LIMITATION: EXAMINED (UT) 96.7% OF THE CODE REQUIRED VOLUME, DUE TO THE OBSTRUCTION FROM AN ADJACENT BRANCH CONNECTION.																						
130500	4-SJ-1182-27 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**4-SS-160-.533-28-SAM-R**
130600	4-SJ-1182-28 PIPE TO TEE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO TEE CONFIGURATION. **4-SS-160-.533-28-SAM-R**
130700	4-SJ-1182-29 TEE TO REDUCER	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO TEE CONFIGURATION. NO UT FROM DOWNSTREAM SIDE DUE TO REDUCER CONFIGURATION. **4-SS-160-.533-28-SAM-R**

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**						
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD										
				1	2	3	4	1	2	3	4	1	2	3	4							
4-SJ-1172 (REF. DWG. NO. A-75)																						
130800	4-SJ-1172-1 VALVE TO PIPE	B-J B9.11	PT UT	1	C	-	-	-	-	1	-	-	-	-	-	1	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO VALVE CONFIGURATION. (NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
89 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																						
130900	4-SJ-1172-2 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	2	-	-	-	-	-	3	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **
131000	4-SJ-1172-3 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	2	-	-	-	-	-	3	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **
131100	4-SJ-1172-4 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	2	-	-	-	-	-	3	-	-	-	-	-	**4-SS-160-.533-28-SAM-R **
131200	4-SJ-1172-5 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	C	2	-	-	-	-	C	3	-	-	-	-	X	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **

93 - W.O.#931121035 (NDE). THE PT EXAM REVEALED 6 LINEAR RECORDABLE INDICATIONS. DURING THE RELEVANCY DETERMINATION PROCESS, SURFACE CONDITIONING PROCEEDED A RE-EXAM WITH NO LINEAR INDICATIONS IDENTIFIED. UT45 GEOMETRIC, DUE TO WELD COUNTERBORE.

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
131300	4-SJ-1172-6 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**4-SS-160-.533-28-SAM-R **
131400	4-SJ-1172-7 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**4-SS-160-.533-28-SAM-R **
131500	4-SJ-1172-8 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	NO UT FROM UPSTREAM SIDE AND LIMITED UT FROM DOWNSTREAM SIDE DUE TO WALL INTERFERENCE. **4-SS-160-.533-28-SAM-R **
131600	4-SJ-1172-9 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																			
131700	4-SJ-1172-10 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**4-SS-160-.533-28-SAM-R **
131800	4-SJ-1172-11 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**4-SS-160-.533-28-SAM-R **

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
131900	4-SJ-1172-12 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**4-SS-160-.533-28-SAM-R **
132000	4-SJ-1172-13 ELBOW TO PIPE	B-J B9.11	PT UT	1	C	-	-	-	2	C	-	-	-	3	X	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R **
89 - EXAMINATION PERFORMED PER 76-06 REQUIREMENTS.																			
132100	4-SJ-1172-14 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	**4-SS-160-.533-28-SAM-R **
132200	4-SJ-1172-15 PIPE TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	**4-SS-160-.533-28-SAM-R **
132300	4-SJ-1172-16 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	**4-SS-160-.533-28-SAM-R **
132400	4-SJ-1172-17 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	**4-SS-160-.533-28-SAM-R **



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**					
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD									
				1	2	3	4	1	2	3	4	1	2	3	4						
132500	4-SJ-1172-18 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	-	(NRC BULLETIN 76-06 REQUIREMENTS WERE PREVIOUSLY APPLIED) **4-SS-160-.533-28-SAM-R**
91 - EXAMINED PER IEB 76-06. EXAMINED OVER 90% OF CODE REQUIRED VOLUME FOR CIRCUMFERENTIAL AND AXIAL INDICATIONS. LIMITED UT EXAM FROM THE UPSTREAM SIDE.																					
132600	4-SJ-1172-19 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO PROXIMITY OF WELD 4-SJ-1172-19PS-1. **4-SS-160-.533-28-SAM-R**
132610	4-SJ-1172-19PL-1 THRU 4 PIPE LUGS	B-K B10.20	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	REF NON-IWF SUM# 506660. (1P-SIG-PS71). INACCESSIBLE, DO NOT SELECT.
132700	4-SJ-1172-19PS-1 PIPE TO PENETRATION	B-K B10.20	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	-	-	-	NON LOAD BEARING MEMBER.
132800	4-SJ-1172-19PS-2 PENETRATION TO PIPE	B-K B10.20	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 506655 (1P-SIA-PS71). NO UT FROM UPSTREAM SIDE DUE TO PENETRATION CONFIGURATION. NO UT ON WELD DUE TO WELD CONFIGURATION. NOTE: ID/OD RATIO REQUIRES THE USE OF A <30 DEGREE TRANSDUCER (REF. AR#990423129, CRCA# 01). **4-SS-XX-.689-27-SAM**

91 - PT EXAM REVEALED 1/4" LINEAR INDICATION ON PENETRATION BASE MATERIAL. SEE CNF 5. THICKNESS IN THE INDICATION AREA WAS 1-1/2" MAKING THE INDICATION ALLOWABLE. ACCEPTED "AS IS" BY PSE&G PERSONNEL.

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
132900	4-SJ-1172-20 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**4-SS-160-.533-28-SAM-R **
133000	4-SJ-1172-21 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**4-SS-160-.533-28-SAM-R **
133100	4-SJ-1172-22 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**4-SS-160-.533-28-SAM-R **
133200	4-SJ-1172-23 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**4-SS-160-.533-28-SAM-R **
133300	4-SJ-1172-24 PIPE TO ELBOW	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**4-SS-160-.533-28-SAM-R **
133400	4-SJ-1172-25 ELBOW TO PIPE	B-J B9.11	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**4-SS-160-.533-28-SAM-R **
133500	4-SJ-1172-25/2-SJ-1147 2 IN. BRANCH CONNECTION	B-J B9.32	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
133600	4-SJ-1172-26 PIPE TO TEE	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM DOWNSTREAM SIDE DUE TO TEE CONFIGURATION. **4-SS-160-.533-28-SAM-R**
133700	4-SJ-1172-27 TEE TO CAP	B-J B9.11	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO TEE CONFIGURATION. NO UT FROM DOWNSTREAM SIDE DUE TO CAP CONFIGURATION. NO UT ON WELD DUE TO WELD CONFIGURATION. **4-SS-160-.533-28-SAM-R**
133800	4-SJ-1172-28 TEE TO REDUCER	B-J B9.11	PT UT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	-	NO UT FROM UPSTREAM SIDE DUE TO TEE CONFIGURATION. NO UT FROM DOWNSTREAM SIDE DUE TO REDUCER CONFIGURATION. **4-SS-160-.533-28-SAM-R**
93 -	W.O.#931121035 TO PERFORM NDE. THE UT45 INDICATION IS A GEOMETRIC REFLECTOR FROM THE WELD ROOT.																		
	3-SJ-1192 (REF. DWG. NO. A-72)																		
133900	3-SJ-1192-1 REDUCING ELBOW TO PIPE	B-J B9.21	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
134000	3-SJ-1192-2 PIPE TO TEE	B-J B9.21	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
134100	3-SJ-1192-3 REDUCING ELBOW TO TEE	B-J B9.21	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
134200	3-SJ-1192-4 TEE TO PIPE	B-J B9.21	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
134300	3-SJ-1192-5 PIPE TO ELBOW	B-J B9.21	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
134400	3-SJ-1192-6 ELBOW TO PIPE	B-J B9.21	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
134500	3-SJ-1192-7 PIPE TO ELBOW	B-J B9.21	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
134600	3-SJ-1192-8 ELBOW TO PIPE	B-J B9.21	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
134700	3-SJ-1192-8A PIPE TO PIPE	B-J B9.21	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	-	UT PERFORMED DURING FIRST INTERVAL.
92 -	EXAMINED PER IEB 76-06.																		
93 -	W.O.#931121035 TO PERFORM NDE.																		
134800	3-SJ-1192-9 PIPE TO PIPE	B-J B9.21	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
135500	3-SJ-1192-12/1.5-SJ-11 32 1 1/2IN. BRANCH CONNECTION	B-J B9.32	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
135600	3-SJ-1192-12/1.5-SJ-11 22 1 1/2IN. BRANCH CONNECTION	B-J B9.32	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
135700	3-SJ-1192-12/1.5-SJ-11 42 1 1/2IN. BRANCH CONNECTION	B-J B9.32	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
135800	3-SJ-1192-13 PIPE TO CAP	B-J B9.32	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
2-SJ-1149 (REF. DWG. NO. A-76, A-77)																			
135900	2-SJ-1149-1 TEE TO PIPE	B-J B9.21	PT	1	C	-	-	-	1	C	-	-	-	1	C	-	-	-	UT PERFORMED DURING FIRST INTERVAL. NO UT FROM UPSTREAM SIDE DUE TO TEE CONFIGURATION.
136000	2-SJ-1149-2 PIPE TO FLANGE	B-J B9.40	PT	1	-	-	-	-	1	C	-	-	-	1	C	-	-	-	
136100	2-SJ-1149-2FB FLANGE BOLTING	B-G-2 B7.50	VT-1	1	-	-	-	-	1	C	-	-	-	1	C	-	-	-	

91 - W.O.# 901120026, ACT 24  
 99RF - W.O.#50000402 TO PERFORM NDE.

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
136200	2-SJ-1149-3 FLANGE TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
136300	2-SJ-1149-4 PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
136400	2-SJ-1149-5-R1 VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	C	2/3/2 - CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3237-157E-B IS ISI WELD # 2-SJ-1149-5-R1
01RF - MQS TO PERFORM PSI NDE UNDER W/O# 60006083. AND CJP# S-00-189. CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3237-157E-B IS ISI WELD # 2-SJ-1149-5-R1																			
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																			
136500	2-SJ-1149-6-R1 PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	P	2/3/2 - CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3237-158E-B IS ISI WELD # 2-SJ-1149-6-R1
01RF - MQS TO PERFORM PSI NDE UNDER W/O# 60006083. AND CJP# S-00-189. CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3237-158E-B IS ISI WELD # 2-SJ-1149-6-R1																			
136600	2-SJ-1149-7-R1 VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	P	2/3/2 - CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3237-159E-B IS ISI WELD # 2-SJ-1149-7-R1
01RF - MQS TO PERFORM PSI NDE UNDER W/O# 60006083. AND CJP# S-00-189. CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3237-159E-B IS ISI WELD # 2-SJ-1149-7-R1																			

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**								
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD												
				1	2	3	4	1	2	3	4	1	2	3	4									
136700	2-SJ-1149-8-R1 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	2/3/2 - CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3237-160E-B IS ISI WELD # 2-SJ-1149-8-R1

01RF - MQS TO PERFORM PSI NDE UNDER W/O# 60006083. AND CJP# S-00-189. CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3237-160E-B IS ISI WELD # 2-SJ-1149-8-R1

136800	2-SJ-1149-9 ELBOW TO PIPE	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

136900	2-SJ-1149-10 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

137000	2-SJ-1149-11 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

2-SJ-1149 (REF. DWG. NO. A-76)

137010	2-SJ-1149-11A PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).

137012	2-SJ-1149-11B ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).

137014	2-SJ-1149-11C PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
137016	2-SJ-1149-11D ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
137018	2-SJ-1149-11E PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
137020	2-SJ-1149-11F ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
137022	2-SJ-1149-11G PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
137024	2-SJ-1149-11H ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
137026	2-SJ-1149-11I PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
137028	2-SJ-1149-11J ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
137900	2-SJ-1149-20 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
138000	2-SJ-1149-21 PIPE TO ELBOW	B-J B9.40	PT	1	C	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	C	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	X	-	-	-	3	-	-	-	-	3	-	-	-	-	
138100	2-SJ-1149-22 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
138200	2-SJ-1149-23 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
138300	2-SJ-1149-24 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
138400	2-SJ-1149-25 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
138500	2-SJ-1149-26 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
138600	2-SJ-1149-27 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
138700	2-SJ-1149-28 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
138800	2-SJ-1149-29 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
138900	2-SJ-1149-30 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
139000	2-SJ-1149-31 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
139100	2-SJ-1149-32 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
139200	2-SJ-1149-33 PIPE TO COUPLING	B-J B9.40	PT	1	C	-	-	-	1	C	-	-	-	1	C	-	-	-	
91 -	PT EXAM REVEALED 5/8" LINEAR INDICATION ON PIPE SIDE OF WELD. SEE CNF 11. REEXAMINATION AFTER COSMETIC BUFFING REVEALED NO RECORDABLE INDICATIONS.																		
139300	2-SJ-1149-34 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
139400	2-SJ-1149-35 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
139500	2-SJ-1149-36 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
-----																		
	2-SJ-1149 (REF. DWG. NO. A-77)																	
139600	2-SJ-1149-37 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	
				2	-	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	X	-	-	-	
-----																		
99RF -	FTI UNDER W.O.#50000402 TO PERFORM NDE.																	
-----																		
	2-SJ-1149 (REF. DWG. NO. A-76, A-77)																	
139700	2-SJ-1149-38 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
-----																		
139800	2-SJ-1149-39 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
-----																		
139900	2-SJ-1149-40 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
-----																		
140000	2-SJ-1149-41 PIPE TO ELBOW	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	
-----																		
140100	2-SJ-1149-42 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
-----																		
140200	2-SJ-1149-43 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	





SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
141900	2-SJ-1147-12 PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
142000	2-SJ-1147-13 VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	X	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																			
142100	2-SJ-1147-14 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
142200	2-SJ-1147-15 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
142300	2-SJ-1147-16 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
142310	2-SJ-1147-16A PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
142312	2-SJ-1147-16B ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
142314	2-SJ-1147-16C PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
142316	2-SJ-1147-16D ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																	
142318	2-SJ-1147-16E PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																	
142320	2-SJ-1147-16F ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																	
142400	2-SJ-1147-17R1 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	P	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																	
142500	2-SJ-1147-18R1 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																	
142510	2-SJ-1147-18A PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																	
142512	2-SJ-1147-18B ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																	
142514	2-SJ-1147-18C PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
142516	2-SJ-1147-18D ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
142600	2-SJ-1147-19 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
142700	2-SJ-1147-20 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
142800	2-SJ-1147-21 PIPE TO ELBOW	B-J B9.40	PT	1	C	-	-	-	1	C	-	-	-	1	C	-	-	-	
				2	C	-	-	-	2	C	-	-	-	2	C	-	-	-	
				3	X	-	-	-	3	X	-	-	-	3	X	-	-	-	
142900	2-SJ-1147-22 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
143000	2-SJ-1147-23 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
143100	2-SJ-1147-24 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
143200	2-SJ-1147-25 PIPE TO BRANCH CONNECTION	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
2-SJ-1139 (REF. DWG. NO. A-79)																		
143300	2-SJ-1139-1 REDUCING ELBOW TO PIPE	B-J B9.21	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	UT PERFORMED DURING FIRST INTERVAL. NO UT FROM UPSTREAM SIDE DUE TO REDUCING ELBOW CONFIGURATION.
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	
-----																		
143400	2-SJ-1139-1A PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
-----																		
143500	2-SJ-1139-1B COUPLING TO PIPE	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	-	
-----																		
143600	2-SJ-1139-2 PIPE TO FLANGE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	-	
-----																		
143700	2-SJ-1139-2FB FLANGE BOLTING	B-G-2 B7.50	VT-1	1	C	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	K	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	X	-	-	-	
-----																		
91 -	W.O.# 901120026, ACT 25																	
99RF -	W.O.#50000402 TO PERFORM NDE.																	
-----																		
143800	2-SJ-1139-3 FLANGE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
-----																		
143900	2-SJ-1139-4R1 PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	P	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	
-----																		
95RF -	PSI BASELINE PERFORMED BY MQS PER S-96-084 / 960111096 (13SJ143 VALVE REPLACEMENT).																	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
144000	2-SJ-1139-5R1 VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED BY MQS PER S-96-084 / 960111096 (13SJ143 VALVE REPLACEMENT).																			
144100	2-SJ-1139-6 PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
144200	2-SJ-1139-7 VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
144300	2-SJ-1139-8 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-
				2	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	X	-	-
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																			
144400	2-SJ-1139-9 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	X	-	-
144500	2-SJ-1139-10 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
144600	2-SJ-1139-11 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
144610	2-SJ-1139-11A PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	-	-	-	-	-	P	-	-	-	-	-	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**											
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD															
				1	2	3	4	1	2	3	4	1	2	3	4												
144612	2-SJ-1139-11B ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																											
144614	2-SJ-1139-11C PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																											
144616	2-SJ-1139-11D ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																											
144618	2-SJ-1139-11E PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																											
144620	2-SJ-1139-11F ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																											
144622	2-SJ-1139-11G PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																											
144624	2-SJ-1139-11H ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																											
144626	2-SJ-1139-11I PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																											

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
144628	2-SJ-1139-11J ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-				P	-	-	-	-	-		
				3	-	-	-	-				-	-	-	-	-	-		
95RF - PSI BASELINE PERFORMED PER IEC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
144700	2-SJ-1139-12 PIPE TO TEE	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	-	-	
144800	2-SJ-1139-13 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
144900	2-SJ-1139-14 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
145000	2-SJ-1139-15 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
145100	2-SJ-1139-16 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	-	
145200	2-SJ-1139-17 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
145300	2-SJ-1139-18 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
145400	2-SJ-1139-19 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
145500	2-SJ-1139-20 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
145600	2-SJ-1139-21 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
145700	2-SJ-1139-22 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
145800	2-SJ-1139-23 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
145900	2-SJ-1139-24 COUPLING TO PIPE	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	-	
146000	2-SJ-1139-25 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	-	
146100	2-SJ-1139-26 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
146200	2-SJ-1139-27 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
146300	2-SJ-1139-28 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	-	
146400	2-SJ-1139-29 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
146500	2-SJ-1139-30 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
146600	2-SJ-1139-31 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
146700	2-SJ-1139-32 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
146800	2-SJ-1139-33 ELBOW TO BRANCH CONNECTION	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	X	-	-	-	

99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
2-SJ-1137 (REF. DWG. NO. A-80)																
146900	2-SJ-1137-1 REDUCER TO PIPE	B-J B9.21	PT	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
.....																
147000	2-SJ-1137-2 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
.....																
147100	2-SJ-1137-3 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
.....																
147200	2-SJ-1137-4 PIPE TO ELBOW	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-		
				2	C	-	-	-	-	-	-	-	-	-		
				3	X	-	-	-	-	-	-	-	-	-		
.....																
147300	2-SJ-1137-5 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
.....																
147400	2-SJ-1137-6 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
.....																
147500	2-SJ-1137-7 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	C	-	-		
				2	-	-	-	-	-	-	-	C	-	-		
				3	-	-	-	-	-	-	-	X	-	-		
.....																
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																
.....																
147600	2-SJ-1137-8 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	C	-	-		
				2	-	-	-	-	-	-	-	C	-	-		
				3	-	-	-	-	-	-	-	X	-	-		
.....																
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**						
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD										
				1	2	3	4	1	2	3	4	1	2	3	4							
148500	2-SJ-1137-16 PIPE TO TEE	B-J B9.40	PT	1	C	-	-	-	-	2	C	-	-	-	-	3	X	-	-	-	-	
148600	2-SJ-1137-17 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	-	2	-	-	-	-	-	3	-	-	-	-	-	
148700	2-SJ-1137-18 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	2	-	-	-	-	-	3	-	-	-	-	-	
148800	2-SJ-1137-19 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	2	-	-	-	-	-	3	-	-	-	-	-	
148900	2-SJ-1137-20 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	2	-	-	-	-	C	3	-	-	-	-	X	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																						
148910	2-SJ-1137-20A PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	2	-	-	-	P	-	3	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																						
148912	2-SJ-1137-20B ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	2	-	-	-	P	-	3	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																						
148914	2-SJ-1137-20C PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	2	-	-	-	P	-	3	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																						

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
148916	2-SJ-1137-20D ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
148918	2-SJ-1137-20E PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
148920	2-SJ-1137-20F ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
149000	2-SJ-1137-21 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
149100	2-SJ-1137-22 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
149200	2-SJ-1137-23 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
149300	2-SJ-1137-24 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
149400	2-SJ-1137-25 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
149500	2-SJ-1137-26 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
149600	2-SJ-1137-27 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
149700	2-SJ-1137-28 ELBOW TO PIPE	B-J B9.40	PT	1	C	-	-	-	2	C	-	-	-	3	X	-	-	-	
149800	2-SJ-1137-29 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
149900	2-SJ-1137-30 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
150000	2-SJ-1137-31 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
150100	2-SJ-1137-32 COUPLING TO BRANCH CONNCTN	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	C C X

99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
2-SJ-1129 (REF. DWG. NO. A-81, A-82)																
150200	2-SJ-1129-1 TEE TO PIPE	B-J B9.21	PT	1	C	-	-	-	-	-	-	-	-	-	-	UT PERFORMED DURING FIRST INTERVAL. NO UT FROM UPSTREAM SIDE DUE TO TEE CONFIGURATION.
				2	C	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	
-----																
150300	2-SJ-1129-2 PIPE TO FLANGE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
-----																
150400	2-SJ-1129-2FB FLANGE BOLTING	B-G-2 B7.50	VT-1	1	C	-	-	-	-	-	-	-	-	-	-	
				2	-	K	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	
-----																
91 -	W.O.# 901120026, ACT 26															
99RF -	W.O.#50000402 TO PERFORM NDE.															
-----																
150500	2-SJ-1129-3 FLANGE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
-----																
150600	2-SJ-1129-4 PIPE TO VALVE	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	
-----																
150700	2-SJ-1129-5-R1 VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	2/3/2 - CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3224-124E-A IS ISI WELD # 2-SJ-1129-5-R1
				2	-	-	-	-	-	-	-	-	P	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
-----																
01RF -	MQS TO PERFORM NDE UNDER W/O# 60006082. AND CJP# S-00-188. CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3224-124E-A IS ISI WELD # 2-SJ-1129-5-R1															



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
151300	2-SJ-1129-11 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
.....																	
	2-SJ-1129 (REF. DWG. NO. A-81)																
151310	2-SJ-1129-11A PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
95RF -	PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																
.....																	
151312	2-SJ-1129-11B ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
95RF -	PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																
.....																	
151314	2-SJ-1129-11C PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
95RF -	PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																
.....																	
151316	2-SJ-1129-11D ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
95RF -	PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																
.....																	
151318	2-SJ-1129-11E PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
95RF -	PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																
.....																	
151320	2-SJ-1129-11F ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
95RF -	PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																
.....																	
151322	2-SJ-1129-11G PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
95RF -	PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
151324	2-SJ-1129-11H ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
151326	2-SJ-1129-11I PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
151328	2-SJ-1129-11J ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
2-SJ-1129 (REF. DWG. NO. A-81, A-82)																			
151400	2-SJ-1129-12 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
151500	2-SJ-1129-13 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																			
151600	2-SJ-1129-14 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
151700	2-SJ-1129-15 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
151800	2-SJ-1129-16 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
151900	2-SJ-1129-17 PIPE TO ELBOW	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	-	
152000	2-SJ-1129-18 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
152100	2-SJ-1129-19 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
152200	2-SJ-1129-20 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
152300	2-SJ-1129-21 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	
92 -	LIMITED EXAM DUE TO PROXIMITY OF ADJACENT PIPING. EXAMINED 84% OF REQUIRED AREA.																	
152400	2-SJ-1129-22 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
152500	2-SJ-1129-23 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
152600	2-SJ-1129-24 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
2-SJ-1129 (REF. DWG. NO. A-82)																		
152700	2-SJ-1129-25 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	
				2	-	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	X	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																		
2-SJ-1129 (REF. DWG. NO. A-81, A-82)																		
152800	2-SJ-1129-26 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
152900	2-SJ-1129-27 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
153000	2-SJ-1129-28 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
153100	2-SJ-1129-29 PIPE TO COUPLING	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	-	
153200	2-SJ-1129-30 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
153300	2-SJ-1129-31 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
153400	2-SJ-1129-32 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**						
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD										
				1	2	3	4	1	2	3	4	1	2	3	4							
154300	2-SJ-1129-41 PIPE TO ELBOW	B-J B9.40	PT	1	C	-	-	-	-	1	C	-	-	-	-	1	C	-	-	-	-	
				2	-	-	-	-	-	2	-	-	-	-	-	2	-	-	-	-	-	
				3	-	-	-	-	-	3	X	-	-	-	-	3	-	-	-	-	-	
154400	2-SJ-1129-42 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	1	-	-	-	-	-	1	-	-	-	-	-	
				2	-	-	-	-	-	2	-	-	-	-	-	2	-	-	-	-	-	
				3	-	-	-	-	-	3	-	-	-	-	-	3	-	-	-	-	-	
154500	2-SJ-1129-43 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	1	-	-	-	-	-	1	-	-	-	-	-	
				2	-	-	-	-	-	2	-	-	-	-	-	2	-	-	-	-	-	
				3	-	-	-	-	-	3	-	-	-	-	-	3	-	-	-	-	-	
154600	2-SJ-1129-44 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	1	-	-	-	-	-	1	-	-	-	-	-	
				2	-	-	-	-	-	2	-	-	-	-	-	2	-	-	-	-	-	
				3	-	-	-	-	-	3	-	-	-	-	-	3	-	-	-	-	-	
154700	2-SJ-1129-45 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	C	1	C	-	-	-	-	1	-	-	-	-	-	
				2	-	-	-	-	C	2	C	-	-	-	-	2	-	-	-	-	-	
				3	-	-	-	-	X	3	X	-	-	-	-	3	-	-	-	-	-	
154800	2-SJ-1129-46 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	1	-	-	-	-	-	1	-	-	-	-	-	
				2	-	-	-	-	-	2	-	-	-	-	-	2	-	-	-	-	-	
				3	-	-	-	-	-	3	-	-	-	-	-	3	-	-	-	-	-	
154900	2-SJ-1129-47 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	1	-	-	-	-	-	1	-	-	-	-	-	
				2	-	-	-	-	-	2	-	-	-	-	-	2	-	-	-	-	-	
				3	-	-	-	-	-	3	-	-	-	-	-	3	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**				
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD								
				1	2	3	4	1	2	3	4	1	2	3	4					
2-SJ-1129 (REF. DWG. NO. A-82)																				
155000	2-SJ-1129-48	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
	COUPLING TO BRANCH	B9.40		2	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
	CONNCTN			3	-	-	-	-	-	-	-	-	-	-	-	X	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																				
2-SJ-1128 (REF. DWG. NO. A-83,84,85)																				
155100	2-SJ-1128-1	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	TEE TO PIPE	B9.21		2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
2-SJ-1128-1A																				
155200	PIPE TO COUPLING	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
		B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
2-SJ-1128-1B																				
155300	COUPLING TO PIPE	B-J	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	-	-	
		B9.40		2	-	-	-	-	C	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	-	-	
2-SJ-1128-2																				
155400	PIPE TO FLANGE	B-J	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
		B9.40		2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
2-SJ-1128 (REF. DWG. NO. A-83)																				
155500	2-SJ-1128-2FB	B-G-2	VT-1	1	-	-	-	-	C	-	-	-	-	-	-	-	-	-	-	
	FLANGE BOLTING	B7.50		2	-	-	-	-	-	K	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	X	-	-	-	
93 - W.O.# 920810149 & 931121035.																				
99RF - W.O.#50000402 TO PERFORM NDE.																				









SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
157900	2-SJ-1128-26 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	HANGER INTERFERENCE PROBLEMS.
93 - THIS WELD WAS REPLACED BY SUMMARY #158200, DUE TO HANGER INTERFERENCE.																		
158000	2-SJ-1128-27 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
158100	2-SJ-1128-28 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
158200	2-SJ-1128-29 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
93 - W.O. #931121035 TO PERFORM NDE. THIS WELD REPLACES SUMMARY #157900, DUE TO HANGER INTERFERENCE.																		
2-SJ-1128 (REF. DWG. NO. A-84)																		
158300	2-SJ-1128-30 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	C	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																		
2-SJ-1128 (REF. DWG. NO. A-83,84,85)																		
158400	2-SJ-1128-30A TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
158500	2-SJ-1128-31 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
158600	2-SJ-1128-32 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	C	-	-	
93 - W.O. #931121035 TO PERFORM NDE. THIS EXAM REPLACES SUMMARY #159100, DUE TO ALARA CONCERNS. SUMMARY #159100 WAS LOCATED IN THE DECAY TUNNEL.																		

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**						
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD										
				1	2	3	4	1	2	3	4	1	2	3	4							
158700	2-SJ-1128-33 COUPLING TO PIPE	B-J B9.40	PT	1	C	-	-	-	-	2	C	-	-	-	-	3	X	-	-	-	-	
158800	2-SJ-1128-34 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	2	-	-	-	-	-	3	-	-	-	-	-	
158900	2-SJ-1128-35 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	2	-	-	-	-	-	3	-	-	-	-	-	
159000	2-SJ-1128-36 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	2	-	-	-	-	-	3	-	-	-	-	-	
159100	2-SJ-1128-37 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	C	2	-	-	-	-	-	3	-	-	-	-	-	LOCATED INSIDE OF THE DECAY TUNNEL.
93 -	THIS EXAM WAS REPLACED WITH SUMMARY #158600, DUE TO ALARA CONCERNS. THIS EXAM WAS LOCATED INSIDE OF THE DECAY TUNNEL.																					
159200	2-SJ-1128-38 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	2	-	-	-	-	-	3	-	-	-	-	-	
159300	2-SJ-1128-39 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	2	-	-	-	-	-	3	-	-	-	-	-	
159400	2-SJ-1128-40 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	2	-	-	-	-	-	3	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
2-SJ-1128 (REF. DWG. NO. A-84)																		
159500	2-SJ-1128-41 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	
				2	-	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	X	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																		
2-SJ-1128 (REF. DWG. NO. A-83,84,85)																		
159600	2-SJ-1128-42 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
159700	2-SJ-1128-43 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
159800	2-SJ-1128-44 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
159900	2-SJ-1128-45 ELBOW TO PIPE	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	-	-	
160000	2-SJ-1128-46 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
160100	2-SJ-1128-47 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
160200	2-SJ-1128-48 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**				
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD								
				1	2	3	4	1	2	3	4	1	2	3	4					
161100	2-SJ-1128-57 COUPLING TO PIPE	B-J B9.40	PT	1	C	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	C	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	X	-	-	-	3	-	-	-	-	3	-	-	-	-	
91 - EXAMINED 83% OF THE CODE REQUIRED AREA. LIMITED EXAM DUE TO SNUBBER SUPPORT CLAMPS.																				
161200	2-SJ-1128-58 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
161300	2-SJ-1128-59 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
161400	2-SJ-1128-60 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
161500	2-SJ-1128-61 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	C	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	C	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	X	3	-	-	-	-	3	-	-	-	-	
161600	2-SJ-1128-62 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
161700	2-SJ-1128-63 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
161800	2-SJ-1128-64 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	-	3	-	-	-	-	3	-	-	-	-	



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
162700	2-SJ-1128-73 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
.....																			
	2-SJ-1128 (REF. DWG. NO. A-85)																		
162800	2-SJ-1128-74 PIPE TO REDUCER	B-J B9.21	PT	1	-	-	-	-	1	-	-	-	-	C	-	-	-	-	UT PERFORMED DURING FIRST INTERVAL. NO UT FROM DOWNSTREAM SIDE DUE TO REDUCER CONFIGURATION.
				2	-	-	-	-	2	-	-	-	-	C	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	X	-	-	-	-	
.....																			
99RF -	FTI UNDER W.O.#50000402 TO PERFORM NDE.																		
.....																			
	2-SJ-1119 (REF. DWG. NO. A-86)																		
162900	2-SJ-1119-1 TEE TO PIPE	B-J B9.21	PT	1	-	-	-	-	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	-	-	-	-	-	
.....																			
163000	2-SJ-1119-2 PIPE TO FLANGE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	-	-	-	-	-	
.....																			
163100	2-SJ-1119-2FB FLANGE BOLTING	B-G-2 B7.50	VT-1	1	-	-	-	-	1	-	-	-	-	C	-	-	-	-	
				2	-	K	-	-	2	-	K	-	-	C	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	X	-	-	-	-	
.....																			
91 -	W.O.# 901120026, ACT 27																		
99RF -	W.O.#50000402 TO PERFORM NDE.																		
.....																			
163200	2-SJ-1119-3 FLANGE TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	-	-	-	-	-	
.....																			
163300	2-SJ-1119-4 PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	-	-	-	-	-	



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
163400	2-SJ-1119-5-R1 VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	2/3/2 - CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3216-107E-A IS ISI WELD # 2-SJ-1119-5-R1
01RF - MQS TO PERFORM PSI NDE UNDER W/O# 60005307. AND CJP# S-00-41. CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3216-107E-A IS ISI WELD # 2-SJ-1119-5-R1																		
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																		
163500	2-SJ-1119-6-R1 PIPE TO VALVE	B-J B9.40-	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	2/3/2 - CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3216-108E-A IS ISI WELD # 2-SJ-1119-6-R1
01RF - MQS TO PERFORM PSI NDE UNDER W/O# 60005307. AND CJP# S-00-41. CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3216-108E-A IS ISI WELD # 2-SJ-1119-6-R1																		
163600	2-SJ-1119-7-R1 VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	P	-	-	2/3/2 - CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3216-109E-A IS ISI WELD # 2-SJ-1119-7-R1
01RF - MQS TO PERFORM PSI NDE UNDER W/O# 60005307. AND CJP# S-00-41. CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3216-109E-A IS ISI WELD # 2-SJ-1119-7-R1																		
163700	2-SJ-1119-8-R1 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	P	-	-	2/3/2 - CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3216-110E-A IS ISI WELD # 2-SJ-1119-8-R1
01RF - MQS TO PERFORM PSI NDE UNDER W/O# 60005307. AND CJP# S-00-41. CONSTRUCTION NDE TO SATISFY SECTION XI PSI REQUIREMENTS. FIELD WELD # S1-RH-3216-110E-A IS ISI WELD # 2-SJ-1119-8-R1																		

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
163800	2-SJ-1119-9 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	
.....																		
163900	2-SJ-1119-10 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
164000	2-SJ-1119-11 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
164010	2-SJ-1119-11A PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																		
.....																		
164012	2-SJ-1119-11B ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																		
.....																		
164014	2-SJ-1119-11C PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																		
.....																		
164016	2-SJ-1119-11D ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																		
.....																		
164018	2-SJ-1119-11E PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																		

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
164020	2-SJ-1119-11F ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
164022	2-SJ-1119-11G PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
164024	2-SJ-1119-11H ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
164026	2-SJ-1119-11I PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
164028	2-SJ-1119-11J ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
164100	2-SJ-1119-12 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
164200	2-SJ-1119-13 TEE TO REDUCER	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			
164300	2-SJ-1119-14 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-1 / PS-96-029 / 960116178 (ADDED NEW ORIFICES).																			



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**						
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD										
				1	2	3	4	1	2	3	4	1	2	3	4							
165200	2-SJ-1119-23 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	X	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																						
165300	2-SJ-1119-24 ELBOW TO BRANCH CONNECTION	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
2-SJ-1118 (REF. DWG. NO. A-87, A-88)																						
165400	2-SJ-1118-1 REDUCER TO PIPE	B-J B9.21	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	-	-	-	-	
165500	2-SJ-1118-2 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
165600	2-SJ-1118-3 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
165700	2-SJ-1118-4 PIPE TO FLANGE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
165800	2-SJ-1118-4FB FLANGE BOLTING	B-G-2 B7.50	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				2	-	-	-	-	-	K	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	X	-	-	-	
93 - W.O.# 920810151 & 931121035.																						
99RF - W.O.#50000402 TO PERFORM NDE.																						
165900	2-SJ-1118-5 FLANGE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	X	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																						

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
166000	2-SJ-1118-6 PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
.....																			
166100	2-SJ-1118-7 VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
.....																			
166200	2-SJ-1118-8R1 PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	P	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
.....																			
95RF - PSI BASELINE PER S-95-292 / 931002072 (VALVE 11SJ139 REPLACEMENT, NEW WELD).																			
.....																			
166300	2-SJ-1118-9R1 VALVE TO PIPE	B-J B9.40	PT	1	C	-	-	-	1	C	-	-	-	1	C	-	-	-	
				2	C	-	-	-	2	C	-	-	P	2	C	-	-	-	
				3	X	-	-	-	3	X	-	-	-	3	X	-	-	-	
.....																			
95RF - PSI BASELINE PER S-95-292 / 931002072 (VALVE 11SJ139 REPLACEMENT, NEW WELD).																			
.....																			
166400	2-SJ-1118-10 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
.....																			
166500	2-SJ-1118-11 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
.....																			
166600	2-SJ-1118-12 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**						
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD										
				1	2	3	4	1	2	3	4	1	2	3	4							
167100	2-SJ-1118-17 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	X	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																						
167200	2-SJ-1118-18 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
167300	2-SJ-1118-19 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
167400	2-SJ-1118-20 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
167500	2-SJ-1118-21 ELBOW TO PIPE	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
167600	2-SJ-1118-22 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
167700	2-SJ-1118-23 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
167800	2-SJ-1118-24 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	





SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
168600	2-SJ-1118-32 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
168700	2-SJ-1118-33 ELBOW TO PIPE	B-J B9.40	PT	1	C	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	C	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	X	-	-	-	3	X	-	-	-	3	X	-	-	-	
168800	2-SJ-1118-34 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
168900	2-SJ-1118-35 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
169000	2-SJ-1118-36 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
169100	2-SJ-1118-37 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	C	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	C	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	X	-	-	-	3	-	-	-	-	
169200	2-SJ-1118-38 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
169300	2-SJ-1118-39 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
169400	2-SJ-1118-40 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
169500	2-SJ-1118-41 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
169600	2-SJ-1118-42 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
169700	2-SJ-1118-43 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
169800	2-SJ-1118-44 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	-	
169900	2-SJ-1118-45 PIPE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
1.5-SJ-1142 (REF. DWG. NO. A-89,90,91)																			
170000	1 1/2-SJ-1142-1 BRANCH CONNECTION TO ELBOW	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	-	
170100	1 1/2-SJ-1142-2 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
1.5-SJ-1142 (REF. DWG. NO. A-89)																			
170105	1 1/2-SJ-1142-2A PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																			
170110	1 1/2-SJ-1142-2B ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																			
170115	1 1/2-SJ-1142-2C PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																			
170120	1 1/2-SJ-1142-2D ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																			
170125	1 1/2-SJ-1142-2E PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																			
170130	1 1/2-SJ-1142-2F ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																			
1.5-SJ-1142 (REF. DWG. NO. A-89,90,91)																			
170200	1 1/2-SJ-1142-3 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																			
170300	1 1/2-SJ-1142-4 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
170900	1 1/2-SJ-1142-9R1 PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	X	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																			
171000	1 1/2-SJ-1142-10R1 VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
171005	1 1/2-SJ-1142-10A PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
171010	1 1/2-SJ-1142-10B VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
1.5-SJ-1142 (REF. DWG. NO. A-89,90,91)																			
171100	1 1/2-SJ-1142-11 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
171200	1 1/2-SJ-1142-12 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
171300	1 1/2-SJ-1142-13 TEE TO PIPE	B-J B9.40	PT	1	C	-	-	-	1	C	-	-	-	1	C	-	-	-	
				2	C	-	-	-	2	C	-	-	-	2	C	-	-	-	
				3	X	-	-	-	3	X	-	-	-	3	X	-	-	-	
171400	1 1/2-SJ-1142-14 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
171500	1 1/2-SJ-1142-15 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
171600	1 1/2-SJ-1142-16 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
1.5-SJ-1142 (REF. DWG. NO. A-90)																		
171700	1 1/2-SJ-1142-17 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	
.....																		
171800	1 1/2-SJ-1142-18 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
171900	1 1/2-SJ-1142-19 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
172000	1 1/2-SJ-1142-20 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
172100	1 1/2-SJ-1142-21 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	C	-	-	-	-	
				2	-	-	-	-	-	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	-	-	

99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
1.5-SJ-1142 (REF. DWG. NO. A-89,90,91)																
172200	1 1/2-SJ-1142-22 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
.....																
172300	1 1/2-SJ-1142-23 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-	
.....																
172400	1 1/2-SJ-1142-24 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-	
.....																
172500	1 1/2-SJ-1142-25 TEE TO REDUCER	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-		
				3	X	-	-	-	-	-	-	-	-	-	-	
.....																
172600	1 1/2-SJ-1142-26 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-	
.....																
172700	1 1/2-SJ-1142-27 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-	
.....																
172800	1 1/2-SJ-1142-28 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-	-	
.....																
172900	1 1/2-SJ-1142-29 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-		
				3	-	-	-	-	X	-	-	-	-	-	-	



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
173000	1 1/2-SJ-1142-30 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
173100	1 1/2-SJ-1142-31 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
173200	1 1/2-SJ-1142-32 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
1.5-SJ-1142 (REF. DWG. NO. A-91)																			
173300	1 1/2-SJ-1142-33 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	C	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																			
1.5-SJ-1142 (REF. DWG. NO. A-89,90,91)																			
173400	1 1/2-SJ-1142-34 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
173500	1 1/2-SJ-1142-35 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
173600	1 1/2-SJ-1142-36 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
173700	1 1/2-SJ-1142-37 PIPE TO COUPLING	B-J B9.40	PT	1	C	-	-	-	1	C	-	-	-	1	C	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
173800	1 1/2-SJ-1142-38 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
173900	1 1/2-SJ-1142-39 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
174000	1 1/2-SJ-1142-40 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
174100	1 1/2-SJ-1142-41 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
93 -	THIS WELD WAS REPLACED BY SUMMARY #174300, DUE TO A HANGER OBSTRUCTION.																		
174200	1 1/2-SJ-1142-42 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
174300	1 1/2-SJ-1142-43 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
93 -	W.O. #931121035 TO PERFORM NDE. THIS WELD REPLACED SUMMARY #174100, DUE TO A HANGER OBSTRUCTION.																		
174400	1 1/2-SJ-1142-44 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
1.5-SJ-1142 (REF. DWG. NO. A-91')																		
174500	1 1/2-SJ-1142-45 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	
				2	-	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	X	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																		
1.5-SJ-1142 (REF. DWG. NO. A-89,90,91)																		
174600	1 1/2-SJ-1142-46 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
174700	1 1/2-SJ-1142-47 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
174800	1 1/2-SJ-1142-48 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
174900	1 1/2-SJ-1142-49R PIPE TO VALVE	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	P	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	-	-	
93 - PSI BASELINE EXAMINATION WAS PERFORMED, DUE TO THE REPLACEMENT OF THIS WELD PER DCP 1E0-2309, CJP# S-93-184 & W.O# 920508129.																		
175000	1.5-SJ-1142-50R VALVE TO PIPE	B-J B9.40	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
				2	A	A	-	-	A	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
89 - UT EXAMINATION FOR NRCB 88-08.																		
91 - EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE. PT EXAM REVEALED ONE LINEAR CODE ALLOWABLE INDICATION. SEE CNF 8. ACCEPTED "AS IS" BY PSE&G PERSONNEL.																		
92 - EXAMINED PER IEB 88-08.																		
175001	1.5-SJ-1142-50R VALVE TO PIPE	A-E NB88-08	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
				2	-	-	-	-	A	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
93 - 88-08 EXAMS WAIVED, REPLACEMENT. W.O.#931121035 TO PERFORM NDE. PSI BASELINE EXAMINATION WAS PERFORMED, DUE TO THE REPLACEMENT OF THIS WELD PER DCP 1E0-2309, CJP# S-93-184 & W.O# 920508129.																		

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**								
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD												
				1	2	3	4	1	2	3	4	1	2	3	4									
175100	1.5-SJ-1142-51R PIPE TO ELBOW	B-J B9.40	PT UT	1	-	-	-	-	2	A	A	-	-	3	-	-	-	-	4	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
89 -	UT EXAMINATION FOR NRCB 88-08.																							
91 -	EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE.																							
92 -	EXAMINED PER IEB 88-08.																							
175101	1.5-SJ-1142-51R PIPE TO ELBOW	A-E NB88-08	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
93 -	88-08 EXAMS WAIVED, REPLACEMENT. W.O.#931121035 TO PERFORM NDE. PSI BASELINE EXAMINATION WAS PERFORMED, DUE TO THE REPLACEMENT OF THIS WELD PER DCP 1E0-2309, CJP# S-93-184 & W.O# 920508129.																							
175200	1.5-SJ-1142-52 ELBOW TO PIPE	B-J B9.40	PT UT	1	-	-	-	-	2	A	A	-	-	3	-	-	-	-	4	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
89 -	UT EXAMINATION FOR NRCB 88-08.																							
91 -	EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE.																							
92 -	EXAMINED PER IEB 88-08.																							
175201	1.5-SJ-1142-52 ELBOW TO PIPE	A-E NB88-08	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
93 -	EXAMINED PER NRC BULLETIN 88-08. W.O. #931121035 TO PERFORM NDE.																							
175300	1.5-SJ-1142-53 PIPE TO BRANCH CONNECTION	B-J B9.40	PT UT	1	-	-	-	-	2	A	A	-	-	3	-	-	-	-	4	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
89 -	UT EXAMINATION FOR NRCB 88-08.																							
91 -	EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE.																							
92 -	EXAMINED PER IEB 88-08.																							
175301	1.5-SJ-1142-53 PIPE TO BRANCH CONNECTION	A-E NB88-08	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
93 -	EXAMINED PER NRC BULLETIN 88-08. W.O.#931121035 TO PERFORM NDE.																							

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**				
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD								
				1	2	3	4	1	2	3	4	1	2	3	4					
	1.5-SJ-1132 (REF. DWG. NO. A-92, A-93)																			
175400	1.5-SJ-1132-1 BRANCH CONNCTN TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-
				2	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-
				3	-	-	-	-	-	-	-	-	-	-	-	-	X	-	-	-
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																				
175500	1.5-SJ-1132-2 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
175600	1.5-SJ-1132-3 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
175700	1.5-SJ-1132-4 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
1.5-SJ-1132 (REF. DWG. NO. A-92)																				
175705	1.5-SJ-1132-4A PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
99RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																				
175710	1.5-SJ-1132-4B ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
99RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																				
175715	1.5-SJ-1132-4C PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
99RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																				
175720	1.5-SJ-1132-4D ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
99RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																				

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
175725	1.5-SJ-1132-4E PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																			
175730	1.5-SJ-1132-4F ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																			
1.5-SJ-1132 (REF. DWG. NO. A-92, A-93)																			
175800	1.5-SJ-1132-5 PIPE TO ELBOW	B-J B9.40	PT	1	C	-	-	-	2	C	-	-	-	3	X	-	-	-	
175900	1.5-SJ-1132-6 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
176000	1.5-SJ-1132-7 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
176100	1.5-SJ-1132-8 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
176200	1.5-SJ-1132-9 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
176300	1.5-SJ-1132-10 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
176400	1.5-SJ-1132-11 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
176500	1.5-SJ-1132-12 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
176600	1.5-SJ-1132-13 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	C C X
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																			
176700	1.5-SJ-1132-14 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
176710	1.5-SJ-1132-14PL-1 THRU 8 PIPE LUGS	B-K B10.20	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
176800	1.5-SJ-1132-14PS-1 PIPE SUPPORT	B-K B10.20	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	REF SUM# 506485 (1C-13SIG-127). REDEFINED AS 1.5-SJ-1132-14PS-1 & 2. SEE SUMMARY NUMBERS 176800 & 176900.
177000	1.5-SJ-1132-15 PIPE TO FLANGE	B-J B9.40	PT	1	C	-	-	-	2	C	-	-	-	3	X	-	-	-	
177100	1.5-SJ-1132-15FB FLANGE BOLTING	B-G-2 B7.50	VT-1	1	C	-	-	-	2	-	-	-	-	3	-	-	-	-	C X
99RF - W.O.#50000402 TO PERFORM NDE.																			

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
177200	1.5-SJ-1132-16 FLANGE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
	1.5-SJ-1132 (REF. DWG. NO. A-92)																		
177205	1.5-SJ-1132-16A PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
177210	1.5-SJ-1132-16B COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
177300	1.5-SJ-1132-17R1 PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
177400	1.5-SJ-1132-18R1 VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
177405	1.5-SJ-1132-18A PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
177410	1.5-SJ-1132-18B VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	





SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
178200	1.5-SJ-1132-26 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
178300	1.5-SJ-1132-27 ELBOW TO PIPE	B-J B9.40	PT	1	C	-	-	-	2	-	-	-	-	3	-	-	-	-	HANGER ON WELD.
178400	1.5-SJ-1132-28 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
178500	1.5-SJ-1132-29 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
178600	1.5-SJ-1132-30 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
178700	1.5-SJ-1132-31 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	C	-	-	-	3	X	-	-	-	
178800	1.5-SJ-1132-32 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
178900	1.5-SJ-1132-33 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
179000	1.5-SJ-1132-34 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
.....																			
	1.5-SJ-1132 (REF. DWG. NO. A-93)																		
179100	1.5-SJ-1132-35 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	C	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	C	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	X	-	-	-	-	
99RF -	FTI UNDER W.O.#50000402 TO PERFORM NDE.																		
.....																			
	1.5-SJ-1132 (REF. DWG. NO. A-92, A-93)																		
179200	1.5-SJ-1132-36 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	-	-	-	-	-	
.....																			
179300	1.5-SJ-1132-37 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	-	-	-	-	-	
.....																			
179400	1.5-SJ-1132-38 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	-	-	-	-	-	
.....																			
179500	1.5-SJ-1132-39R PIPE TO VALVE	B-J B9.40	PT	1	C	-	-	-	1	C	-	-	-	-	-	-	-	-	
				2	C	-	-	-	2	C	-	-	-	P	-	-	-	-	
				3	X	-	-	-	3	X	-	-	-	-	-	-	-	-	
93 -	PSI BASELINE EXAMINATION WAS PERFORMED, DUE TO THE REPLACEMENT OF THIS WELD PER DCP 1E0-2309, CJP# S-93-183 & W.O# 921117149.																		
.....																			
179600	1.5-SJ-1132-40R VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	-	-	-	-	-	NRC BULLETIN 88-08
				2	A	A	-	-	2	A	A	-	-	-	-	-	-	-	PREVIOUSLY APPLIED.
				3	-	-	-	-	3	-	-	-	-	-	-	-	-	-	**1.5-SS-COUP-111-SAM**
89 -	UT EXAMINATION FOR NRCB 88-08.																		
91 -	EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE. PT EXAM REVEALED ONE LINEAR CODE ALLOWABLE INDICATION. SEE CNF 7. ACCEPTED "AS IS" BY PSE&G PERSONNEL.																		
92 -	EXAMINED PER IEB 88-08. PT EXAM REVEALED ONE INDICATION WHICH EXCEEDED CODE ALLOWABLE DIMENSIONS. SEE CNF SAM1-8. REEXAMINATION AFTER SURFACE PREPARATION REVEALED NO RECORDABLE INDICATIONS.																		

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**								
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD												
				1	2	3	4	1	2	3	4	1	2	3	4									
179601	1.5-SJ-1132-40R VALVE TO PIPE	A-E NB88-08	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
93 -	88-08 EXAMS WAIVED, REPLACEMENT. W.O.#931121035 TO PERFORM NDE. PSI BASELINE EXAMINATION WAS PERFORMED, DUE TO THE REPLACEMENT OF THIS WELD PER DCP 1E0-2309, CJP# S-93-183 & W.O# 921117149.																							
179700	1.5-SJ-1132-41R PIPE TO ELBOW	B-J B9.40	PT UT	1	-	-	-	-	2	A	A	-	-	3	A	-	-	-	4	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
89 -	UT EXAMINATION FOR NRCB 88-08.																							
91 -	EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE.																							
92 -	EXAMINED PER IEB 88-08.																							
179701	1.5-SJ-1132-41R PIPE TO ELBOW	A-E NB88-08	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
93 -	88-08 EXAMS WAIVED, REPLACEMENT. W.O.#931121035 TO PERFORM NDE. PSI BASELINE EXAMINATION WAS PERFORMED, DUE TO THE REPLACEMENT OF THIS WELD PER DCP 1E0-2309, CJP# S-93-183 & W.O# 921117149.																							
179800	1.5-SJ-1132-42 ELBOW TO PIPE	B-J B9.40	PT UT	1	-	-	-	-	2	A	A	-	-	3	A	-	-	-	4	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
89 -	UT EXAMINATION FOR NRCB 88-08.																							
91 -	EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE.																							
92 -	EXAMINED PER IEB 88-08.																							
179801	1.5-SJ-1132-42 ELBOW TO PIPE	A-E NB88-08	PT UT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
93 -	EXAMINED PER NRC BULLETIN 88-08. W.O. #931121035 TO PERFORM NDE.																							
179900	1.5-SJ-1132-43 PIPE TO BRANCH CONNECTION	B-J B9.40	PT UT	1	-	-	-	-	2	A	A	-	-	3	A	-	-	-	4	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
89 -	UT EXAMINATION FOR NRCB 88-08.																							
91 -	EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE.																							
92 -	EXAMINED PER IEB 88-08.																							

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
179901	1.5-SJ-1132-43 PIPE TO BRANCH CONNECTION	A-E NB88-08	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**CALIBRATION BLOCK** NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**

93 - EXAMINED PER NRC BULLETIN 88-08. W.O.#931121035 TO PERFORM NDE.

1.5-SJ-1122 (REF. DWG. NO. A-94, A-95)

180000	1.5-SJ-1122-1 BRANCH CONNECTION TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	

180100	1.5-SJ-1122-2 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	

180200	1.5-SJ-1122-2A PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	

180300	1.5-SJ-1122-2B TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	

180400	1.5-SJ-1122-2C TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	

1.5-SJ-1122 (REF. DWG. NO. A-94)

180405	1.5-SJ-1122-2D PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	P	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	

95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
180410	1.5-SJ-1122-2E ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																		
180415	1.5-SJ-1122-2F PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																		
180420	1.5-SJ-1122-2G ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																		
180425	1.5-SJ-1122-2H PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																		
180430	1.5-SJ-1122-2I ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																		
1.5-SJ-1122 (REF. DWG. NO. A-94, A-95)																		
180500	1.5-SJ-1122-3 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																		
180600	1.5-SJ-1122-4 ELBOW TO PIPE	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																		
180700	1.5-SJ-1122-5 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
180800	1.5-SJ-1122-6 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
180900	1.5-SJ-1122-7 TEE TO PIPE	B-J B9.40	PT	1	C	-	-	-	2	C	-	-	-	3	X	-	-	-	
89 -	LIMITED EXAMINATION DUE TO WELDED PIPE SUPPORT. EXAMINED 74% OF CODE REQUIRED AREA.																		
181000	1.5-SJ-1122-8 PIPE TO FLANGE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
181100	1.5-SJ-1122-8FB FLANGE BOLTING	B-G-2 B7.50	VT-1	1	-	-	-	C	2	-	-	-	-	3	-	-	-	X	
99RF -	W.O.#50000402 TO PERFORM NDE.																		
181200	1.5-SJ-1122-9 FLANGE TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
181300	1.5-SJ-1122-10 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
181400	1.5-SJ-1122-11 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	C	2	-	-	-	C	3	-	-	-	X	
181500	1.5-SJ-1122-12 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
181600	1.5-SJ-1122-13 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
	1.5-SJ-1122 (REF. DWG. NO. A-94)																		
181700	1.5-SJ-1122-14R1 PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
181800	1.5-SJ-1122-15R1 VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	C	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	X	-	-	-	-	
.....																			
99RF -	FTI UNDER W.O.#50000402 TO PERFORM NDE.																		
.....																			
	1.5-SJ-1122 (REF. DWG. NO. A-94, A-95)																		
181810	1.5-SJ-1122-15PL-1 AND 2 PIPE LUGS	B-K B10.20	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 506405 (1C-12SIG-211).
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
	1.5-SJ-1122 (REF. DWG. NO. A-94)																		
182005	1.5-SJ-1122-15A PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
182010	1.5-SJ-1122-15B VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
	1.5-SJ-1122 (REF. DWG. NO. A-94, A-95)																		
182100	1.5-SJ-1122-16 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
182200	1.5-SJ-1122-17 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																			
182300	1.5-SJ-1122-18 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
182400	1.5-SJ-1122-19 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
182500	1.5-SJ-1122-20 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
182600	1.5-SJ-1122-21 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
182700	1.5-SJ-1122-22 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
182800	1.5-SJ-1122-23 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
182900	1.5-SJ-1122-24 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
183000	1.5-SJ-1122-25 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
183100	1.5-SJ-1122-26 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
183200	1.5-SJ-1122-27 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
183300	1.5-SJ-1122-28 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
183400	1.5-SJ-1122-29 PIPE TO COUPLING	B-J B9.40	PT	1	C	-	-	-	2	C	-	-	-	3	X	-	-	-	
183500	1.5-SJ-1122-30 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
183600	1.5-SJ-1122-31 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	
183700	1.5-SJ-1122-32 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
183800	1.5-SJ-1122-33 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	
183900	1.5-SJ-1122-34 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
184000	1.5-SJ-1122-35 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
184100	1.5-SJ-1122-36 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
184200	1.5-SJ-1122 (REF. DWG. NO. A-95) 1.5-SJ-1122-37 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	C	-	-	-	-	
				2	-	-	-	-	-	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	-	-	
99RF -	FTI UNDER W.O.#50000402 TO PERFORM NDE.																	
184300	1.5-SJ-1122 (REF. DWG. NO. A-94, A-95) 1.5-SJ-1122-38 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
184400	1.5-SJ-1122-39 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
184500	1.5-SJ-1122-40 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**				
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD								
				1	2	3	4	1	2	3	4	1	2	3	4					
184600	1.5-SJ-1122-41R TEE TO PIPE	B-J B9.40	PT	1	C	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
93 - PSI BASELINE EXAMINATION WAS PERFORMED. DUE TO THE REPLACEMENT OF THIS WELD PER DCP 1E0-2309, CJP# S-93-181 & W.O.3 930709175.																				
184700	1.5-SJ-1122-42R PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
93 - PSI BASELINE EXAMINATION WAS PERFORMED, DUE TO THE REPLACEMENT OF THIS WELD PER DCP 1E0-2309, CJP# S-93-181 & W.O.# 930709175.																				
184800	1.5-SJ-1122-43R VALVE TO PIPE	B-J B9.40	PT UT	1	-	-	-	-	-	2	A	A	-	-	3	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
89 - UT EXAMINATION FOR NRCB 88-08. 91 - EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE. 92 - EXAMINED PER IEB 88-08.																				
184801	1.5-SJ-1122-43R VALVE TO PIPE	A-E NB88-08	PT UT	1	-	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
93 - 88-08 EXAMS WAIVED, REPLACEMENT. W.O.#931121035 TO PERFORM NDE. PSI BASELINE EXAMINATION WAS PERFORMED, DUE TO THE REPLACEMENT OF THIS WELD PER DCP 1E0-2309, CJP# S-93-181 & W.O.# 930709175.																				
184900	1.5-SJ-1122-44 PIPE TO ELBOW	B-J B9.40	PT UT	1	-	-	-	-	-	2	A	A	-	-	3	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
89 - UT EXAMINATION FOR NRCB 88-08. 91 - EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE. 92 - EXAMINED PER IEB 88-08.																				
184901	1.5-SJ-1122-44 PIPE TO ELBOW	A-E NB88-08	PT UT	1	-	-	-	-	-	2	-	-	-	-	3	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
93 - EXAMINED PER NRC BULLETIN 88-08. W.O. #931121035 TO PERFORM NDE.																				

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
185000	1.5-SJ-1122-45 ELBOW TO PIPE	B-J B9.40	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	**CALIBRATION BLOCK** NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
89 -	UT EXAMINATION FOR NRCB 88-08.																		
91 -	EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE.																		
92 -	EXAMINED PER IEB 88-08.																		
185001	1.5-SJ-1122-45 ELBOW TO PIPE	A-E NB88-08	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
93 -	EXAMINED PER NRC BULLETIN 88-08. W.O. #931121035 TO PERFORM NDE.																		
185100	1.5-SJ-1122-46 PIPE TO BRANCH CONNECTION	B-J B9.40	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
99 -	UT EXAMINATION FOR NRCB 88-08.																		
91 -	EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE.																		
92 -	EXAMINED PER IEB 88-08.																		
185101	1.5-SJ-1122-46 PIPE TO BRANCH CONNECTION	A-E NB88-08	PT UT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
93 -	EXAMINED PER NRC BULLETIN 88-08. W.O.#931121035 TO PERFORM NDE.																		
185200	1.5-SJ-1112-1 BRANCH CONNCTN TO COUPLING	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
185300	1.5-SJ-1112-2 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**				
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD								
				1	2	3	4	1	2	3	4	1	2	3	4					
185400	1.5-SJ-1112-3 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																				
-----																				
185500	1.5-SJ-1112-4 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-----																				
1.5-SJ-1112 (REF. DWG. NO. A-96)																				
185505	1.5-SJ-1112-4A PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-----																				
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																				
-----																				
185510	1.5-SJ-1112-4B ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-----																				
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																				
-----																				
185515	1.5-SJ-1112-4C PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-----																				
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																				
-----																				
185520	1.5-SJ-1112-4D ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-----																				
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																				
-----																				
185525	1.5-SJ-1112-4E PIPE TO ORIFICE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-----																				
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																				
-----																				
185530	1.5-SJ-1112-4F ORIFICE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
-----																				
95RF - PSI BASELINE PERFORMED PER 1EC-3530-2 / PS-97-029 / 970623168 (ADDED NEW ORIFICES).																				



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
186400	1.5-SJ-1112-12 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	
186500	1.5-SJ-1112-13 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
186600	1.5-SJ-1112-14 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
186700	1.5-SJ-1112-15 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	C	-	-	-	-	
				2	-	-	-	-	-	-	-	-	C	-	-	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE.																		
186800	1.5-SJ-1112-16 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
	1.5-SJ-1112 (REF. DWG. NO. A-96)																	
186900	1.5-SJ-1112-17R1 PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
187000	1.5-SJ-1112-18R1 VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
187005	1.5-SJ-1112-18A PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
187010	1.5-SJ-1112-18B VALVE TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
.....																			
	1.5-SJ-1112 (REF. DWG. NO. A-96, A-97)																		
187100	1.5-SJ-1112-19 PIPE TO TEE	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	-	
.....																			
187200	1.5-SJ-1112-20 TEE TO REDUCER	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
187300	1.5-SJ-1112-21 TEE TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
187400	1.5-SJ-1112-22 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
187500	1.5-SJ-1112-23 ELBOW TO PIPE	B-J B9.40	PT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
187600	1.5-SJ-1112-24 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
187700	1.5-SJ-1112-25 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
187710	1.5-SJ-1112-25PL-1 THRU 4 PIPE LUGS	B-K B10.20	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
187800	1.5-SJ-1112-26 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
187900	1.5-SJ-1112-27 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
188000	1.5-SJ-1112-28 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
188100	1.5-SJ-1112-29 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
188200	1.5-SJ-1112-30 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
188300	1.5-SJ-1112-31 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	1	-	-	-	-	
188400	1.5-SJ-1112-32 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
188500	1.5-SJ-1112-33 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
188600	1.5-SJ-1112-34 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
188700	1.5-SJ-1112-35 COUPLING TO PIPE	B-J B9.40	PT	1	C	-	-	-	1	C	-	-	-	1	C	-	-	-	
				2	C	-	-	-	2	C	-	-	-	2	C	-	-	-	
				3	X	-	-	-	3	X	-	-	-	3	X	-	-	-	
188800	1.5-SJ-1112-36 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
188900	1.5-SJ-1112-37 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
189000	1.5-SJ-1112-38 PIPE TO ELBOW	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
	1.5-SJ-1112 (REF. DWG. NO. A-97)																		
189100	1.5-SJ-1112-39 ELBOW TO PIPE	B-J B9.40	PT	1	-	-	-	-	1	-	-	-	-	1	C	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	C	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	X	-	-	-	
99RF	- FTI UNDER W.O.#50000402 TO PERFORM NDE.																		



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
189900	1.5-SJ-1112-47 PIPE TO COUPLING	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
190000	1.5-SJ-1112-48 COUPLING TO PIPE	B-J B9.40	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	
190100	1.5-SJ-1112-49R PIPE TO VALVE	B-J B9.40	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	PSI BASELINE EXAMINATION WAS PERFORMED, DUE TO THE REPLACEMENT OF THIS WELD PER DCP 1E0-2309, CJP# S-93-182 & W.O# 921117147.																	
190200	1.5-SJ-1112-50R VALVE TO PIPE	B-J B9.40	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
89 -	UT EXAMINATION FOR NRCB 88-08.																	
91 -	EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE.																	
92 -	EXAMINED PER IEB 88-08.																	
190201	1.5-SJ-1112-50R VALVE TO PIPE	A-E NB88-08	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
93 -	88-08 EXAMS WAIVED, REPLACEMENT. W.O.#931121035 TO PERFORM NDE. PSI BASELINE EXAMINATION WAS PERFORMED, DUE TO THE REPLACEMENT OF THIS WELD PER DCP 1E0-2309, CJP# S-93-182 & W.O# 921117147.																	
190300	1.5-SJ-1112-51R PIPE TO ELBOW	B-J B9.40	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
89 -	UT EXAMINATION FOR NRCB 88-08.																	
91 -	EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE.																	
92 -	EXAMINED PER IEB 88-08.																	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
190301	1.5-SJ-1112-51R PIPE TO ELBOW	A-E NB88-08	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	**CALIBRATION BLOCK** NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
93 -	88-08 EXAMS WAIVED, REPLACEMENT. W.O.#931121035 TO PERFORM NDE. PSI BASELINE EXAMINATION WAS PERFORMED, DUE TO THE REPLACEMENT OF THIS WELD PER DCP 1E0-2309, CJP# S-93-182 & W.O# 921117147.																		
190400	1.5-SJ-1112-52 ELBOW TO PIPE	B-J B9.40	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
89 -	UT EXAMINATION FOR NRCB 88-08.																		
91 -	EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE. PT EXAM REVEALED 5/8" LINEAR INDICATION ON SOCKET. SEE CNF 10. REEXAMINATION AFTER COSMETIC BUFFING REVEALED NO RECORDABLE INDICATIONS.																		
92 -	EXAMINED PER IEB 88-08.																		
190401	1.5-SJ-1112-52 ELBOW TO PIPE	A-E NB88-08	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
93 -	EXAMINED PER NRC BULLETIN 88-08. W.O. #931121035 TO PERFORM NDE.																		
190500	1.5-SJ-1112-53 PIPE TO BRANCH CONNECTION	B-J B9.40	PT UT	1	C	-	-	-	-	-	-	-	-	-	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
89 -	UT EXAMINATION FOR NRCB 88-08.																		
91 -	EXAMINED PER NRCB 88-08 FOR THE SECOND CONSECUTIVE OUTAGE.																		
92 -	EXAMINED PER IEB 88-08.																		
190501	1.5-SJ-1112-53 PIPE TO BRANCH CONNECTION	A-E NB88-08	PT UT	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	NRC BULLETIN 88-08 PREVIOUSLY APPLIED. **1.5-SS-COUP-111-SAM**
93 -	EXAMINED PER NRC BULLETIN 88-08. W.O.#931121035 TO PERFORM NDE.																		

REACTOR COOLANT PUMP 11

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
BOLTING (REF. DWG. NO. A-98)																
190800	11-PMP-BOLTS 1-24	B-G-1	UT	1	-	C	-	-	-	-	-	-	-	-	-	LIMITATION: EXAMINED 17 OF 24 BOLTS IN-PLACE. 7 BOLTS ARE INACCESSIBLE DUE TO PIPING INTERFERENCE. PERFORM A VT-2 EVERY RFO IAW R/T# 290049. IEB 82-02 PREVIOUSLY APPLIED. **4.5-.75-8-CS-70-SAM**
		B6.180	VT-2	2	A	-	-	-	C	-	A	-	A	A	-	
				3	S	S	-	-	X	S	-	-	S	S	-	
01RF -	W/O# 50009730 TO PERFORM NDE. VT-2 EXAM PERFORMED EACH OUTAGE IN ACCORDANCE WITH RELIEF REQUEST RR-B1															
89 -	EXAMINED 17 OF 24 BOLTS IN PLACE. 7 BOLTS INACCESSIBLE DUE TO PIPING.															
92 -	NO EXAM ON BOLTS 3, 4, 5, 6, 13, 22, AND 23 DUE TO OBSTRUCTIONS FROM OIL PANS, CVC AND INSTRUMENT LINES.															
95 -	W.O.#950526019 TO PERFORM NDE IAW 82-02. BORON RESIDUE WAS FOUND BY VT-2, SEE AR# 950811362. MQS TO PERFORM F-MT & VT-1, FOR SOME OF THE REMOVED BOLTS. PSI BASELINE PERFORMED PER S-96-071 / 950811362 (BOLT REPLACEMENT).															
99RF -	W.O.#50000402 TO PERFORM VT-2.															
LIGAMENTS BETWEEN THREADED STUD HOLES (REF. DWG. NO. A-98)																
190900	11-PMP-LIG 1-24	B-G-1	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	TO BE EXAMINED ONLY WHEN THE PUMP IS DISASSEMBLED.
		B6.190		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
INTEGRALLY WELDED SUPPORTS (REF. DWG. NO. A-98)																
191000	11-PMP-1LG LUG	B-K	PT	1	-	-	-	-	-	-	-	-	C	-	-	
		B10.30		2	C	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	
89 -	LIMITED EXAMINATION DUE TO PUMP SUPPORT. EXAMINED 83% OF CODE REQUIRED AREA.															
191100	11-PMP-2LG LUG	B-K	PT	1	-	-	-	-	-	-	-	-	C	-	-	
		B10.30		2	C	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	
89 -	LIMITED EXAMINATION DUE TO PUMP SUPPORT. EXAMINED 83% OF CODE REQUIRED AREA.															
191150	11-PMP-3LG LUG	B-K	PT	1	-	-	-	-	-	-	-	-	C	-	-	
		B10.30		2	C	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
89 -	LIMITED EXAMINATION DUE TO PUMP SUPPORT. EXAMINED 83% OF CODE REQUIRED AREA.															

REACTOR COOLANT PUMP 11

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**				
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD								
				1	2	3	4	1	2	3	4	1	2	3	4					
PUMP CASING (REF. DWG. NO. A-98)																				
191270	RCP 11 CASING WELDS	B-L-1	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	CODE CASE N-481 APPLIES (VT-1 IN LIEU OF RT).
	PUMP CASING	B12.10		2	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	PERFORM VT-1 ON THE PUMP CASING EXTERNAL WELD.
	CIRCUMFERENTIAL WELD			3	-	-	-	-	-	-	-	-	-	-	-	X	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE. VT-1 ON THE PUMP CASING EXTERNAL WELD TO BE PERFORMED IAW CODE CASE N-481.																				
-----																				
191280	RCP 11 INTERNAL SURFACE PUMP CASING INTERNAL SURF.	B-L-2	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
		B12.20		2	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	X	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE. PERFORM VT-3 ON THE EXTERNAL SURFACE OF THE PUMP CASING WELD IAW ISI LTP RR-B3.																				
-----																				



REACTOR COOLANT PUMP 12

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD			SECOND PERIOD				THIRD PERIOD					
				1	2	3	1	2	3	4	1	2	3	4		
BOLTING (REF. DWG. NO. A-98)																
191600	12-PMP-BOLTS 1-24	B-G-1	UT	1	-	-	-	-	-	C	-	-	-	-	-	LIMITATION: EXAMINED 16 OF 24 BOLTS IN-PLACE. 8 BOLTS ARE INACCESSIBLE DUE TO PIPING INTERFERENCES. PERFORM A VT-2 EVERY RFO IAW R/T# 290049. IEB 82-02 PREVIOUSLY APPLIED. **4.5-.75-8-CS-70-SAM**
		B6.180	VT-2	2	-	-	-	-	C	-	A	-	A	A	-	
				3	S	S	-	-	X	S	-	-	S	S	-	
01RF -	W/O# 50009730 TO PERFORM NDE. VT-2 EXAM PERFORMED EACH OUTAGE IN ACCORDANCE WITH RELIEF REQUEST RR-B1															
92 -	NO EXAM ON BOLTS 3, 4, 5, 6, 7, 13, 14, AND 23 DUE TO OBSTRUCTIONS FROM OIL PANS, CVC AND INSTRUMENT LINES.															
95 -	W.O.# 950526019, NDE IAW 82-02. BORON FOUND BY VT-2, (AR# 950811368). MQS TO PERFORM F-MT & VT-1, FOR ALL REMOVED BOLTS. PSI BASELINE PERFORMED PER S-96-059 / 950800368 (REPLACE). SEE AR# 960127093 FOR VT-1 FAILURES.															
99RF -	W.O.#50000402 TO PERFORM NDE. PERFORM VT-2 ON PUMP BODY-TO-COVER CONNECTION PER WESTINGHOUSE RECOMMENDATIONS.															
LIGAMENTS BETWEEN THREADED STUD HOLES (REF. DWG. NO. A-98)																
191700	12-PMP-LIG 1-24	B-G-1	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	TO BE EXAMINED ONLY WHEN THE CONNECTION IS DISASSEMBLED.
		B6.190		2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
INTEGRALLY WELDED SUPPORTS (REF. DWG. NO. A-98)																
191800	12-PMP-1LG LUG	B-K	PT	1	-	-	-	-	-	C	-	-	-	-	-	NO EXAM FROM THE BOTTOM SIDE OF THE LUG DUE TO INACCESSIBILITY.
		B10.30		2	-	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	W.O.#931121035 TO PERFORM NDE. LIMITATION: THE EXAM IS LIMITED TO 72% COVERAGE, DUE TO THE PUMP BRACING AT THE BOTTOM OF THE LUG.															
191850	12-PMP-2LG LUG	B-K	PT	1	-	-	-	-	-	C	-	-	-	-	-	NO EXAM FROM THE BOTTOM SIDE OF THE LUG DUE TO INACCESSIBILITY.
		B10.30		2	-	-	-	-	-	C	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 -	W.O.#931121035 TO PERFORM NDE. LIMITATION: THE EXAM IS LIMITED TO 72% COVERAGE, DUE TO THE PUMP BRACING AT THE BOTTOM OF THE LUG.															

REACTOR COOLANT PUMP 12

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
191900	12-PMP-3LG LUG	B-K B10.30	PT	1	-	-	-	-	C	-	-	-	-	-	-	-	-	NO EXAM FROM THE BOTTOM SIDE OF THE LUG DUE TO INACCESSIBILITY.
93 - W.O.#931121035 TO PERFORM NDE. LIMITATION: THE EXAM IS LIMITED TO 76% COVERAGE, DUE TO THE PUMP BRACING AT THE BOTTOM OF THE LUG.																		
PUMP CASING (REF. DWG. NO. A-98)																		
192040	RCP 12 CASING WELD PUMP CASING WELD	B-L-1 B12.10	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	CODE CASE N-481 APPLIES (VT-1 IN LIEU OF RT).
192050	RCP 12 INTERNAL SURFACE PUMP CASING INTERNAL SURF.	B-L-2 B12.20	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT PUMP 13

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
BOLTING (REF. DWG. NO. A-98)																			
192400	13-PMP-BOLTS 1-24	B-G-1	UT	1	-	-	-	-	-	-	-	-	-	-	-	C	-	-	PERFORM A VT-2 EVERY RFO IAW R/T# 290049. IEB 82-02 PREVIOUSLY APPLIED. LIMITATION: UT EXAMINED 97% OF THE CODE REQUIRED VOLUME, DUE TO A PERMANENT OBSTRUCTION (SEAL WATER PIPING) OVER BOLT #12. **4.5-.75-8-CS-70-SAM**
		B6.180	VT-2	2	-	-	-	-	-	-	A	-	-	-	-	C	A	-	
				3	S	S	-	-	S	S	-	-	-	-	-	X	S	-	
01RF -	W/O# 50009730 TO PERFORM NDE. VT-2 EXAM PERFORMED EACH OUTAGE IN ACCORDANCE WITH RELIEF REQUEST RR-B1																		
95 -	W.O.# 950526019, NDE IAW 82-02. BORON FOUND BY VT-2, SEE AR# 950811370. MQS TO PERFORM F-MT & VT-1, FOR ALL REMOVED BOLTS. PSI BASELINE PERFORMED PER S-96-072 / 950811370 (REPLACE). SEE AR# 960212104 FOR VT-1 FAILURE.																		
99RF -	FTI UNDER W.O.#50000402 TO PERFORM UT EXAM. PSE&G TO PERFORM VT-2 ON PUMP BODY-TO-COVER CONN. PER WEST. RECOM. LIMITATION: UT EXAMINED 97% OF THE CODE REQUIRED VOLUME, DUE TO A PERMANENT OBSTRUCTION (SEAL WATER PIPING) OVER BOLT #12.																		
LIGAMENTS BETWEEN THREADED STUD HOLES (REF. DWG. NO. A-98)																			
192500	13-PMP-LIG 1-24	B-G-1	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	TO BE EXAMINED ONLY WHEN THE CONNECTION IS DISASSEMBLED.
	LIGAMENTS	B6.190		2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
INTEGRALLY WELDED SUPPORTS (REF. DWG. NO. A-98)																			
192600	13-PMP-1LG	B-K	PT	1	-	-	-	-	-	-	-	-	-	-	-	C	-	-	LIMITATION: EXAMINED (PT) 77.5 % OF THE CODE REQUIRED SURFACE, DUE TO CONFIGURATION OF THE PUMP SUPPORT STRUCTURE.
	LUG	B10.30		2	-	-	-	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
99RF -	FTI UNDER W.O.#50000402 TO PERFORM NDE. LIMITATION: EXAMINED (PT) 77.5 % OF THE CODE REQUIRED SURFACE, DUE TO CONFIGURATION OF THE PUMP SUPPORT STRUCTURE.																		

REACTOR COOLANT PUMP 13

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**				
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD								
				1	2	3	4	1	2	3	4	1	2	3	4					
192650	13-PMP-2LG LUG	B-K B10.30	PT	1	-	-	-	-	O U T A G E				-	-	-	-	C	-	-	LIMITATION: EXAMINED (PT) 77.5 % OF THE CODE REQUIRED SURFACE, DUE TO CONFIGURATION OF THE PUMP SUPPORT STRUCTURE.
				2	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE. LIMITATION: EXAMINED (PT) 77.5 % OF THE CODE REQUIRED SURFACE, DUE TO CONFIGURATION OF THE PUMP SUPPORT STRUCTURE.																				
192700	13-PMP-3LG LUG	B-K B10.30	PT	1	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	LIMITATION: EXAMINED (PT) 77.5 % OF THE CODE REQUIRED SURFACE, DUE TO CONFIGURATION OF THE PUMP SUPPORT STRUCTURE.
				2	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
99RF - FTI UNDER W.O.#50000402 TO PERFORM NDE. LIMITATION: EXAMINED (PT) 77.5 % OF THE CODE REQUIRED SURFACE, DUE TO CONFIGURATION OF THE PUMP SUPPORT STRUCTURE.																				
PUMP CASING (REF. DWG. NO. A-98)																				
.92840	RCP 13 CASING WELDS PUMP CASING WELD	B-L-1 B12.10	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	CODE CASE N-481 APPLIES (VT-1 IN LIEU OF RT).
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
192850	RCP 13 INTERNAL SURFACE PUMP CASING INTERNAL SURF.	B-L-2 B12.20	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

REACTOR COOLANT PUMP 14

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
BOLTING (REF. DWG. NO. A-98)																		
193200	14-PMP-BOLTS 1-24	B-G-1	UT	1	C	-	-	-	-	-	-	-	-	-	C	-	-	PERFORM A VT-2 EVERY RFO IAW R/T# 290049. IEB 82-02 PREVIOUSLY APPLIED. **4.5-.75-8-CS-70-SAM**
		B6.180	VT-2	2	-	-	-	-	C	-	A	-	A	A	-	-		
				3	S	S	-	-	X	S	-	-	S	S	-	-		

- 01RF - W/O# 50009730 TO PERFORM NDE. VT-2 EXAM PERFORMED EACH OUTAGE IN ACCORDANCE WITH RELIEF REQUEST RR-B1
- 92 - NO EXAM ON BOLTS 1, 2, 13, 19, 22, 23, AND 24 DUE TO OBSTRUCTIONS FROM OIL PANS, CVC AND INSTRUMENT LINES. NO EXAM ON BOLTS 3 AND 11 DUE TO OBSTRUCTIONS IN HEATER HOLES.
- 95 - W.O.# 950526019, NDE IAW 82-02. BORON FOUND BY VT-2, SEE AR# 950811372. MQS TO PERFORM F-MT & VT-1, FOR ALL REMOVED BOLTS. PSI BASELINE PERFORMED PER S-96-062 / 950811372 (REPLACE). SEE AR# 960130269 FOR VT-1 FAILURE.
- 99RF - W.O.#50000402 TO PERFORM NDE. PERFORM VT-2 ON PUMP BODY-TO-COVER CONNECTION PER WESTINGHOUSE RECOMMENDATIONS.

LIGAMENTS BETWEEN THREADED STUD HOLES (REF. DWG. NO. A-98)

193300	14-PMP-LIG 1-24 LIGAMENTS	B-G-1	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	TO BE EXAMINED ONLY IF THE CONNECTION IS DISASSEMBLED.
		B6.190		2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

INTEGRALLY WELDED SUPPORTS (REF. DWG. NO. A-98)

193400	14-PMP-1LG LUG	B-K	PT	1	-	-	-	-	-	-	-	-	-	C	-	-	NO EXAM FROM THE BOTTOM SIDE OF THE LUG DUE TO INACCESSIBILITY.
		B10.30		2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

- 93 - W.O.#931121035 TO PERFORM NDE. LIMITATION: THE EXAM IS LIMITED TO 77% COVERAGE, DUE TO THE PUMP BRACING AT THE BOTTOM OF THE LUG.

193450	14-PMP-2LG LUG	B-K	PT	1	-	-	C	-	-	-	-	-	-	-	-	-	NO EXAM FROM THE BOTTOM SIDE OF THE LUG DUE TO INACCESSIBILITY.
		B10.30		2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	

- 93 - W.O.#931121035 TO PERFORM NDE. LIMITATION: THE EXAM IS LIMITED TO 74% COVERAGE, DUE TO THE PUMP BRACING AT THE BOTTOM OF THE LUG.



VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
VALVE BODIES (REF. DWG. NO. A-15)																
193795	1 PR 3 VB ON LINE 6-PR-1103	B-M-2 B12.50	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS. **VALVE GROUP # 1**
95RF - WYLE TO PERFORM VT-3 PER P.O.# P3 0933105 0630. NOTE: THIS EXAM DOES NOT SATISFY SECTION XI REQUIREMENTS, PERFORMED AS A PSE&G A-E.																
99RF - PERFORMED PSI BASELINE PER 1EC-3729-1/PS-98-007/980713162 (REPLACED W/ NEW BLOCK BODY STYLE VALVE S/N (TBD). PT IN LIEU OF VT-3 IAW REPAIR MANUAL SECTION 9.2.3.11. VALVE SERIAL NO. N91590-00-0005.																
VALVE BODIES (REF. DWG. NO. A-14)																
193796	1 PR 4 VB ON LINE 6-PR-1104	B-M-2 B12.50	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS. **VALVE GROUP # 1**
95RF - WYLE TO PERFORM VT-3 PER P.O.# P3 0933105 0630. NOTE: THIS EXAM DOES NOT SATISFY SECTION XI REQUIREMENTS, PERFORMED AS A PSE&G A-E.																
99RF - PERFORMED PSI BASELINE PER 1EC-3729-1/PS-98-007/980713162 (REPLACED W/ NEW BLOCK BODY STYLE VALVE S/N (TBD). PT IN LIEU OF VT-3 IAW REPAIR MANUAL SECTION 9.2.3.11. VALVE SERIAL NO. N91590-00-0006.																
VALVE BODIES (REF. DWG. NO. A-13)																
193797	1 PR 5 VB ON LINE 6-PR-1105	B-M-2 B12.50	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS. **VALVE GROUP # 1**
95RF - WYLE TO PERFORM VT-3 PER P.O.# P3 0933105 0630. NOTE: THIS EXAM DOES NOT SATISFY SECTION XI REQUIREMENTS, PERFORMED AS A PSE&G A-E.																
99RF - PERFORMED PSI BASELINE PER 1EC-3729-1/PS-98-007/980713162 (REPLACED W/ NEW BLOCK BODY STYLE VALVE S/N (TBD). PT IN LIEU OF VT-3 IAW REPAIR MANUAL SECTION 9.2.3.11. VALVE SERIAL NO. N91590-00-0004.																
VALVE BODIES (REF. DWG. NO. A-52)																
193798	1 RH 1 VB ON LINE 14-RH-1111	B-M-2 B12.50	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS. **VALVE GROUP # 2**

VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
193799	1 RH 2 VB ON LINE 14-RH-1111	B-M-2 B12.50	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS. **VALVE GROUP # 2**
.....																			
VALVE BODIES (REF. DWG. NO. A-53)																			
193800	1 RH 26 VB ON LINE 12-SJ-1151	B-M-2 B12.50	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS. **VALVE GROUP # 3**
.....																			
97RF -	1) W.O.# 970701013 TO PERFORM VT-3. MAINT. DISASSEMBLED VALVE. VT-3 FOUND SEATING SURFACE WEAR. 2) W.O.# 970620282 TO PERFORM 2ND VT-3 AFTER RESURFACING THE SEATING SURFACE.																		
.....																			
193805	13 RH 27 VB ON LINE 12-SJ-1151	B-M-2 B12.50	VT-3	1	-	-	-	-	1	-	C	-	-	1	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS. **VALVE GROUP # 4**
.....																			
91 -	W.O.# 920531002, ACT 18 & 970701014, ACT 01																		
93 -	THIS EXAM WAS DELETED. DURING THIS 2ND INTERVAL, ONE OF THE RH 27 VALVES WERE SATISFACTORILY INSPECTED PREVIOUSLY.																		
.....																			
VALVE BODIES (REF. DWG. NO. A-62)																			
193810	14 RH 27 VB ON LINE 8-SJ-1145	B-M-2 B12.50	VT-3	1	-	C	-	-	1	-	-	-	-	1	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS. **VALVE GROUP # 4**
.....																			
93 -	THIS EXAM WAS DELETED. DURING THIS 2ND INTERVAL, ONE OF THE RH 27 VALVES WERE SATISFACTORILY INSPECTED PREVIOUSLY.																		
.....																			
VALVE BODIES (REF. DWG. NO. A-70)																			
193815	11 SJ 43 VB ON LINE 6-SJ-1112	B-M-2 B12.50	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS. **VALVE GROUP # 5**



VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
VALVE BODIES (REF. DWG. NO. A-68)																			
193820	12 SJ 43 VB ON LINE 6-SJ-1122	B-M-2 B12.50	VT-3	1	-	-	-	-	2	-	C	-	-	3	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS. **VALVE GROUP # 5**
91 - W.O.# 900717082, ACT 04 & 970701023, ACT 01																			
VALVE BODIES (REF. DWG. NO. A-66)																			
193825	13 SJ 43 VB ON LINE 6-SJ-1132	B-M-2 B12.50	VT-3	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS. **VALVE GROUP # 5**
VALVE BODIES (REF. DWG. NO. A-64)																			
193830	14 SJ 43 VB ON LINE 6-SJ-1142	B-M-2 B12.50	VT-3	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS. **VALVE GROUP # 5**
VALVE BODIES (REF. DWG. NO. A-60)																			
193835	11 SJ 49 VB ON LINE 8-SJ-1152	B-M-2 B12.50	VT-3	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS. **VALVE GROUP # 6**
VALVE BODIES (REF. DWG. NO. A-58)																			
193840	12 SJ 49 VB ON LINE 8-SJ-1162	B-M-2 B12.50	VT-3	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS. **VALVE GROUP # 6**





VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
VALVE BODIES (REF. DWG. NO. A-56)																
193890	12 SJ 56 VB ON LINE 10-SJ-1121	B-M-2 B12.50	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS **VALVE GROUP # 8**
				2	-	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
91 - W.O.# 970701031, ACT 01																
VALVE BODIES (REF. DWG. NO. A-55)																
193895	13 SJ 56 VB ON LINE 10-SJ-1131	B-M-2 B12.50	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS **VALVE GROUP # 8**
				2	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
VALVE BODIES (REF. DWG. NO. A-54)																
193900	14 SJ 56 VB ON LINE 10-SJ-1141	B-M-2 B12.50	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS. **VALVE GROUP # 8**
				2	-	-	-	-	-	R	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS EXAM WAS DELETED. DURING THIS 2ND INTERVAL, ONE OF THE SJ 56 VALVES WERE SATISFACTORILY INSPECTED PREVIOUSLY.																
VALVE BODIES (REF. DWG. NO. A-88)																
193905	11 SJ 156 VB ON LINE 6-SJ-1111	B-M-2 B12.50	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS **VALVE GROUP # 9**
				2	-	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
91 - W.O.# 900917018, ACT 04 & 970701034, ACT 04																
VALVE BODIES (REF. DWG. NO. A-69)																
193910	12 SJ 156 VB ON LINE 6-SJ-1121	B-M-2 B12.50	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS **VALVE GROUP # 9**
				2	-	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
91 - W.O.# 920713003, ACT 07 & 970701037, ACT 01																

VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
VALVE BODIES (REF. DWG. NO. A-67)																			
193915	13 SJ 156 VB ON LINE 6-SJ-1131	B-M-2 B12.50	VT-3	1	-	-	-	-	2	-	C	-	-	3	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS **VALVE GROUP # 9**
91 - W.O.# 900715077, ACT 07 & 970701037, ACT 07																			
VALVE BODIES (REF. DWG. NO. A-65)																			
193920	14 SJ 156 VB ON LINE 6-SJ-1141	B-M-2 B12.50	VT-3	1	-	-	-	-	2	-	C	-	-	3	-	-	-	-	TO BE EXAMINED ONLY IF DISASSEMBLED FOR OTHER REASONS **VALVE GROUP # 9**
91 - W.O.# 900717076, ACT 07 & 970701037, ACT 07																			
BOLTING (REF. DWG. NO. A-10)																			
194000	1 CV 77 ON LINE 3-CV-1133	B-G-2 B7.70	VT-1	1	-	-	-	-	2	-	C	-	-	3	-	X	-	-	
91 - W.O.# 901120026, ACT 45																			
194100	1 CV 78 ON LINE 3-CV-1133	B-G-2 B7.70	VT-1	1	-	-	-	-	2	-	-	-	C	3	-	-	-	-	
93 - W.O.# 920810209 AND 931121035 TO PERFORM NDE. ONE (1) STUD WAS FOUND WITH INADEQUATE THREAD ENGAGEMENT. A DR WAS ISSUED TO SYSTEM ENGINEERING. W.O. #93100204 CORRECTED THE THREAD ENGAGEMENT PROBLEM. A SATISFACTORY RE-EXAM WAS PERFORMED.																			
95RF - PSI BASELINE PERFORMED PER S-95-287 / 931002337 (NEW BOLTING). PSI EXAM WAS INITIALLY MISSED ( REF. AR# 951115179). MANUFACTURES (ALLIED NUT & BOLT CO.) VT INSPECTION REPORTS TO DOCUMENT PSI (REF. NBU/QA LETTER NQP95-5117)																			
BOLTING (REF. DWG. NO. A-8)																			
194120	1 CV 2 ON LINE 3-CV-1143	B-G-2 B7.70	VT-1	1	-	-	-	-	2	-	C	-	-	3	-	X	-	-	
91 - W.O.# 901120026, ACT 47																			

VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**				
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD								
				1	2	3	4	1	2	3	4	1	2	3	4					
BOLTING (REF. DWG. NO. A-11)																				
194140	1 CV 75 ON LINE 2-CV-1175	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	C	-	-	-	-	P	-	-	-	-	-	-	-	-	-
				3	-	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-
91 -	W.O.# 901120026, ACT 48																			
95 -	1) PSI BASELINE PERFORMED PER S-95-026 / 941112125 (BOLTING REPLACEMENT PERFORMED IN FORCED OUTAGE ON 2/95). 2) PSI BASELINE ALSO PERFORMED PER S-95-180 / 950505099 (BOLTING REPLACEMENT DURING EXTENDED OUTAGE).																			
BOLTING (REF. DWG. NO. A-9)																				
194200	1 CV 79 ON LINE 3-CV-1141	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-
91 -	W.O.# 901120026, ACT 49																			
BOLTING (REF. DWG. NO. A-9)																				
194300	1 CV 80 ON LINE 3-CV-1141	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	C	-	-	-	-	P	-	-	-	-	-	-	-	-	-
				3	-	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-
91 -	W.O.# 901120026, ACT 50																			
95RF -	PSI BASELINE PERFORMED PER S-95-254 / 950527006 (BOLTING REPLACEMENT).																			
BOLTING (REF. DWG. NO. A-10)																				
194400	1 CV 274 ON LINE 3-CV-1133	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-
91 -	W.O.# 901120026, ACT 51																			
BOLTING (REF. DWG. NO. A-9)																				
194500	1 CV 275 ON LINE 3-CV-1141	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-
				3	-	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-
91 -	W.O.# 901120026, ACT 52																			

VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
BOLTING (REF. DWG. NO. A-8)																
194600	1 CV 277 ON LINE 3-CV-1143	B-G-2 B7.70	VT-1	1	-	-	-	-	C	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	
91 - W.O.# 901120026, ACT 53																
BOLTING (REF. DWG. NO. A-17)																
194700	1 PR 1 ON LINE 3-PR-1106	B-G-2 B7.70	VT-1	1	-	-	-	-	C	-	-	-	-	-	-	
				2	-	C	-	-	P	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	
91 - W.O.# 901120026, ACT 11																
93 - PSI BASELINE EXAMINATION WAS PERFORMED, DUE TO DCP 1EC-3219-1, CJP# PS-93-053 & W.O.# 930126150. NEW STUDS AND NUTS WERE INSTALLED.																
BOLTING (REF. DWG. NO. A-16)																
194800	1 PR 2 ON LINE 3-PR-1107	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	C	-	-	
				2	-	C	-	-	P	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	
91 - W.O.# 901120026, ACT 12																
93 - PSI BASELINE EXAMINATION WAS PERFORMED, DUE TO DCP 1EC-3219-1, CJP# PS-93-054 & W.O.# 930126150. NEW STUDS AND NUTS WERE INSTALLED.																
BOLTING (REF. DWG. NO. A-15)																
194900	1 PR 3 ON LINE 6-PR-1103	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	C	-	-	IEB 82-02 PREVIOUSLY APPLIED.
				2	-	K	-	-	-	K	-	P	C	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																
91 - W.O.# 901120026, ACT 13																
95RF - 1) WYLE TO PERFORM VT-1 PER P.O.# P3 0933105 0630. 2) PSE&G TO PERFORM VT-1 IN-PLACE PER W.O.# 950526019.																
99RF - PERFORMED PSI BASELINE PER 1EC-3729-1/PS-98-007/980713162 (REPLACED W/ NEW BLOCK BODY STYLE VALVE).																
BOLTING (REF. DWG. NO. A-14)																
195000	1 PR 4 ON LINE 6-PR-1104	B-G-2 B7.70	VT-1	1	-	-	-	-	C	-	-	-	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
				2	-	K	-	-	-	K	-	P	C	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																
91 - W.O.# 901120026, ACT 14																
95RF - 1) WYLE PERFORMED A-E, VT-1 PER P.O.# P3 0933105 0630. FOUND (4) NUTS WITH LOCALIZED CORROSION (TO BE REPLACED, AR# 980226082) 2) WYLE PERFORMED PSI VT-1 ON THE REPLACED (4) NUTS. 3) PSE&G TO PERFORM VT-1 IN-PLACE PER W.O.# 950526019.																
99RF - PERFORMED PSI BASELINE PER 1EC-3729-1/PS-98-007/980713162 (REPLACED W/ NEW BLOCK BODY STYLE VALVE).																

VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**				
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD								
				1	2	3	4	1	2	3	4	1	2	3	4					
BOLTING (REF. DWG. NO. A-13)																				
195100	1 PR 5 ON LINE 6-PR-1105	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
				2	-	K	-	-	-	-	K	-	-	-	-	P	C	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	X	-	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																				
91 - W.O.# 901120026, ACT 15																				
95RF - 1) WYLE PERFORMED A-E, VT-1 PER P.O.# P3 0933105 0630. FOUND (1) NUT WITH FRACTURES (TO BE REPLACED, AR# 980226082) 2) WYLE PERFORMED PSI VT-1 ON THE REPLACED (1) NUT. 3) PSE&G TO PERFORM VT-1 IN-PLACE PER W.O.# 950526019.																				
99RF - PERFORMED PSI BASELINE PER 1EC-3729-1/PS-98-007/980713162 (REPLACED W/ NEW BLOCK BODY STYLE VALVE).																				
BOLTING (REF. DWG. NO. A-17)																				
195200	1 PR 6 ON LINE 3-PR-1106	B-G-2 B7.70	VT-1	1	-	-	-	-	-	C	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	R	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	-	-	-	-	
91 - W.O.# 901120026, ACT 16																				
93 - THE BOLTING WAS REPLACED PER CJP # S-93-193/W.O. #930708098. THE BOLTING WAS FOUND TO BE ACCEPTABLE, NO BOLTS WERE REPLACED.																				
BOLTING (REF. DWG. NO. A-16)																				
195300	1 PR 7 ON LINE 3-PR-1107	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				2	-	C	-	-	-	R	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	-	-	-	-	
91 - W.O.# 901120026, ACT 17																				
93 - THE BOLTING WAS REPLACED PER CJP #S-93-192 & W.O. #930708100. THE BOLTING WAS FOUND TO BE ACCEPTABLE, NO BOLTS WERE REPLACED.																				
BOLTING (REF. DWG. NO. A-22)																				
195400	1 PS 1 ON LINE 4-PS-1111	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				2	-	C	-	-	-	P	P	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	-	-	-	-	
91 - W.O.# 901120026, ACT 18																				
93 - THE BOLTING WAS REPLACED PER 1EC-3249-1/PS-93-056/930708108 & 931121035.																				
95RF - 1) PSI BASELINE PERFORMED PER S-93-036 / 920804179 (STUD & NUT REPLACEMENT). THE PSI EXAM WILL BE SATISFIED BY THE MANUFACTURES (VELAN) VISUAL EXAMINATION OF THE BOLTING MATERIALS.																				



VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
BOLTING (REF. DWG. NO. A-20)																
195500	1 PS 3 ON LINE 4-PS-1131	B-G-2 B7.70	VT-1	1	-	-	-	-	C	-	-	-	-	-	-	
				2	-	C	-	-	P	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	
91 -	W.O.# 901120026, ACT 19															
93 -	THE BOLTING WAS REPLACED PER IEC-3249-1/PS-93-057/930708111 & 931121035.															
BOLTING (REF. DWG. NO. A-22)																
195600	1 PS 24 ON LINE 4-PS-1111	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	C	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	
91 -	W.O.# 901120026, ACT 20															
195700	1 PS 25 ON LINE 4-PS-1111	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	C	-	-	
				2	-	C	-	-	-	P	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	
91 -	W.O.# 901120026, ACT 21															
95RF -	PSI BASELINE PERFORMED PER S-97-262 / 971107115 (REPLACED VALVE BOLTING).															
BOLTING (REF. DWG. NO. A-20)																
195800	1 PS 28 ON LINE 4-PS-1131	B-G-2 B7.70	VT-1	1	-	-	-	-	C	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	
91 -	W.O.# 901120026, ACT 22															
BOLTING (REF. DWG. NO. A-21)																
195900	1 PS 29 ON LINE 4-PS-1131	B-G-2 B7.70	VT-1	1	-	-	-	-	C	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	
91 -	W.O.# 901120026, ACT 23															
BOLTING (REF. DWG. NO. A-52)																
196000	1 RH 1 ON LINE 14-RH-1111	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	C	-	-	IEB 82-02 PREVIOUSLY APPLIED.
				2	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	
99RF -	W.O.#50000402 TO PERFORM VT-1. PACKING LEAK ON VALVE 1RH1 IDENTIFIED, NOT# 20007015 WAS WRITTEN TO CLEAN BORON AND REMOVE ONE STUD FOR VT-3 (A-E).															

VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**						
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD										
				1	2	3	4	1	2	3	4	1	2	3	4							
196100	1 RH 2 ON LINE 14-RH-1111	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
99RF - W.O.#50000402 TO PERFORM NDE.																						
BOLTING (REF. DWG. NO. A-53)																						
196200	1 RH 26 ON LINE 12-SJ-1151	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	IEB 82-02 PREVIOUSLY APPLIED.
99RF - W.O.#50000402 TO PERFORM NDE.																						
BOLTING (REF. DWG. NO. A-72)																						
196300	1 SJ 12 ON LINE 4-SJ-1193	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	
91 - W.O.# 901120026, ACT 28																						
196400	1 SJ 13 ON LINE 4-SJ-1195	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	
91 - W.O.# 901120026, ACT 29																						
BOLTING (REF. DWG. NO. A-73)																						
196500	1 SJ 135 ON LINE 4-SJ-1194	B-G-2 B7.70	VT-1	1	-	-	-	-	-	C	-	-	-	-	-	-	-	-	-	-	-	
92 - W.O.# 920414093																						
BOLTING (REF. DWG. NO. A-72)																						
196600	1 SJ 150 ON LINE 3-SJ-1192	B-G-2 B7.70	VT-1	1	-	-	-	-	-	C	-	-	-	-	-	-	-	-	-	-	-	
91 - W.O.# 901120026, ACT 30																						
95RF - PSI BASELINE PERFORMED PER S-95-176 / 950520006 (REPLACEMENT BOLTING).																						

VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
BOLTING (REF. DWG. NO. A-75)																
196900	11 SJ 40 ON LINE 4-SJ-1172	B-G-2 B7.70	VT-1	1	-	-	-	-	C	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	
92 - W.O.# 920414094																
BOLTING (REF. DWG. NO. A-70)																
197000	11 SJ 43 ON LINE 6-SJ-1112	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	C	-	IEB 82-02 PREVIOUSLY APPLIED.
				2	-	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	
93 - W.O.# 920810155 AND 931121035 TO PERFORM NDE.																
BOLTING (REF. DWG. NO. A-60)																
197100	11 SJ 49 ON LINE 8-SJ-1152	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	C	-	IEB 82-02 PREVIOUSLY APPLIED.
				2	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	
99RF - W.O.#50000402 TO PERFORM NDE.																
BOLTING (REF. DWG. NO. A-57)																
197200	11 SJ 54 ON LINE 10-SJ-1111	B-G-2 B7.70	VT-1	1	-	-	-	-	C	-	-	-	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
				2	-	K	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	
91 - W.O.# 901120026, ACT 31																
99RF - W.O.#50000402 TO PERFORM NDE. BORON WAS FOUND ON THE VALVE PACKING (REF. NOT# 20006544), NO LEAKAGE ON THE BOLTING.																
BOLTING (REF. DWG. NO. A-57)																
197300	11 SJ 55 ON LINE 10-SJ-1111	B-G-2 B7.70	VT-1	1	-	-	-	-	C	-	-	-	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
				2	-	-	-	-	C	-	-	-	P	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	
01RF - W/O# 60005775 TO PERFORM NDE. VT-1 EXAM NOTED ONE STUD REJECTED DUE TO THREE DAMAGAED THREADS NOTIFICATION # 20062945 WAS GENERATED AND ONE STUD & ONE NUT ACCEPTED.																
92 - W.O.# 920418062, ACT 03																
BOLTING (REF. DWG. NO. A-57)																
197400	11 SJ 56 ON LINE 10-SJ-1111	B-G-2 B7.70	VT-1	1	-	-	-	-	C	-	-	-	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
				2	-	-	-	-	R	P	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	X	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																
93 - DEFERRED TO SIRFO#12.																
95 - W.O.#950526019 TO PERFORM NDE. PSI PERFORMED IAW S-95-025 / 950203274 (REPLACED STUDS, DURING FORCED OUTAGE 2/95). DURING RFO#12, MAINT. TO DISASSEMBLE & INSPECT UNDER W.O. #950531002. DELETED DISASSEMBLY, PER MATT CONROY.																

VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**				
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD								
				1	2	3	4	1	2	3	4	1	2	3	4					
BOLTING (REF. DWG. NO. A-88)																				
197500	11 SJ 156 ON LINE 6-SJ-1111	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
				2	-	-	-	-	-	R	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	X	-	-	-	-	-	-	-	-	-	
93 -	DEFERRED TO SIRFO#12.																			
95 -	W.O.#950526019 TO PERFORM NDE. DURING IN-PLACE VT-1, BORON RESIDUE WAS FOUND ON THE BONNET CONNECTION ( NOT ON THE BOLTING). AR# 950909378 WAS WRITTEN TO REMOVE THE BORON RESIDUE.																			
BOLTING (REF. DWG. NO. A-74)																				
197800	12 SJ 40 ON LINE 4-SJ-1182	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	-	-	
92 -	W.O.# 920414097																			
BOLTING (REF. DWG. NO. A-68)																				
197900	12 SJ 43 ON LINE 6-SJ-1122	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
				2	-	-	-	-	-	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	X	-	-	-	-	-	-	-	-	-	
93 -	W.O.# 920810158 AND 931121035 TO PERFORM NDE.																			
BOLTING (REF. DWG. NO. A-58)																				
198000	12 SJ 49 ON LINE 8-SJ-1162	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
				2	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	X	-	-	-	
99RF -	W.O.#50000402 TO PERFORM NDE.																			
BOLTING (REF. DWG. NO. A-56)																				
198100	12 SJ 54 ON LINE 10-SJ-1121	B-G-2 B7.70	VT-1	1	-	-	-	-	-	C	-	-	-	-	-	-	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
				2	-	K	-	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	X	-	-	-	
91 -	W.O.# 901120026, ACT 34																			
99RF -	W.O.#50000402 TO PERFORM NDE. BORON WAS FOUND ON THE VALVE PACKING (REF. NOT# 20006546), NO LEAKAGE ON THE BOLTING.																			
BOLTING (REF. DWG. NO. A-56)																				
198200	12 SJ 55 ON LINE 10-SJ-1121	B-G-2 B7.70	VT-1	1	-	-	-	-	-	C	-	-	-	-	-	-	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
				2	-	-	-	-	-	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	X	-	-	-	-	-	-	-	-	-	
93 -	W.O.# 920810195 & 931121035 TO PERFORM NDE. THE VT-1 EXAM REVEALED BORON RESIDUE BETWEEN THE VALVE BODY TO BONNET. THE VALVE WAS DISASSEMBLED & INSPECTED & BOLTING MATERIAL WAS REPLACED UNDER W.O. # 931002074 & CJP #S-93-250.																			

VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
198300	12 SJ 56 ON LINE 10-SJ-1121	B-G-2 B7.70	VT-1	1	-	-	-	-	C	-	-	-	-	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
93 -	W.O.# 920810203																
BOLTING (REF. DWG. NO. A-69)																	
198400	12 SJ 156 ON LINE 6-SJ-1121	B-G-2 B7.70	VT-1	1	-	-	-	-	C	-	-	-	-	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
93 -	DEFERRED TO SIRFO#12.																
95 -	W.O.#950526019 TO PERFORM NDE.																
BOLTING (REF. DWG. NO. A-63)																	
198700	13 RH 27 ON LINE 8-SJ-1135	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	C	-	-	IEB 82-02 PREVIOUSLY APPLIED.
91 -	W.O.# 901120026, ACT 43																
99RF -	W.O.#50000402 TO PERFORM NDE.																
BOLTING (REF. DWG. NO. A-66)																	
198800	13 SJ 43 ON LINE 6-SJ-1132	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	C	-	-	IEB 82-02 PREVIOUSLY APPLIED.
93 -	W.O.# 920810161 & 931121035 TO PERFORM NDE. BORON RESIDUE WAS FOUND ON SEVERAL STUDS. W.O. #931026136 REMOVED THE BORON AND A SATISFACTORY VT RE-EXAM WAS PERFORMED.																
95RF -	W.O.#959526019 TO PERFORM NDE. MAINTENANCE TO DISASSEMBLE VALVE UNDER W.O.#950325009.																
BOLTING (REF. DWG. NO. A-55)																	
198900	13 SJ 54 ON LINE 10-SJ-1131	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	C	-	-	IEB 82-02 PREVIOUSLY APPLIED.
91 -	W.O.# 901120026, ACT 37																
99RF -	W.O.#50000402 TO PERFORM NDE.																
199000	13 SJ 55 ON LINE 10-SJ-1131	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	C	-	-	IEB 82-02 PREVIOUSLY APPLIED.
93 -	DEFERRED TO SIRFO#12.																
95RF -	W.O.#950526019 TO PERFORM NDE.																

VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**					
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD									
				1	2	3	4	1	2	3	4	1	2	3	4						
199100	13 SJ 56 ON LINE 10-SJ-1131	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	IEB 82-02 PREVIOUSLY APPLIED.
91 -	W.O.# 901120026, ACT 39																				
	BOLTING (REF. DWG. NO. A-67)																				
199200	13 SJ 156 ON LINE 6-SJ-1131	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	IEB 82-02 PREVIOUSLY APPLIED.
93 -	W.O.# 920810173																				
	BOLTING (REF. DWG. NO. A-62)																				
199500	14 RH 27 ON LINE 8-SJ-1145	B-G-2 B7.70	VT-1	1	-	-	-	-	-	C	-	-	-	-	-	-	-	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
91 -	W.O.# 901120026, ACT 44																				
93 -	THE BOLTING MATERIAL WAS REPLACED IN ACCORDANCE WITH CJP #S-93-249 & W.O. #940326008.																				
99RF -	W.O.#50000402 TO PERFORM NDE.																				
	BOLTING (REF. DWG. NO. A-64)																				
199600	14 SJ 43 ON LINE 6-SJ-1142	B-G-2 B7.70	VT-1	1	-	-	-	-	-	C	-	-	-	-	-	-	-	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
93 -	W.O.# 920810162 AND 931121035 TO PERFORM NDE.																				
	BOLTING (REF. DWG. NO. A-54)																				
199700	14 SJ 54 ON LINE 10-SJ-1141	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	C	IEB 82-02 PREVIOUSLY APPLIED.
93 -	W.O.# 920810207 & 931121035 TO PERFORM NDE. THE VT REVEALED BORON RESIDUE ON THE STUDS. W.O. #931013197 WAS INITIATED TO CLEAN OFF THE BORON. AFTER THE BORON WAS REMOVED A SATISFACTORY VT-1 EXAM WAS PERFORMED.																				
95RF -	W.O.# 920613072, FOR THE DISASSEMBLY OF VALVE 14SJ54, WAS RE-CALLED. NO FUTURE SCHEDULE HAS BEEN IDENTIFIED.																				
99RF -	W.O.#50000402 TO PERFORM NDE.																				
199800	14 SJ 55 ON LINE 10-SJ-1141	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	IEB 82-02 PREVIOUSLY APPLIED.
93 -	W.O.# 920810201																				

VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**						
		ASME SEC. XI CATEGY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD										
				1	2	3	4	1	2	3	4	1	2	3	4							
199900	14 SJ 56 ON LINE 10-SJ-1141	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
93 - W.O.# 920810206 & 931121035 TO PERFORM NDE. THE VISUAL EXAMINATION REVEALED SEVERAL STUDS WITH A LACK OF THREAD ENGAGEMENT. W.O. #930730004 DISSASSEMBLED & INSPECTED THIS VALVE. DURING RE-ASSEMBLY THE LACK OF THREAD ENGAGEMENT WAS CORRECTED.																						
BOLTING (REF. DWG. NO. A-65)																						
200000	14 SJ 156 ON LINE 6-SJ-1141	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	-	IEB 82-02 PREVIOUSLY APPLIED.
93 - DEFERRED SIRFO#12. 95RF - W.O.#950526019 TO PERFORM NDE. DURING THE IN-PLACE VT-1, BORON RESIDUE WAS FOUND ON THE BONNET CONNECTION. AR# 950909366 WAS WRITTEN TO REMOVE THE BORON RESIDUE (NO BORON ON BOLTING).																						
BOLTING (REF. DWG. NO. A-96)																						
200100	11 SJ 388 ON LINE 1.5-SJ-1112	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - W.O.#950526019 TO PERFORM NDE. PERFORMED VT-1 IAW PR# 970624102, MISSING FROM LTP.																						
BOLTING (REF. DWG. NO. A-94)																						
200200	12 SJ 388 ON LINE 1.5-SJ-1122	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - W.O.#950526019 TO PERFORM NDE. PERFORMED VT-1 IAW PR# 970624102, MISSING FROM LTP.																						
BOLTING (REF. DWG. NO. A-92)																						
200300	13 SJ 388 ON LINE 1.5-SJ-1132	B-G-2 B7.70	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
95RF - W.O.#950526019 TO PERFORM NDE. PERFORMED VT-1 IAW PR# 970624102, MISSING FROM LTP.																						

VALVES

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
	BOLTING (REF. DWG. NO. A-89)																
200400	14 SJ 388	B-G-2	VT-1	1	-	-	-	-	-	-	-	-	-	-	-	-	-
	ON LINE 1.5-SJ-1142	B7.70		2	-	-	-	-	-	C	-	-	-	-	-	-	-
				3	-	-	-	-	-	X	-	-	-	-	-	-	-

95RF - W.O.#950526019 TO PERFORM NDE. PERFORMED VT-1 IAW PR# 970624102, MISSING FROM LTP.





CHEMICAL AND VOLUME CONTROL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
503970	1C-CVCG-276 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
93 - THIS SUPPORT WAS MODIFIED PER 1EC-3167/PS-92-40/920805116.																		
503975	1C-CVCS-284 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
503980	1C-CVCH-314 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
RC1091 (REF. DWG. NO. CV-1-4B 01)																		
503985	1C-CVCA-285 ANCHOR	F-A F1.10-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	REF. DWG. 232478, SHT. 149A.
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
503990	1C-CVCS-286 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
503995	1C-CVCH-287 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
504000	1C-CVCH-288 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	



PRESSURIZER RELIEF SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
PS1001 (REF. DWG. NO. RC-1-2A 01)																			
504935	1C-PRA-158 ANCHOR	F-A F1.10-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	-	-	
PS1005 (REF. DWG. NO. RC-1-2A 01)																			
504945	1C-PRH-161 HANGER	F-A F1.10-H	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	-	-	
PS1006 (REF. DWG. NO. RC-1-2A 01)																			
504955	1C-PRH-153 HANGER	F-A F1.10-H	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	X	-	-	
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730. VT-2 EXAM NOTED MISSING SCALE. USED SCALE FROM ANOTHER SUPPORT TO VARYIFY SETTING NOTIFICATION # 20063951 GENERATED TO ACCEPT THIS METHOD.																			
504960	1C-PRA-154 ANCHOR	F-A F1.10-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	P	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
99RF - PSI BASELINE PERFORMED PER 1EC-3729-01 / PS-98-008 / 980713162 (MODIFIED COMPONENT SUPPORT FOR NEW BLOCK BODY VALVES).																			

PRESSURIZER RELIEF SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
PS1010 (REF. DWG. NO. RC-1-2A 01)																
504965	1C-PRH-145 HANGER	F-A F1.10-H	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	P	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
95RF - 1) A-E EXAM PERFORMED UNDER W.O.# 940413245 AND FOUND BENT ROD, DR WAS WRITTEN. 2) PSI BASELINE PERFORMED PER S-94-049 / 940424126 (REPLACEMENT OF HANGER ROD AND NUTS).																
-----																
504970	1C-PRA-146 ANCHOR	F-A F1.10-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	P	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
99RF - PSI BASELINE PERFORMED PER 1EC-3729-01 / PS-98-008 / 980713162 (MODIFIED COMPONENT SUPPORT FOR NEW BLOCK BODY VALVES).																
-----																
PS1013 (REF. DWG. NO. RC-1-2A 01)																
504975	1C-PRH-149 HANGER	F-A F1.10-H	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	P	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	
95RF - 1) A-E EXAM PERFORMED UNDER W.O.# 940413245 AND FOUND BENT ROD, DR WAS WRITTEN. 2 & 3) PSI BASELINE PERFORMED PER S-94-049 / 940424126 (REPLACEMENT OF HANGER ROD AND NUTS).																
-----																
504980	1C-PRA-150 ANCHOR	F-A F1.10-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	P	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	
99RF - PSI BASELINE PERFORMED PER 1EC-3729-01 / PS-98-008 / 980713162 (MODIFIED COMPONENT SUPPORT FOR NEW BLOCK BODY VALVES).																

PRESSURIZING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
	RC1276 (REF. DWG. NO. RC-1-1A 01)																	
505065	1C-PSH-001 SPRING CAN HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	A-E EXAMS PERFORMED DUE TO NRC BULLETIN 88-11. BULLETIN 88-11 COMMITMENT WAS SATISFIED DURING RFO#12, PER ENGR'G LETTER MEC-94-1451, DATED 9/6/94.
93 -	W.O.#931121035 TO PERFORM NDE.																	EXAMINED PER NRC BULLETIN 88-11.
95 -	W.O.#950526019 TO PERFORM NDE.																	A-E PERFORMED IAW NB 88-11.
505066	R-239776-1	A-E NB88-11	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	A-E EXAMS PERFORMED DUE TO NRC BULLETIN 88-11. BULLETIN 88-11 COMMITMENT WAS SATISFIED DURING RFO#12, PER ENGR'G LETTER MEC-94-1451, DATED 9/6/94.
93 -	W.O.#931121035 TO PERFORM NDE.																	EXAMINED PER NRC BULLETIN 88-11.
95 -	W.O.#950526019 TO PERFORM NDE.																	A-E PERFORMED IAW NB 88-11.
505067	R-239776-2	A-E NB88-11	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	A-E EXAMS PERFORMED DUE TO NRC BULLETIN 88-11. BULLETIN 88-11 COMMITMENT WAS SATISFIED DURING RFO#12, PER ENGR'G LETTER MEC-94-1451, DATED 9/6/94.
93 -	W.O.#931121035 TO PERFORM NDE.																	EXAMINED PER NRC BULLETIN 88-11.
95 -	W.O.#950526019 TO PERFORM NDE.																	A-E PERFORMED IAW NB 88-11.

PRESSURIZING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**					
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD									
				1	2	3	4	1	2	3	4	1	2	3	4						
505068	R-239776-3	A-E NB88-11	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	A-E EXAMS PERFORMED DUE TO NRC BULLETIN 88-11. BULLETIN 88-11 COMMITMENT WAS SATISFIED DURING RFO#12, PER ENGR'G LETTER MEC-94-1451, DATED 9/6/94.
93 -	W.O.#931121035	TO PERFORM NDE. EXAMINED PER NRC BULLETIN 88-11.																			
95 -	W.O.#950526019	TO PERFORM NDE. A-E PERFORMED LAW NB 88-11.																			
505069	R-239776-4	A-E NB88-11	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	A-E EXAMS PERFORMED DUE TO NRC BULLETIN 88-11. BULLETIN 88-11 COMMITMENT WAS SATISFIED DURING RFO#12, PER ENGR'G LETTER MEC-94-1451, DATED 9/6/94.
93 -	W.O.#931121035	TO PERFORM NDE. EXAMINED PER NRC BULLETIN 88-11.																			
95 -	W.O.#950526019	TO PERFORM NDE. A-E PERFORMED LAW NB 88-11.																			
505070	1C-PSH-002 SPRING CAN HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	A-E EXAMS PERFORMED DUE TO NRC BULLETIN 88-11. BULLETIN 88-11 COMMITMENT WAS SATISFIED DURING RFO#12, PER ENGR'G LETTER MEC-94-1451, DATED 9/6/94.
93 -	W.O.#931121035	TO PERFORM NDE. EXAMINED PER NRC BULLETIN 88-11.																			
95 -	W.O.#950526019	TO PERFORM NDE. A-E PERFORMED LAW NB 88-11.																			

PRESSURIZING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**					
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD									
				1	2	3	4	1	2	3	4	1	2	3	4						
505071	R-239776-5	A-E NB88-11	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	A-E EXAMINATIONS PERFORMED DUE TO NRC BULLETIN 88-11. COMMITMENT WAS SATISFIED DURING RFO#12, PER ENGR'G LETTER MEC-94-1451, DATED 9/6/94.
93 -	W.O.#931121035	TO PERFORM NDE.		EXAMINED PER NRC BULLETIN 88-11.																	
95 -	W.O.#950526019	TO PERFORM NDE.		A-E PERFORMED IAW NB 88-11.																	
505072	R-239776-6	A-E NB88-11	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	A-E EXAMS PERFORMED DUE TO NRC BULLETIN 88-11. COMMITMENT WAS SATISFIED DURING RFO#12, PER ENGR'G LETTER MEC-94-1451, DATED 9/6/94.
93 -	W.O.#931121035	TO PERFORM NDE.		EXAMINED PER NRC BULLETIN 88-11.																	
95 -	W.O.#950526019	TO PERFORM NDE.		A-E PERFORMED IAW NB 88-11.																	
505073	R-239776-7	A-E NB88-11	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	A-E EXAMS PERFORMED DUE TO NRC BULLETIN 88-11. COMMITMENT WAS SATISFIED DURING RFO#12, PER ENGR'G LETTER MEC-94-1451, DATED 9/6/94.
93 -	W.O.#931121035	TO PERFORM NDE.		EXAMINED PER NRC BULLETIN 88-11.																	
95 -	W.O.#950526019	TO PERFORM NDE.		A-E PERFORMED IAW NB 88-11.																	



PRESSURIZING SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
505075	1C-PSH-003 SPRING CAN HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	A-E EXAMS PERFORMED DUE TO NRC BULLETIN 88-11. BULLETIN 88-11 COMMITMENT WAS SATISFIED DURING RFO#12, PER ENGR'G LETTER MEC-94-1451, DATED 9/6/94.
				2	-	C	-	A	A	A	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	

- 93 - W.O.#931121035 TO PERFORM NDE. EXAMINED PER NRC BULLETIN 88-11.
- 95 - W.O.#950526019 TO PERFORM NDE. A-E PERFORMED IAW NB 88-11.

PRESSURIZER RELIEF SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
RC1281 (REF. DWG. NO. RC-1-2B 01)																
505080	1C-PRG-051 GUIDE	F-A F1.10-E	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	
.....																
505085	1C-PRG-052 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-		
				3	-	-	-	-	X	-	-	-	-	-		
.....																
505090	1C-PRG-053 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	-	-	-	C	-		
				3	-	-	-	-	-	-	-	-	X	-		
.....																
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																
.....																
505095	1C-PRH-185 HANGER	F-A F1.10-H	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	C	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
.....																
505100	1C-PRH-186 HANGER	F-A F1.10-H	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	C	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
.....																
505105	1C-PRH-187 HANGER	F-A F1.10-H	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	C	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
.....																
505110	1C-PRA-188 ANCHOR	F-A F1.10-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	REF SUM# 020810 (2-CV-1175-23PS).	
				2	-	-	-	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-	-	-	-		
.....																
505115	1C-PRG-189 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-		
				2	-	-	-	-	-	-	-	-	C	-		
				3	-	-	-	-	-	-	-	-	X	-		
.....																
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																



PRESSURIZER RELIEF SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
505160	1C-PRG-215 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	C	-	-	1	-	R	-	-	1	-	-	-	-	
				3	-	X	-	-	1	-	-	-	-	1	-	-	-	-	
93 - THIS SUPPORT WAS SUPPOSED TO BE MODIFIED PER 1EC-3167/P-92-40/920805116. NO REWORK WAS PERFORMED ON THIS SUPPORT.																			
505165	1C-PRH-271 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	1	-	C	-	-	1	-	-	-	-	
				3	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
505170	1C-PRG-272 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	1	-	C	-	-	1	-	-	-	-	
				3	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
505175	1C-PRG-273 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				3	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
505180	1C-PRG-274 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				3	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
505185	1C-PRG-270 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	1	-	C	-	-	1	-	-	-	-	
				3	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
RC1282 (REF. DWG. NO. RC-1-2B 01)																			
505190	1C-PRG-048 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				3	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
505195	1C-PRG-049 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	C	-	-	-	1	-	-	-	-	1	-	-	-	-	
				3	-	-	-	-	1	-	-	-	-	1	-	-	-	-	





PRESSURIZER RELIEF SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
505270	1C-PRG-044 GUIDE	F-A F1.10-E	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
505275	1C-PRG-045 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
505280	1C-PRG-046 GUIDE	F-A F1.10-E	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	
505285	1C-PRG-047 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
505290	1C-PRH-175 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
505295	1C-PRH-176 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
505300	1C-PRH-177 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	P	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
93 -	THIS SUPPORT WAS MODIFIED PER 1EC-3168/PS-92-41/920805117.																	
505305	1C-PRH-179 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	R	-	-	-	H	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
01RF -	NDE TO BE PERFORMED UNDER W/O# 50009730.																	
93 -	RESCHEDULED TO SIRFO#13 (NEXT PERIOD).																	

PRESSURIZER RELIEF SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**								
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD												
				1	2	3	4	1	2	3	4	1	2	3	4									
505310	1C-PRA-180 ANCHOR	F-A F1.10-A	VT-3	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	REF. SUM# 031000 (4-PS-1131-7PS-1 & 2).
505315	1C-PRH-181 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	
505320	1C-PRH-178 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	2	C	-	-	-	3	-	-	-	-	4	-	-	-	-	REF. SUM# 031800 (4-PS-1131-12PL).
505325	1C-PRG-241 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	2	-	-	-	-	3	-	-	-	-	4	-	-	-	-	





RESIDUAL HEAT REMOVAL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
505370	1C-13RHS-006 SUPPORT	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
505375	1C-13RHH-007 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
505380	1C-13RHH-008 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
RC1094 (REF. DWG. NO. RH-1-3A 02)																		
505385	1C-14RHH-015 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
505390	1C-14RHH-014 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
505395	1C-14RHS-013 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
505400	1C-14RHH-012 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
505405	1C-14RHG-016 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	



RESIDUAL HEAT REMOVAL SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
505450	1C-14RHS-010 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	C	-	-	-	2	C	-	-	-	2	C	-	-	-	
				3	X	-	-	-	3	X	-	-	-	3	X	-	-	-	
505455	1C-14RHS-009 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	C	-	-	2	-	C	-	-	2	-	C	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
505460	1C-14RHH-008 HANGER	F-A F1.10-L	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	C	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
505465	1C-14RHG-007 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	C	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	X	3	-	-	-	-	
505470	1C-14RHS-006 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
505475	1C-14RHH-5A HANGER	F-A F1.10-L	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	P	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
95 -	PSI BASELINE PERFORMED PER 1EC-3396-1 / PS-95-028 / 950606218 (MODIFIED).																		
505480	1C-14RHG-005 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	REF. SUM# 112150
				2	C	-	-	-	2	C	-	-	-	2	C	-	-	-	(8-SJ-1145-5PS).
				3	X	-	-	-	3	X	-	-	-	3	X	-	-	-	
505485	1C-14RHH-004 HANGER	F-A F1.10-L	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	C	-	-	2	-	C	-	-	2	-	C	-	-	
				3	-	X	-	-	3	-	X	-	-	3	-	X	-	-	



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**				
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD								
				1	2	3	4	1	2	3	4	1	2	3	4					
RC1023 (REF. DWG. NO. RH-1-3F 01)																				
506175	1C-13SIS-128A SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	X	-	-	
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																				
506180	1C-11SIH-135 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	X	-	-	
01RF - NDE TO BE PERFORMED UNDER W/O# 50009730.																				
506185	1C-11SIS-134 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
506190	1C-11SIG-184 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
506195	1C-11SIS-133 SUPPORT	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	H	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	-	-	-	-	
93 - W.O.#931121035 TO PERFORM NDE. RE-EXAM FROM 1RFO#10.																				
506200	1C-11SIH-132 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	X	-	-	-	-	-	-	-	-	-	
506205	1C-11SIG-108A GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																				
506210	1C-11SIA-108 ANCHOR	F-A F1.10-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	X	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																				







SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**				
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD								
				1	2	3	4	1	2	3	4	1	2	3	4					
RC1031 (REF. DWG. NO. RH-1-3A 02)																				
506290	1C-12SIS-023 SUPPORT	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	X	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																				
.....																				
506295	1C-12SIA-024 ANCHOR	F-A F1.10-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 100300
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	-	-	(10-SJ-1121-8PS).
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	-	-	
.....																				
506300	1C-12SIH-025 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																				
506305	1C-12SIS-026 SUPPORT	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	X	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																				
.....																				
RC1032 (REF. DWG. NO. RH-1-3F 01)																				
506310	1C-12SIH-213 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																				
506315	1C-12SIS-243 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	C	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	X	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																				
.....																				
506320	1C-12SIH-212 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																				
506325	1C-12SIH-210 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**									
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD													
				1	2	3	4	1	2	3	4	1	2	3	4										
506330	1C-12SIG-153A GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	2	-	C	-	-	3	-	X	-	-							
506335	1C-12SIA-153 ANCHOR	F-A F1.10-A	VT-3	1	-	-	-	-	2	-	-	-	C	-	P	-	-	3	-	-	-	-	-	-	
95 -	PSI BASELINE PERFORMED PER 1EC-3396-1 / PS-95-028 / 950606218 (MODIFIED).																								
506340	1C-12SIH-151 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	2	-	-	-	C	-	-	-	-	3	-	-	-	-	-	-	
506345	1C-12SIG-149 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	2	-	-	-	-	-	-	C	-	3	-	-	-	-	-	X	
91RF -	W/O# 50009730 TO PERFORM NDE.																								
506350	1C-12SIS-147 SUPPORT	F-A F1.10-N	VT-3	1	-	-	-	-	2	-	-	-	-	-	-	-	-	3	-	-	-	-	-	-	
506355	1C-12SIG-146 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	2	C	-	-	-	-	-	-	-	3	X	-	-	-	-	-	
506360	1C-12SIG-142 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	2	-	C	-	-	-	-	-	-	3	-	X	-	-	-	-	
506365	1C-12SIS-140 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	2	-	-	-	C	-	-	-	-	3	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
506370	1C-12SIG-138 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
506375	1C-12SIS-136 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																			
506380	1C-12SIS-134 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																			
506385	1C-12SIG-132 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
506390	1C-12SIS-130 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
506395	1C-12SIH-128 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
506400	1C-12SIS-144 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
506405	1C-12SIG-211 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 181810 (1.5-SJ-1122-15PL-1 & 2).
95 -	PSI BASELINE PERFORMED PER 1EC-3396-1 / PS-95-028 / 950606218 (MODIFIED).																		

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**					
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD									
				1	2	3	4	1	2	3	4	1	2	3	4						
506410	1C-13SIS-128B SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	X	-	
01RF - W/O# 50009730 TO PERFORM NDE.																					
RC1075 (REF. DWG. NO. RH-1-3A 02)																					
506415	1C-13SIH-007 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	X	-	
01RF - W/O# 50009730 TO PERFORM NDE.																					
506420	1C-13SIA-006 ANCHOR	F-A F1.10-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	REF SUM# 098000 (10-SJ-1131-5PS).
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	
				3	-	-	-	-	-	-	-	X	-	-	-	-	-	-	-	-	
95RF - W.O.#950526019 TO PERFORM NDE.																					
506425	1C-13SIH-005 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																					
506430	1C-13SIS-008 SUPPORT	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																					
506435	1C-13SIH-117 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	C	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	X	-	
01RF - W/O# 50009730 TO PERFORM NDE.																					
506440	1C-13SIS-119 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
01RF - W/O# 50009730 TO PERFORM NDE.																					
506445	1C-13SIG-120 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	



















SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
506765	1C-11SIS-161 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	
.....																		
506770	1C-11SIS-160 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	C	-	-	-	
				3	-	-	-	-	-	-	-	-	-	X	-	-	-	
.....																		
01RF - W/O# 50009730 TO PERFORM NDE.																		
.....																		
506775	1C-11SIS-159 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
506780	1C-11SIH-158 HANGER	F-A F1.10-E	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
506785	1C-11SIS-157 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
506790	1C-11SIS-156 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
506795	1C-11SIH-155 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	P	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
99RF - PSI BASELINE EXAM PERFORMED PER S-99-216 / CM980320203 (REPLACE ROD EYE BOLTING MATERIALS).																		















SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**		
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	1	2	3	4	1	2	3	4			
507045	1C-14SIS-171 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
507050	1C-14SIA-170 ANCHOR	F-A F1.10-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
507055	1C-14SIG-169 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	
				3	-	-	-	-	X	-	-	-	-	-	-	-	-	
.....																		
507060	1C-14SIS-168A SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
507065	1C-14SIS-168 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
507070	1C-14SIS-167A SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
507075	1C-14SIS-167 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
507080	1C-14SIH-166 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	H	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																		
01RF -	W/O# 50009730 TO PERFORM NDE.																	
93 -	RESCHEDULED TO SIRFO#13 (NEXT PERIOD).																	



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
507125	1C-14SIS-166A HANGER	F-A F1.10-M	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
RC1193 (REF. DWG. NO. RH-1-3A 02)																			
507130	1C-12SIS-028 SUPPORT	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
507135	1C-12SIS-027 SUPPORT	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	X	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
507140	1C-12SIH-021 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
RC1198 (REF. DWG. NO. RH-1-3B 02)																			
507145	1P-11SIG-032 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
507150	1P-11SIH-031 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
.....																			
RC1198 (REF. DWG. NO. RH-1-3A 02)																			
507155	1C-11SIH-040 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
507205	1C-13SIG-133 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
507210	1C-13SIA-134 ANCHOR	F-A F1.10-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
507215	1C-11SIG-140 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
507220	1C-11SIH-144 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
RC1204 (REF. DWG. NO. RH-1-3A 02)																	
507225	1C-13SIS-001 SUPPORT	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
507230	1C-13SIH-002 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
507235	1C-13SIS-003 SUPPORT	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	











SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
507405	1C-12SIH-152 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
507410	1C-12SIA-154 ANCHOR	F-A F1.10-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
507415	1C-11SIG-138 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
95 -	PSI BASELINE PERFORMED PER 1EC-3396-1 / PS-95-028 / 950606218 (MODIFIED).																
507420	1C-11SIH-142 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
	RC1253 (REF. DWG. NO. RH-1-3E 02)																
507425	1C-12SIS-238 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
507430	1C-12SIH-239 HANGER	F-A F1.10-E	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
507435	1C-12SIG-216A GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
507440	1C-12SIA-216 ANCHOR	F-A F1.10-A	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	

SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
507445	1C-12SIH-100 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
507450	1C-12SIS-102 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
507455	1C-12SIS-103 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
507460	1C-12SIS-104 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
507465	1C-12SIS-105 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	C	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
507470	1C-12SIG-106 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	C	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
507475	1C-12SIG-107 GUIDE	F-A F1.10-N	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
507480	1C-12SIS-108 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	
				2	-	-	-	-	C	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	



SAFETY INJECTION SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**			
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	1	2	3	4	1	2	3	4				
507525	1C-12SIS-117 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	C	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	X	-	-	3	-	-	-	-	3	-	-	-	-	
.....																			
507530	1C-12SIH-118 HANGER	F-A F1.10-I	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
.....																			
507535	1C-12SIS-119 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
.....																			
507540	1C-12SIS-120 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
.....																			
507545	1C-12SIS-121 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
.....																			
				RC1253 (REF. DWG. NO. RH-1-3D 02)															
507550	1C-12SIS-237 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	
.....																			
				RC1253 (REF. DWG. NO. RH-1-3E 02)															
507555	1C-12SIS-110 SUPPORT	F-A F1.10-M	VT-3	1	-	-	-	-	1	-	-	-	-	1	-	-	-	-	
				2	-	-	-	-	2	-	-	-	-	2	-	-	-	-	
				3	-	-	-	-	3	-	-	-	-	3	-	-	-	-	







REACTOR COOLANT SYSTEM

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS												INSTRUCTIONS **CALIBRATION BLOCK**	
		ASME SEC. XI CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
510860	#11 RCP SUPPORT	F-A F1.40-K	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
.....																	
510865	#12 RCP SUPPORT	F-A F1.40-K	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
.....																	
510870	#13 RCP SUPPORT	F-A F1.40-K	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	2/1/2 EXAM COMPLETED
				2	-	C	-	-	-	-	-	-	-	-	-	-	UNDER W.O.#
				3	-	X	-	-	-	-	-	-	-	-	-	-	901120026-80.
.....																	
510875	#14 RCP SUPPORT	F-A F1.40-K	VT-3	1	-	-	-	-	-	-	-	-	-	-	-	-	NOT SELECTED
				2	-	-	-	-	-	-	-	-	-	-	-	-	
				3	-	-	-	-	-	-	-	-	-	-	-	-	
.....																	