

2.0 SAFETY LIMITS (SLs)

2.1 SLs

2.1.1 Reactor Core SLs

2.1.1.1 With the reactor steam dome pressure < 785 psig or core flow < 10% rated core flow:

THERMAL POWER shall be \leq 23.8% RTP.

2.1.1.2 With the reactor steam dome pressure \geq 785 psig and core flow \geq 10% rated core flow:

MCPR shall be \geq 1.08 for two recirculation loop operation
or \geq 1.10 for single recirculation loop operation.

2.1.1.3 Reactor vessel water level shall be greater than the top of active irradiated fuel.

2.1.2 Reactor Coolant System Pressure SL

Reactor steam dome pressure shall be \leq 1325 psig.

2.2 SL Violations

With any SL violation, the following actions shall be completed:

2.2.1 Within 1 hour, notify the NRC Operations Center, in accordance with 10 CFR 50.72.

2.2.2 Within 2 hours:

2.2.2.1 Restore compliance with all SLs; and

2.2.2.2 Insert all insertable control rods.

2.2.3 Within 24 hours, notify the plant manager and the corporate executive responsible for overall plant nuclear safety.

(continued)

5.6 Reporting Requirements

5.6.2 Annual Radiological Environmental Operating Report (continued)

results are not available for inclusion with the report, the report shall be submitted noting and explaining the reasons for the missing results. The missing data shall be submitted in a supplementary report as soon as possible.

5.6.3 Radioactive Effluent Release Report

The Radioactive Effluent Release Report covering the operation of the unit during the previous calendar year shall be submitted by May 1 of each year. The report shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the unit. The material provided shall be consistent with the objectives outlined in the ODCM and process control program and in conformance with 10 CFR 50.36a and 10 CFR 50, Appendix I, Section IV.B.1.

5.6.4 Monthly Operating Reports

Routine reports of operating statistics and shutdown experience, including documentation of all challenges to the main steam safety/relief valves, shall be submitted on a monthly basis no later than the 15th of each month following the calendar month covered by the report.

5.6.5 CORE OPERATING LIMITS REPORT (COLR)

- a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:
 - 1) LCO 3.2.1, Average Planar Linear Heat Generation Rate (APLHGR).
 - 2) LCO 3.2.2, Minimum Critical Power Ratio (MCPR)(including power and flow dependent limits).
 - 3) LCO 3.2.3, Linear Heat Generation Rate (LHGR)(including power and flow dependent limits).
 - 4) LCO 3.2.4, Fraction of Core Boiling Boundary (FCBB)
 - 5) LCO 3.3.1.1, RPS Instrumentation (RPS), Function 2.b
 - 6) LCO 3.3.1.3, Periodic Based Detection System (PBDS)
- b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents.

(continued)

5.6 Reporting Requirements

5.6.5 CORE OPERATING LIMITS REPORT (COLR) (continued)

- 1) XN-NF-81-58(P)(A), "RODEX2 Fuel Rod Thermal-Mechanical Response Evaluation Model", Exxon Nuclear Company, Richland, WA.
- 2) XN-NF-85-67(P)(A), "Generic Mechanical Design for Exxon Nuclear Jet Pump BWR Reload Fuel", Exxon Nuclear Company, Richland, WA.
- 3) EMF-85-74(P) Supplement 1 (P)(A) and Supplement 2(P)(A), "RODEX2A (BWR) Fuel Rod Thermal-Mechanical Evaluation Model", Siemens Power Corporation, Richland, WA.
- 4) ANF-89-98(P)(A), "Generic Mechanical Design Criteria for BWR Fuel Designs", Advanced Nuclear Fuels Corporation, Richland, WA.
- 5) XN-NF-80-19(P)(A) Volume 1, "Exxon Nuclear Methodology for Boiling Water Reactors - Neutronic Methods for Design and Analysis", Exxon Nuclear Company, Richland, WA.
- 6) XN-NF-80-19(P)(A) Volume 4, "Exxon Nuclear Methodology for Boiling Water Reactors: Application for the ENC Methodology to BWR Reloads", Exxon Nuclear Company, Richland, WA.
- 7) EMF-2158(P)(A), "Siemens Power Corporation Methodology for Boiling Water Reactors: Evaluation and Validation of CASMO-4/MICROBURN-B2", Siemens Power Corporation, Richland, WA.
- 8) XN-NF-80-19(P)(A) Volume 3, "Exxon Nuclear Methodology for Boiling Water Reactors, THERMEX: Thermal Limits Methodology Summary Description", Exxon Nuclear Company, Richland, WA.
- 9) XN-NF-84-105(P)(A), Volume 1, "XCOBRA-T: A Computer Code for BWR Transient Thermal-Hydraulic Core Analysis", Exxon Nuclear Company, Richland, WA.
- 10) ANF-524(P)(A), "ANF Critical Power Methodology for Boiling Water Reactors", Advanced Nuclear Fuels Corporation, Richland, WA.
- 11) ANF-913(P)(A) Volume 1, "CONTRANS2: A Computer Program for Boiling Water Reactor Transient Analysis", Advanced Nuclear Fuels Corporation, Richland, WA.

5.6 Reporting Requirements

5.6.5 CORE OPERATING LIMITS REPORT (COLR) (continued)

- 12) XN-NF-825(P)(A), Supplement 2, "BWR/6 Generic Rod Withdrawal Error Analysis, MCPR_p for Plant Operations within the Extended Operating Domain", Exxon Nuclear Company, Richland, Wa.
- 13) ANF-1358(P)(A), "The Loss of Feedwater Heating Transient in Boiling Water Reactors", Advanced Nuclear Fuels Corporation, Richland, WA.
- 14) EMF-1997(P)(A), "ANFB-10 Critical Power Correlation", Siemens Power Corporation, Richland, WA.
- 15) EMF-1997(P) Supplement 1 (P)(A), "ANFB-10 Critical Power Correlation: High Local Peaking Results", Siemens Power Corporation, Richland, WA.
- 16) EMF-2209(P)(A), "SPCB Critical Power Correlation", Siemens Power Corporation, Richland, WA.
- 17) EMF-2245(P)(A), "Application of Siemens Power Corporation's Critical Power Correlations to Co-Resident Fuel", Siemens Power Corporation, Richland, WA.
- 18) XN-NF-80-19(P)(A) Volumes 2, 2A, 2B, And 2C, "Exxon Nuclear Methodology for Boiling Water Reactors: EXEM BWR ECCS Evaluation Model", Exxon Nuclear Company, Richland, WA.
- 19) ANF-91-048(P)(A), "Advanced Nuclear Fuels Corporation Methodology for Boiling Water Reactors EXEM BWR Evaluation Model", Advanced Nuclear Fuels, Richland, WA.
- 20) ANF-91-048(P)(A) Supplements 1 and 2, "BWR Jet Pump Model Revision for RELAX", Siemens Power Corporation, Richland, WA.
- 21) XN-CC-33(A), "HUXY: A Generalized Multirod Heatup Code with 10 CFR 50 Appendix K Heatup Option Users Manual", Exxon Nuclear Company, Richland, WA.
- 22) EMF-CC-074(P)(A), Volume 4, "BWR Stability Analysis Assessment of STAIF with Input from MICROBURN-B2", Siemens Power Corporation, Richland, WA.
- 23) EMF-2292(P)(A), "ATRIUM-10 Appendix K Spray Heat Transfer Coefficients", Siemens Power Corporation, Richland, WA.

5.6 Reporting Requirements

5.6.5 CORE OPERATING LIMITS REPORT (COLR) (continued)

- 24) NEDE-24011-P-A, "General Electric Standard Application for Reactor Fuel (GESTAR-II)"
- c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal mechanical limits, core thermal hydraulic limits, Emergency Core Cooling Systems (ECCS) limits, nuclear limits such as SDM, transient analysis limits, and accident analysis limits) of the safety analysis are met.
- d. The COLR, including any midcycle revisions or supplements, shall be provided upon issuance for each reload cycle to the NRC.
-