

August 4, 1976

DISTRIBUTION:
 Docket File ✓ Dross
 NRC PDR
 L PDR
 ORB#4 Rdg
 VStello
 BJones
 MFairtile
 RIngram
 JMcGough
 Attorney, OELD
 OI&E (5)
 TBAbernathy
 KRGoeller
 TJCarter
~~JK~~JRBuchanan
 AERMS
 ACRS (16)

Dockets Nos.: 50-280 ✓
 and 50-281 ✓

Virginia Electric & Power Company
 ATTN: Mr. W. L. Proffitt
 Senior Vice President - Power
 P. O. Box 26666
 Richmond, Virginia 23261

Gentlemen:

On July 12, 1976, the Commission issued Amendments No. 22 to Facility Licenses Nos. DPR-32 and DPR-37 for the Surry Power Station, Units Nos. 1 and 2. Technical Specification page 6.4-2 contained a typographical error which we have corrected. Enclosed are corrected pages for each license.

Sincerely,

Original Signed by

Robert W. Reid, Chief
 Operating Reactors Branch #4
 Division of Operating Reactors

Enclosures:
 Page TS 6.4-2 to
 DPR-32 and DPR-37

T

OFFICE →	ORB#4:DOR	ORB#4:DOR	C-ORB#4:DOR			
SURNAME →	RIngram:rm	MFairtile	RR Reid			
DATE →	8/ /76	8/ /76	8/176			

Virginia Electric & Power Company - 2 -

cc w/enclosures:

Michael W. Maupin, Esq.
Hunton, Williams, Gay & Gibson
P. O. Box 1535
Richmond, Virginia 23213

Swem Library
College of William & Mary
Williamsburg, Virginia 23185

Mr. Sherlock Holmes, Chairman
Board of Supervisors of Surry County
Surry County Courthouse
Surry, Virginia 23683

Ms. Susan T. Wilburn
Commonwealth of Virginia
Council on the Environment
903 9th Street Office Building
Richmond, Virginia 23219

1. The intent of 10 CFR 20.203(c)(2)(iii) shall be implemented by satisfying the following conditions:
 - a. The entrance to each radiation area in which the intensity of radiation is greater than 100 mrem/hr but less than 1000 mrem/hr shall be barricaded and conspicuously posted.
 - b. The entrance to each radiation area in which the intensity of radiation is equal to or greater than 1000 mrem/hr shall be provided with locked barricades to prevent unauthorized entry into these areas. Keys to these locked barricades shall be maintained under the administrative control of the Shift Supervisor.
 - c. All such accessible high radiation areas shall be surveyed by Health Physics personnel on a routine schedule, as determined by the Supervisor-Health Physics, to assure a safe and practical program.
 - d. Any individual entering a high radiation area shall have completed the indoctrination course designed to explain the hazards and safety requirements involved, or shall be escorted at all times by a person who has completed the course.
 - e. Any individual or group of individuals permitted to enter a high radiation area per 1.d. above, shall be provided with a radiation monitoring device which continuously indicates the radiation dose rate in the area.

1. The intent of 10 CFR 20.203(c)(2)(iii) shall be implemented by satisfying the following conditions:
 - a. The entrance to each radiation area in which the intensity of radiation is greater than 100 mrem/hr but less than 1000 mrem/hr shall be barricaded and conspicuously posted.
 - b. The entrance to each radiation area in which the intensity of radiation is equal to or greater than 1000 mrem/hr shall be provided with locked barricades to prevent unauthorized entry into these areas. Keys to these locked barricades shall be maintained under the administrative control of the Shift Supervisor.
 - c. All such accessible high radiation areas shall be surveyed by Health Physics personnel on a routine schedule, as determined by the Supervisor-Health Physics, to assure a safe and practical program.
 - d. Any individual entering a high radiation area shall have completed the indoctrination course designed to explain the hazards and safety requirements involved, or shall be escorted at all times by a person who has completed the course.
 - e. Any individual or group of individuals permitted to enter a high radiation area per 1.d. above, shall be provided with a radiation monitoring device which continuously indicates the radiation dose rate in the area.