

3.7 PLANT SYSTEMS

3.7.10 Emergency Chilled Water (ECW)

LCO 3.7.10 Two ECW trains shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS -----NOTE-----
Each Unit shall enter applicable ACTIONS separately.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One ECW train inoperable.	A.1 Restore ECW train to OPERABLE status.	14 days
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	6 hours
	<u>AND</u> B.2 Be in MODE 5.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.7.10.1 Verify each ECW manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position.	31 days

(continued)

3.7 PLANT SYSTEMS

3.7.11 Control Room Emergency Air Cleanup System (CREACUS)

LCO 3.7.11 Two CREACUS trains shall be OPERABLE.

-----NOTE-----
The control room boundary may be opened intermittently under administrative control.

APPLICABILITY: MODES 1, 2, 3, 4, 5, and 6,
During movement of irradiated fuel assemblies.

ACTIONS -----NOTES-----
1. The provisions of LCO 3.0.4 are not applicable when entering MODES 5, 6, or defueled configuration.
2. Each Unit shall enter applicable ACTIONS separately.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One CREACUS train inoperable.	A.1 Restore CREACUS train to OPERABLE status.	14 days
B. Two CREACUS trains inoperable due to inoperable control room boundary in Modes 1, 2, 3, or 4.	B.1 Restore control room boundary to OPERABLE status.	24 hours
C. Required Action and associated Completion Time of Condition A or B not met in MODE 1, 2, 3, or 4.	C.1 Be in MODE 3.	6 hours
	<u>AND</u> C.2 Be in MODE 5.	36 hours
		(continued)