3.7 PLANT SYSTEMS

3.7.10 Emergency Chilled Water (ECW)

Two ECW trains shall be OPERABLE. LCO 3.7.10

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

-----NOTE-----Each Unit shall enter applicable ACTIONS separately.

| CONDITION | | REQUIRED ACTION | | COMPLETION TIME |
|-----------|---|-------------------|--|-----------------|
| Α. | One ECW train inoperable. | A.1 | Restore ECW train to OPERABLE status. | 14 days |
| В. | Required Action and associated Completion Time not met. | B.1 <u>AND</u> | Be in MODE 3. | 6 hours |
| | | B.2 | Be in MODE 5. | 36 hours |

SURVEILLANCE REQUIREMENTS

| | SURVEILLANCE | | |
|-------------|---|---------|--|
| SR 3.7.10.1 | Verify each ECW manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position. | 31 days | |

(continued)

3.7 PLANT SYSTEMS

3.7.11 Control Room Emergency Air Cleanup System (CREACUS)

Two CREACUS trains shall be OPERABLE. LCO 3.7.11

> -----NOTE-----The control room boundary may be opened intermittently under

administrative control.

APPLICABILITY:

MODES 1, 2, 3, 4, 5, and 6, During movement of irradiated fuel assemblies.

ACTIONS

-----NOTES-----

- 1. The provisions of LCO 3.0.4 are not applicable when entering MODES 5, 6, or defueled configuration.
- 2. Each Unit shall enter applicable ACTIONS separately.

| CONDITION | | REQUIRED ACTION | | COMPLETION TIME |
|-----------|---|-------------------|---|---------------------|
| Α. | One CREACUS train inoperable. | A.1 | Restore CREACUS train to OPERABLE status. | 14 days |
| В. | Two CREACUS trains inoperable due to inoperable control room boundary in Modes 1, 2, 3, or 4. | B.1 | Restore control room boundary to OPERABLE status. | 24 hours |
| С. | Required Action and associated Completion Time of Condition A or B not met in MODE 1, 2, 3, or 4. | C.1 AND C.2 | Be in MODE 3. Be in MODE 5. | 6 hours 36 hours |