



LR-E01-0313

CERTIFIED MAIL
RETURN RECEIPT REQUESTED
ARTICLE NUMBER: 7099 3400 0003 6393 0785

Department of Environmental Protection
Division of Water Quality
Bureau of Permit Management
P.O. Box 029
Trenton, N.J. 08625-0029


**NEW JERSEY POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT
HOPE CREEK GENERATING STATION
NJPDES PERMIT NJ0025411**

Dear Sir:

Attached is the Discharge Monitoring Report for the Hope Creek Generating Station for the month of August 2001.

This report is required by and prepared specifically for the Environmental Protection Agency (EPA) and the New Jersey Department of Environmental Protection (NJDEP). It presents only the observed results of measurements and analysis required to be performed by the above agencies. The choice of the measurement devices and analytical methods are controlled by the EPA and the NJDEP, not by the company, and there are limitations on the accuracy of such measurement devices and analytical techniques even when used and maintained as required. Accordingly, this report is not intended as an assertion that any instrument has measured, or that any reading analytical result represents the true value with absolute accuracy, nor is it an endorsement of the suitability of any analytical or measurement procedure.

If you have any questions concerning this report, please feel free to contact Jeff Serfass at (856) 339-5411.

Sincerely,

David F. Garchow
Vice President – Operations

IE25

LR-E01-0313
NJPDES DMR

Attachments

C Executive Director, DRBC
 USNRC - Docket number 50-354

LR-E01-0313
NJPDES DMR

BC Vice President - Operations
Manager – Nuclear Safety & Licensing
Maureen Vaskis, Esq.
D. K. Hurka
E. J. Keating
NJPDES Tech.
J. Serfass
J. Buchanan
A. Nurk
Chem File HCH 2001-045
Env Lic File 2.1.6 HC Book

NJPDES DMR

Explanation of Conditions

August 2001

The following explanations are included to clarify possible deviation from permit conditions.

General - The columns labeled "No. Ex", on the enclosed DMR, tabulate the number of daily discharge values outside the indicated limits.

Data reporting and accuracy reflect the working environment, the design capabilities and reliability of the monitoring instruments and operating equipment.

Deviations from required sampling, analysis monitoring and reporting methods and periodicities are noted on the respective transmittal sheet.

Results reported on the Discharge Monitoring Report forms are consistent with permit limits, data supplied from contract laboratories, the December 1993 revision of the NJDEP DMR Instruction manual and specific guidance from DEP personnel.

Explanation of Exceedances

August 2001

The following exceedances are included in the attached report and explained below.

DSN No.	EXPLANATION
---------	-------------


No Exceedances

While there were no exceedances, a non-reportable event did occur on August 24, 2001. At approximately 0500 hours during a brief but unexpected start of the fourth service water pump, approximately 25 to 50 gallons of service water was released to the ground behind Hope Creek Generating Station when a relief valve lifted. A portion of this water, which is normally chlorinated, entered a yard drain, DSN 463A. Samples taken downstream but prior to entry into the Delaware River indicated no detectable residual chlorine (<0.05 ppm).

COUNTY OF SALEM
STATE OF NEW JERSEY

I, David F.Garchow, of full age, being duly sworn according to law, upon my oath depose and say:

1. I am the Vice President, Operations for PSEG Nuclear, and as such am authorized to sign Hope Creek's Discharge Monitoring Reports submitted to the New Jersey Department of Environmental Protection pursuant to the Station's New Jersey Pollutant Discharge Elimination System permit.
2. I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.
3. The signature on the attached Discharge Monitoring Reports is my signature and I am submitting this affidavit in satisfaction of the requirement that my signature be notarized.



David F.Garchow
Vice President
Operations

Sworn and subscribed before me
this 24 day of Sept 200 .



SHERI L. HUSTON
NOTARY PUBLIC OF NEW JERSEY
My Commission Expires 12/08/2003

New Jersey Department of Environmental Protection
Division of Water Quality

MONITORING REPORT SUBMITTAL FORM

NJPDES PERMIT NUMBER: NJ0025411
MONITORING REPORT TYPE: Surface Water Discharge N
MONITORING PERIOD: 8/1/2001 - 8/31/2001

MONITORED LOCATION: 461A DSN 461A - dsw
MONITORED LOCATION GROUP: N/A
REGION / COUNTY: Southern / Salem County

REPORT RECIPIENT:
PSE&G
P.O. BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:
PSE&G HOPE CREEK GENERATING ST
ARTIFICIAL ISLAND
FOOT OF BUTTONWOOD RD
LOWER ALLOWAYS CREEK, NJ 08038-0000

CHECK IF APPLICABLE: No Discharge this Monitoring Period

MONITORING REPORT COMMENTS: _____

individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. § 1319.

(Penalties under these statutes may include fines up to \$10,000 and or a maximum imprisonment of between 6 months and 5 years.)

David F. Gardow Vice President Operations
NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

David F. Gardow
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

856-339-3250
AREA CODE / TELEPHONE NUMBER

9/24/01
DATE (MONTH / DAY / YEAR)

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0025411

461A DSN 461A - dsw

8/1/2001 TO 8/31/2001

PSE&G HOPE CREEK GENERATING ST

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	50.273	57.364	MGD	*****	*****	*****	*****	0	Continuous	Meter
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****				
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	8.5	*****	8.7	SU	0	1/Week	GRAB
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	20.1	20.1	MG/L	0	3/Week	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	0.2 01MOAV	0.5 01DAMX				
Temperature, oC 00010 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	32.2	34.8	DEG.C	0	Continuous	CK REQ
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	36.2 01DAMX				
Temperature, oC 00010 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	*****	28.6	29.4	DEG.C	0	Continuous	CK REQ
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX				
Phosphorus, Total (as P) 00665 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	Code=N	Code=N	MG/L	0	1/Month	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX				
Carbon, Tot Organic (TOC) 00680 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	2.5	2.5	MG/L	0	1/Month	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX				
Carbon, Tot Organic (TOC) 00680 2 Effluent Net Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	-1	-1	MG/L	0	1/Month	CALCTD
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	20 01DAMX				

Comments: Your Monitoring Report Forms have been converted to the Department's new N. J. Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Reg'n 2 at (609) 292-4860 or via email at "srosenwi@dep.state.nj.us".

Surface Water Discharge Monitoring Report

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0025411

461A DSN 461A - dsw

8/1/2001 TO 8/31/2001

PSE&G HOPE CREEK GENERATING ST

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Carbon, Tot Organic (TOC) 00680 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****		*****	2,3	2,3		0	1/month	GRAB
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	REPORT 01DAMX	MG/L		1/Month	GRAB
Heat (summer) (per Hr.) 81386 1 Effluent Gross Value	SAMPLE MEASUREMENT	112	191		*****	*****	*****		0	1/Day	CALCTD
	PERMIT REQUIREMENT	REPORT 01MOAV	534 01DAMX	MBTU/HR	*****	*****	*****	*****		1/Day	CALCTD
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17451	77343		06431						
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP

Comments: Your Monitoring Report Forms have been converted to the Department's new N. J. Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Regin 2 at (609) 292-4860 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection
Division of Water Quality

MONITORING REPORT SUBMITTAL FORM

NJPDES PERMIT NUMBER: **NJ0025411**
MONITORING REPORT TYPE: **Surface Water Discharge**
MONITORING PERIOD: **8/1/2001 - 8/31/2001**

MONITORED LOCATION: **461C DSN 461C - DSW internal**
MONITORED LOCATION GROUP: **N/A**
REGION / COUNTY: **Southern / Salem County**

REPORT RECIPIENT:
PSE&G
P.O. BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:
PSE&G HOPE CREEK GENERATING ST
ARTIFICIAL ISLAND
FOOT OF BUTTONWOOD RD
LOWER ALLOWAYS CREEK, NJ 08038-0000

CHECK IF APPLICABLE: **No Discharge this Monitoring Period**

MONITORING REPORT COMMENTS:

individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. § 1319.

(Penalties under these statutes may include fines up to \$10,000 and or a maximum imprisonment of between 6 months and 5 years.)

David F. Garchow vice President OPERATIONS

David F. Garchow

856-339-3250

9/24/01

AREA CODE / TELEPHONE NUMBER

DATE (MONTH / DAY / YEAR)

Surface Water Discharge Monitoring Report

PERMIT NUMBER: MONITORED LOCATION: MONITORING PERIOD: FACILITY NAME:
 NJ0025411 461C DSN 461C - DSW intern: 8/1/2001 TO 8/31/2001 PSE&G HOPE CREEK GENERATING ST

PARAMETER	X		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
	SAMPLE MEASUREMENT	PERMIT REQUIREMENT										
Flow, In Conduit or Thru Treatment Plant 50050 1			0.025	0.070	MGD	*****	*****	*****	*****	0	Continuous	METER
Effluent Gross Value		REPORT 01MOAV	REPORT 01DAMX			*****	*****	*****				
Solids, Total Suspended 00530 1			*****	*****	*****	*****	22.9	42	MG/L	0	1/Month	COMPOS
Effluent Gross Value		*****	*****			*****	30 01MOAV	100 01DAMX				
Petrol Hydrocarbons, Total Recoverable 45501 1			*****	*****	*****	*****	<1	<1	MG/L	0	2/Month	GRAB
Effluent Gross Value		*****	*****			*****	10 01MOAV	15 01DAMX				
Carbon, Tot Organic (TOC) 00680 1			*****	*****	*****	*****	7	7	MG/L	0	1/Month	COMPOS
Effluent Gross Value		*****	*****			*****	REPORT 01MOAV	50 01DAMX				
Lab Certification # 99999 99			17457	77343	*****	06431			*****			
Lab		REPORT Lab #	REPORT Lab #			REPORT Lab #	REPORT Lab #	REPORT Lab #				

Comments: Your Monitoring Report Forms have been converted to the Department's new N. J. Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609) 292-4860 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection
Division of Water Quality

MONITORING REPORT SUBMITTAL FORM

NJPDES PERMIT NUMBER: **NJ0025411**
MONITORING REPORT TYPE: **Surface Water Discharge**
MONITORING PERIOD: **8/1/2001 - 8/31/2001**

MONITORED LOCATION: **462B dsn 462B - dsw outfall**
MONITORED LOCATION GROUP: **N/A**
REGION / COUNTY: **Southern / Salem County**

REPORT RECIPIENT:
PSE&G
P.O. BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:
PSE&G HOPE CREEK GENERATING ST
ARTIFICIAL ISLAND
FOOT OF BUTTONWOOD RD
LOWER ALLOWAYS CREEK, NJ 08038-0000

CHECK IF APPLICABLE: No Discharge this Monitoring Period

MONITORING REPORT COMMENTS: _____

individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. § 1319.

(Penalties under these statutes may include fines up to \$10,000 and or a maximum imprisonment of between 6 months and 5 years.)

David F. Grachew Vice President Operations
NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

David F. Grachew
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

856 - 339 - 3250
AREA CODE / TELEPHONE NUMBER

9/24/01
DATE (MONTH / DAY / YEAR)

Surface Water Discharge Monitoring Report

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0025411

462B dsn 462B - dsw outfall

8/1/2001 TO 8/31/2001

PSE&G HOPE CREEK GENERATING ST

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	0.012	0.022	MGD	*****	*****	*****	*****	0	1/Day	METER
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****		*****	1/Day	METER
BOD, 5-Day (20 oC) 00310 1 Effluent Gross Value	SAMPLE MEASUREMENT	1	1	KG/DAY	*****	*****	*****	*****	0	1/Month	COMPOS
	PERMIT REQUIREMENT	8 01MOAV	REPORT 01DAMX		*****	*****	*****		*****	1/Month	COMPOS
BOD, 5-Day (20 oC) 00310 K Percent Removal	SAMPLE MEASUREMENT	*****	*****	*****	88.7	*****	*****	PERCENT	0	1/Month	CALCTD
	PERMIT REQUIREMENT	*****	*****		87.5 01DAMN	*****	*****		*****	1/Month	CALCTD
Solids, Total Suspended 00530 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	11	11	MG/L	0	1/Month	COMPOS
	PERMIT REQUIREMENT	*****	*****		*****	*****	30 01MOAV		REPORT 01DAMX	*****	1/Month
Solids, Total Suspended 00530 K Percent Removal	SAMPLE MEASUREMENT	*****	*****	*****	95	*****	*****	PERCENT	0	1/Month	CALCTD
	PERMIT REQUIREMENT	*****	*****		*****	85 01MOAVMN	*****		*****	*****	1/Month
Oil and Grease 00556 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	<1	<1	MG/L	0	1/Month	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	*****	10 01MOAV		15 01DAMX	*****	1/Month
Coliform, Fecal General 74055 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	2	2	#/100ML	0	1/Month	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	*****	200 01MOGE		400 01WKGE	*****	1/Month
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17451	77343	*****	06431			*****			
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #		REPORT Lab #	*****	Not Applic

Comments: Your Monitoring Report Forms have been converted to the Department's new N.J. Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609) 292-4860 or via email at "srosenwi@dep.state.nj.us".