

MAR 16 1981

Docket No. 50-281

DISTRIBUTION:

Docket File	CParrish
NRC PDR	Gray File (4)
L PDR	BJones (4)
TERA	BScharf (10)
NSIC	JWetmore
ORB#1 Rdg	ACRS (16)
HDenton	OPA
DEisenhut	RDiggs
RPurple	
TNovak	
RTedesco	
GLainas	
JHeltemes	
OELD, Attorney	
I&E (5)	
SVarga	
DNeighbors	

Mr. J. H. Ferguson
 Executive Vice President - Power
 Virginia Electric and Power Company
 Post Office Box 26666
 Richmond, Virginia 23261

Dear Mr. Ferguson:

The Commission has issued the enclosed Amendment No. 66 to Facility Operating License No. DPR-37 for the Surry Power Station, Unit No. 2. The amendment consists of changes to the Technical Specifications in response to your application transmitted by letter dated February 19, 1981.

The amendment provides a one time 30 day extension for the visual inspection surveillance requirement for inaccessible snubbers.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

Original signed by:
 S. A. Varga
 Steven A. Varga, Chief
 Operating Reactors Branch #1
 Division of Licensing

- Enclosures:
1. Amendment No. 66 to DPR-37
 2. Safety Evaluation
 3. Notice of Issuance

cc: w/enclosures
 See next page



No legal objection to this amendment.
to Division of Reactors.
BER not reviewed

8103260 246

OFFICE	ORB#1:DL	ORB#1:NL	ORB#1:DL	AD/OR:DL	D/DL	OELD
SURNAME	CParrish	DNeighbors:ds	SVarga	TNovak	DEisenhut	CUTCHIN
DATE	3/5/81	3/5/81	3/5/81	3/9/81	3/1/81	3/10/81



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

March 16, 1981

Docket No. 50-281

Mr. J. H. Ferguson
Executive Vice President - Power
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261

Dear Mr. Ferguson:

The Commission has issued the enclosed Amendment No. 66 to Facility Operating License No. DPR-37 for the Surry Power Station, Unit No. 2. The amendment consists of changes to the Technical Specifications in response to your application transmitted by letter dated February 19, 1981.

The amendment provides a one time 30 day extension for the visual inspection surveillance requirement for inaccessible snubbers.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

A handwritten signature in cursive script that reads "Steven A. Varga".

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosures:

1. Amendment No. 66 to DPR-37
2. Safety Evaluation
3. Notice of Issuance

cc: w/enclosures
See next page

Docket

Mr. J. H. Ferguson
Virginia Electric and Power Company

cc: Mr. Michael W. Maupin
Hunton and Williams
Post Office Box 1535
Richmond, Virginia 23213

Mr. J. L. Wilson, Manager
P. O. Box 315
Surry, Virginia 23883

Swem Library
College of William and Mary
Williamsburg, Virginia 23185

Donald J. Burke, Resident Inspector
Surry Power Station
U. S. Nuclear Regulatory Commission
Post Office Box 166
Route 1
Surry, Virginia 23883

Mr. Sherlock Holmes, Chairman
Board of Supervisors of Surry County
Surry County Courthouse, Virginia 23683

Commonwealth of Virginia
Council on the Environment
903 Ninth Street Office Building
Richmond, Virginia 23219

Attorney General
1101 East Broad Street
Richmond, Virginia 23219

Mr. James R. Wittine
Commonwealth of Virginia
State Corporation Commission
Post Office Box 1197
Richmond, Virginia 23209

Director, Criteria and Standards Division
Office of Radiation Programs (ANR-460)
U. S. Environmental Protection Agency
Washington, D. C. 20460

U. S. Environmental Protection Agency
Region III Office
ATTN: EIS COORDINATOR
Curtis Building - 6th Floor
6th and Walnut Streets
Philadelphia, Pennsylvania 19106



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

DOCKET NO. 50-281

SURRY POWER STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 66
License No. DPR-37

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company (the licensee) dated February 19, 1981, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8108260260

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-37 is hereby amended to read as follows:

(B) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 66, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Vargo
Operating Reactor Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 16, 1981

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 66 TO FACILITY OPERATING LICENSE NO. DPR-37

DOCKET NO. 50-281

Revise Appendix A as follows:

Remove Page

4.17-1

Insert Page

4.17-1

4.17 SHOCK SUPPRESSORS (SNUBBERS)

Applicability

Applies to all hydraulic shock suppressors (snubbers) which are required to protect the reactor coolant system and safety related systems.

Objective

To specify the minimum frequency and type of surveillance to be applied to the hydraulic snubbers listed in Table 4.17-1 and 4.17-2.

Specification

- A. All hydraulic shock suppressors whose seal material has been demonstrated by operating experience, lab testing or analysis to be compatible with the operating environment shall be visually inspected.

This inspection shall include but not necessarily be limited to, inspection of the hydraulic-fluid reservoir, fluid connections, and linkage connections to the piping and anchor to verify snubber operability in accordance with the following schedule:

Number of Snubbers Found Inoperable During Inspection or During Inspection Interval	Next Required Inspection Interval
0	18 Months \pm 25%
1	12 Months \pm 25%
2	6 Months \pm 25%*

* The current inspection interval for Unit 2 may be extended to April 19, 1981.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 66 TO FACILITY OPERATING LICENSE NO. DPR-37

VIRGINIA ELECTRIC AND POWER COMPANY

SURRY POWER STATION, UNIT NO. 2

DOCKET NO. 50-281

Introduction

By letter dated February 19, 1981, Virginia Electric and Power Company (the licensee) requested an amendment to the Surry Power Station, Unit No. 2, which would change the Technical Specifications to allow a 30 day extension of the interval for inspecting hydraulic snubbers. The extension would be a one-time extension.

Discussion and Evaluation

The Technical Specifications require periodic inspections of snubbers on a schedule ranging from 31 days \pm 25% if more than eight snubbers are found to be inoperable to 18 months \pm 25% if no snubbers are found to be inoperable. The snubbers were last inspected during the extended steam generator repair and refueling outage. During this outage, all hydraulic snubbers were removed, rebuilt or replaced as necessary, and functionally tested satisfactorily prior to re-installation. The last visual inspection on August 2, 1980, revealed zero inoperable snubbers. The previous inspection test interval was 124 days \pm 25%. The current inspection interval is 6 months \pm 25% (in accordance with the Technical Specifications) and will expire March 19, 1981. The licensee requests a 30 day extension. This extension would allow the surveillance of the snubbers to be accomplished in parallel with a scheduled maintenance outage, thus minimizing downtime. The maintenance outage cannot be scheduled earlier due to the required delivery time of certain materials.

We have reviewed the licensee's request and find it to be reasonable for the following reasons: (1) Thirty days is not a significant extension of time, (2) All snubbers were inspected and maintained during the steam generator repair (SGR) outage, (3) zero inoperable snubbers were found during the SGR outage, (4) zero inoperable snubbers would normally result in an inspection interval of 18 months \pm 25% if it were not for the Technical Specification requirement to increase the interval one step at a time, and (5) all accessible snubbers will be inspected during the required interval.

8108260 269

Based on the above reasons, we conclude that it is reasonable to extend the current inspection interval by 30 days which in this case would be until April 19, 1981.

Environmental Consideration

We have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR §51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

Conclusion

We have concluded, based on the considerations discussed above, that: (1) because the amendment does not involve a significant increase in the probability or consequences of accidents previously considered and does not involve a significant decrease in a safety margin, the amendment does not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: March 16, 1981

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-281VIRGINIA ELECTRIC AND POWER COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No.66 to Facility Operating License No. DPR-37 issued to Virginia Electric and Power Company (the licensee), which revised Technical Specifications for operations for the Surry Power Station, Unit No. 2, (the facility) located in Surry County, Virginia. The amendment is effective as of the date of issuance.

The amendment provides a one time 30 day extension for the visual inspection surveillance requirement for inaccessible snubbers.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since this amendment does not involve a significant hazards consideration.


The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to

10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated February 19, 1981, (2) Amendment No. 66 to License No. DPR-37, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C., and at the Swem Library, College of William and Mary, Williamsburg, Virginia 23185. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 16th day of March, 1981

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing