


DURATEK

**CHARACTERIZATION SURVEY REPORT
for the
MAINE YANKEE ATOMIC POWER PLANT**

**VOLUME 5
RADIOLOGICAL CHARACTERIZATION RESULTS FOR
AFFECTED SYSTEMS**



**APRIL 1998
REVISION 1**

Prepared By:

**GTS Duratek
Radiological Engineering and Field Services
628 Gallaher Road
Kingston, TN 37763**

GTS DURATEK
CHARACTERIZATION SURVEY REPORT
for the
MAINE YANKEE ATOMIC POWER PLANT

APRIL 1998

REVISION 1

VOLUME 5:
RADIOLOGICAL CHARACTERIZATION RESULTS FOR
AFFECTED SYSTEMS

Prepared by: GTS Duratek, Inc.

Date 4-28-98

Reviewed by: Signature on File


Date 4-28-98

Dave Lovett
Project Manager

Reviewed by: 

Date 4-28-98

Dave Hall, CHP
Manager, RE&DS Technical Department

Approved by: 

Date 4-28-98

Harvey F. Story
Director, Radiological Engineering
and Decommissioning Services

Prepared By:

**GTS Duratek
628 Gallaher Road
Kingston, TN 37763**

TABLE OF CONTENTS

VOLUME 5: RADIOLOGICAL CHARACTERIZATION RESULTS FOR AFFECTED SYSTEMS

1.0 BACKGROUND INFORMATION 1

2.0 SITE INFORMATION 2

3.0 CHARACTERIZATION SURVEY OVERVIEW 3

4.0 SURVEY FINDINGS AND RESULTS 5

Appendix A Characterization Reports for Affected Systems

TABLES

1-1 Characterization Survey Report Volumes 1

3-1 Exposure Rate Measurement Detector Selection Guidelines 4

3-2 Guidelines for Selecting Instruments to Count Beta Smears 4

4-1 Sample Type and Geometry for Gamma Spectral Analysis 7

4-2 GROUP "C" Affected Plant Systems Survey Packages 8

1.0 BACKGROUND INFORMATION

GTS Duratek prepared this Characterization Survey Report for the Maine Yankee Atomic Power Company (MYAPCO) to document the results of the characterization survey of the Maine Yankee Atomic Power Plant (MYAPP). The Characterization Survey Report comprises the nine volumes listed in Table 1-1 below. Volume 1 of the Report provides the programmatic information relevant to volumes 2 through 7. This volume (5) provides the characterization results for Group C, Affected Systems.

**Table 1-1
Characterization Survey Report Volumes**

Volume No.	Description
1	Characterization Survey Description
2	Radiological Characterization Results for Unaffected Structures and Surfaces, including Structural Background Survey
3	Radiological Characterization Results for Affected Structures and Surfaces
4	Radiological Characterization Results for Unaffected Systems
5	Radiological Characterization Results for Affected Systems
6	Radiological Characterization Results for Affected and Unaffected Environs, including Environs Background Survey
7	Hazardous Material Characterization
8	Maine Yankee Reactor Vessel Activation Analysis to Support Site Characterization
9	Asbestos Quantity Survey

2.0 SITE INFORMATION

Volume 1, Section 2 of this Characterization Survey Report describes the Maine Yankee Atomic Power Plant site.

3.0 CHARACTERIZATION SURVEY OVERVIEW

Volume 1, Section 3 of this Characterization Survey Report provides an overview of the general survey process, including objectives, organization and responsibilities, instrumentation, planning, survey techniques, survey package implementation, sample analysis and quality control, characterization data review and reporting, and quality assurance. This section (Volume 5 Section 3) provides an overview of the survey of affected systems.

Project personnel used plant historical data, system walkdowns, previous GTS Duratek experience, and assistance from Maine Yankee operations staff to prepare survey packages for 17 plant systems presumed to be radiologically affected by plant operations. Each survey package described the system, its history and use, and the quantity and type of measurements and samples to be collected. For affected systems, the surveys normally included exposure rate measurements at the vertical midpoint of the component, removable alpha and beta measurements of system internals, and smear, crud and debris samples from specified locations for gamma spectral analysis. The survey also included beta scans of accessible surfaces and direct beta measurements to the extent possible, based on access, dose rate and surface radioactivity limitations. GTS Duratek characterized highly contaminated plant systems using indirect measurements (e.g., smears or material samples) and exposure rate measurements. Contact dose rates on smears had to be less than 1 mR/hr to perform gamma spectroscopy analysis. The contaminated system measurements can be used to plan the decommissioning, including decontamination techniques, ALARA measures for the dismantlement/removal of systems, schedules, costs, waste volumes, and health and safety considerations.

Component exposure rate measurements may be affected by the background radiation levels/gradients in the component's general area. To assess this affect, the survey team collected multiple measurements in the vicinity of each surveyed component. Typically, this included measurements 15 cm and one meter from the component surface north, east, south, and west of the component. The survey team used the Ludlum Model 2350 Data Logger to obtain and log these measurements expeditiously, thus maintaining their exposures ALARA.

The survey packages provided the guidelines in Table 3-1 for exposure rate measurement detector selection. Table 3-2 contains the guidelines for selecting instruments to count beta smears.

Table 3-1 Exposure Rate Measurement Detector Selection Guidelines

Exposure Rate Range	Suggested Detector
Exposure Rate \leq 1 mR/hr	Ludlum Model 44-2 in the scaler mode and a 60 second count time
1 mR/hr < Exposure Rate \leq 500 mR/hr	Ludlum Model 44-38 detector (closed window) operated in the rate meter mode and 0 (zero) count time
200 mR/hr < Exposure Rate \leq 4000 mR/hr	Ludlum Model 133-4 detector operated in the rate meter mode and 0 (zero) count time
Exposure Rate > 4000 mR/hr	Selected on a case-by-case basis

Table 3-2 Guidelines for Selecting Instruments to Count Beta Smears

Beta Surface Activity Range	Suggested Detector
< 30,000 dpm/100 cm ²	Tennelec
\geq 30,000 dpm/100 cm ²	Eberline RM-14 or Ludlum 44-40 set for counting smears using the L5 code LAB03

4.0 SURVEY FINDINGS AND RESULTS

Table 4-2 lists the affected systems survey packages.

Appendix A contains a characterization report for each survey package listed in Table 4-2. Each report contains the following forms, which are described in more detail below:

- Characterization Summary,
- Summary of Survey Units,
- Statistical Summary and Graph for selected measurement types,
- Results Listing Report for each measurement type,
- Exposure Rate Distance Ratios,
- Download File & Survey Instrumentation Calibration Summary for selected measurement types,
- Removable Contamination - Tritium Activity Results Listing, and
- Gamma Spectral Analysis Results Listing.

The **Characterization Summary** contains the survey package description and general historical information on the survey area, including equipment, operating history, construction materials, and past contamination incidents. The Characterization Summary also contains a summary of characterization activities, characterization survey results and, if available, references (e.g., documents, interviews).

The **Summary of Survey Units** contains the survey package description (i.e., system), lists the survey units within each survey area (i.e., equipment identification), and the survey reason with code. The Summary of Survey Units also includes a list of materials in each survey area (e.g., metal) and the background values for each that were used to correct gross measurements.

The **Statistical Summary and Graph** presents statistics and a graph of results for each type of measurement (direct measurements for total beta activity, removable alpha and beta activity and exposure rate measurements) performed for the survey area. Statistics typically include: mean, maximum, minimum, standard deviation, minimum detectable activity calculated for the specified data set and measurement type, number of samples reported, and number of samples prescribed. Various tests were performed for each data set and measurement type reported.

A **Results Listing Report** is presented with each Statistical Summary and Graph for each applicable type of measurement (direct measurements for total beta activity, removable alpha and beta activity, and exposure rate). The Results Listing Report contains the corrected data and location information for each measurement. The results of direct measurements for total beta activity are reported in net dpm per 100 cm² after subtracting the background value for the material of construction. The results of the smear samples for removable alpha and beta activity are reported in net dpm/100 cm² from the low background alpha and beta counter instrument. The results of exposure rate measurements are reported in net μ R/hr (micro R per hour). The exposure rates have not been corrected for background from materials of construction.

For the exposure rate measurements, the odd-numbered L8 codes in the results listing denote measurements collected 15 centimeters from the system component surface. The even-numbered L8 codes denote measurements collected 1 meter from the system component surface. The codes designate directional location as follows:

- L8 codes 00001 and 00002 are North compass point readings.
- L8 codes 00003 and 00004 are East compass point readings.
- L8 codes 00005 and 00006 are South compass point readings.
- L8 codes 00007 and 00008 are West compass point readings.

A **Download File & Survey Instrumentation Calibration Summary** is presented with each Statistical Summary and Graph for selected measurement types. The Download File & Survey Instrumentation Calibration Summary provides survey date, file number (Download #- Station #), detector model number, instrument and detector serial numbers and calibration due date(s) and technician's identification number for each instrument and detector combination used to collect data.

The **Exposure Rate Distance Ratios** form provides the ratio of 15 cm to 1 m exposure rates for selected components. The form includes a graph of 15 cm and 1 m exposure rates by component number.

For the surveys prescribing tritium smear samples, a **Removable Contamination - Tritium Activity Results Listing** report is presented. The results listing report contains the corrected data, location information, Sample ID and Sample Type for each measurement. The results of the smear samples for removable tritium activity are reported in net dpm/100 cm² from the liquid scintillation counter instrument. An instrument calibration summary is presented with the results listing and provides survey date, instrument manufacturer, model number, serial number, calibration due date and technician's initials for the instrument used to analyze the sample.

RADIOLOGICAL CHARACTERIZATION RESULTS FOR AFFECTED SYSTEMS

For survey areas/packages where samples for gamma spectral analysis were prescribed, the characterization report contains a **Gamma Spectral Analysis Results Listing**. The results listing includes the sample survey location, Lab ID, Spectrum filename, sample mass, count time and the activity, MDA and associated 2 sigma error (counting uncertainty) for plant-derived radionuclides Mn-54, Co-57, Co-60, Cs-134, and Cs-137. For samples where the activity result is less than the MDA value, a "<" sign (less than) appears to the left of the value in the "Activity" column in units of pCi/g (picoCuries per gram) with a zero pCi/g value for the error. For samples with a positive (greater than MDA) activity pCi/g result, the report includes the associated counting error in units of \pm pCi/g. The activity of naturally-occurring K-40 with MDA and associated error is reported as a quality control check. Other naturally occurring radionuclides may be present, but are not reported. Table 4-1 describes the sample type and geometry as indicated by the three letter prefix of the sample Spectrum filename.

**Table 4-1
Sample Type and Geometry for Gamma Spectral Analysis**

Spectrum Filename Prefix	Sample Type	Sample Geometry	Sample Volume
BIO	Plant Life, Biomass	Marinelli Beaker	1 Liter
ENV	Soil	Marinelli Beaker	1 Liter
FAL	Debris	Petri Dish	40 - 60 ml
H2O	Water	Marinelli Beaker	1 Liter
HDL	Debris, Soil	Marinelli Beaker	0.25 Liter
PET	Filter	Petri Dish	NA

Table 4-2

PACKAGE NUMBER	GROUP "C" Affected Plant Systems Survey Packages
C0100	Primary and Post Accident Sampling System
C0200	Waste Solidification System
C0300	Containment Spray System
C0400	Emergency Core Cooling System
C0500	Residual Heat Removal System
C0600	Primary Vents and Drains
C0700	Fuel Pool Cooling System
C0800	Waste Gas Disposal System
C0900	Pressurizer and Pressurizer Relief System
C1100	Reactor Coolant System
C1200	Boron Recovery System
C1300	Chemical and Volume Control System
C1400	Liquid Waste Disposal System
C1500	Primary Auxiliary Building Drains
C1600	Primary Auxiliary Building Ventilation
C1800	Containment Ventilation System
C1900	Steam Generators

**APPENDIX A
CHARACTERIZATION REPORTS FOR AFFECTED SYSTEMS**



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

CHARACTERIZATION SUMMARY

SURVEY PACKAGE NUMBER :C0100

SYSTEMS

PACKAGE DESCRIPTION

Primary and Post Accident Sampling System

SURVEY AREA DESCRIPTION

Primary and Post Accident Sampling System

GENERAL HISTORICAL INFORMATION (Operational history, etc.)

The Primary and Post Accident Sampling System transported small quantities of radioactive fluids and gases from the primary plant to two separate sampling stations in the Primary Auxiliary Building (PAB). Portions of the system also degassed the pressurizer steam space and allowed a manually valved-in remote pressurizer pressure indication during Control Room evacuation. The Primary Sampling System allowed sampling of the reactor coolant and auxiliary systems during normal operations. The Post Accident Sampling System (PAS) allowed for sampling of reactor coolant following an accident.

SUMMARY OF CHARACTERIZATION ACTIVITIES

Survey units were established for the system by building and elevation as shown in the following Summary of Survey Units. The Surface(s) listing indicates the component name, survey surface code and, where applicable, the Maine Yankee system component number.

A total of 43 exposure rate measurements were collected at 6 component locations. Due to physical interferences, 5 measurements could not be collected.

Beta scan surveys and direct measurements for total beta activity were not prescribed for this survey package.

Smear samples were collected from component interior surfaces to analyze for removable alpha and beta activity at 5 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable tritium activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable plant-derived radionuclide activity by gamma spectroscopy at 3 survey measurement locations indicated on the results listing report.

The survey result statistical summaries, graphs and results listings are shown in the following individual reports including calibration summaries for the instruments used for each measurement type.

CHARACTERIZATION SURVEY RESULTS

o The average and maximum exposure rate measurement results were 1.4 mR/hr and 4.2 mR/hr, respectively. The ratio of the 15 cm distance measurements to the 1 meter distance measurements ranged from 0.8 to 1.4.

o There were 5 measurements for removable beta activity above MDA (maximum MDA was 5,000 dpm/100cm²). The maximum measurement result was 300,000 dpm/100cm².

o 3 of the 5 smear measurements were analyzed for removable alpha activity and no measurements were above MDA (8.4 dpm/100cm²).

o There was 1 measurement for removable tritium activity above MDA (39 dpm/100cm²). The maximum measurement result was 196 dpm/100cm².

CHARACTERIZATION SUMMARY

04/14/98

o Of the 3 samples analyzed by gamma spectroscopy, all samples indicated plant-derived radionuclide activity above MDA. The analysis of the samples indicated the presence of Co-60, Cs-134 and Cs-137.

REFERENCES (Documents, Interviews)

Maine Yankee Drawing 1150 - FM - 96 A, B
Operator System Training Manual, Chapter 5



Maine Yankee Atomic Power Plant Site Characterization

SUMMARY OF SURVEY UNIT(S)

04/14/98

OUTPUT BATCH SN = 831

PACKAGE C0100 SYSTEMS

Primary and Post Accident Sampling System

UNIT(S)	SURFACE(S)
01 - 21' Primary Auxiliary Building Components	H01 (Primary plant sample cooler E-77A) H02 (Primary plant sample cooler E-77B) M01 (Primary sample sink) P01 (SS tubing upstream of PS-74) P02 (SS tubing downstream of PS-33) P03 (SS tubing upstream of valve PS-82)
02 - 36' Primary Auxiliary Building Components	M01 (Water dilution funnel) U01 (Vacuum pump P-153) U02 (Primary water booster pump P-152)

REASON(S) CHARACTERIZATION SURVEY (C01)

MATERIALS	MAT'L CODE	MATERIAL DESCRIPTION	BETA BKGD (dpm/100 cm ²)
	G0031	METAL - BARE (GAMMA)	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package C0100 SYSTEMS

Primary and Post Accident Sampling System


STATISTICAL SUMMARY

TESTS PERFORMED

	$\mu\text{R/hr}$
Mean	1,386.0
Maximum	4,161.0
Minimum	35.4
Standard Deviation	1,422.9

Samples reported satisfy samples prescribed	YES
---	-----

Samples Reported	43
Samples Prescribed	43





Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package : C0100 SYSTEMS

Primary and Post Accident Sampling System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
532 (2)	01	H01	G0031	C01	0.00	00001	3194.5
532 (2)	01	H01	G0031	C01	0.00	00002	2740.8
532 (2)	01	H01	G0031	C01	0.00	00003	2505.9
532 (2)	01	H01	G0031	C01	0.00	00004	1931.0
532 (2)	01	H01	G0031	C01	0.00	00005	2485.6
532 (2)	01	H01	G0031	C01	0.00	00006	2438.0
532 (2)	01	H01	G0031	C01	0.00	00007	3325.5
532 (2)	01	H01	G0031	C01	0.00	00008	2569.8
532 (2)	01	H02	G0031	C01	0.00	00001	2835.4
532 (2)	01	H02	G0031	C01	0.00	00002	2976.4
532 (2)	01	H02	G0031	C01	0.00	00003	3312.7
532 (2)	01	H02	G0031	C01	0.00	00004	3706.9
532 (2)	01	H02	G0031	C01	0.00	00005	2530.5
532 (2)	01	H02	G0031	C01	0.00	00006	2756.7
532 (2)	01	H02	G0031	C01	0.00	00007	2826.4
532 (2)	01	H02	G0031	C01	0.00	00008	2142.7
532 (2)	01	M01	G0031	C01	0.00	00001	2339.6
532 (2)	01	M01	G0031	C01	0.00	00002	1997.1
532 (2)	01	M01	G0031	C01	0.00	00003	4161.0
532 (2)	01	M01	G0031	C01	0.00	00007	3121.2
532 (2)	01	M01	G0031	C01	0.00	00008	2306.4

REMAINING RESULTS PRINTED ON NEXT PAGE

NOTES: Exposure rates reported in net μ R/hr. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 μ R/hr.



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package : C0100 SYSTEMS

Primary and Post Accident Sampling System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
528 (2)	02	M01	G0031	C01	60.00	00001	<u>43.2</u>
528 (2)	02	M01	G0031	C01	60.00	00002	<u>47.8</u>
528 (2)	02	M01	G0031	C01	60.00	00003	<u>50.1</u>
528 (2)	02	M01	G0031	C01	60.00	00004	<u>73.8</u>
528 (2)	02	M01	G0031	C01	60.00	00005	<u>38.6</u>
528 (2)	02	M01	G0031	C01	60.00	00007	<u>41.2</u>
528 (2)	02	M01	G0031	C01	60.00	00008	<u>35.4</u>
528 (2)	02	U01	G0031	C01	60.00	00001	<u>90.8</u>
528 (2)	02	U01	G0031	C01	60.00	00002	<u>90.6</u>
528 (2)	02	U01	G0031	C01	60.00	00003	<u>81.1</u>
528 (2)	02	U01	G0031	C01	60.00	00004	100.4
528 (2)	02	U01	G0031	C01	60.00	00005	<u>91.1</u>
528 (2)	02	U01	G0031	C01	60.00	00007	<u>88.4</u>
528 (2)	02	U01	G0031	C01	60.00	00008	<u>98.9</u>
528 (2)	02	U02	G0031	C01	60.00	00001	<u>48.1</u>
528 (2)	02	U02	G0031	C01	60.00	00002	<u>38.8</u>
528 (2)	02	U02	G0031	C01	60.00	00003	<u>51.3</u>
528 (2)	02	U02	G0031	C01	60.00	00004	<u>55.4</u>
528 (2)	02	U02	G0031	C01	60.00	00005	<u>54.8</u>
528 (2)	02	U02	G0031	C01	60.00	00006	<u>68.3</u>
528 (2)	02	U02	G0031	C01	60.00	00007	<u>50.9</u>
528 (2)	02	U02	G0031	C01	60.00	00008	<u>55.5</u>

NOTES: Exposure rates reported in net $\mu\text{R/hr}$. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 $\mu\text{R/hr}$.
 43 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DOWNLOAD FILE & SURVEY INSTRUMENTATION CALIBRATION SUMMARY

04/14/98

Exposure Rate Measurements

Survey Package : C0100 SYSTEMS

Primary and Post Accident Sampling System

SURVEY DATE	FILE #	M2350		DETECTOR			TECHNICIAN
		INST S/N	CAL DUE	MODEL	S/N	CAL DUE	
2/3/98	528 (2)	126197	3/22/98	44-2	PR126922	4/19/98	JFM0682
CALIBRATION DATES VERIFIED AS ACCEPTABLE							
2/3/98	532 (2)	126185	3/20/98	44-38	075082	7/23/98	JFM0682
CALIBRATION DATES VERIFIED AS ACCEPTABLE							




Maine Yankee Atomic Power Plant Site Characterization
Exposure Rate Distance Ratios


SURVEY PACKAGE C0100

Package Number	Component Number	Component Description	Direction	15 cm mR/hr	1 meter mR/hr	Ratio of 15 cm to 1 meter
C0100	01H01	Primary plant sample cooler E-77A	North	3.2	2.7	1.2
			East	2.5	1.9	1.3
			South	2.5	2.4	1.0
			West	3.3	2.6	1.3
C0100	01H02	Primary plant sample cooler E-77B	North	2.8	3.0	1.0
			East	3.3	3.7	0.9
			South	2.5	2.8	0.9
			West	2.8	2.1	1.3
C0100	01M01	Primary sample sink	North	2.3	2.0	1.2
			East	4.2	*	
			West	3.1	2.3	1.4
C0100	02M01	Water dilution funnel	North	0.0	0.0	0.9
			East	0.1	0.1	0.7
			South	0.0	*	
			West	0.0	0.0	1.2
C0100	02U01	Vacuum pump P-153	North	0.1	0.1	1.0
			East	0.1	0.1	0.8
			South	0.1	*	
			West	0.1	0.1	0.9
C0100	02U02	Primary water booster pump P-152	North	0.0	0.0	1.2
			East	0.1	0.1	0.9
			South	0.1	0.1	0.8
			West	0.1	0.1	0.9

* Measurement not collected due to interfering surface.

Exposure Rates - 15 cm and 1 meter





Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Gross Beta Activity

Survey Package C0100 SYSTEMS

Primary and Post Accident Sampling System


STATISTICAL SUMMARY

TESTS PERFORMED

	Net dpm/100 cm ²
Mean	77,858.4
Maximum	300,000.0
Minimum	2,885.9
Standard Deviation	126,236.0
MDA	5,000.0

MDA <100 net dpm/100 cm ²	NO
Results above 100 net dpm/100 cm ²	5
Number of results above MDA	5

Samples Reported	5
Samples Prescribed	11





Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Gross Alpha Activity

Survey Package C0100 SYSTEMS

Primary and Post Accident Sampling System


STATISTICAL SUMMARY

TESTS PERFORMED

	Net dpm/100 cm ²
Mean	1.5
Maximum	8.0
Minimum	-0.3
Standard Deviation	3.7
MDA	8.4

MDA <10 net dpm/100 cm ²	YES
Results above 20 net dpm/100 cm ²	0
Number of results above MDA	0

Samples Reported	5
Samples Prescribed	11



5 RESULTS ARE GRAPHED

Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination

Survey Package: C0100 SYSTEMS

Primary and Post Accident Sampling System

RESULTS LISTING - SORTED BY SURFACE CODE

XLS FILE	UNIT	SURFACE	REASON	MSRMNT LOCATION	ALPHA	BETA
RM-14DATA2	01	P03	C01	1		<u>60,000.0</u>
RM-14DATA1	01	P02	C01	1		<u>300,000.0</u>
SME1E103.XLS	01	P01	C01	1	8.0	<u>20,088.2</u>
SME1E101.XLS	01	M01	C01	1	-0.3	<u>2,885.9</u>
SME1E101.XLS	01	M01	C01	1	-0.3	<u>6,317.9</u>

NOTES: Activity reported in net dpm/100 cm².

Underlined values exceed the associated MDA.

Bold values exceed 100.00 dpm/100 cm² (beta activity) and/or 20.00 dpm/100 cm² (alpha activity).

5 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DATAFILE & ALPHA - BETA COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination

Survey Package : C0100 SYSTEMS

Primary and Post Accident Sampling System

SURVEYDATE	XLS FILE	INST ID	S/N	CAL DUE	LAB TECHNICIAN
3/28/98	RM-14DATA1	3	8263	5/26/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/28/98	RM-14DATA2	3	8263	5/26/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/16/98	SME1E101.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/16/98	SME1E103.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Tritium Activity

Survey Package: C0100 SYSTEMS

Primary and Post Accident Sampling System

RESULTS LISTING - SORTED BY SURFACE CODE

SAMPLE ID	SAMPLE TYPE	UNIT	SURF	REASN	MSRMNT LOCATION	MDA	TRITIUM ACTIVITY
D23	Hoppes patch	01	P01	C01	00001	38.8	-11.7
D24	Hoppes patch	01	P02	C01	00001	39.2	-0.9
D25	Hoppes patch	01	P03	C01	00001	39.2	<u>195.9</u>

NOTES: Activity reported in net dpm/100 cm².
 Underlined values exceed the associated MDA.
 Bold values exceed 75 dpm/100 cm²,
 Italic values exceed 100 dpm/100 cm².



Maine Yankee Atomic Power Plant Site Characterization

LIQUID SCINTILLATION COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination - Tritium Activity

Survey Package: C0100 SYSTEMS

Primary and Post Accident Sampling System

SURVEYDATE	INSTRUMENT	MODEL	S/N	CAL DUE	LAB TECHNICIAN
3/5/98	Packard	2750	416221	6/16/98	LDT

CALIBRATION DATE VERIFIED AS ACCEPTABLE



Maine Yankee Atomic Power Plant Site Characterization

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 831

Survey Package C0100 SYSTEMS

Primary and Post Accident Sampling System

UNIT : 01 SURFACE : P01 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Plant Piping (interior)
 SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP001	PET00006	1.0	1200	Co-57	< 64.2	64.2	0.0
				Co-60	2450.00	69.8	193.0
				Cs-134	99.90	104.0	67.1
				Cs-137	521.00	132.0	118.0
				K-40	< 899.0	899.0	0.0
				Mn-54	< 157.0	157.0	0.0

UNIT : 01 SURFACE : P02 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Plant Piping (interior)
 SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP002	PET00004	1.0	1200	Co-57	< 211.0	211.0	0.0
				Co-60	15000.00	423.0	5,070.0
				Cs-134	< 553.0	553.0	0.0
				Cs-137	< 691.0	691.0	0.0
				K-40	< 1620.0	1,620.0	0.0
				Mn-54	< 851.0	851.0	0.0

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 831

Survey Package C0100 SYSTEMS

Primary and Post Accident Sampling System

UNIT : 01 SURFACE : P03 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Plant Piping (interior)
 SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP003	PET00005	1.0	1200	Co-57	< 157.0	157.0	0.0
				Co-60	39300.00	409.0	1,830.0
				Cs-134	533.00	321.0	208.0
				Cs-137	2270.00	357.0	917.0
				K-40	< 1280.0	1,280.0	0.0
				Mn-54	< 544.0	544.0	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

CHARACTERIZATION SUMMARY

SURVEY PACKAGE NUMBER :C0200

SYSTEMS

PACKAGE DESCRIPTION

Waste Solidification System

SURVEY AREA DESCRIPTION

Waste Solidification System

GENERAL HISTORICAL INFORMATION (Operational history, etc.)

The primary purpose of the Waste Solidification System is storage, solidification and packaging of liquid waste and exhausted demineralizer resin beads for eventual off-site disposal. In conjunction with the plant's installed waste solidification system, two contractor systems are also used for waste solidification. The Hittman system is used primarily for the solidification of liquid waste and is not currently used for processing spent resins. A Duratek system is also used for the processing of normal liquid waste.

SUMMARY OF CHARACTERIZATION ACTIVITIES

Survey units were established for the system by building and elevation as shown in the following Summary of Survey Units. The Surface(s) listing indicates the component name, survey surface code and, where applicable, the Maine Yankee system component number.

A total of 30 exposure rate measurements were collected at 5 component locations. Due to physical interferences, 10 measurements could not be collected.

Beta scan surveys and direct measurements for total beta activity were not prescribed for this survey package.

Smear samples were collected from component interior surfaces to analyze for removable alpha and beta activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable tritium activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable plant-derived radionuclide activity by gamma spectroscopy at 3 survey measurement locations indicated on the results listing report.

The survey result statistical summaries, graphs and results listings are shown in the following individual reports including calibration summaries for the instruments used for each measurement type.

CHARACTERIZATION SURVEY RESULTS

- o The average and maximum exposure rate measurement results were 23.3 mR/hr and 219.3 mR/hr, respectively. The ratio of the 15 cm distance measurements to the 1 meter distance measurements ranged from 0.7 to 2.6.
- o There were 3 measurements for removable beta activity above MDA (34 dpm/100cm²) and 2 measurements were above 100 dpm/100cm². The maximum measurement result was 4,073 dpm/100cm².
- o There were no measurements for removable alpha activity above MDA (8.4 dpm/100cm²).
- o There was 1 measurement for removable tritium activity above MDA (39 dpm/100cm²). The maximum measurement result was 1,212 dpm/100cm².

CHARACTERIZATION SUMMARY

04/14/98

o Of the 3 samples analyzed by gamma spectroscopy, 2 samples indicated plant-derived radionuclide activity above MDA. The analysis of the samples indicated the presence of Co-60, Cs-134 and Cs-137.

REFERENCES (Documents, Interviews)

Maine Yankee Drawing 1150 - FM - 99 A, B
Operator System Training Manual, Chapter 39



Maine Yankee Atomic Power Plant Site Characterization

SUMMARY OF SURVEY UNIT(S)

04/14/98

OUTPUT BATCH SN = 837

PACKAGE C0200 SYSTEMS

Waste Solidification System

UNIT(S)	SURFACE(S)
01 - RCA Room Components	P01 (1/2" spoolpiece between valves WSS-A-22 & WSS-A-23) P02 (2" line at valve WSS-91) T02 (Secondary flush accumulator tank TK-98) T03 (Waste hold up tank TK-95) U01 (Dewatering pump P-123) U02 (Waste feed pump P-120)
02 - 21' Primary Auxiliary Building Components	T01 (Primary water flush tank TK-80)

REASON(S) CHARACTERIZATION SURVEY (C01)

MATERIALS	MAT'L CODE	MATERIAL DESCRIPTION	BETA BKGD (dpm/100 cm ²)
	G0031	METAL - BARE (GAMMA)	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package C0200 SYSTEMS

Waste Solidification System


STATISTICAL SUMMARY

TESTS PERFORMED

	$\mu\text{R/hr}$
Mean	23,333.2
Maximum	219,339.5
Minimum	12.7
Standard Deviation	53,199.1

Samples reported satisfy samples prescribed	YES
---	-----

Samples Reported	30
Samples Prescribed	30



30 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package : C0200 SYSTEMS

Waste Solidification System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
545 (2)	01	T02	G0031	C01	60.00	00001	1179.4
545 (2)	01	T02	G0031	C01	60.00	00002	1246.3
545 (2)	01	T02	G0031	C01	60.00	00003	1117.5
545 (2)	01	T02	G0031	C01	60.00	00004	1341.0
545 (2)	01	T02	G0031	C01	60.00	00005	1029.5
545 (2)	01	T02	G0031	C01	60.00	00007	820.3
530 (2)	01	T03	G0031	C01	0.00	00001	<u>219339.5</u>
530 (2)	01	T03	G0031	C01	0.00	00003	<u>135314.5</u>
530 (2)	01	T03	G0031	C01	0.00	00005	<u>136557.2</u>
530 (2)	01	T03	G0031	C01	0.00	00006	<u>53301.5</u>
530 (2)	01	T03	G0031	C01	0.00	00007	<u>101489.8</u>
530 (2)	01	U01	G0031	C01	0.00	00001	<u>3064.3</u>
530 (2)	01	U01	G0031	C01	0.00	00003	<u>3612.4</u>
530 (2)	01	U01	G0031	C01	0.00	00005	<u>4690.0</u>
530 (2)	01	U01	G0031	C01	0.00	00006	<u>4282.6</u>
530 (2)	01	U01	G0031	C01	0.00	00007	<u>4470.2</u>
530 (2)	01	U01	G0031	C01	0.00	00008	<u>3017.0</u>
530 (2)	01	U02	G0031	C01	0.00	00001	<u>3101.2</u>
530 (2)	01	U02	G0031	C01	0.00	00003	<u>3461.6</u>
530 (2)	01	U02	G0031	C01	0.00	00005	<u>4300.0</u>
530 (2)	01	U02	G0031	C01	0.00	00006	<u>4259.2</u>
530 (2)	01	U02	G0031	C01	0.00	00007	<u>3742.4</u>
530 (2)	01	U02	G0031	C01	0.00	00008	<u>5143.5</u>
545 (2)	02	T01	G0031	C01	60.00	00001	13.2
545 (2)	02	T01	G0031	C01	60.00	00002	16.9
545 (2)	02	T01	G0031	C01	60.00	00003	12.7
545 (2)	02	T01	G0031	C01	60.00	00005	15.2
545 (2)	02	T01	G0031	C01	60.00	00006	20.5
545 (2)	02	T01	G0031	C01	60.00	00007	16.1
545 (2)	02	T01	G0031	C01	60.00	00008	20.8

NOTES: Exposure rates reported in net $\mu\text{R/hr}$. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 $\mu\text{R/hr}$.
 30 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DOWNLOAD FILE & SURVEY INSTRUMENTATION CALIBRATION SUMMARY

04/14/98

Exposure Rate Measurements

Survey Package : C0200 SYSTEMS

Waste Solidification System

SURVEY DATE	FILE #	M2350		DETECTOR			TECHNICIAN
		INST S/N	CAL DUE	MODEL	S/N	CAL DUE	
2/3/98	530 (2)	095348	3/20/98	44-38	088919	7/23/98	MAP5535
CALIBRATION DATES VERIFIED AS ACCEPTABLE							
2/4/98	545 (2)	126182	3/22/98	44-2	128338	4/19/98	MAP5535
CALIBRATION DATES VERIFIED AS ACCEPTABLE							




Maine Yankee Atomic Power Plant Site Characterization
Exposure Rate Distance Ratios

SURVEY PACKAGE C0200

Package Number	Component Number	Component Description	Direction	15 cm mR/hr	1 meter mR/hr	Ratio of 15 cm to 1 meter
C0200	01T02	Secondary flush accumulator tank TK-98	North	1.2	1.2	0.9
			East	1.1	1.3	0.8
			South	1.0	*	
			West	0.8	*	
C0200	01T03	Waste hold up tank TK-95	North	219.3	*	
			East	135.3	*	
			South	136.6	53.3	2.6
			West	101.5	*	
C0200	01U01	Dewatering pump P-123	North	3.1	*	
			East	3.6	*	
			South	4.7	4.3	1.1
			West	4.5	3.0	1.5
C0200	01U02	Waste feed pump P-120	North	3.1	*	
			East	3.5	*	
			South	4.3	4.3	1.0
			West	3.7	5.1	0.7
C0200	02T01	Primary water flush tank TK-80	North	0.0	0.0	0.8
			East	0.0	*	
			South	0.0	0.0	0.7
			West	0.0	0.0	0.8

* Measurement not collected due to interfering surface.

Exposure Rates - 15 cm and 1 meter





Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Gross Beta Activity

Survey Package C0200 SYSTEMS

Waste Solidification System


STATISTICAL SUMMARY

TESTS PERFORMED

	Net dpm/100 cm ²
Mean	2,344.4
Maximum	4,072.5
Minimum	50.3
Standard Deviation	2,069.9
MDA	33.8

MDA <100 net dpm/100 cm ²	YES
Results above 100 net dpm/100 cm ²	2
Number of results above MDA	3

Samples Reported	3
Samples Prescribed	9



3 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Gross Alpha Activity

Survey Package C0200 SYSTEMS

Waste Solidification System


STATISTICAL SUMMARY

TESTS PERFORMED

	Net dpm/100 cm ²
Mean	-0.3
Maximum	-0.3
Minimum	-0.3
Standard Deviation	0.0
MDA	8.4

MDA < 10 net dpm/100 cm ²	YES
Results above 20 net dpm/100 cm ²	0
Number of results above MDA	0

Samples Reported	3
Samples Prescribed	9



3 RESULTS ARE GRAPHED

Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination

Survey Package: C0200 SYSTEMS

Waste Solidification System

RESULTS LISTING - SORTED BY SURFACE CODE

XLS FILE	UNIT	SURFACE	REASON	MSRMNT LOCATION	ALPHA	BETA
SME1E109.XLS	01	T03	C01	1	-0.3	<u>2,910.3</u>
SME1E107.XLS	01	P02	C01	1	-0.3	<u>4,072.5</u>
SME1E105.XLS	01	P01	C01	1	-0.3	50.3

NOTES: Activity reported in net dpm/100 cm².
 Underlined values exceed the associated MDA.
 Bold values exceed 100.00 dpm/100 cm² (beta activity) and/or 20.00 dpm/100 cm² (alpha activity).
 3 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DATAFILE & ALPHA - BETA COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination

Survey Package: C0200 SYSTEMS

Waste Solidification System

SURVEYDATE	XLS FILE	INST ID	S/N	CAL DUE	LAB TECHNICIAN
3/16/98	SME1E105.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/16/98	SME1E107.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/16/98	SME1E109.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					

Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Tritium Activity

Survey Package: C0200 SYSTEMS

Waste Solidification System

RESULTS LISTING - SORTED BY SURFACE CODE

SAMPLE ID	SAMPLE TYPE	UNIT	SURF	REASN	MSRMNT LOCATION	MDA	TRITIUM ACTIVITY
D26	Hoppes patch	01	P01	C01	00001	39.1	-23.7
D27	Hoppes patch	01	P02	C01	00001	39.1	11.2
D28	Hoppes patch	01	P03	C01	00001	39.1	<u>1,212.2</u>

NOTES: Activity reported in net dpm/100 cm².
 Underlined values exceed the associated MDA.
 Bold values exceed 75 dpm/100 cm²,
 Italic values exceed 100 dpm/100 cm².



Maine Yankee Atomic Power Plant Site Characterization

LIQUID SCINTILLATION COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination - Tritium Activity

Survey Package: C0200 SYSTEMS

Waste Solidification System

SURVEYDATE	INSTRUMENT	MODEL	S/N	CAL DUE	LAB TECHNICIAN
3/5/98	Packard	2750	416221	6/16/98	LDT

CALIBRATION DATE VERIFIED AS ACCEPTABLE



Maine Yankee Atomic Power Plant Site Characterization

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 862

Survey Package C0200 SYSTEMS

Waste Solidification System

UNIT : 01	SURFACE : P01	REASON : C01	ANALYSIS TYPE CODE : LAB05				
SAMPLE TYPE OR SURFACE SAMPLED: Plant Piping (interior)							
SAMPLE LOCATOR: 00001							
LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP33	PET00051	1.0	1200	Co-57	< 52.9	52.9	0.0
				Co-60	< 67.9	67.9	0.0
				Cs-134	< 69.4	69.4	0.0
				Cs-137	< 84.1	84.1	0.0
				K-40	< 899.0	899.0	0.0
				Mn-54	< 76.6	76.6	0.0

UNIT : 01	SURFACE : P02	REASON : C01	ANALYSIS TYPE CODE : LAB05				
SAMPLE TYPE OR SURFACE SAMPLED: Plant Piping (interior)							
SAMPLE LOCATOR: 00001							
LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP34	PET00052	1.0	1200	Co-57	< 261.0	261.0	0.0
				Co-60	42700.00	271.0	1,950.0
				Cs-134	10500.00	378.0	542.0
				Cs-137	88300.00	563.0	5,700.0
				K-40	< 1170.0	1,170.0	0.0
				Mn-54	< 361.0	361.0	223.0

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 862

Survey Package C0200 SYSTEMS

Waste Solidification System

UNIT : 01 SURFACE : T03 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Tank
SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP32	PET00050	1.0	1200	Co-57	< 66.4	66.4	0.0
				Co-60	2740.00	79.4	210.0
				Cs-134	< 116.0	116.0	0.0
				Cs-137	264.00	111.0	88.0
				K-40	< 987.0	987.0	0.0
				Mn-54	< 168.0	168.0	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

CHARACTERIZATION SUMMARY

SURVEY PACKAGE NUMBER :C0300

SYSTEMS

PACKAGE DESCRIPTION

Containment Spray System

SURVEY AREA DESCRIPTION

Containment Spray System

GENERAL HISTORICAL INFORMATION (Operational history, etc.)

The Containment Spray System was designed to reduce the peak pressure in containment to less than 55 psig following a postulated Loss-of-Coolant Accident (LOCA) by spraying water into the containment atmosphere. The system was capable of removing radioactive iodine released to the containment atmosphere during a LOCA by scavenging with sodium hydroxide. The system was also designed to supply water to the suction of the High Pressure Safety Injection pumps to provide the required net positive suction head.

SUMMARY OF CHARACTERIZATION ACTIVITIES

Survey units were established for the system by building and elevation as shown in the following Summary of Survey Units. The Surface(s) listing indicates the component name, survey surface code and, where applicable, the Maine Yankee system component number.

A total of 48 exposure rate measurements were collected at 6 component locations.

Beta scan surveys and direct measurements for total beta activity were not prescribed for this survey package.

Smear samples were collected from component interior surfaces to analyze for removable alpha and beta activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable tritium activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable plant-derived radionuclide activity by gamma spectroscopy at 3 survey measurement locations indicated on the results listing report.

The survey result statistical summaries, graphs and results listings are shown in the following individual reports including calibration summaries for the instruments used for each measurement type.

CHARACTERIZATION SURVEY RESULTS

- o The average and maximum exposure rate measurement results were 2.6 mR/hr and 22.9 mR/hr, respectively. The ratio of the 15 cm distance measurements to the 1 meter distance measurements ranged from 0.2 to 5.4.
- o There were 3 measurements for removable beta activity above MDA (34 dpm/100cm²) and all 3 measurements were above 100 dpm/100cm². The maximum measurement result was 39,530 dpm/100cm².
- o There was 1 measurement for removable alpha activity above MDA (8.4 dpm/100cm²) and 1 measurement above 20 dpm/100cm². The maximum measurement result was 24.7 dpm/100cm².
- o There was 1 measurement for removable tritium activity above MDA (39 dpm/100cm²). The maximum measurement result was 47.6 dpm/100cm².

CHARACTERIZATION SUMMARY

04/14/98

o Of the 3 samples analyzed by gamma spectroscopy, all samples indicated plant-derived radionuclide activity above MDA. The analysis of the samples indicated the presence of Co-60, Cs-134 and Cs-137.

REFERENCES (Documents, Interviews)

Maine Yankee Drawing 1150 - FM - 92 A
Operator System Training Manual, Chapter 8



Maine Yankee Atomic Power Plant Site Characterization

SUMMARY OF SURVEY UNIT(S)

04/14/98

OUTPUT BATCH SN = 838

PACKAGE C0300 SYSTEMS

Containment Spray System

UNIT(S)	SURFACE(S)
01 - Spray Building Components	P01 (Pump P-61A discharge piping) P02 (Pump P-61B discharge piping) P03 (Pump P-61S discharge piping) U01 (Containment spray pump P-61A (pump removed)) U02 (Containment spray pump P-61S) U03 (Containment spray pump P-61B (pump is removed))
02 - Yard Components	T01 (Refueling water storage tank TK-4) T02 (Spray chemical addition tank TK-54)
03 - -2' Containment Annulus Components	K01 (Containment safeguards sump)

REASON(S) CHARACTERIZATION SURVEY (C01)

MATERIALS	MAT'L CODE	MATERIAL DESCRIPTION	BETA BKGD (dpm/100 cm ²)
	G0031	METAL - BARE (GAMMA)	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package C0300 SYSTEMS

Containment Spray System


STATISTICAL SUMMARY

TESTS PERFORMED

	$\mu\text{R/hr}$
Mean	2,592.8
Maximum	22,861.6
Minimum	201.4
Standard Deviation	4,192.2

Samples reported satisfy samples prescribed	YES
---	-----

Samples Reported	48
Samples Prescribed	48



48 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package : C0300 SYSTEMS

Containment Spray System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
544 (2)	01	U01	G0031	C01	60.00	00001	454.9
544 (2)	01	U01	G0031	C01	60.00	00002	415.6
544 (2)	01	U01	G0031	C01	60.00	00003	510.0
544 (2)	01	U01	G0031	C01	60.00	00004	345.9
544 (2)	01	U01	G0031	C01	60.00	00005	586.6
544 (2)	01	U01	G0031	C01	60.00	00006	516.9
544 (2)	01	U01	G0031	C01	60.00	00007	410.6
544 (2)	01	U01	G0031	C01	60.00	00008	377.8
536 (2)	01	U02	G0031	C01	0.00	00001	<u>1127.1</u>
536 (2)	01	U02	G0031	C01	0.00	00002	<u>1011.2</u>
536 (2)	01	U02	G0031	C01	0.00	00003	<u>1131.2</u>
536 (2)	01	U02	G0031	C01	0.00	00004	<u>1948.0</u>
536 (2)	01	U02	G0031	C01	0.00	00005	<u>3093.0</u>
536 (2)	01	U02	G0031	C01	0.00	00006	<u>4757.6</u>
536 (2)	01	U02	G0031	C01	0.00	00007	<u>1604.7</u>
536 (2)	01	U02	G0031	C01	0.00	00008	<u>2010.3</u>
544 (2)	01	U03	G0031	C01	60.00	00001	408.0
544 (2)	01	U03	G0031	C01	60.00	00002	201.4
544 (2)	01	U03	G0031	C01	60.00	00003	547.3
544 (2)	01	U03	G0031	C01	60.00	00004	253.7
544 (2)	01	U03	G0031	C01	60.00	00005	585.3
544 (2)	01	U03	G0031	C01	60.00	00006	234.9
544 (2)	01	U03	G0031	C01	60.00	00007	444.7
544 (2)	01	U03	G0031	C01	60.00	00008	314.9

REMAINING RESULTS PRINTED ON NEXT PAGE

NOTES: Exposure rates reported in net μ R/hr. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 μ R/hr.



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package: C0300 SYSTEMS

Containment Spray System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
536 (2)	02	T01	G0031	C01	0.00	00001	<u>16787.8</u>
536 (2)	02	T01	G0031	C01	0.00	00002	<u>3086.4</u>
536 (2)	02	T01	G0031	C01	0.00	00003	<u>4364.6</u>
536 (2)	02	T01	G0031	C01	0.00	00004	<u>22861.6</u>
536 (2)	02	T01	G0031	C01	0.00	00005	<u>4927.8</u>
536 (2)	02	T01	G0031	C01	0.00	00006	<u>1611.3</u>
536 (2)	02	T01	G0031	C01	0.00	00007	<u>11950.3</u>
536 (2)	02	T01	G0031	C01	0.00	00008	<u>4239.0</u>
536 (2)	02	T02	G0031	C01	0.00	00001	<u>2579.6</u>
536 (2)	02	T02	G0031	C01	0.00	00002	<u>3343.6</u>
544 (2)	02	T02	G0031	C01	60.00	00003	<u>389.6</u>
544 (2)	02	T02	G0031	C01	60.00	00004	<u>527.8</u>
544 (2)	02	T02	G0031	C01	60.00	00005	<u>241.0</u>
544 (2)	02	T02	G0031	C01	60.00	00006	<u>308.8</u>
536 (2)	02	T02	G0031	C01	0.00	00007	<u>2264.9</u>
536 (2)	02	T02	G0031	C01	0.00	00008	<u>1322.8</u>
582 (2)	03	K01	G0031	C01	0.00	00001	<u>1747.0</u>
582 (2)	03	K01	G0031	C01	0.00	00002	<u>2398.0</u>
582 (2)	03	K01	G0031	C01	0.00	00003	<u>2214.3</u>
582 (2)	03	K01	G0031	C01	0.00	00004	<u>2609.4</u>
582 (2)	03	K01	G0031	C01	0.00	00005	<u>2330.5</u>
582 (2)	03	K01	G0031	C01	0.00	00006	<u>2874.8</u>
582 (2)	03	K01	G0031	C01	0.00	00007	<u>2750.1</u>
582 (2)	03	K01	G0031	C01	0.00	00008	<u>3430.0</u>

NOTES: Exposure rates reported in net $\mu\text{R/hr}$. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 $\mu\text{R/hr}$.
 48 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DOWNLOAD FILE & SURVEY INSTRUMENTATION CALIBRATION SUMMARY

04/14/98

Exposure Rate Measurements

Survey Package : C0300 SYSTEMS

Containment Spray System

SURVEY DATE	FILE #	M2350		DETECTOR			TECHNICIAN
		INST S/N	CAL DUE	MODEL	S/N	CAL DUE	
2/4/98	536 (2)	126185	3/20/98	44-38	075082	7/23/98	JFM0682
CALIBRATION DATES VERIFIED AS ACCEPTABLE							
2/4/98	544 (2)	126197	3/22/98	44-2	PR126922	4/19/98	JFM0682
CALIBRATION DATES VERIFIED AS ACCEPTABLE							
2/10/98	582 (2)	095348	3/20/98	44-38	088919	7/23/98	JFM0682
CALIBRATION DATES VERIFIED AS ACCEPTABLE							




Maine Yankee Atomic Power Plant Site Characterization
Exposure Rate Distance Ratios

SURVEY PACKAGE C0300

Package Number	Component Number	Component Description	Direction	15 cm mR/hr	1 meter mR/hr	Ratio of 15 cm to 1 meter
C0300	01U01	Containment spray pump P-61A (pump removed)	North	0.5	0.4	1.1
			East	0.5	0.3	1.5
			South	0.6	0.5	1.1
			West	0.4	0.4	1.1
C0300	01U02	Containment spray pump P-61S	North	1.1	1.0	1.1
			East	1.1	1.9	0.6
			South	3.1	4.8	0.7
			West	1.6	2.0	0.8
C0300	01U03	Containment spray pump P-61B (pump is removed)	North	0.4	0.2	2.0
			East	0.5	0.3	2.2
			South	0.6	0.2	2.5
			West	0.4	0.3	1.4
C0300	02T01	Refueling water storage tank TK-4	North	16.8	3.1	5.4
			East	4.4	22.9	0.2
			South	4.9	1.6	3.1
			West	12.0	4.2	2.8
C0300	02T02	Spray chemical addition tank TK-54	North	2.6	3.3	0.8
			East	0.4	0.5	0.7
			South	0.2	0.3	0.8
			West	2.3	1.3	1.7
C0300	03K01	Containment safeguards sump	North	1.7	2.4	0.7
			East	2.2	2.6	0.8
			South	2.3	2.9	0.8
			West	2.8	3.4	0.8

Exposure Rates - 15 cm and 1 meter





Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Gross Beta Activity

Survey Package C0300 SYSTEMS

Containment Spray System


STATISTICAL SUMMARY

TESTS PERFORMED

	Net dpm/100 cm ²
Mean	25,185.4
Maximum	39,529.8
Minimum	10,796.4
Standard Deviation	14,366.8
MDA	33.8

MDA <100 net dpm/100 cm ²	YES
Results above 100 net dpm/100 cm ²	3
Number of results above MDA	3

Samples Reported	3
Samples Prescribed	9



3 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Gross Alpha Activity

Survey Package C0300 SYSTEMS

Containment Spray System


STATISTICAL SUMMARY

TESTS PERFORMED

	Net dpm/100 cm ²
Mean	11.5
Maximum	24.7
Minimum	3.9
Standard Deviation	11.5
MDA	8.4

MDA <10 net dpm/100 cm ²	YES
Results above 20 net dpm/100 cm ²	1
Number of results above MDA	1

Samples Reported	3
Samples Prescribed	9



3 RESULTS ARE GRAPHED

Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination

Survey Package: C0300 SYSTEMS

Containment Spray System

RESULTS LISTING - SORTED BY SURFACE CODE

XLS FILE	UNIT	SURFACE	REASON	MSRMNT LOCATION	ALPHA	BETA
SME1E111.XLS	01	P03	C01	1	<u>24.7</u>	<u>39,529.8</u>
SME1E113.XLS	01	P02	C01	1	3.9	<u>25,230.1</u>
SME1E115.XLS	01	P01	C01	1	6.0	<u>10,796.4</u>

NOTES: Activity reported in net dpm/100 cm².

Underlined values exceed the associated MDA.

Bold values exceed 100.00 dpm/100 cm² (beta activity) and/or 20.00 dpm/100 cm² (alpha activity).

3 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DATAFILE & ALPHA - BETA COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination

Survey Package: C0300 SYSTEMS

Containment Spray System

SURVEYDATE	XLS FILE	INST ID	S/N	CAL DUE	LAB TECHNICIAN
3/16/98	SME1E111.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/16/98	SME1E113.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/16/98	SME1E115.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					

Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Tritium Activity

Survey Package: C0300 SYSTEMS

Containment Spray System

RESULTS LISTING - SORTED BY SURFACE CODE

SAMPLE ID	SAMPLE TYPE	UNIT	SURF	REASN	MSRMNT LOCATION	MDA	TRITIUM ACTIVITY
D29	Hoppes patch	01	P01	C01	00001	39.1	-6.4
D30	Hoppes patch	01	P02	C01	00001	38.8	<u>47.6</u>
D31	Hoppes patch	01	P03	C01	00001	39.0	14.0

NOTES: Activity reported in net dpm/100 cm².
 Underlined values exceed the associated MDA.
 Bold values exceed 75 dpm/100 cm²,
 Italic values exceed 100 dpm/100 cm².



Maine Yankee Atomic Power Plant Site Characterization

LIQUID SCINTILLATION COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination - Tritium Activity

Survey Package : C0300 SYSTEMS

Containment Spray System

SURVEYDATE	INSTRUMENT	MODEL	S/N	CAL DUE	LAB TECHNICIAN
3/5/98	Packard	2750	416221	6/16/98	LDT

CALIBRATION DATE VERIFIED AS ACCEPTABLE



Maine Yankee Atomic Power Plant Site Characterization

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 838

Survey Package C0300 SYSTEMS

Containment Spray System

UNIT : 01 SURFACE : P01 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Plant Piping (interior)
SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP35	PET00053	1.0	1200	Co-57	< 65.2	65.2	0.0
				Co-60	1070.00	66.5	117.0
				Cs-134	< 139.0	139.0	0.0
				Cs-137	1640.00	116.0	197.0
				K-40	< 610.0	610.0	0.0
				Mn-54	< 117.0	117.0	0.0

UNIT : 01 SURFACE : P02 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Plant Piping (interior)
SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP36	PET00054	1.0	1200	Co-57	< 0.0	0.0	0.0
				Co-60	2690.00	0.0	207.0
				Cs-134	137.00	0.0	86.8
				Cs-137	1850.00	0.0	214.0
				K-40	< 0.0	0.0	0.0
				Mn-54	< 0.0	0.0	0.0

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 838

Survey Package C0300 SYSTEMS

Containment Spray System

UNIT : 01 SURFACE : P03 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Plant Piping (interior)
SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYD087	PET00024	1.0	1200	Co-57	< 96.6	96.6	0.0
				Co-60	10900.00	178.0	606.0
				Cs-134	< 257.0	257.0	0.0
				Cs-137	1310.00	333.0	258.0
				K-40	< 849.0	849.0	0.0
				Mn-54	< 305.0	305.0	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

CHARACTERIZATION SUMMARY

SURVEY PACKAGE NUMBER :C0400

SYSTEMS

PACKAGE DESCRIPTION

Emergency Core Cooling System

SURVEY AREA DESCRIPTION

Emergency Core Cooling System

GENERAL HISTORICAL INFORMATION (Operational history, etc.)

The Emergency Core Cooling System was designed to inject borated water to cool the reactor core in the event of a Loss-Of-Coolant Accident (LOCA). The injected borated water would have provided negative reactivity in the event of a Steam Line Rupture (SLR) accident and post-accident core cooling.

SUMMARY OF CHARACTERIZATION ACTIVITIES

Survey units were established for the system by building and elevation as shown in the following Summary of Survey Units. The Surface(s) listing indicates the component name, survey surface code and, where applicable, the Maine Yankee system component number.

A total of 56 exposure rate measurements were collected at 7 component locations.

Beta scan surveys and direct measurements for total beta activity were not prescribed for this survey package.

Smear samples were collected from component interior surfaces to analyze for removable alpha and beta activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable tritium activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable plant-derived radionuclide activity by gamma spectroscopy at 3 survey measurement locations indicated on the results listing report.

The survey result statistical summaries, graphs and results listings are shown in the following individual reports including calibration summaries for the instruments used for each measurement type.

CHARACTERIZATION SURVEY RESULTS

- o The average and maximum exposure rate measurement results were 4.4 mR/hr and 34.7 mR/hr, respectively. The ratio of the 15 cm distance measurements to the 1 meter distance measurements ranged from 0.2 to 2.8.
- o There were 3 measurements for removable beta activity above MDA (maximum MDA was 5,000 dpm/100cm²). The maximum measurement result was 200,000 dpm/100cm².
- o 2 of the 3 smear measurements were analyzed for removable alpha activity and no measurements were above MDA (8.4 dpm/100cm²).
- o There were 2 measurements for removable tritium activity above MDA (maximum MDA was 139 dpm/100cm²). The maximum measurement result was 3,597 dpm/100cm².
- o Of the 3 samples analyzed by gamma spectroscopy, all samples indicated plant-derived radionuclide activity above MDA. The analysis of the samples indicated the presence of Co-60, Cs-134, Cs-137 and Mn-54.

CHARACTERIZATION SUMMARY

04/14/98

REFERENCES (Documents, Interviews)

Maine Yankee Drawing 1150 - FM - 91 B, 92 A
Operator System Training Manual, Chapter 6



Maine Yankee Atomic Power Plant Site Characterization

SUMMARY OF SURVEY UNIT(S)

04/14/98

OUTPUT BATCH SN = 839

PACKAGE C0400 SYSTEMS

Emergency Core Cooling System

UNIT(S)	SURFACE(S)
01 - 11' Primary Auxiliary Building Components	U01 (Auxiliary charging pump P-7)
02 - 21' Primary Auxiliary Building Components	U01 (HPSI pump P-14A) U02 (HPSI pump P-14B) V01 (Valve CH-10) V02 (Valve HSI-S-46)
03 - Spray Building Components	U01 (LPSI pump P-12B) V01 (Valve LSI-56)
04 - -2' Containment Building Components	T01 (Safety injection tank TK-53-1 (loop 1)) T02 (Safety injection tank TK-53-2 (loop 2)) T03 (Safety injection tank TK-53-3 (loop 3))

REASON(S) CHARACTERIZATION SURVEY (C01)

MATERIALS	MAT'L CODE	MATERIAL DESCRIPTION	BETA BKGD (dpm/100 cm ²)
	G0031	METAL - BARE (GAMMA)	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package C0400 SYSTEMS

Emergency Core Cooling System


STATISTICAL SUMMARY

TESTS PERFORMED

	$\mu\text{R/hr}$
Mean	4,416.1
Maximum	34,690.7
Minimum	369.6
Standard Deviation	6,025.6

Samples reported satisfy samples prescribed	YES
---	-----

Samples Reported	56
Samples Prescribed	56



56 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package: C0400 SYSTEMS

Emergency Core Cooling System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
531 (2)	01	U01	G0031	C01	60.00	00001	615.9
531 (2)	01	U01	G0031	C01	60.00	00002	576.6
531 (2)	01	U01	G0031	C01	60.00	00003	512.3
531 (2)	01	U01	G0031	C01	60.00	00004	590.0
531 (2)	01	U01	G0031	C01	60.00	00005	406.4
531 (2)	01	U01	G0031	C01	60.00	00006	479.0
531 (2)	01	U01	G0031	C01	60.00	00007	1166.3
530 (2)	01	U01	G0031	C01	0.00	00008	<u>1280.7</u>
531 (2)	02	U01	G0031	C01	60.00	00001	823.5
531 (2)	02	U01	G0031	C01	60.00	00002	369.6
531 (2)	02	U01	G0031	C01	60.00	00003	968.9
531 (2)	02	U01	G0031	C01	60.00	00004	390.1
531 (2)	02	U01	G0031	C01	60.00	00005	1255.6
531 (2)	02	U01	G0031	C01	60.00	00006	451.9
531 (2)	02	U01	G0031	C01	60.00	00007	697.6
531 (2)	02	U01	G0031	C01	60.00	00008	447.5
530 (2)	02	U02	G0031	C01	0.00	00001	<u>4895.7</u>
530 (2)	02	U02	G0031	C01	0.00	00002	<u>3079.1</u>
530 (2)	02	U02	G0031	C01	0.00	00003	<u>2783.9</u>
530 (2)	02	U02	G0031	C01	0.00	00004	<u>4329.4</u>
530 (2)	02	U02	G0031	C01	0.00	00005	<u>2409.4</u>
530 (2)	02	U02	G0031	C01	0.00	00006	<u>2128.5</u>
530 (2)	02	U02	G0031	C01	0.00	00007	<u>2397.0</u>
530 (2)	02	U02	G0031	C01	0.00	00008	<u>1602.6</u>
668 (2)	03	U01	G0031	C01	0.00	00001	<u>1089.0</u>
668 (2)	03	U01	G0031	C01	0.00	00002	871.7
668 (2)	03	U01	G0031	C01	0.00	00003	1799.0
668 (2)	03	U01	G0031	C01	0.00	00004	1147.9
668 (2)	03	U01	G0031	C01	0.00	00005	1930.5
668 (2)	03	U01	G0031	C01	0.00	00006	1656.8
668 (2)	03	U01	G0031	C01	0.00	00007	2127.5
668 (2)	03	U01	G0031	C01	0.00	00008	1387.0
666 (2)	04	T01	G0031	C01	0.00	00001	5175.6
666 (2)	04	T01	G0031	C01	0.00	00002	4761.0
666 (2)	04	T01	G0031	C01	0.00	00003	2465.8
666 (2)	04	T01	G0031	C01	0.00	00004	9093.9
666 (2)	04	T01	G0031	C01	0.00	00005	3903.4
666 (2)	04	T01	G0031	C01	0.00	00006	16037.2
666 (2)	04	T01	G0031	C01	0.00	00007	8594.7
666 (2)	04	T01	G0031	C01	0.00	00008	11478.8

NOTES: Exposure rates reported in net $\mu\text{R/hr}$. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 $\mu\text{R/hr}$.



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package: C0400 SYSTEMS

Emergency Core Cooling System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
666 (2)	04	T02	G0031	C01	0.00	00001	6802.5
666 (2)	04	T02	G0031	C01	0.00	00002	<u>5630.7</u>
666 (2)	04	T02	G0031	C01	0.00	00003	<u>1620.5</u>
666 (2)	04	T02	G0031	C01	0.00	00004	<u>2116.9</u>
666 (2)	04	T02	G0031	C01	0.00	00005	<u>1663.6</u>
666 (2)	04	T02	G0031	C01	0.00	00006	<u>3751.0</u>
666 (2)	04	T02	G0031	C01	0.00	00007	<u>5411.6</u>
666 (2)	04	T02	G0031	C01	0.00	00008	<u>6088.2</u>
666 (2)	04	T03	G0031	C01	0.00	00001	<u>15176.1</u>
666 (2)	04	T03	G0031	C01	0.00	00002	<u>15198.9</u>
666 (2)	04	T03	G0031	C01	0.00	00003	<u>1712.3</u>
666 (2)	04	T03	G0031	C01	0.00	00004	<u>2078.2</u>
666 (2)	04	T03	G0031	C01	0.00	00005	<u>10133.1</u>
666 (2)	04	T03	G0031	C01	0.00	00006	<u>8192.1</u>
666 (2)	04	T03	G0031	C01	0.00	00007	<u>18855.4</u>
666 (2)	04	T03	G0031	C01	0.00	00008	<u>34690.7</u>

NOTES: Exposure rates reported in net $\mu\text{R/hr}$. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 $\mu\text{R/hr}$.
 56 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DOWNLOAD FILE & SURVEY INSTRUMENTATION CALIBRATION SUMMARY

04/14/98

Exposure Rate Measurements

Survey Package : C0400 SYSTEMS

Emergency Core Cooling System

SURVEY DATE	FILE #	M2350		DETECTOR			TECHNICIAN
		INST S/N	CAL DUE	MODEL	S/N	CAL DUE	
2/3/98	530 (2)	095348	3/20/98	44-38	088919	7/23/98	MAP5535
CALIBRATION DATES VERIFIED AS ACCEPTABLE							
2/3/98	531 (2)	126182	3/22/98	44-2	128338	4/19/98	MAP5535
CALIBRATION DATES VERIFIED AS ACCEPTABLE							
3/18/98	666 (2)	126185	3/20/98	44-38	075082	7/23/98	AOK2982
CALIBRATION DATES VERIFIED AS ACCEPTABLE							
3/18/98	668 (2)	95348	3/20/98	44-38	088919	7/23/98	AOK2982
CALIBRATION DATES VERIFIED AS ACCEPTABLE							



Maine Yankee Atomic Power Plant Site Characterization
Exposure Rate Distance Ratios


SURVEY PACKAGE C0400

Package Number	Component Number	Component Description	Direction	15 cm mR/hr	1 meter mR/hr	Ratio of 15 cm to 1 meter
C0400	01U01	Auxiliary charging pump P-7	North	0.6	0.6	1.1
			East	0.5	0.6	0.9
			South	0.4	0.5	0.8
			West	1.2	1.3	0.9
C0400	02U01	HPSI pump P-14A	North	0.8	0.4	2.2
			East	1.0	0.4	2.5
			South	1.3	0.5	2.8
			West	0.7	0.4	1.6
C0400	02U02	HPSI pump P-14B	North	4.9	3.1	1.6
			East	2.8	4.3	0.6
			South	2.4	2.1	1.1
			West	2.4	1.6	1.5
C0400	03U01	LPSI pump P-12B	North	1.1	0.9	1.2
			East	1.8	1.1	1.6
			South	1.9	1.7	1.2
			West	2.1	1.4	1.5
C0400	04T01	Safety Injection tank TK-53-1 (loop 1)	North	5.2	4.8	1.1
			East	2.5	9.1	0.3
			South	3.9	16.0	0.2
			West	8.6	11.5	0.7
C0400	04T02	Safety injection tank TK-53-2 (loop 2)	North	6.8	5.6	1.2
			East	1.6	2.1	0.8
			South	1.7	3.8	0.4
			West	5.4	6.1	0.9
C0400	04T03	Safety Injection tank TK-53-3 (loop 3)	North	15.2	15.2	1.0
			East	1.7	2.1	0.8
			South	10.1	8.2	1.2
			West	18.9	34.7	0.5

Maine Yankee Atomic Power Plant Site Characterization
Exposure Rate Distance Ratios

SURVEY PACKAGE C0400

Exposure Rates - 15 cm and 1 meter





Maine Yankee Atomic Power Plant Site Characterization

04/14/98 Removable Contamination - Gross Beta Activity

Survey Package C0400 SYSTEMS

Emergency Core Cooling System


STATISTICAL SUMMARY

TESTS PERFORMED

	Net dpm/100 cm ²
Mean	70,933.3
Maximum	200,000.0
Minimum	5,873.7
Standard Deviation	111,776.3
MDA	5,000.0

MDA <100 net dpm/100 cm ²	NO
Results above 100 net dpm/100 cm ²	3
Number of results above MDA	3

Samples Reported	3
Samples Prescribed	9



3 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Gross Alpha Activity

Survey Package C0400 SYSTEMS

Emergency Core Cooling System


STATISTICAL SUMMARY

TESTS PERFORMED

	Net dpm/100 cm ²
Mean	3.3
Maximum	5.9
Minimum	
Standard Deviation	3.0
MDA	8.4

MDA <10 net dpm/100 cm ²	YES
Results above 20 net dpm/100 cm ²	0
Number of results above MDA	0

Samples Reported	3
Samples Prescribed	9



3 RESULTS ARE GRAPHED

Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination

Survey Package: C0400 SYSTEMS

Emergency Core Cooling System

RESULTS LISTING - SORTED BY SURFACE CODE

XLS FILE	UNIT	SURFACE	REASON	MSRMNT LOCATION	ALPHA	BETA
SME1E119.XLS	03	V01	C01	1	3.9	<u>6,926.4</u>
SME1E117.XLS	02	V02	C01	1	6.0	<u>5,873.7</u>
RM-14DATA3	02	V01	C01	1		<u>200,000.0</u>

NOTES: Activity reported in net dpm/100 cm².
 Underlined values exceed the associated MDA.
 Bold values exceed 100.00 dpm/100 cm² (beta activity) and/or 20.00 dpm/100 cm² (alpha activity).
 3 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DATAFILE & ALPHA - BETA COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination

Survey Package: C0400 SYSTEMS

Emergency Core Cooling System

SURVEYDATE	XLS FILE	INST ID	S/N	CAL DUE	LAB TECHNICIAN
3/28/98	RM-14DATA3	3	8263	5/26/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/16/98	SME1E117.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/16/98	SME1E119.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					

Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Tritium Activity

Survey Package: C0400 SYSTEMS

Emergency Core Cooling System

RESULTS LISTING - SORTED BY SURFACE CODE

SAMPLE ID	SAMPLE TYPE	UNIT	SURF	REASN	MSRMNT LOCATION	MDA	TRITIUM ACTIVITY
D32	Hoppes patch	03	V01	C01	00001	38.9	-5.2
D62	Hoppes patch	02	V01	C01	00001	138.9	<u>3,596.9</u>
D63	Hoppes patch	02	V02	C01	00001	138.9	<u>542.1</u>

NOTES: Activity reported in net dpm/100 cm².
 Underlined values exceed the associated MDA.
 Bold values exceed 75 dpm/100 cm²,
 Italic values exceed 100 dpm/100 cm².



Maine Yankee Atomic Power Plant Site Characterization

LIQUID SCINTILLATION COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination - Tritium Activity

Survey Package : C0400 SYSTEMS

Emergency Core Cooling System

SURVEYDATE	INSTRUMENT	MODEL	S/N	CAL DUE	LAB TECHNICIAN
3/5/98	Packard	2750	416221	6/16/98	LDT
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
4/6/98	Packard	2750	416221	6/16/98	LDT
CALIBRATION DATE VERIFIED AS ACCEPTABLE					



Maine Yankee Atomic Power Plant Site Characterization

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 839

Survey Package C0400 SYSTEMS

Emergency Core Cooling System

UNIT : 02 SURFACE : V01 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
 SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP20	PET00037	1.0	1200	Co-57	< 261.0	261.0	0.0
				Co-60	45000.00	499.0	6,330.0
				Cs-134	< 609.0	609.0	0.0
				Cs-137	< 788.0	788.0	0.0
				K-40	< 1450.0	1,450.0	0.0
				Mn-54	2260.00	849.0	548.0

UNIT : 02 SURFACE : V02 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
 SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP19	PET00025	1.0	1200	Co-57	< 54.3	54.3	0.0
				Co-60	1360.00	66.5	147.0
				Cs-134	< 83.1	83.1	0.0
				Cs-137	< 132.0	132.0	0.0
				K-40	< 849.0	849.0	0.0
				Mn-54	< 115.0	115.0	0.0

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 839

Survey Package C0400 SYSTEMS

Emergency Core Cooling System

UNIT : 03 SURFACE : V01 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP004	PET00007	1.0	1200	Co-57	< 63.2	63.2	0.0
				Co-60	848.00	78.7	105.0
				Cs-134	337.00	97.4	66.6
				Cs-137	1610.00	72.6	267.0
				K-40	< 799.0	799.0	0.0
				Mn-54	< 92.4	92.4	0.0



Maine Yankee Atomic Power Plant Site Characterization

 CHARACTERIZATION SUMMARY

04/14/98

SURVEY PACKAGE NUMBER :C0500

SYSTEMS

PACKAGE DESCRIPTION

Residual Heat Removal System

SURVEY AREA DESCRIPTION

Residual Heat Removal System (RHR)

 GENERAL HISTORICAL INFORMATION (Operational history, etc.)

The Residual Heat Removal System (RHR) reduced the temperature of the Reactor Coolant System (RCS) during cool-down operations. The RHR system was designed to reduce RCS temperature from 400 F to a refueling temperature of 125 F in 24 hours. It provided reactor coolant circulation for core decay heat removal in the cold shutdown and refueling modes.

 SUMMARY OF CHARACTERIZATION ACTIVITIES

Survey units were established for the system by building and elevation as shown in the following Summary of Survey Units. The Surface(s) listing indicates the component name, survey surface code and, where applicable, the Maine Yankee system component number.

A total of 44 exposure rate measurements were collected at 6 component locations.

Beta scan surveys and direct measurements for total beta activity were not prescribed for this survey package.

Smear samples were collected from component interior surfaces to analyze for removable alpha and beta activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable tritium activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable plant-derived radionuclide activity by gamma spectroscopy at 3 survey measurement locations indicated on the results listing report.

The survey result statistical summaries, graphs and results listings are shown in the following individual reports including calibration summaries for the instruments used for each measurement type.

 CHARACTERIZATION SURVEY RESULTS

- o The average and maximum exposure rate measurement results were 4.9 mR/hr and 15.8 mR/hr, respectively. The ratio of the 15 cm distance measurements to the 1 meter distance measurements ranged from 0.9 to 2.6.
- o There were 3 measurements for removable beta activity above MDA (maximum MDA was 5,000 dpm/100cm²). The maximum measurement result was 180,000 dpm/100cm².
- o None of the 3 smear measurements were analyzed for removable alpha activity.
- o There were 2 measurements for removable tritium activity above MDA (138.9 dpm/100cm²). The maximum measurement result was 58,475 dpm/100cm².
- o Of the 3 samples analyzed by gamma spectroscopy, all samples indicated plant-derived radionuclide activity above MDA. The analysis of the samples indicated the presence of Co-58, Co-60, and Sb-125.

CHARACTERIZATION SUMMARY

04/14/98

REFERENCES (Documents, Interviews)

Maine Yankee Drawing 1150 - FM - 92 A
Operator System Training Manual, Chapter 7



Maine Yankee Atomic Power Plant Site Characterization

SUMMARY OF SURVEY UNIT(S)

04/14/98

OUTPUT BATCH SN = 840

PACKAGE C0500 SYSTEMS

Residual Heat Removal System

UNIT(S)	SURFACE(S)
01 - 21' Spray Building Components	H01 (RHR heat exchanger E-3B) H02 (RHR heat exchanger E-3A)
02 - 13' Containment Building Loop 2 Components	V01 (Valve RH-S-24)
03 - 21' Spray Building Components	V01 (Valve RH-20) V02 (Valve RH-21)
04 - 12' Spray Building Components	V01 (Valve RH-T-12) V02 (Valve RH-11) V03 (Valve LSI-S-63) V04 (Valve LSI-35)

REASON(S) CHARACTERIZATION SURVEY (C01)

MATERIALS	MAT'L CODE	MATERIAL DESCRIPTION	BETA BKGD (dpm/100 cm ²)
	G0031	METAL - BARE (GAMMA)	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package C0500 SYSTEMS

Residual Heat Removal System


STATISTICAL SUMMARY

TESTS PERFORMED

	$\mu\text{R/hr}$
Mean	4,881.6
Maximum	15,772.4
Minimum	1,182.4
Standard Deviation	4,111.9

Samples reported satisfy samples prescribed YES

Samples Reported	44
Samples Prescribed	44



44 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package : C0500 SYSTEMS

Residual Heat Removal System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
668 (2)	01	H01	G0031	C01	0.00	00001	<u>1596.2</u>
668 (2)	01	H01	G0031	C01	0.00	00002	<u>1182.4</u>
668 (2)	01	H01	G0031	C01	0.00	00003	<u>1726.9</u>
668 (2)	01	H01	G0031	C01	0.00	00004	<u>1262.3</u>
668 (2)	01	H01	G0031	C01	0.00	00005	<u>4786.2</u>
668 (2)	01	H01	G0031	C01	0.00	00006	<u>2230.5</u>
668 (2)	01	H01	G0031	C01	0.00	00007	<u>2803.5</u>
668 (2)	01	H01	G0031	C01	0.00	00008	<u>2218.5</u>
668 (2)	01	H02	G0031	C01	0.00	00001	<u>7099.7</u>
668 (2)	01	H02	G0031	C01	0.00	00002	<u>3170.2</u>
668 (2)	01	H02	G0031	C01	0.00	00003	<u>9420.3</u>
668 (2)	01	H02	G0031	C01	0.00	00004	<u>3609.4</u>
668 (2)	01	H02	G0031	C01	0.00	00005	<u>8517.7</u>
668 (2)	01	H02	G0031	C01	0.00	00006	<u>4005.5</u>
668 (2)	01	H02	G0031	C01	0.00	00007	<u>10343.4</u>
668 (2)	01	H02	G0031	C01	0.00	00008	<u>4383.1</u>
668 (2)	03	V01	G0031	C01	0.00	00001	<u>1410.4</u>
668 (2)	03	V01	G0031	C01	0.00	00002	<u>1301.0</u>
668 (2)	03	V01	G0031	C01	0.00	00003	<u>1581.6</u>
668 (2)	03	V01	G0031	C01	0.00	00004	<u>1395.2</u>
668 (2)	03	V01	G0031	C01	0.00	00005	<u>2605.9</u>
668 (2)	03	V01	G0031	C01	0.00	00006	<u>1657.3</u>

REMAINING RESULTS PRINTED ON NEXT PAGE

NOTES: Exposure rates reported in net $\mu\text{R/hr}$. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 $\mu\text{R/hr}$.

Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package : C0500 SYSTEMS

Residual Heat Removal System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
668 (2)	03	V02	G0031	C01	0.00	00001	<u>5014.7</u>
668 (2)	03	V02	G0031	C01	0.00	00002	<u>3549.9</u>
668 (2)	03	V02	G0031	C01	0.00	00003	<u>5263.8</u>
668 (2)	03	V02	G0031	C01	0.00	00004	<u>3342.5</u>
668 (2)	03	V02	G0031	C01	0.00	00005	<u>5265.4</u>
668 (2)	03	V02	G0031	C01	0.00	00006	<u>5951.8</u>
668 (2)	04	V01	G0031	C01	0.00	00001	<u>2152.7</u>
668 (2)	04	V01	G0031	C01	0.00	00002	<u>1967.6</u>
668 (2)	04	V01	G0031	C01	0.00	00003	<u>2094.7</u>
668 (2)	04	V01	G0031	C01	0.00	00004	<u>1586.3</u>
668 (2)	04	V01	G0031	C01	0.00	00005	<u>1855.2</u>
668 (2)	04	V01	G0031	C01	0.00	00006	<u>1402.6</u>
668 (2)	04	V01	G0031	C01	0.00	00007	<u>1917.5</u>
668 (2)	04	V01	G0031	C01	0.00	00008	<u>1554.4</u>
668 (2)	04	V02	G0031	C01	0.00	00001	<u>15772.4</u>
668 (2)	04	V02	G0031	C01	0.00	00002	<u>15284.8</u>
668 (2)	04	V02	G0031	C01	0.00	00003	<u>12173.5</u>
668 (2)	04	V02	G0031	C01	0.00	00004	<u>12697.8</u>
668 (2)	04	V02	G0031	C01	0.00	00005	<u>11667.8</u>
668 (2)	04	V02	G0031	C01	0.00	00006	<u>8814.7</u>
668 (2)	04	V02	G0031	C01	0.00	00007	<u>11047.8</u>
668 (2)	04	V02	G0031	C01	0.00	00008	<u>6104.8</u>

NOTES: Exposure rates reported in net $\mu\text{R/hr}$. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 $\mu\text{R/hr}$.
 44 results are listed.

Maine Yankee Atomic Power Plant Site Characterization

DOWNLOAD FILE & SURVEY INSTRUMENTATION CALIBRATION SUMMARY

04/14/98

Exposure Rate Measurements

Survey Package : C0500 SYSTEMS

Residual Heat Removal System

SURVEY DATE	FILE #	M2350		DETECTOR			TECHNICIAN
		INST S/N	CAL DUE	MODEL	S/N	CAL DUE	
3/18/98	668 (2)	95348	3/20/98	44-38	088919	7/23/98	AOK2982

CALIBRATION DATES VERIFIED AS ACCEPTABLE




Maine Yankee Atomic Power Plant Site Characterization
Exposure Rate Distance Ratios

SURVEY PACKAGE C0500

Package Number	Component Number	Component Description	Direction	15 cm mR/hr	1 meter mR/hr	Ratio of 15 cm to 1 meter
C0500	01H01	RHR heat exchanger E-3B	North	1.6	1.2	1.4
			East	1.7	1.3	1.4
			South	4.8	2.2	2.1
			West	2.8	2.2	1.3
C0500	01H02	RHR heat exchanger E-3A	North	7.1	3.2	2.2
			East	9.4	3.6	2.6
			South	8.5	4.0	2.1
			West	10.3	4.4	2.4
C0500	03V01	Valve RH-20	North	1.4	1.3	1.1
			East	1.6	1.4	1.1
			South	2.6	1.7	1.6
C0500	03V02	Valve RH-21	North	5.0	3.5	1.4
			East	5.3	3.3	1.6
			South	5.3	6.0	0.9
C0500	04V01	Valve RH-T-12	North	2.2	2.0	1.1
			East	2.1	1.6	1.3
			South	1.9	1.4	1.3
			West	1.9	1.6	1.2
C0500	04V02	Valve RH-11	North	15.8	15.3	1.0
			East	12.2	12.7	1.0
			South	11.7	8.8	1.3
			West	11.0	6.1	1.8

Exposure Rates - 15 cm and 1 meter





Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Gross Beta Activity

Survey Package C0500 SYSTEMS

Residual Heat Removal System


STATISTICAL SUMMARY

TESTS PERFORMED

	Net dpm/100 cm ²
Mean	76,000.0
Maximum	180,000.0
Minimum	8,000.0
Standard Deviation	91,476.8
MDA	5,000.0

MDA <100 net dpm/100 cm ²	NO
Results above 100 net dpm/100 cm ²	3
Number of results above MDA	3

Samples Reported	3
Samples Prescribed	9



3 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination

Survey Package: C0500 SYSTEMS

Residual Heat Removal System

RESULTS LISTING - SORTED BY SURFACE CODE

XLS FILE	UNIT	SURFACE	REASON	MSRMNT LOCATION	ALPHA	BETA
RM-14DATA6	04	V04	C01	1		<u>8,000.0</u>
RM-14DATA5	04	V03	C01	1		<u>40,000.0</u>
RM-14DATA4	02	V01	C01	1		<u>180,000.0</u>

NOTES: Activity reported in net dpm/100 cm².

Underlined values exceed the associated MDA.

Bold values exceed 100.00 dpm/100 cm² (beta activity) and/or 20.00 dpm/100 cm² (alpha activity).

3 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DATAFILE & ALPHA - BETA COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination

Survey Package : C0500 SYSTEMS

Residual Heat Removal System

SURVEYDATE	XLS FILE	INST ID	S/N	CAL DUE	LAB TECHNICIAN
3/28/98	RM-14DATA4	3	8263	5/26/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/28/98	RM-14DATA5	3	8263	5/26/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/28/98	RM-14DATA6	3	8263	5/26/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Tritium Activity

Survey Package: C0500 SYSTEMS

Residual Heat Removal System

RESULTS LISTING - SORTED BY SURFACE CODE

SAMPLE ID	SAMPLE TYPE	UNIT	SURF	REASN	MSRMNT LOCATION	MDA	TRITIUM ACTIVITY
D66	Hoppes patch	02	V01	C01	00001	138.9	<u>58,475.2</u>
D67	Hoppes patch	04	V03	C01	00001	138.9	<u>12,274.8</u>
D71	Hoppes patch	04	V04	C01	00001	138.9	<u>102.1</u>

NOTES: Activity reported in net dpm/100 cm².
 Underlined values exceed the associated MDA.
 Bold values exceed 75 dpm/100 cm²,
 Italic values exceed 100 dpm/100 cm².



Maine Yankee Atomic Power Plant Site Characterization

LIQUID SCINTILLATION COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination - Tritium Activity

Survey Package : C0500 SYSTEMS

Residual Heat Removal System

SURVEYDATE	INSTRUMENT	MODEL	S/N	CAL DUE	LAB TECHNICIAN
4/6/98	Packard	2750	416221	6/16/98	LDT

CALIBRATION DATE VERIFIED AS ACCEPTABLE



Maine Yankee Atomic Power Plant Site Characterization

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 840

Survey Package C0500 SYSTEMS

Residual Heat Removal System

UNIT : 02 SURFACE : V01 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
 SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP23	PET00028	1.0	1800	Co-57	< 164.0	164.0	0.0
				Co-58	779.00	749.0	454.0
				Co-60	86400.00	303.0	3,780.0
				Cs-134	< 502.0	502.0	0.0
				Cs-137	< 529.0	529.0	0.0
				K-40	< 1250.0	1,250.0	0.0
				Mn-54	< 605.0	605.0	0.0
				Sb-125	7220.00	1,010.0	590.0

UNIT : 04 SURFACE : V03 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
 SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP25	PET00029	1.0	1800	Co-57	< 88.8	88.8	0.0
				Co-60	26600.00	252.0	0.0
				Cs-134	< 222.0	222.0	0.0
				Cs-137	< 285.0	285.0	0.0
				K-40	< 1080.0	1,080.0	0.0
				Mn-54	< 349.0	349.0	0.0

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 840

Survey Package C0500 SYSTEMS

Residual Heat Removal System

UNIT : 04 SURFACE : V04 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
 SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP29	PET00030	1.0	1800	Co-57	< 53.3	53.3	0.0
				Co-60	5630.00	108.0	329.0
				Cs-134	< 119.0	119.0	0.0
				Cs-137	< 154.0	154.0	0.0
				K-40	< 821.0	821.0	0.0
				Mn-54	< 186.0	186.0	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

CHARACTERIZATION SUMMARY

SURVEY PACKAGE NUMBER :C0600

SYSTEMS

PACKAGE DESCRIPTION

Primary Vents and Drains

SURVEY AREA DESCRIPTION

Primary Vent and Drains System

GENERAL HISTORICAL INFORMATION (Operational history, etc.)

The Primary Vent and Drains System collected radioactive and potentially radioactive gases and liquids from the Reactor Coolant System (RCS) and associated auxiliary systems for processing and disposal.

SUMMARY OF CHARACTERIZATION ACTIVITIES

Survey units were established for the system by building and elevation as shown in the following Summary of Survey Units. The Surface(s) listing indicates the component name, survey surface code and, where applicable, the Maine Yankee system component number.

A total of 27 exposure rate measurements were collected at 6 component locations.

Beta scan surveys and direct measurements for total beta activity were not prescribed for this survey package.

Smear samples were collected from component interior surfaces to analyze for removable alpha and beta activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable tritium activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable plant-derived radionuclide activity by gamma spectroscopy at 3 survey measurement locations indicated on the results listing report.

The survey result statistical summaries, graphs and results listings are shown in the following individual reports including calibration summaries for the instruments used for each measurement type.

CHARACTERIZATION SURVEY RESULTS

- o The average and maximum exposure rate measurement results were 165.6 mR/hr and 1,326 mR/hr, respectively. The ratio of the 15 cm distance measurements to the 1 meter distance measurements ranged from 1.0 to 2.2.
- o There were 3 measurements for removable beta activity above MDA (maximum MDA was 5,000 dpm/100cm²). The maximum measurement result was 140,000 dpm/100cm².
- o 2 of the 3 smear measurements were analyzed for removable alpha activity and no measurements were above MDA (8.4 dpm/100cm²).
- o There were 2 measurements for removable tritium activity above MDA (39 dpm/100cm²). The maximum measurement result was 1,535 dpm/100cm².
- o Of the 3 samples analyzed by gamma spectroscopy, all samples indicated plant-derived radionuclide activity above MDA. The analysis of the samples indicated the presence of Co-58, Co-60, Cs-134, Cs-137 and Sb-125.

CHARACTERIZATION SUMMARY

04/14/98

REFERENCES (Documents, Interviews)

Maine Yankee Drawing 1150 - FM - 93 A, B
Operator System Training Manual, Chapter 17



Maine Yankee Atomic Power Plant Site Characterization

SUMMARY OF SURVEY UNIT(S)

04/14/98

OUTPUT BATCH SN = 841

PACKAGE C0600 SYSTEMS

Primary Vents and Drains

UNIT(S)

01 - 11' Primary Auxiliary Building Components

SURFACE(S)

- S01 (Duplex strainer STR-6B)
- T01 (Primary drain tank TK-11)
- T02 (Aerated drain tank TK-12A)
- T03 (Aerated drain tank TK-12B)
- U01 (Primary drain tank pump P-15A)
- U02 (Primary drain tank pump P-15B)
- V01 (Valve PD-3)
- V02 (Valve PD-8)
- V03 (Valve PD-165)

REASON(S) CHARACTERIZATION SURVEY (C01)

MATERIALS	MAT'L CODE	MATERIAL DESCRIPTION	BETA BKGD (dpm/100 cm ²)
	G0031	METAL - BARE (GAMMA)	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package C0600 SYSTEMS

Primary Vents and Drains


STATISTICAL SUMMARY

TESTS PERFORMED

	$\mu\text{R/hr}$
Mean	165,583.0
Maximum	1,326,311.
Minimum	1,683.0
Standard Deviation	325,891.8

Samples reported satisfy samples prescribed NO

Samples Reported	27
Samples Prescribed	28



27 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package: C0600 SYSTEMS

Primary Vents and Drains

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
557 (2)	01	S01	G0031	C01	0.00	00001	49511.4
557 (2)	01	S01	G0031	C01	0.00	00003	52873.6
557 (2)	01	S01	G0031	C01	0.00	00004	24014.2
557 (2)	01	S01	G0031	C01	0.00	00005	53830.8
557 (2)	01	T01	G0031	C01	0.00	00002	21836.5
556 (2)	01	T02	G0031	C01	0.00	00001	778714.7
556 (2)	01	T02	G0031	C01	0.00	00003	226411.7
556 (2)	01	T02	G0031	C01	0.00	00005	712207.4
557 (2)	01	T02	G0031	C01	0.00	00007	54495.0
556 (2)	01	T03	G0031	C01	0.00	00001	674441.7
556 (2)	01	T03	G0031	C01	0.00	00003	1326311.0
556 (2)	01	T03	G0031	C01	0.00	00005	315180.9
557 (2)	01	T03	G0031	C01	0.00	00007	103077.2
557 (2)	01	U01	G0031	C01	0.00	00001	3107.7
557 (2)	01	U01	G0031	C01	0.00	00002	2648.4
557 (2)	01	U01	G0031	C01	0.00	00003	3121.0
557 (2)	01	U01	G0031	C01	0.00	00004	1934.0
557 (2)	01	U01	G0031	C01	0.00	00005	2775.6
557 (2)	01	U01	G0031	C01	0.00	00007	8255.8
557 (2)	01	U01	G0031	C01	0.00	00008	8068.0
557 (2)	01	U02	G0031	C01	0.00	00001	9226.4
557 (2)	01	U02	G0031	C01	0.00	00002	4655.7
557 (2)	01	U02	G0031	C01	0.00	00003	2122.9
557 (2)	01	U02	G0031	C01	0.00	00004	1683.0
557 (2)	01	U02	G0031	C01	0.00	00005	10789.2
557 (2)	01	U02	G0031	C01	0.00	00007	13360.0
557 (2)	01	U02	G0031	C01	0.00	00008	6086.2

NOTES: Exposure rates reported in net $\mu\text{R/hr}$. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 $\mu\text{R/hr}$.
 27 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DOWNLOAD FILE & SURVEY INSTRUMENTATION CALIBRATION SUMMARY

04/14/98

Exposure Rate Measurements

Survey Package : C0600 SYSTEMS

Primary Vents and Drains

SURVEY DATE	FILE #	M2350		DETECTOR			TECHNICIAN
		INST S/N	CAL DUE	MODEL	S/N	CAL DUE	
2/6/98	556 (2)	126183	4/16/98	133-4	092368	7/23/98	LCF0451
CALIBRATION DATES VERIFIED AS ACCEPTABLE							
2/6/98	557 (2)	117573	4/14/98	44-38	075085	7/23/98	LCF0451
CALIBRATION DATES VERIFIED AS ACCEPTABLE							




Maine Yankee Atomic Power Plant Site Characterization
Exposure Rate Distance Ratios

SURVEY PACKAGE C0600

Package Number	Component Number	Component Description	Direction	15 cm mR/hr	1 meter mR/hr	Ratio of 15 cm to 1 meter
C0600	01S01	Duplex strainer STR-6B	North	49.5	*	
			East	52.9	24.0	2.2
			South	53.8	*	
C0600	01T01	Primary drain tank TK-11	North	39.2	21.8	1.8
C0600	01T02	Aerated drain tank TK-12A	North	778.7	*	
			East	226.4	*	
			South	712.2	*	
			West	54.5	*	
C0600	01T03	Aerated drain tank TK-12B	North	674.4	*	
			East	1326.3	*	
			South	315.2	*	
			West	103.1	*	
C0600	01U01	Primary drain tank pump P-15A	North	3.1	2.6	1.2
			East	3.1	1.9	1.6
			South	2.8	*	
			West	8.3	8.1	1.0
C0600	01U02	Primary drain tank pump P-15B	North	9.2	4.7	2.0
			East	2.1	1.7	1.3
			South	10.8	*	
			West	13.4	6.1	2.2

* Measurement not collected due to interfering surface.

Exposure Rates - 15 cm and 1 meter





Maine Yankee Atomic Power Plant Site Characterization

04/14/98 Removable Contamination - Gross Beta Activity

Survey Package C0600 SYSTEMS

Primary Vents and Drains


STATISTICAL SUMMARY

TESTS PERFORMED

	Net dpm/100 cm ²
Mean	50,584.5
Maximum	140,000.0
Minimum	5,344.3
Standard Deviation	77,438.0
MDA	5,000.0

MDA <100 net dpm/100 cm ²	NO
Results above 100 net dpm/100 cm ²	3
Number of results above MDA	3

Samples Reported	3
Samples Prescribed	9



3 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Gross Alpha Activity

Survey Package C0600 SYSTEMS

Primary Vents and Drains


STATISTICAL SUMMARY

TESTS PERFORMED

	Net dpm/100 cm ²
Mean	-0.2
Maximum	0.0
Minimum	-0.3
Standard Deviation	0.2
MDA	8.4

MDA < 10 net dpm/100 cm ²	YES
Results above 20 net dpm/100 cm ²	0
Number of results above MDA	0

Samples Reported	3
Samples Prescribed	9



3 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination

Survey Package : C0600 SYSTEMS

Primary Vents and Drains

RESULTS LISTING - SORTED BY SURFACE CODE

XLS FILE	UNIT	SURFACE	REASON	MSRMNT LOCATION	ALPHA	BETA
SME1E123.XLS	01	V03	C01	1	-0.3	<u>6,409.1</u>
RM-14DATA7	01	V02	C01	1		<u>140,000.0</u>
SME1E121.XLS	01	V01	C01	1	-0.3	<u>5,344.3</u>

NOTES: Activity reported in net dpm/100 cm².
 Underlined values exceed the associated MDA.
 Bold values exceed 100.00 dpm/100 cm² (beta activity) and/or 20.00 dpm/100 cm² (alpha activity).
 3 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DATAFILE & ALPHA - BETA COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination

Survey Package : C0600 SYSTEMS

Primary Vents and Drains

SURVEYDATE	XLS FILE	INST ID	S/N	CAL DUE	LAB TECHNICIAN
3/28/98	RM-14DATA7	3	8263	5/26/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/16/98	SME1E121.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/16/98	SME1E123.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Tritium Activity

Survey Package : C0600 SYSTEMS

Primary Vents and Drains

RESULTS LISTING - SORTED BY SURFACE CODE

SAMPLE ID	SAMPLE TYPE	UNIT	SURF	REASN	MSRMNT LOCATION	MDA	TRITIUM ACTIVITY
D33	Hoppes patch	01	V01	C01	00001	38.9	<u>1,535.3</u>
D34	Hoppes patch	01	V02	C01	00001	39.0	<u>20.7</u>
D35	Hoppes patch	01	V03	C01	00001	39.0	<u>88.4</u>

NOTES: Activity reported in net dpm/100 cm².
 Underlined values exceed the associated MDA.
 Bold values exceed 75 dpm/100 cm².
 Italic values exceed 100 dpm/100 cm².



Maine Yankee Atomic Power Plant Site Characterization

LIQUID SCINTILLATION COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination - Tritium Activity

Survey Package : C0600 SYSTEMS

Primary Vents and Drains

SURVEYDATE	INSTRUMENT	MODEL	S/N	CAL DUE	LAB TECHNICIAN
3/5/98	Packard	2750	416221	6/16/98	LDT

CALIBRATION DATE VERIFIED AS ACCEPTABLE



Maine Yankee Atomic Power Plant Site Characterization

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 841

Survey Package C0600 SYSTEMS

Primary Vents and Drains

UNIT : 01 SURFACE : V01 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
 SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP005	PET00006	1.0	1200	Co-57	< 48.0	48.0	0.0
				Co-60	1580.00	103.0	163.0
				Cs-134	< 135.0	135.0	0.0
				Cs-137	< 199.0	199.0	0.0
				K-40	< 927.0	927.0	0.0
				Mn-54	< 129.0	129.0	0.0

UNIT : 01 SURFACE : V02 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
 SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP006	PET00009	1.0	1200	Co-57	< 120.0	120.0	0.0
				Co-60	20100.00	146.0	977.0
				Cs-134	< 386.0	386.0	0.0
				Cs-137	902.00	205.0	1,960.0
				K-40	< 851.0	851.0	0.0
				Mn-54	< 356.0	356.0	0.0

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 841

Survey Package C0600 SYSTEMS

Primary Vents and Drains

UNIT : 01 SURFACE : V03 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP37	PET00055	1.0	1200	Co-57	< 226.0	226.0	0.0
				Co-58	826.00	1,060.0	641.0
				Co-60	54500.00	284.0	2,450.0
				Cs-134	1490.00	283.0	263.0
				Cs-137	37900.00	620.0	2,530.0
				K-40	< 1170.0	1,170.0	0.0
				Mn-54	< 598.0	598.0	0.0
				Sb-125	1380.00	902.0	407.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

CHARACTERIZATION SUMMARY

SURVEY PACKAGE NUMBER :C0700

SYSTEMS

PACKAGE DESCRIPTION

Fuel Pool Cooling System

SURVEY AREA DESCRIPTION

Fuel Pool Cooling and Refueling Purification System

GENERAL HISTORICAL INFORMATION (Operational history, etc.)

The Fuel Pool Cooling System removed decay heat generated by spent fuel assemblies stored in the spent fuel pool and purified the spent fuel pool water by removing particulate matter and dissolved solids. The Refueling Purification System provided a means for RWST recirculation and/or purification of water from the Refueling Water Storage Tank, provided spent fuel pool makeup, refueling cavity flooding and/or draining, refueling cavity purification, Residual Heat Removal system purification via the spent fuel or letdown purification systems and Reactor Coolant System degasification via the letdown system.

SUMMARY OF CHARACTERIZATION ACTIVITIES

Survey units were established for the system by building and elevation as shown in the following Summary of Survey Units. The Surface(s) listing indicates the component name, survey surface code and, where applicable, the Maine Yankee system component number.

A total of 43 exposure rate measurements were collected at 7 component locations. Due to physical interferences, 13 measurements could not be collected.

Beta scan surveys and direct measurements for total beta activity were not prescribed for this survey package.

Smear samples were collected from component interior surfaces to analyze for removable alpha and beta activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable tritium activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable plant-derived radionuclide activity by gamma spectroscopy at 4 survey measurement locations indicated on the results listing report.

The survey result statistical summaries, graphs and results listings are shown in the following individual reports including calibration summaries for the instruments used for each measurement type.

CHARACTERIZATION SURVEY RESULTS

o The average and maximum exposure rate measurement results were 829 mR/hr and 16,945 mR/hr, respectively. The ratio of the 15 cm distance measurements to the 1 meter distance measurements ranged from 0.7 to 3.5.

o There were 3 measurements for removable beta activity above MDA (maximum MDA was 5,000 dpm/100cm²). The maximum measurement result was 20,000 dpm/100cm².

o 1 of the 3 smear measurements was analyzed for removable alpha activity was above MDA (8.4 dpm/100cm²). The maximum measurement result was 10.1 dpm/100cm².

o There was 1 measurement for removable tritium activity above MDA (39.5 dpm/100cm²). The maximum

CHARACTERIZATION SUMMARY

04/14/98

measurement result was 52.2 dpm/100cm².

o Of the 4 samples analyzed by gamma spectroscopy, all samples indicated plant-derived radionuclide activity above MDA. The analysis of the samples indicated the presence of Co-60, Cs-137 and Sb-125.

REFERENCES (Documents, Interviews)

Maine Yankee Drawing 1150 - FM - 97 A, 101 A
Operator System Training Manual, Chapter 37



Maine Yankee Atomic Power Plant Site Characterization

SUMMARY OF SURVEY UNIT(S)

04/14/98

OUTPUT BATCH SN = 842

PACKAGE C0700 SYSTEMS

Fuel Pool Cooling System

UNIT(S)	SURFACE(S)
01 - Fuel Building Components	H01 (Fuel pool heat exchanger E-25) U01 (Fuel pool cooling pump P-17A) U02 (Fuel pool purification pump P-85) V01 (Valve FP-6) V02 (Valve FP-12) V03 (Valve FPU-6)
02 - Components under new fuel laydown area	S01 (Fuel pool prefilter FL-2) S02 (Fuel pool post filter FL-29)
03 - -2' Containment Annulus	P01 (Spoolpiece downstream of CPU-3)
04 - Primary Auxiliary Building Lower Level Pipe Tunnel Components	M01 (Fuel pool demineralizer I-4)

REASON(S) CHARACTERIZATION SURVEY (C01)

MATERIALS	MAT'L CODE	MATERIAL DESCRIPTION	BETA BKGD (dpm/100 cm ²)
	G0031	METAL - BARE (GAMMA)	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package C0700 SYSTEMS

Fuel Pool Cooling System


STATISTICAL SUMMARY

TESTS PERFORMED

	$\mu\text{R/hr}$
Mean	829,672.1
Maximum	16,945,540
Minimum	554.2
Standard Deviation	2,924,669.

Samples reported satisfy samples prescribed	YES
---	-----

Samples Reported	43
Samples Prescribed	43



43 RESULTS ARE GRAPHED

Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package : C0700 SYSTEMS

Fuel Pool Cooling System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
543 (2)	01	H01	G0031	C01	0.00	00001	554.2
543 (2)	01	H01	G0031	C01	0.00	00002	809.2
543 (2)	01	H01	G0031	C01	0.00	00003	8115.0
543 (2)	01	H01	G0031	C01	0.00	00004	3176.1
543 (2)	01	H01	G0031	C01	0.00	00005	1300.2
543 (2)	01	H01	G0031	C01	0.00	00006	1122.2
543 (2)	01	H01	G0031	C01	0.00	00007	8454.9
543 (2)	01	H01	G0031	C01	0.00	00008	4504.6
543 (2)	01	U01	G0031	C01	0.00	00001	1256.7
543 (2)	01	U01	G0031	C01	0.00	00002	1609.1
543 (2)	01	U01	G0031	C01	0.00	00003	2944.2
543 (2)	01	U01	G0031	C01	0.00	00004	3378.3
543 (2)	01	U01	G0031	C01	0.00	00005	2402.2
543 (2)	01	U01	G0031	C01	0.00	00006	2107.1
543 (2)	01	U01	G0031	C01	0.00	00007	1894.7
543 (2)	01	U01	G0031	C01	0.00	00008	1492.4
543 (2)	01	U02	G0031	C01	0.00	00001	5555.6
543 (2)	01	U02	G0031	C01	0.00	00002	3046.5
543 (2)	01	U02	G0031	C01	0.00	00003	5510.2
543 (2)	01	U02	G0031	C01	0.00	00004	5786.5
543 (2)	01	U02	G0031	C01	0.00	00005	2245.5

REMAINING RESULTS PRINTED ON NEXT PAGE

NOTES: Exposure rates reported in net $\mu\text{R/hr}$. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 $\mu\text{R/hr}$.



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package: C0700 SYSTEMS

Fuel Pool Cooling System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
543 (2)	01	U02	G0031	C01	0.00	00006	<u>2372.3</u>
543 (2)	01	U02	G0031	C01	0.00	00007	<u>2379.3</u>
543 (2)	01	U02	G0031	C01	0.00	00008	<u>1734.3</u>
583 (2)	02	S01	G0031	C01	0.00	00001	16945540.0
583 (2)	02	S01	G0031	C01	0.00	00003	7231879.0
583 (2)	02	S01	G0031	C01	0.00	00005	4184741.0
583 (2)	02	S01	G0031	C01	0.00	00007	5610534.0
583 (2)	02	S02	G0031	C01	0.00	00001	<u>11042.6</u>
583 (2)	02	S02	G0031	C01	0.00	00003	<u>6076.6</u>
583 (2)	02	S02	G0031	C01	0.00	00005	<u>4251.7</u>
583 (2)	02	S02	G0031	C01	0.00	00007	<u>6409.9</u>
561 (2)	03	P01	G0031	C01	0.00	00001	<u>47290.2</u>
561 (2)	03	P01	G0031	C01	0.00	00002	<u>38327.5</u>
561 (2)	03	P01	G0031	C01	0.00	00003	<u>152598.4</u>
561 (2)	03	P01	G0031	C01	0.00	00004	<u>43965.3</u>
561 (2)	03	P01	G0031	C01	0.00	00005	<u>180310.9</u>
561 (2)	03	P01	G0031	C01	0.00	00006	<u>458877.5</u>
561 (2)	03	P01	G0031	C01	0.00	00007	<u>307488.2</u>
561 (2)	04	M01	G0031	C01	0.00	00001	<u>86819.6</u>
561 (2)	04	M01	G0031	C01	0.00	00003	<u>14729.4</u>
561 (2)	04	M01	G0031	C01	0.00	00005	<u>112138.8</u>
561 (2)	04	M01	G0031	C01	0.00	00007	<u>159126.9</u>

NOTES: Exposure rates reported in net μ R/hr. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 μ R/hr.
 43 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DOWNLOAD FILE & SURVEY INSTRUMENTATION CALIBRATION SUMMARY

04/14/98

Exposure Rate Measurements

Survey Package: C0700 SYSTEMS

Fuel Pool Cooling System

SURVEY DATE	FILE #	M2350		DETECTOR			TECHNICIAN
		INST S/N	CAL DUE	MODEL	S/N	CAL DUE	
2/4/98	543 (2)	095348	3/20/98	44-38	088919	7/23/98	MAP5535
CALIBRATION DATES VERIFIED AS ACCEPTABLE							
2/6/98	561 (2)	126185	3/20/98	44-38	075082	7/23/98	KFS5185
CALIBRATION DATES VERIFIED AS ACCEPTABLE							
2/10/98	583 (2)	095349	4/15/98	133-4	092366	7/23/98	KFS5185
CALIBRATION DATES VERIFIED AS ACCEPTABLE							



Maine Yankee Atomic Power Plant Site Characterization
Exposure Rate Distance Ratios

SURVEY PACKAGE C0700

Package Number	Component Number	Component Description	Direction	15 cm mR/hr	1 meter mR/hr	Ratio of 15 cm to 1 meter
C0700	01H01	Fuel pool heat exchanger E-25	North	0.6	0.8	0.7
			East	8.1	3.2	2.6
			South	1.3	1.1	1.2
			West	8.5	4.5	1.9
C0700	01U01	Fuel pool cooling pump P-17A	North	1.3	1.6	0.8
			East	2.9	3.4	0.9
			South	2.4	2.1	1.1
			West	1.9	1.5	1.3
C0700	01U02	Fuel pool purification pump P-85	North	5.6	3.0	1.8
			East	5.5	5.8	1.0
			South	2.2	2.4	0.9
			West	2.4	1.7	1.4
C0700	02S01	Fuel pool prefilter FL-2	North	16945.5	*	
			East	7231.9	*	
			South	4184.7	*	
			West	5610.5	*	
C0700	02S02	Fuel pool post filter FL-29	North	11.0	*	
			East	6.1	*	
			South	4.3	*	
			West	6.4	*	
C0700	03P01	Spoolpiece downstream of CPU-3	North	47.3	38.3	1.2
			East	152.6	44.0	3.5
			South	180.3	458.9	0.4
			West	307.5		
C0700	04M01	Fuel pool demineralizer I-4	North	86.8	*	
			East	14.7	*	
			South	112.1	*	
			West	159.1	*	


* Measurement not collected due to interfering surface.



Maine Yankee Atomic Power Plant Site Characterization
Exposure Rate Distance Ratios

SURVEY PACKAGE C0700

Exposure Rates - 15 cm and 1 meter





Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Gross Beta Activity

Survey Package C0700 SYSTEMS

Fuel Pool Cooling System


STATISTICAL SUMMARY

TESTS PERFORMED

	Net dpm/100 cm ²
Mean	13,692.8
Maximum	20,000.0
Minimum	7,078.5
Standard Deviation	6,466.2
MDA	5,000.0

MDA <100 net dpm/100 cm ²	NO
Results above 100 net dpm/100 cm ²	3
Number of results above MDA	3

Samples Reported	3
Samples Prescribed	9



3 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Gross Alpha Activity

Survey Package C0700 SYSTEMS

Fuel Pool Cooling System


STATISTICAL SUMMARY

TESTS PERFORMED

	Net dpm/100 cm ²
Mean	3.4
Maximum	10.1
Minimum	
Standard Deviation	5.8
MDA	8.4

MDA < 10 net dpm/100 cm ²	YES
Results above 20 net dpm/100 cm ²	0
Number of results above MDA	1

Samples Reported	3
Samples Prescribed	9



3 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination

Survey Package : C0700 SYSTEMS

Fuel Pool Cooling System

RESULTS LISTING - SORTED BY SURFACE CODE

XLS FILE	UNIT	SURFACE	REASON	MSRMNT LOCATION	ALPHA	BETA
RM-14DATA9	01	V03	C01	1		<u>20,000.0</u>
RM-14DATA8	01	V02	C01	1		<u>14,000.0</u>
SME1E125.XLS	01	V01	C01	1	<u>10.1</u>	<u>7,078.5</u>

NOTES: Activity reported in net dpm/100 cm².
 Underlined values exceed the associated MDA.
 Bold values exceed 100.00 dpm/100 cm² (beta activity) and/or 20.00 dpm/100 cm² (alpha activity).
 3 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DATAFILE & ALPHA - BETA COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination

Survey Package: C0700 SYSTEMS

Fuel Pool Cooling System

SURVEYDATE	XLS FILE	INST ID	S/N	CAL DUE	LAB TECHNICIAN
3/28/98	RM-14DATA8	3	8263	5/26/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/28/98	RM-14DATA9	3	8263	5/26/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/16/98	SME1E125.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					

Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Tritium Activity

Survey Package: C0700 SYSTEMS

Fuel Pool Cooling System

RESULTS LISTING - SORTED BY SURFACE CODE

SAMPLE ID	SAMPLE TYPE	UNIT	SURF	REASN	MSRMNT LOCATION	MDA	TRITIUM ACTIVITY
D36	Hoppes patch	01	V01	C01	00001	39.5	<u>52.2</u>
D37	Hoppes patch	01	V02	C01	00001	38.9	10.9
D38	Hoppes patch	01	V03	C01	00001	38.8	29.8

NOTES: Activity reported in net dpm/100 cm².
 Underlined values exceed the associated MDA.
 Bold values exceed 75 dpm/100 cm²,
 Italic values exceed 100 dpm/100 cm².



Maine Yankee Atomic Power Plant Site Characterization

LIQUID SCINTILLATION COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination - Tritium Activity

Survey Package: C0700 SYSTEMS

Fuel Pool Cooling System

SURVEYDATE	INSTRUMENT	MODEL	S/N	CAL DUE	LAB TECHNICIAN
3/5/98	Packard	2750	416221	6/16/98	LDT

CALIBRATION DATE VERIFIED AS ACCEPTABLE



Maine Yankee Atomic Power Plant Site Characterization

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 4

04/14/98

OUTPUT BATCH SN = 842

Survey Package C0700 SYSTEMS

Fuel Pool Cooling System

UNIT : 01 SURFACE : V01 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYD083	PET00019	1.0	1200	Co-57	< 59.8	59.8	0.0
				Co-60	3150.00	74.0	247.0
				Cs-134	< 113.0	113.0	0.0
				Cs-137	< 160.0	160.0	0.0
				K-40	< 761.0	761.0	0.0
				Mn-54	< 189.0	189.0	0.0

SAMPLE TYPE OR SURFACE SAMPLED: Valve
SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP007	PET00007	1.0	1200	Co-57	< 71.9	71.9	0.0
				Co-60	5100.00	112.0	341.0
				Cs-134	< 206.0	206.0	0.0
				Cs-137	500.00	139.0	125.0
				K-40	< 1120.0	1,120.0	0.0
				Mn-54	< 185.0	185.0	0.0

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 4

04/14/98

OUTPUT BATCH SN = 842

Survey Package C0700 SYSTEMS

Fuel Pool Cooling System

UNIT : 01 SURFACE : V02 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP38	PET00056	1.0	1200	Co-57	< 86.8	86.8	0.0
				Co-60	5130.00	133.0	324.0
				Cs-134	< 199.0	199.0	0.0
				Cs-137	359.00	146.0	111.0
				K-40	< 799.0	799.0	0.0
				Mn-54	< 194.0	194.0	0.0
				Sb-125	1230.00	338.0	225.0

UNIT : 01 SURFACE : V03 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP008	PET00010	1.0	1200	Co-57	< 57.9	57.9	0.0
				Co-60	2390.00	76.0	193.0
				Cs-134	< 110.0	110.0	0.0
				Cs-137	167.00	94.7	71.3
				K-40	< 899.0	899.0	0.0
				Mn-54	< 124.0	124.0	0.0



Maine Yankee Atomic Power Plant Site Characterization

CHARACTERIZATION SUMMARY

04/14/98

SURVEY PACKAGE NUMBER :C0800

SYSTEMS

PACKAGE DESCRIPTION

Waste Gas Disposal System

SURVEY AREA DESCRIPTION

Waste Gas Disposal System

GENERAL HISTORICAL INFORMATION (Operational history, etc.)

The Waste Gas Disposal System collected and stored radioactive waste gas for decay of short-lived radioisotopes and controlled the discharge of waste gas to the environment to ensure the release rate of activity was within regulatory limits.

SUMMARY OF CHARACTERIZATION ACTIVITIES

Survey units were established for the system by building and elevation as shown in the following Summary of Survey Units. The Surface(s) listing indicates the component name, survey surface code and, where applicable, the Maine Yankee system component number.

A total of 68 exposure rate measurements were collected at 9 component locations. Due to physical interferences, 4 measurements could not be collected.

Beta scan surveys and direct measurements for total beta activity were not prescribed for this survey package.

Smear samples were collected from component interior surfaces to analyze for removable alpha and beta activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable tritium activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable plant-derived radionuclide activity by gamma spectroscopy at 3 survey measurement locations indicated on the results listing report.

The survey result statistical summaries, graphs and results listings are shown in the following individual reports including calibration summaries for the instruments used for each measurement type.

CHARACTERIZATION SURVEY RESULTS

- o The average and maximum exposure rate measurement results were 3.3 mR/hr and 23.6 mR/hr, respectively. The ratio of the 15 cm distance measurements to the 1 meter distance measurements ranged from 0.6 to 2.1.
- o There were 3 measurements for removable beta activity above MDA (34 dpm/100cm²). The maximum measurement result was 6,470 dpm/100cm².
- o There were no measurements for removable alpha activity above MDA (8.4 dpm/100cm²).
- o There were 3 measurements for removable tritium activity above MDA (39 dpm/100cm²). The maximum measurement result was 17,125 dpm/100cm².
- o Of the 3 samples analyzed by gamma spectroscopy, 1 sample indicated plant-derived radionuclide activity above MDA. The analysis of the sample indicated the presence of Co-60.

CHARACTERIZATION SUMMARY

04/14/98

REFERENCES (Documents, Interviews)

Maine Yankee Drawing 1150 - FM - 100 A
Operator System Training Manual, Chapter 24



Maine Yankee Atomic Power Plant Site Characterization

SUMMARY OF SURVEY UNIT(S)

04/14/98

OUTPUT BATCH SN = 832

PACKAGE C0800 SYSTEMS

Waste Gas Disposal System

UNIT(S)

SURFACE(S)

01 - 11' Primary Auxiliary Building Components	H01 (Degasifier effluent cooler E-72B) U01 (Degasifier pump P-66B) U02 (Degasifier pump P-66A) V01 (Valve WD-67)
02 - 36' Primary Auxiliary Building Components	M01 (Waste gas compressor C-3A) M02 (Waste gas compressor C-3B) T01 (Waste gas surge tank TK-10) T02 (Waste gas decay tank TK-60A) T03 (Waste gas decay tank TK-60E) V01 (Valve WD-357) V02 (Valve WD-358)
03 - Yard Components	M01 (Primary vent stack)

REASON(S) CHARACTERIZATION SURVEY (C01)

MATERIALS	MAT'L CODE	MATERIAL DESCRIPTION	BETA BKGD (dpm/100 cm ²)
	G0031	METAL - BARE (GAMMA)	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package C0800 SYSTEMS

Waste Gas Disposal System


STATISTICAL SUMMARY

TESTS PERFORMED

	$\mu\text{R/hr}$
Mean	3,294.8
Maximum	23,554.2
Minimum	15.6
Standard Deviation	4,999.5

Samples reported satisfy samples prescribed	YES
---	-----

Samples Reported	68
Samples Prescribed	68



68 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package: C0800 SYSTEMS

Waste Gas Disposal System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
546 (2)	01	H01	G0031	C01	0.00	00001	3807.4
546 (2)	01	H01	G0031	C01	0.00	00003	7082.4
546 (2)	01	H01	G0031	C01	0.00	00004	9804.0
546 (2)	01	H01	G0031	C01	0.00	00005	4856.7
546 (2)	01	H01	G0031	C01	0.00	00006	6475.2
546 (2)	01	H01	G0031	C01	0.00	00007	9236.6
546 (2)	01	H01	G0031	C01	0.00	00008	12413.6
546 (2)	01	U01	G0031	C01	0.00	00001	23554.2
546 (2)	01	U01	G0031	C01	0.00	00002	11059.0
546 (2)	01	U01	G0031	C01	0.00	00003	9889.2
546 (2)	01	U01	G0031	C01	0.00	00004	8458.2
546 (2)	01	U01	G0031	C01	0.00	00005	6400.5
546 (2)	01	U01	G0031	C01	0.00	00006	5636.3
546 (2)	01	U01	G0031	C01	0.00	00007	10856.6
546 (2)	01	U01	G0031	C01	0.00	00008	8757.4
546 (2)	01	U02	G0031	C01	0.00	00001	15138.3
546 (2)	01	U02	G0031	C01	0.00	00002	10909.1
546 (2)	01	U02	G0031	C01	0.00	00003	9469.6
546 (2)	01	U02	G0031	C01	0.00	00004	11790.5
546 (2)	01	U02	G0031	C01	0.00	00005	8609.1
546 (2)	01	U02	G0031	C01	0.00	00006	9029.5
546 (2)	01	U02	G0031	C01	0.00	00007	6595.8
546 (2)	01	U02	G0031	C01	0.00	00008	7411.4
547 (2)	02	M01	G0031	C01	60.00	00001	20.2
547 (2)	02	M01	G0031	C01	60.00	00002	26.9
547 (2)	02	M01	G0031	C01	60.00	00003	24.4
547 (2)	02	M01	G0031	C01	60.00	00004	22.6
547 (2)	02	M01	G0031	C01	60.00	00005	19.7
547 (2)	02	M01	G0031	C01	60.00	00006	22.1
547 (2)	02	M01	G0031	C01	60.00	00007	22.4
547 (2)	02	M01	G0031	C01	60.00	00008	22.3
547 (2)	02	M02	G0031	C01	60.00	00001	19.6
547 (2)	02	M02	G0031	C01	60.00	00002	21.8
547 (2)	02	M02	G0031	C01	60.00	00003	24.7
547 (2)	02	M02	G0031	C01	60.00	00004	27.9
547 (2)	02	M02	G0031	C01	60.00	00005	24.2
547 (2)	02	M02	G0031	C01	60.00	00006	27.0
547 (2)	02	M02	G0031	C01	60.00	00007	21.7
547 (2)	02	M02	G0031	C01	60.00	00008	23.0
547 (2)	02	T01	G0031	C01	60.00	00001	727.0

NOTES: Exposure rates reported in net $\mu\text{R/hr}$. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 $\mu\text{R/hr}$.



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package : C0800 SYSTEMS

Waste Gas Disposal System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
547 (2)	02	T01	G0031	C01	60.00	00003	269.6
547 (2)	02	T01	G0031	C01	60.00	00004	224.7
547 (2)	02	T01	G0031	C01	60.00	00005	600.5
547 (2)	02	T01	G0031	C01	60.00	00006	443.4
547 (2)	02	T01	G0031	C01	60.00	00007	612.0
547 (2)	02	T01	G0031	C01	60.00	00008	433.5
547 (2)	02	T02	G0031	C01	60.00	00001	237.2
547 (2)	02	T02	G0031	C01	60.00	00003	82.5
547 (2)	02	T02	G0031	C01	60.00	00004	106.9
547 (2)	02	T02	G0031	C01	60.00	00005	223.6
547 (2)	02	T02	G0031	C01	60.00	00006	326.9
547 (2)	02	T02	G0031	C01	60.00	00007	196.8
547 (2)	02	T02	G0031	C01	60.00	00008	201.3
547 (2)	02	T03	G0031	C01	60.00	00001	332.9
547 (2)	02	T03	G0031	C01	60.00	00002	234.2
547 (2)	02	T03	G0031	C01	60.00	00003	99.1
547 (2)	02	T03	G0031	C01	60.00	00004	108.0
547 (2)	02	T03	G0031	C01	60.00	00005	250.4
547 (2)	02	T03	G0031	C01	60.00	00007	263.4
547 (2)	02	T03	G0031	C01	60.00	00008	273.5
547 (2)	03	M01	G0031	C01	60.00	00001	18.1
547 (2)	03	M01	G0031	C01	60.00	00002	16.6
547 (2)	03	M01	G0031	C01	60.00	00003	15.6
547 (2)	03	M01	G0031	C01	60.00	00004	20.5
547 (2)	03	M01	G0031	C01	60.00	00005	23.0
547 (2)	03	M01	G0031	C01	60.00	00006	37.3
547 (2)	03	M01	G0031	C01	60.00	00007	24.2
547 (2)	03	M01	G0031	C01	60.00	00008	32.9

NOTES: Exposure rates reported in net $\mu\text{R/hr}$. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed $15 \mu\text{R/hr}$.
 68 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DOWNLOAD FILE & SURVEY INSTRUMENTATION CALIBRATION SUMMARY

04/14/98

Exposure Rate Measurements

Survey Package: C0800 SYSTEMS

Waste Gas Disposal System

SURVEY DATE	FILE #	M2350		DETECTOR			TECHNICIAN
		INST S/N	CAL DUE	MODEL	S/N	CAL DUE	
2/5/98	546 (2)	095348	3/20/98	44-38	088919	7/23/98	MAP5535
CALIBRATION DATES VERIFIED AS ACCEPTABLE							
2/5/98	547 (2)	126197	3/22/98	44-2	PR126922	4/19/98	JFM0682
CALIBRATION DATES VERIFIED AS ACCEPTABLE							



Maine Yankee Atomic Power Plant Site Characterization
Exposure Rate Distance Ratios

SURVEY PACKAGE C0800

Package Number	Component Number	Component Description	Direction	15 cm mR/hr	1 meter mR/hr	Ratio of 15 cm to 1 meter
C0800	01H01	Degasifier effluent cooler E-72B	North	3.8	*	
			East	7.1	9.8	0.7
			South	4.9	6.5	0.8
			West	9.2	12.4	0.7
C0800	01U01	Degasifier pump P-66B	North	23.6	11.1	2.1
			East	9.9	8.5	1.2
			South	6.4	5.6	1.1
			West	10.9	8.8	1.2
C0800	01U02	Degasifier pump P-66A	North	15.1	10.9	1.4
			East	9.5	11.8	0.8
			South	8.6	9.0	1.0
			West	6.6	7.4	0.9
C0800	02M01	Waste gas compressor C-3A	North	0.0	0.0	0.8
			East	0.0	0.0	1.1
			South	0.0	0.0	0.9
			West	0.0	0.0	1.0
C0800	02M02	Waste gas compressor C-3B	North	0.0	0.0	0.9
			East	0.0	0.0	0.9
			South	0.0	0.0	0.9
			West	0.0	0.0	0.9
C0800	02T01	Waste gas surge tank TK-10	North	0.7	*	
			East	0.3	0.2	1.2
			South	0.6	0.4	1.4
			West	0.6	0.4	1.4
C0800	02T02	Waste gas decay tank TK-60A	North	0.2	*	
			East	0.1	0.1	0.8
			South	0.2	0.3	0.7
			West	0.2	0.2	1.0
C0800	02T03	Waste gas decay tank TK-60E	North	0.3	0.2	1.4
			East	0.1	0.1	0.9
			South	0.3	*	
			West	0.3	0.3	1.0
C0800	03M01	Primary vent stack	North	0.0	0.0	1.1
			East	0.0	0.0	0.8
			South	0.0	0.0	0.6
			West	0.0	0.0	0.7


* Measurement not collected due to interfering surface.



Maine Yankee Atomic Power Plant Site Characterization
Exposure Rate Distance Ratios

SURVEY PACKAGE C0800

Exposure Rates - 15 cm and 1 meter





Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Gross Beta Activity

Survey Package C0800 SYSTEMS

Waste Gas Disposal System


STATISTICAL SUMMARY

TESTS PERFORMED

	Net dpm/100 cm ²
Mean	3,251.0
Maximum	6,470.0
Minimum	1,030.0
Standard Deviation	2,854.0
MDA	33.8

MDA <100 net dpm/100 cm ²	YES
Results above 100 net dpm/100 cm ²	3
Number of results above MDA	3

Samples Reported	3
Samples Prescribed	9



3 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Gross Alpha Activity

Survey Package C0800 SYSTEMS

Waste Gas Disposal System


STATISTICAL SUMMARY

TESTS PERFORMED

	Net dpm/100 cm ²
Mean	-0.3
Maximum	-0.3
Minimum	-0.3
Standard Deviation	0.0
MDA	8.4

MDA < 10 net dpm/100 cm ²	YES
Results above 20 net dpm/100 cm ²	0
Number of results above MDA	0

Samples Reported	3
Samples Prescribed	9



3 RESULTS ARE GRAPHED

Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination

Survey Package: C0800 SYSTEMS

Waste Gas Disposal System

RESULTS LISTING - SORTED BY SURFACE CODE

XLS FILE	UNIT	SURFACE	REASON	MSRMNT LOCATION	ALPHA	BETA
SME1E131.XLS	02	V02	C01	1	-0.3	<u>6,470.0</u>
SME1E129.XLS	02	V01	C01	1	-0.3	<u>1,030.0</u>
SME1E127.XLS	01	V01	C01	1	-0.3	<u>2,253.1</u>

NOTES: Activity reported in net dpm/100 cm².

Underlined values exceed the associated MDA.

Bold values exceed 100.00 dpm/100 cm² (beta activity) and/or 20.00 dpm/100 cm² (alpha activity).

3 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DATAFILE & ALPHA - BETA COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination

Survey Package: C0800 SYSTEMS

Waste Gas Disposal System

SURVEYDATE	XLS FILE	INST ID	S/N	CAL DUE	LAB TECHNICIAN
3/16/98	SME1E127.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/16/98	SME1E129.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/16/98	SME1E131.XLS	1	15632	8/5/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					

Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Tritium Activity

Survey Package : C0800 SYSTEMS

Waste Gas Disposal System

RESULTS LISTING - SORTED BY SURFACE CODE

SAMPLE ID	SAMPLE TYPE	UNIT	SURF	REASN	MSRMNT LOCATION	MDA	TRITIUM ACTIVITY
D39	Hoppes patch	01	V01	C01	00001	39.0	<u>17,124.9</u>
D40	Hoppes patch	02	V01	C01	00001	38.7	<u>186.1</u>
D41	Hoppes patch	02	V02	C01	00001	39.0	<u>163.4</u>

NOTES: Activity reported in net dpm/100 cm².
 Underlined values exceed the associated MDA.
 Bold values exceed 75 dpm/100 cm²,
 Italic values exceed 100 dpm/100 cm².



Maine Yankee Atomic Power Plant Site Characterization

LIQUID SCINTILLATION COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination - Tritium Activity

Survey Package : C0800 SYSTEMS

Waste Gas Disposal System

SURVEYDATE	INSTRUMENT	MODEL	S/N	CAL DUE	LAB TECHNICIAN
3/5/98	Packard	2750	416221	6/16/98	LDT

CALIBRATION DATE VERIFIED AS ACCEPTABLE



Maine Yankee Atomic Power Plant Site Characterization

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 832

Survey Package C0800 SYSTEMS

Waste Gas Disposal System

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
UNIT : 01 SURFACE : V01 REASON : C01 ANALYSIS TYPE CODE : LAB05							
SAMPLE TYPE OR SURFACE SAMPLED: Valve SAMPLE LOCATOR: 00001							
MYP009	PET00011	1.0	1200	Co-57	< 62.8	62.8	0.0
				Co-60	2390.00	76.0	191.0
				Cs-134	< 140.0	140.0	0.0
				Cs-137	174.00	141.0	93.5
				K-40	< 851.0	851.0	0.0
				Mn-54	< 140.0	140.0	0.0

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
UNIT : 02 SURFACE : V01 REASON : C01 ANALYSIS TYPE CODE : LAB05							
SAMPLE TYPE OR SURFACE SAMPLED: Valve SAMPLE LOCATOR: 00001							
MYP010	PET00008	1.0	1200	Co-57	< 42.7	42.7	0.0
				Co-60	< 65.1	65.1	0.0
				Cs-134	< 75.9	75.9	0.0
				Cs-137	< 49.6	49.6	0.0
				K-40	< 927.0	927.0	0.0
				Mn-54	< 72.2	72.2	0.0

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 832

Survey Package C0800 SYSTEMS

Waste Gas Disposal System

UNIT : 02 SURFACE : V02 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
 SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP011	PET00009	1.0	1200	Co-57	< 35.1	35.1	0.0
				Co-60	< 76.0	76.0	0.0
				Cs-134	< 70.6	70.6	0.0
				Cs-137	< 89.8	89.8	0.0
				K-40	< 849.0	849.0	0.0
				Mn-54	< 72.3	72.3	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

CHARACTERIZATION SUMMARY

SURVEY PACKAGE NUMBER :C0900

SYSTEMS

PACKAGE DESCRIPTION

Pressurizer and PZR Relief System

SURVEY AREA DESCRIPTION

Pressurizer and Pressurizer Relief System

GENERAL HISTORICAL INFORMATION (Operational history, etc.)

The Pressurizer and Pressurizer Relief System maintained the Reactor Coolant System (RCS) operating pressure and compensated for variations in coolant volume during load changes.

SUMMARY OF CHARACTERIZATION ACTIVITIES

Survey units were established for the system by building and elevation as shown in the following Summary of Survey Units. The Surface(s) listing indicates the component name, survey surface code and, where applicable, the Maine Yankee system component number.

A total of 64 exposure rate measurements were collected at 8 component locations.

Beta scan surveys and direct measurements for total beta activity were not prescribed for this survey package.

Smear samples were collected from component interior surfaces to analyze for removable alpha and beta activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable tritium activity at 3 survey measurement locations indicated on the results listing report.

Smear samples were collected from component interior surfaces to analyze for removable plant-derived radionuclide activity by gamma spectroscopy at 3 survey measurement locations indicated on the results listing report.

The survey result statistical summaries, graphs and results listings are shown in the following individual reports including calibration summaries for the instruments used for each measurement type.

CHARACTERIZATION SURVEY RESULTS

- o The average and maximum exposure rate measurement results were 41.6 mR/hr and 376 mR/hr, respectively. The ratio of the 15 cm distance measurements to the 1 meter distance measurements ranged from 0.4 to 3.8.
- o There were 3 measurements for removable beta activity above MDA (maximum MDA was 5,000 dpm/100cm²). The maximum measurement result was 360,000 dpm/100cm².
- o None of the 3 smear measurements were analyzed for removable alpha activity.
- o There were 2 measurements for removable tritium activity above MDA (138.9 dpm/100cm²). The maximum measurement result was 229,514 dpm/100cm².
- o Of the 3 samples analyzed by gamma spectroscopy, all samples indicated plant-derived radionuclide activity above MDA. The analysis of the samples indicated the presence of Co-58, Co-60, Cs-134, Cs-137, Mn-54, Ag-110M and Sb-125.

CHARACTERIZATION SUMMARY

04/14/98

REFERENCES (Documents, Interviews)

Maine Yankee Drawing 1150 - FM - 90 A
Operator System Training Manual, Chapter 3



Maine Yankee Atomic Power Plant Site Characterization

SUMMARY OF SURVEY UNIT(S)

04/14/98

OUTPUT BATCH SN = 844

PACKAGE C0900 SYSTEMS

Pressurizer and PZR Relief System

UNIT(S)	SURFACE(S)
01 - -2' Containment Building Components	H01 (Pressurizer quench tank cooler E-70) T01 (Pressurizer quench tank TK-8) U01 (Pressurizer quench tank pump P-68A) U02 (Pressurizer quench tank pump P-68B) V01 (Valve PR-34) V02 (Valve PR-35)
02 - 46' Containment Building Pressurizer Doghouse Components	V01 (3" pressurizer safety valve PR-S-11) V02 (3" power operated relief valve PR-S-14) V03 (Valve PR-S-13)
03 - 20' Containment Building Pressurizer E-2	M01 (Pressurizer E-2)
04 - 46' Containment Building Pressurizer E-2	M01 (Pressurizer E-2)

REASON(S) CHARACTERIZATION SURVEY (C01)

MATERIALS	MAT'L CODE	MATERIAL DESCRIPTION	BETA BKGD (dpm/100 cm ²)
	G0031	METAL - BARE (GAMMA)	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package C0900 SYSTEMS

Pressurizer and PZR Relief System


STATISTICAL SUMMARY

TESTS PERFORMED

	$\mu\text{R/hr}$
Mean	41,636.4
Maximum	376,269.4
Minimum	1,038.2
Standard Deviation	59,187.4

Samples reported satisfy samples prescribed	YES
---	-----

Samples Reported	64
Samples Prescribed	64



64 RESULTS ARE GRAPHED

Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package : C0900 SYSTEMS

Pressurizer and PZR Relief System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
666 (2)	01	H01	G0031	C01	0.00	00001	62581.3
666 (2)	01	H01	G0031	C01	0.00	00002	54991.3
666 (2)	01	H01	G0031	C01	0.00	00003	44384.7
666 (2)	01	H01	G0031	C01	0.00	00004	48519.3
666 (2)	01	H01	G0031	C01	0.00	00005	140961.2
666 (2)	01	H01	G0031	C01	0.00	00006	56463.4
666 (2)	01	H01	G0031	C01	0.00	00007	70238.5
666 (2)	01	H01	G0031	C01	0.00	00008	64135.1
666 (2)	01	T01	G0031	C01	0.00	00001	28113.7
666 (2)	01	T01	G0031	C01	0.00	00002	72144.9
666 (2)	01	T01	G0031	C01	0.00	00003	22265.3
666 (2)	01	T01	G0031	C01	0.00	00004	51022.4
666 (2)	01	T01	G0031	C01	0.00	00005	20545.4
666 (2)	01	T01	G0031	C01	0.00	00006	26012.7
666 (2)	01	T01	G0031	C01	0.00	00007	12129.2
666 (2)	01	T01	G0031	C01	0.00	00008	17303.0
666 (2)	01	U01	G0031	C01	0.00	00001	68817.9
666 (2)	01	U01	G0031	C01	0.00	00002	96142.0
666 (2)	01	U01	G0031	C01	0.00	00003	59031.0
666 (2)	01	U01	G0031	C01	0.00	00004	69660.0
666 (2)	01	U01	G0031	C01	0.00	00005	64946.9
666 (2)	01	U01	G0031	C01	0.00	00006	76811.3
666 (2)	01	U01	G0031	C01	0.00	00007	78953.6
666 (2)	01	U01	G0031	C01	0.00	00008	73190.5
666 (2)	01	U02	G0031	C01	0.00	00001	133334.2
666 (2)	01	U02	G0031	C01	0.00	00002	79225.2
666 (2)	01	U02	G0031	C01	0.00	00003	167377.2
666 (2)	01	U02	G0031	C01	0.00	00004	115752.4
666 (2)	01	U02	G0031	C01	0.00	00005	376269.4
666 (2)	01	U02	G0031	C01	0.00	00006	99367.2
666 (2)	01	U02	G0031	C01	0.00	00007	95379.8
666 (2)	01	U02	G0031	C01	0.00	00008	78367.7
666 (2)	02	V01	G0031	C01	0.00	00001	1364.9
666 (2)	02	V01	G0031	C01	0.00	00002	1614.5
666 (2)	02	V01	G0031	C01	0.00	00003	1193.6
666 (2)	02	V01	G0031	C01	0.00	00004	1433.8
666 (2)	02	V01	G0031	C01	0.00	00005	1378.3
666 (2)	02	V01	G0031	C01	0.00	00006	1319.0
666 (2)	02	V01	G0031	C01	0.00	00007	1294.0
666 (2)	02	V01	G0031	C01	0.00	00008	1256.5

NOTES: Exposure rates reported in net $\mu\text{R/hr}$. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 $\mu\text{R/hr}$.

Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package : C0900 SYSTEMS

Pressurizer and PZR Relief System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
666 (2)	02	V02	G0031	C01	0.00	00001	<u>1103.1</u>
666 (2)	02	V02	G0031	C01	0.00	00002	<u>1164.8</u>
666 (2)	02	V02	G0031	C01	0.00	00003	<u>1084.1</u>
666 (2)	02	V02	G0031	C01	0.00	00004	<u>1141.6</u>
666 (2)	02	V02	G0031	C01	0.00	00005	<u>1182.6</u>
666 (2)	02	V02	G0031	C01	0.00	00006	<u>1070.5</u>
666 (2)	02	V02	G0031	C01	0.00	00007	<u>1092.1</u>
666 (2)	02	V02	G0031	C01	0.00	00008	<u>1038.2</u>
666 (2)	03	M01	G0031	C01	0.00	00001	<u>16999.5</u>
666 (2)	03	M01	G0031	C01	0.00	00002	<u>14099.8</u>
666 (2)	03	M01	G0031	C01	0.00	00003	<u>13347.5</u>
666 (2)	03	M01	G0031	C01	0.00	00004	<u>9235.3</u>
666 (2)	03	M01	G0031	C01	0.00	00005	<u>16173.8</u>
666 (2)	03	M01	G0031	C01	0.00	00006	<u>11900.2</u>
666 (2)	03	M01	G0031	C01	0.00	00007	<u>10248.3</u>
666 (2)	03	M01	G0031	C01	0.00	00008	<u>11323.1</u>
666 (2)	04	M01	G0031	C01	0.00	00001	<u>3224.2</u>
666 (2)	04	M01	G0031	C01	0.00	00002	<u>1325.3</u>
666 (2)	04	M01	G0031	C01	0.00	00003	<u>1909.6</u>
666 (2)	04	M01	G0031	C01	0.00	00004	<u>1471.3</u>
666 (2)	04	M01	G0031	C01	0.00	00005	<u>3452.5</u>
666 (2)	04	M01	G0031	C01	0.00	00006	<u>1711.2</u>
666 (2)	04	M01	G0031	C01	0.00	00007	<u>2539.3</u>
666 (2)	04	M01	G0031	C01	0.00	00008	<u>1601.3</u>

NOTES: Exposure rates reported in net $\mu\text{R/hr}$. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 $\mu\text{R/hr}$.
 64 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DOWNLOAD FILE & SURVEY INSTRUMENTATION CALIBRATION SUMMARY

04/14/98

Exposure Rate Measurements

Survey Package : C0900 SYSTEMS

Pressurizer and PZR Relief System

SURVEY DATE	FILE #	M2350		DETECTOR			TECHNICIAN
		INST S/N	CAL DUE	MODEL	S/N	CAL DUE	
3/18/98	666 (2)	126185	3/20/98	44-38	075082	7/23/98	AOK2982

CALIBRATION DATES VERIFIED AS ACCEPTABLE



Maine Yankee Atomic Power Plant Site Characterization
Exposure Rate Distance Ratios

SURVEY PACKAGE C0900


Package Number	Component Number	Component Description	Direction	15 cm mR/hr	1 meter mR/hr	Ratio of 15 cm to 1 meter
C0900	01H01	Pressurizer quench tank cooler E-70	North	62.6	55.0	1.1
			East	44.4	48.5	0.9
			South	141.0	56.5	2.5
			West	70.2	64.1	1.1
C0900	01T01	Pressurizer quench tank TK-8	North	28.1	72.1	0.4
			East	22.3	51.0	0.4
			South	20.5	26.0	0.8
			West	12.1	17.3	0.7
C0900	01U01	Pressurizer quench tank pump P-68A	North	68.8	96.1	0.7
			East	59.0	69.7	0.8
			South	64.9	76.8	0.8
			West	79.0	73.2	1.1
C0900	01U02	Pressurizer quench tank pump P-68B	North	133.3	79.2	1.7
			East	167.4	115.8	1.4
			South	376.3	99.4	3.8
			West	95.4	78.4	1.2
C0900	02V01	3" pressurizer safety valve PR-S-11	North	1.4	1.6	0.8
			East	1.2	1.4	0.8
			South	1.4	1.3	1.0
			West	1.3	1.3	1.0
C0900	02V02	3" power operated relief valve PR-S-14	North	1.1	1.2	0.9
			East	1.1	1.1	0.9
			South	1.2	1.1	1.1
			West	1.1	1.0	1.1
C0900	03M01	Pressurizer E-2	North	17.0	14.1	1.2
			East	13.3	9.2	1.4
			South	16.2	11.9	1.4
			West	10.2	11.3	0.9
C0900	04M01	Pressurizer E-2	North	3.2	1.3	2.4
			East	1.9	1.5	1.3
			South	3.5	1.7	2.0
			West	2.5	1.6	1.6




Maine Yankee Atomic Power Plant Site Characterization
Exposure Rate Distance Ratios

SURVEY PACKAGE C0900

Exposure Rates - 15 cm and 1 meter





Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Gross Beta Activity

Survey Package C0900 SYSTEMS

Pressurizer and PZR Relief System


STATISTICAL SUMMARY

TESTS PERFORMED


	Net dpm/100 cm ²
Mean	213,333.3
Maximum	360,000.0
Minimum	120,000.0
Standard Deviation	128,582.0
MDA	5,000.0

MDA <100 net dpm/100 cm ²	NO
Results above 100 net dpm/100 cm ²	3
Number of results above MDA	3

Samples Reported	3
Samples Prescribed	9



3 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination

Survey Package: C0900 SYSTEMS

Pressurizer and PZR Relief System

RESULTS LISTING - SORTED BY SURFACE CODE

XLS FILE	UNIT	SURFACE	REASON	MSRMNT LOCATION	ALPHA	BETA
RM-14DATA12	02	V03	C01	1		<u>120,000.0</u>
RM-14DATA11	01	V02	C01	1		<u>360,000.0</u>
RM-14DATA10	01	V01	C01	1		<u>160,000.0</u>

NOTES: Activity reported in net dpm/100 cm².

Underlined values exceed the associated MDA.

Bold values exceed 100.00 dpm/100 cm² (beta activity) and/or 20.00 dpm/100 cm² (alpha activity).

3 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DATAFILE & ALPHA - BETA COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination

Survey Package : C0900 SYSTEMS

Pressurizer and PZR Relief System

SURVEYDATE	XLS FILE	INST ID	S/N	CAL DUE	LAB TECHNICIAN
3/28/98	RM-14DATA10	3	8263	5/26/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/28/98	RM-14DATA11	3	8263	5/26/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					
3/28/98	RM-14DATA12	3	8263	5/26/98	JWD
CALIBRATION DATE VERIFIED AS ACCEPTABLE					



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Removable Contamination - Tritium Activity

Survey Package : C0900 SYSTEMS

Pressurizer and PZR Relief System

RESULTS LISTING - SORTED BY SURFACE CODE

SAMPLE ID	SAMPLE TYPE	UNIT	SURF	REASN	MSRMNT LOCATION	MDA	TRITIUM ACTIVITY
D68	Hoppes patch	01	V01	C01	00001	138.9	<u>229,514.</u>
D69	Hoppes patch	01	V02	C01	00001	138.9	<u>17,879.5</u>
D70	Hoppes patch	02	V03	C01	00001	138.9	9.5

NOTES: Activity reported in net dpm/100 cm².
 Underlined values exceed the associated MDA.
 Bold values exceed 75 dpm/100 cm²,
 Italic values exceed 100 dpm/100 cm².



Maine Yankee Atomic Power Plant Site Characterization

LIQUID SCINTILLATION COUNTER CALIBRATION SUMMARY

04/14/98

Removable Contamination - Tritium Activity

Survey Package : C0900 SYSTEMS

Pressurizer and PZR Relief System

SURVEYDATE	INSTRUMENT	MODEL	S/N	CAL DUE	LAB TECHNICIAN
4/6/98	Packard	2750	416221	6/16/98	LDT

CALIBRATION DATE VERIFIED AS ACCEPTABLE



Maine Yankee Atomic Power Plant Site Characterization

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 844

Survey Package C0900 SYSTEMS

Pressurizer and PZR Relief System

UNIT : 01 SURFACE : V01 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
 SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP26	PET00041	1.0	1800	Ag-110M	5870.00	467.0	392.0
				Co-57	< 217.0	217.0	0.0
				Co-58	3760.00	726.0	520.0
				Co-60	88000.00	533.0	8,090.0
				Cs-134	818.00	423.0	171.0
				Cs-137	8580.00	477.0	750.0
				K-40	< 1500.0	1,500.0	0.0
				Mn-54	1280.00	534.0	341.0
				Sb-125	7910.00	1,330.0	750.0

UNIT : 01 SURFACE : V02 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
 SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP27	PET00044	1.0	1800	Co-57	< 423.0	423.0	0.0
				Co-58	833.00	1,180.0	704.0
				Co-60	96000.00	982.0	5,500.0
				Cs-134	3260.00	819.0	471.0
				Cs-137	61500.00	830.0	4,200.0
				K-40	< 2310.0	2,310.0	0.0
				Mn-54	< 1450.0	1,450.0	0.0

GAMMA SPECTRAL ANALYSIS RESULTS LISTING

NUMBER OF SAMPLES REPORTED = 3

04/14/98

OUTPUT BATCH SN = 844

Survey Package C0900 SYSTEMS

Pressurizer and PZR Relief System

UNIT : 02 SURFACE : V03 REASON : C01 ANALYSIS TYPE CODE : LAB05

SAMPLE TYPE OR SURFACE SAMPLED: Valve
 SAMPLE LOCATOR: 00001

LAB ID	SPECTRUM	MASS (grams)	COUNT TIME (seconds)	NUCLIDE	ACTIVITY (pCi/g)	MDA (pCi/g)	ERROR (± pCi/g)
MYP28	PET00045	1.0	1800	Co-57	< 130.0	130.0	0.0
				Co-58	834.00	382.0	248.0
				Co-60	53600.00	287.0	2,370.0
				Cs-134	< 301.0	301.0	0.0
				Cs-137	< 359.0	359.0	0.0
				K-40	< 889.0	889.0	0.0
				Mn-54	< 444.0	444.0	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

CHARACTERIZATION SUMMARY

SURVEY PACKAGE NUMBER :C1100

SYSTEMS

PACKAGE DESCRIPTION

Reactor Coolant System

SURVEY AREA DESCRIPTION

Reactor Coolant System

GENERAL HISTORICAL INFORMATION (Operational history, etc.)

The primary function of the Reactor Coolant System (RCS) was to transfer heat from the reactor core to secondary systems via the steam generators. The water acted as a neutron moderator and reflector and as a solvent for the boric acid used in chemical shim control. The coolant provided a barrier against the release of radioactivity generated in the core to the environment.

SUMMARY OF CHARACTERIZATION ACTIVITIES

Survey units were established for the system by building and elevation as shown in the following Summary of Survey Units. The Surface(s) listing indicates the component name, survey surface code and, where applicable, the Maine Yankee system component number.

A total of 48 exposure rate measurements were collected at 6 component locations.

Beta scan surveys and direct measurements for total beta activity were not prescribed for this survey package.

No smear samples were collected for removable alpha and beta activity.

No smear samples were collected for removable tritium activity.

No smear samples were collected for removable plant-derived radionuclide activity by gamma spectroscopy.

The survey result statistical summaries, graphs and results listings are shown in the following individual reports including calibration summaries for the instruments used for each measurement type.

CHARACTERIZATION SURVEY RESULTS

o The average and maximum exposure rate measurement results were 53.6 mR/hr and 181.3 mR/hr, respectively. The ratio of the 15 cm distance measurements to the 1 meter distance measurements ranged from 0.5 to 1.5.

REFERENCES (Documents, Interviews)

Maine Yankee Drawing 1150 - FM - 90 A, 91 A
Professional Staff Orientation Manual, Chapter 2



Maine Yankee Atomic Power Plant Site Characterization

SUMMARY OF SURVEY UNIT(S)

04/14/98

OUTPUT BATCH SN = 846

PACKAGE C1100 SYSTEMS

Reactor Coolant System

UNIT(S)	SURFACE(S)
01 - -2' Containment Building Components	P01 (Reactor coolant system loop 1 hot leg) P02 (Reactor coolant system loop 2 hot leg) P03 (Reactor coolant system loop 3 hot leg)
02 - 13' Containment Building Components	U01 (Reactor Coolant Pump P-1-1) U02 (Reactor Coolant Pump P-1-2) U03 (Reactor Coolant Pump P-1-3)

REASON(S) CHARACTERIZATION SURVEY (C01)

MATERIALS	MAT'L CODE	MATERIAL DESCRIPTION	BETA BKGD (dpm/100 cm ²)
	G0031	METAL - BARE (GAMMA)	0.0



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package C1100 SYSTEMS

Reactor Coolant System


STATISTICAL SUMMARY

TESTS PERFORMED

	$\mu\text{R/hr}$
Mean	53,580.6
Maximum	181,322.8
Minimum	6,043.9
Standard Deviation	34,274.7

Samples reported satisfy samples prescribed	YES
---	-----

Samples Reported	48
Samples Prescribed	48



48 RESULTS ARE GRAPHED



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package : C1100 SYSTEMS

Reactor Coolant System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
671 (2)	01	P01	G0031	C01	0.00	00001	89262.0
671 (2)	01	P01	G0031	C01	0.00	00002	88842.7
671 (2)	01	P01	G0031	C01	0.00	00003	47365.0
671 (2)	01	P01	G0031	C01	0.00	00004	38513.7
671 (2)	01	P01	G0031	C01	0.00	00005	55919.3
671 (2)	01	P01	G0031	C01	0.00	00006	49870.2
671 (2)	01	P01	G0031	C01	0.00	00007	31297.7
671 (2)	01	P01	G0031	C01	0.00	00008	27679.4
671 (2)	01	P02	G0031	C01	0.00	00001	46482.2
671 (2)	01	P02	G0031	C01	0.00	00002	48338.2
671 (2)	01	P02	G0031	C01	0.00	00003	33951.4
671 (2)	01	P02	G0031	C01	0.00	00004	37617.5
671 (2)	01	P02	G0031	C01	0.00	00005	22059.6
671 (2)	01	P02	G0031	C01	0.00	00006	22934.2
671 (2)	01	P02	G0031	C01	0.00	00007	45373.7
671 (2)	01	P02	G0031	C01	0.00	00008	40118.5
671 (2)	01	P03	G0031	C01	0.00	00001	104443.8
671 (2)	01	P03	G0031	C01	0.00	00002	107605.3
671 (2)	01	P03	G0031	C01	0.00	00003	81942.0
671 (2)	01	P03	G0031	C01	0.00	00004	181322.8
671 (2)	01	P03	G0031	C01	0.00	00005	31616.2
671 (2)	01	P03	G0031	C01	0.00	00006	31616.2
671 (2)	01	P03	G0031	C01	0.00	00007	51125.3
671 (2)	01	P03	G0031	C01	0.00	00008	106845.5

REMAINING RESULTS PRINTED ON NEXT PAGE

NOTES: Exposure rates reported in net μ R/hr. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 μ R/hr.



Maine Yankee Atomic Power Plant Site Characterization

04/14/98

Exposure Rate Measurements

Survey Package : C1100 SYSTEMS

Reactor Coolant System

RESULTS LISTING - SORTED BY SURFACE CODE

FILE #	UNIT	SURFACE	MATERIAL	REASON	COUNT TIME	MSRMNT LOCATION	RESULT
671 (2)	02	U01	G0031	C01	0.00	00001	<u>58307.9</u>
671 (2)	02	U01	G0031	C01	0.00	00002	<u>45707.2</u>
671 (2)	02	U01	G0031	C01	0.00	00003	<u>71674.5</u>
671 (2)	02	U01	G0031	C01	0.00	00004	<u>88418.3</u>
671 (2)	02	U01	G0031	C01	0.00	00005	<u>91764.4</u>
671 (2)	02	U01	G0031	C01	0.00	00006	<u>97634.3</u>
671 (2)	02	U01	G0031	C01	0.00	00007	<u>106658.5</u>
671 (2)	02	U01	G0031	C01	0.00	00008	<u>75200.4</u>
671 (2)	02	U02	G0031	C01	0.00	00001	<u>74359.9</u>
671 (2)	02	U02	G0031	C01	0.00	00002	<u>52199.8</u>
671 (2)	02	U02	G0031	C01	0.00	00003	<u>35337.9</u>
671 (2)	02	U02	G0031	C01	0.00	00004	<u>29922.9</u>
671 (2)	02	U02	G0031	C01	0.00	00005	<u>23779.7</u>
671 (2)	02	U02	G0031	C01	0.00	00006	<u>23512.2</u>
671 (2)	02	U02	G0031	C01	0.00	00007	<u>20320.5</u>
671 (2)	02	U02	G0031	C01	0.00	00008	<u>19507.2</u>
671 (2)	02	U03	G0031	C01	0.00	00001	<u>6043.9</u>
671 (2)	02	U03	G0031	C01	0.00	00002	<u>6461.5</u>
671 (2)	02	U03	G0031	C01	0.00	00003	<u>72915.1</u>
671 (2)	02	U03	G0031	C01	0.00	00004	<u>50148.2</u>
671 (2)	02	U03	G0031	C01	0.00	00005	<u>30488.5</u>
671 (2)	02	U03	G0031	C01	0.00	00006	<u>27764.1</u>
671 (2)	02	U03	G0031	C01	0.00	00007	<u>20568.7</u>
671 (2)	02	U03	G0031	C01	0.00	00008	<u>21028.8</u>

NOTES: Exposure rates reported in net μ R/hr. Count times are reported in seconds.
 Underlined results did not meet the minimum required count time.
 Bold values exceed 15 μ R/hr.
 48 results are listed.



Maine Yankee Atomic Power Plant Site Characterization

DOWNLOAD FILE & SURVEY INSTRUMENTATION CALIBRATION SUMMARY

04/14/98

Exposure Rate Measurements

Survey Package: C1100 SYSTEMS

Reactor Coolant System

SURVEY DATE	FILE #	M2350		DETECTOR			TECHNICIAN
		INST S/N	CAL DUE	MODEL	S/N	CAL DUE	
3/24/98	671 (2)	95349	4/15/98	44-38	PR088919	7/23/98	AOK2982

CALIBRATION DATES VERIFIED AS ACCEPTABLE



Maine Yankee Atomic Power Plant Site Characterization
Exposure Rate Distance Ratios

SURVEY PACKAGE C01100

Package Number	Component Number	Component Description	Direction	15 cm mR/hr	1 meter mR/hr	Ratio of 15 cm to 1 meter
C1100	01P01	Reactor coolant system loop 1 hot leg	North	89.3	88.8	1.0
			East	47.4	38.5	1.2
			South	55.9	49.9	1.1
			West	31.3	27.7	1.1
C1100	01P02	Reactor coolant system loop 2 hot leg	North	46.5	48.3	1.0
			East	34.0	37.6	0.9
			South	22.1	22.9	1.0
			West	45.4	40.1	1.1
C1100	01P03	Reactor coolant system loop 3 hot leg	North	104.4	107.6	1.0
			East	81.9	181.3	0.5
			South	31.6	31.6	1.0
			West	51.1	106.8	0.5
C1100	02U01	Reactor Coolant Pump P-1-1	North	58.3	45.7	1.3
			East	71.7	88.4	0.8
			South	91.8	97.6	0.9
			West	106.7	75.2	1.4
C1100	02U02	Reactor Coolant Pump P-1-2	North	74.4	52.2	1.4
			East	35.3	29.9	1.2
			South	23.8	23.5	1.0
			West	20.3	19.5	1.0
C1100	02U03	Reactor Coolant Pump P-1-3	North	6.0	6.5	0.9
			East	72.9	50.1	1.5
			South	30.5	27.8	1.1
			West	20.6	21.0	1.0

Exposure Rates - 15 cm and 1 meter

