

HSA

Historical Site Assessment

MYAPC

HSA ID# 95

RADIOLOGICAL INCIDENT REPORT INDEX

Steve White

Phil Mann

1987

RIR #	TITLE
87-1	RWST Siphon Heater Area
87-2	RCA/Drumming Room
87-3	Loop 2, el-2, RCM 23
87-3a	Checkpoint
87-3b	Checkpoint
87-4	Containment Outerannulus
87-4a	Checkpoint
87-4b	Checkpoint
87-4c	Checkpoint
87-4d	Checkpoint
87-5	High Rad Barrier
87-6	CTMT Trash Storage Area
87-8	CTMT, Loop 1
87-7	High Rad Areas over 1,000 mRem
87-8	Spray Building el 36' T.S. 5.12 Locked Door #1
87-9	ADT "Tank" Cubicle Door
87-035	Investigation of Inappropriately Positioned High Radiation Area Barrier

*Jrc
Training Lab.*

RADIOLOGICAL INCIDENT REPORT INDEX

1988

RIR #	TITLE
88-1	Potential for Loss of Source Control
88-2	RWST Siphon Heater Leak
88-3	Personnel Contamination Not Immediately Removed
88-4	RWST Siphon Heater Repeat Leak
88-5	Radwaste Shipment - Resin Found in Cask
88-6	Dosimetry Records - Termination Letters Not Issued
88-7	Radwaste Shipping Violation - Filters had to be stabilized in HIC or solidified because isotopes with $T_{1/2} > 5$ years exceed 1 uCi/cc total
88-8	Radioactive Material Shipping Violation by SEG on an Empty B-88 box which read 375 mR/hr
88-9	Radioactive Shipping Paper Discrepancy
88-10	Using Outdated Vendor Procedure
88-11	Entering posted high rad area without survey meter and/or RWP - Tech spec 5.12 violation
88-12	HRA entry without RWP - Potential
88-13	Storage of respirators filter cartridge barrels - potential Part 20 violation
88-14	Hi Rad Key inventory discrepancy
88-15	Personnel contamination from "Hot Particles"
88-16	Exceeding administrative overexposure limits by more than 10%
88-17	High Airborne Activity 89.5 MPC hrs/hr
88-18	Significant skin exposure exceeding 750 mRad (D. Magnarelli)
88-19	Administrative overexposure (greater than 10%) but not over Part 20 limits (exceeded quarterly limit 2282 vs. 2000 limit)
88-20	Personnel contamination from hot particle
88-21	Personnel contamination from hot particles
88-22	Worker exceed weekly dosimeter limits
88-23	Contamination found inside the Wiscasset Wall

88-24 '1	Voided
88-25	Violation of 10CFR20.408(b) 2 Maine Yankee employees terminating did not receive their lifetime term letters within the 30 day period as required by Part 20.

RADIOLOGICAL INCIDENT REPORT INDEX

1993

RIR #	TITLE
93-1	Containment entry without neutron dosimetry (complete)
93-2	No RIR
93-3	Entry into a High Rad Area without T.S. Controls (complete)
93-4	Workers in loops opened locked HRA gate for a member of their work party
93-5	Multiple personnel contaminations due to venting S/G to containment atmosphere
93-6	Failure to adequately control work - 3 persons as a result (complete)
93-7	Lost Th-230 source (activity <10X Appendix C)
93-8	OPS left key ring at containment access (information only)

1994 RIR INDEX

RIR #	Title
94-1	HRA Gate found not latched (mechanical failure)
94-2	Improper paperwork for waste shipment
94-3	RC Tech Removed HRA key from site
94-4	Survey log signed off - Survey not completed (Potential NRC Violation)
94-5	RAM Shipment left on site without RP notification
94-6	PAB contaminated by Ops filter change
94-7	Tour group contaminated

*Phil
man*

1995 RADIOLOGICAL INCIDENT REPORT INDEX

RIR #	DATE	RIR TITLE	INITIATED BY
95-001	1/09/95	Loss of Control of Spare Key Locker	
95-002	2/15/95	Containment High Rad Posting	
95-003	2/14/95	Unlabeled Bag of Contaminated Rags	
95-004	2/14/95	U-pender Pit Dose Investigation	
95-005	2/17/95	Not an RIR	
95-006	3/01/95	Hot Filters in PAB Pipe Tunnel	
95-007	3/07/95	Loss of RCA by RCP Contaminated.	
95-008	3/06/95	Worker Entered HRA Without RWP Controls	
95-009	3/18/95	RP Tech Discovered T.S. HR Door Unlocked	
95-010	3/04/95	Multi-Personnel Contaminations in LSA	
95-011	3/24/95	Worker Exceeded Admin Level in Ugly Bucket	
95-012	4/03/95	Improper Posting of T.S. HR Entrance	
95-013	5/28/95	Unauthorized Delivery of Radioactive Material	
95-014	6/02/95	Failure to Respond to a Request for Exposure	G. Stewart
95-015	6/21/95	Failure To Post Notice of Violation	E. Heath
95-016	6/29/95	Inadvertant Release of Radioactive Reed Switches	J. O'Connor
95-017	6/30/95	Unaccounted High Rad Key	J. O'Connor

1995 RADIOLOGICAL INCIDENT REPORT INDEX

RIR #	DATE	RIR TITLE	INITIATED BY
95-018	7/12/95	Limited Quantity RAM Shipment Found Stored in Warehouse	A. Capristo
95-019	7/21/95	Out of Specification Receipt of Radioactive Material/Related Receipt Issues	
95-020	7/24/95	Possible Compromise of Tech Spec 5.12 Barriers	G. Stewart
95-021	8/1/95	Contamination of PAB during Decon of Pipe Tunnel	
95-022	8/14/95	ISCO Composite Sampler found Non-operational	
95-023	8/17/95	Significant Potential to Exceed Public Dose	G. Stewart
95-024	8/30/95	T.S. 5.12--Unauthorized Access	R. Shippee
95-025	9/07/95	Unauthorized Receipt of Radioactive Material	A. Capristo
95-026	9/08/95	Potential T.S. 5.12 Violation	M. Finn/J. O'Connor
95-027	9/13/95	Failure to Perform Frisk Prior to Exiting Restricted Area	M. Finn
95-028	9/24/95	Containment Pressurizer Door found ajar	R. Shippee
95-029	9/25/95	Improper Posting of High Rad Area	A. Capristo
95-030	10/02/95	Release of Contaminated Modesty Garments	R. Shippee/R. Warnick
95-031	10/03/95	Unposted Access to the Restricted Area	R. Shippee

1995 RADIOLOGICAL INCIDENT REPORT INDEX

RIR #	DATE	RIR TITLE	INITIATED BY
95-032	10/07/95	Failure to Follow H.P. direction-- interference with H.P. Tech.	J. O'Connor
95-033	10/08/95	Violation of RWP Dress Requirements--Westinghouse	J. O'Connor
95-034	10/19/95	T.S. High Rad Door Found Opened & Unattended	A. Capristo
95-035	10/19/95	Radiological Spill in the CS Building (UOR 95-080)	E. Heath
95-036	11/13/95	Use of Long Handled Tools in the Reactor Cavity	A. Capristo/D. Widger
95-037	11/15/95	High Rad Key Control (OPS)	J. O'Connor
95-038	12/01/95	Loss of Control of T.S. High Rad Key	R. Warnick
95-039 (DRAFT)	12/08/95	Failure to Read SRD Procedure 9-7-100 Violation (DRAFT)	J. O'Connor
95-040	12/10/95	Loss of Control of T.S. High Rad Key	A. Capristo
95-041	12/11/95	Exposure in Excess of Administrative Limits	M. Finn
95-042	12/07/95	Unanticipated Creation of HRA-- UOR 95-096	S. Shelanskey
95-043	12/12/95	T.S. 5.12 Door Watch Found Asleep	J. O'Connor
95-044	12/12/95	Failure to Initial Source Check Sticker on a Survey Meter RO-2A and Potential to Use an Unsource- Checked Meter	Y. Zhu
95-045	12/15/95	Limited Quantity Shipment Out of Spec.	M. Readinger
95-046	12/17/95	Unposted High Radiation Area in Spent Fuel Pool Building	R. Shippee

1995 RADIOLOGICAL INCIDENT REPORT INDEX

Page 4 of 4

RIR #	DATE	RIR TITLE	INITIATED BY
95-047	12/18/95	Spread of Contamination beyond Contaminated area boundaries	J. O'Connor

1995 RADIOLOGICAL INCIDENT REPORT INDEX

RIR #	DATE	RIR TITLE	INITIATED BY
95-048	12/21/95	Apparent Falsification of HP Instrument Source Check Records	Y. Zhu

1996 RADIOLOGICAL INCIDENT REPORT INDEX

RIR #	DATE	RIR TITLE	INITIATED BY
96-001	01/03/96	Gate House Portal Monitor Alarm	R. Shippee
96-002	01/05/96	Unexpected radiation levels outside the RA	D. Lagueux
96-003	02/29/96	Gas Leak in PAB	J. O'Connor
96-004	3/15/96	Area Monitor Found Not Source Checked	Y. Zhu
96-005	4/5/96	Unposted Radiation Area	G. Collins
96-006	4/5/96	Maint. Cut Piping at CH-99 with Sys. Press.	E. Heath
96-007	4/16/96	Gas Release During VCT Burp	G. Collins
n/a 96-008	4/16/96	Contaminated hose found in clean area	G. Collins
96-009	6/27/96	Failure to Perform Adequate Personnel Monitoring	M. A. Finn
96-010	7/16/96	Unanticipated Extremity Exposure During Filter Change-out	G. M. Collins
96-011	7/29/96	Spill of H ₂ O from down-ended rack	P. Plante
96-012	8/16/96	High Rad Key left in AO's locker	Ops
96-013	9/20/96	Spill at PD Pump Area	Ops
96-014	9/25/96	Rad Material found in uncontrolled area	A. Capristo

1996 RADIOLOGICAL INCIDENT REPORT INDEX

RIR #	DATE	RIR TITLE	INITIATED BY
96-015	10/17/96	Contaminated Tools Outside of Controlled Area	J. O'Connor
96-016	12/4/96	Hot particle found in chair	M. A. Finn

UNUSUAL OCCURRENCE REPORT LOG

YEAR 1987

Report No.	Date	Subject
1-87	1/3/87	#2 governing valve will not return to normal position during turbine valve test
002-87	1/3/87	RWST Leak
003-87	1/6/87	Improper Assembly found on BA-10
04-87	1-8-87	DG-18 low fuel oil pressure / improper strainer assembly
5-87	1-9-87	APSC channels A, B, D Loss of Load Trip + Pretrip Alarm lights without plant trip
6-87	1/12/87	Loss of control power to the #1 RRM's cabinet
7-87	1/13/87	TM/LP Ch B Pretrip
8-87	1/13/87	DG IA inoperable due to a burned foot relay
9-87	2-1-87	MS-169 + MS-185 Found Maloked
10-87	2-5-87	Main CEP bottles inoperable.
11-87	2-6-87	PAP Flammless
12-87	2/12/87	PVS APD pump tripped
13-87	2-13-87	SFP JIB crane installed w/o yellow tag
14-87	2/18/87	PVS APD pump tripped
14A-87	2/23/87	CEA 34 position indication during CEA exercising
15-87	2/22/87	ENS phone inoperable
16-87	2/25/87	Caustic spill in H ₂ O treatment area
17-87	2/25/87	RWST Heater Leak
18-87	2-6-87	Air Ejector Whistling
19-87	3-13-87	Loss of power to CEAS stationary sirens
20-87	3-14-87	HEATER DRAIN TANK HIGH LEVEL CONTROL VALVE OPENED AT POWER
21-87	3-15-87	STEAM GEN. LO PRESS. PRE-TRIP "locked in" on Ch. B
22-87	3-17-87	F26 control valve to Fuelvent PI 1206

UNUSUAL OCCURRENCE REPORT LOG

YEAR 1987

Report No.	Date	Subject
23-87	3/18/87	Reversal of drum valve operation control for first point heater extraction steam stream
24-87	3-20-87	Channel A B and D RPS S/G to press pedrip lock
25-87	3-21-87	Long Handled Fuel Tool damaged in Spent Fuel Pool
26-87	3/21/87	Violation of Tagging Rules by Complete removal of a tagged shut valve
27-87	3-22-87	Excessive Load on TK-35 (Seal Water Ref Th...)
28-87	3/26/87	Loss of CW flow and vacuum pumping in "A" water box with "B" box ops
29-87	3/27/87	E-11A FW safety valve failed open FW-S-31
30-87	3/27/87	P-28 failed to start Tripped immediately following start
31-87	3/28/87	Trip of containment purge when T+H was opened during plant shutdown
32-87	3/28/87	RCF#2 trip when loop 2 TC stop valve (ECH21) was partially stroked.
33-87	3/30/87	Spring Hanger SI-H-29 found blocked.
34-87	3/30/87	Aux. Boiler vents left open causing B-1A F.D. Fan to Start.
35-87	4-3-87	Burned Sump pump in circ house
36-87	4/6/87	Violation of Tagging Rules by signing clear of incorrect Tagging order
37-87	4/9/87	Water from RWST drained into RHR system when RWST was secured to investigate low level indication discrepancies.
38-87	4/11/87	SCC isolation valves open with their trip function disabled.
39-87	4/14/87	RAS activation Deenergizing DP/BUCK 16
40-87	4-14-87	Plastic piece found in CE valve seat
41-87	4-14-87	Broken Fuel Pin result of reconstituted
42-87	4/14/87	SCC ^{spill} tank at Seal Oil Unit due to Inadequate Drainage
43-87	4/17/87	Tagging violation - Air isolation valve tagged shut lined open.
44-87	4-24-87	Disconnection of 2ST and 2nd pt tank blanket steam
45-87	4-24-87	Refructing Machine. Apparent collision.

UNUSUAL OCCURRENCE REPORT LOG

YEAR 1987

0575

Report No.	Date	Subject
46-87	4/24/87	PCC overflow at Tanker Truck Filling Pan E-3A
47-87	4-24-87	Through wall crack one inch long on RWST
48-87	4/29/87	MS-S-32 failed surveillance
49-87	4-30-87	Worker Injured with through access opening
50-87	4-30-87	Torque switch on CS-M-91 set low / wrong spring pressure
51-87	5-4-87	Leak on RH-8
52-87	5/4/87	SCC-A-460,461 open with ^{disabled} strip function
53-87	5-5-87	SCC and PCC interconnection on loss of control air
54-87	5-6-87	SCC Isolation valves inadvertent opening
55-87	5/9/87	Fire barrier door found open
56-87	5/9/87	Steam Generator Safety MS-5-16 ^{surveillance} failed
57-87	5/11/87	HSI-M-54,55 failed MOVATS
58-87	5/11/87	Overflowed upender Pit to ICI Sump
59-87	5/11/87	Choked Water Spill
60-87	5/12/87	ADT overflowed thru SL-58 to PAB floor
61-87	5/13/87	Raychem Heat Shrink Tubing on WIRE SPICES for Conn Seal Assemblies may not meet EA Requirements.
62-87	5/13/87	Crane tipped over in equipment hold area outside containment
63-87 62-87	5/18/87	CH-M-86 Rotating Valve Stem
64-87	5/15/87	Polynuclear Aromatic Hydrocarbons
65-87	5/22/87	Excitor Activation relay for Cable Vault inoperable
66-87	5/22/87	SH HT-X Drain Valve ^{checked} but not on PM's or in 1-12-5
67-87	5-22-87	EQ Discrepancy in Cont Sump level transmitters
68-87	5-23-87	MS-S-170 Relief on P-25R tested inoperable

UNUSUAL OCCURRENCE REPORT LOG

YEAR 1987

Report No.	Date	Subject
69-87	5/24/87	P-14A LOSS OF DISCHARGE PRESSURE MA FLOW
70-87	5-25-87	Distortion of Pipe Support in PZR cubicle
71-87	5-25-87	charging Pump Dixie ct valves nuts loose
72-87	5-26-87	Loop RTD. EQ discrepancies in 4 RTDs
73-87	5-27-87	Steam Generator over pressurization
74-87	5/28/87	P14 B failed to start.
75-87	5/28/87	Lowered PZR level while recovering RWST.
76-87	5/29/87	Load shift During Installation of Fueler Manway
77-87	5-30-87	DG-1B Start Failure + Low Frequency.
78-87	5/30/87	Temporary instrumentation installed on Loops 7 & 8
79-87	5/31/87	Inadvertent transfer 200 gal from BAST to #2-SIT
80-87	6/1/87	P12 B found running backward
81-87	6/2/87	"A" test route unacceptable for release and unacceptable for refueling.
82-87	6/4/87	HELB "B" Steam fired when TIA 242 C & D were deenergized.
83-87	6/4/87	200 gal of NaOH from SCAT dumped into RWST.
84-87	6/4/87	PPT 110 (core AP) strainmeter damaged when valved in.
85-87	6-4-87	P-14A auto trip in green flag
86-87	6-5-87	HSI-11-41 Failed to Close
87-87	6-5-87	HSI-5-47 latched during ECCS valve tests
88-87	6-6-87	PT-303, 1/2 RWST Header pressure, zoning line between leak
89-87	6-8-87	P-25B reaction relief lifting when starting pumps
90-87	6-8-87	Lightning Strike at Foxboro
91-87	6-10-87	PW-51 leak causes RCS dilution

UNUSUAL OCCURRENCE REPORT LOG

YEAR 1987

Report No.	Date	Subject
92-87	6-13-87	Auto trip of BKR 8F8A while trying to X tie Bus 7+8
93-87	6-13-87	Auto trip of BKR 8A1 ⁶⁰⁸¹ and loss of Bus 7+8 loads
94-87	6-15-87	Steam Dump/Turbine Bypass Switches Misplaced
95-87	6-16-87	CH-A-32 Locking By
96-87	6-18-87	E decay drum inadvertent release while releasing "D" dec ^{dec}
97-87	6-19-87	ACB 2R auto close while ACB 2U already powered ds.
98-87	6-20-87	Unusual Rhythmic Clanging Sound at E-4A inlet
99-87	6-22-87	Seismic Problem with ICI Seal Table
100-87	6-26-87	Inappropriate use of MS-91 and MS-92 or long term (> 72 hrs) rebound for MS-90
101-87	6-27-87	Close Call on #3 SG Level
102-87	6-27-87	Manual Trip, close to #3 STG in control on loss of MFRV control.
103-87	6-29-87	AMERTAP Bolts clog takes in ESB
104-87	6-29-87	P25B, inoperable due to improper ms-5170 ^{operation}
105-87	7-1-87	Manual ^{turbine} Trip due to high vibration on #5 bearing
106-87	7-2-87	SCCM 165 failed to cycle
107-87	7-3-87	CST Level Indication Isolated
108-87	7/7/87	FK 85 not 5 feet of water in FK 85 cabinet Waste Basin Storage Tank
109-87	7-9-87	CH-M-49 Apparently Cycling Open & Closed
110-87	7-10-87	Unidentified Valve off CH-50
111-87	7-10-87	Na ⁺ in RCS
112-87	7-13-87	Low 115KV Line Alarm When Starting #3 RCP
113-87	7-15-87	SIT #3 Leak To Quench Tank Through ^{SIA-541}
114-87	7-15-87	Channel B Hi PZR, Press Pre TRIP

UNUSUAL OCCURRENCE REPORT LOG

YEAR 1987

Report No.	Date	Subject
115-87	7-26-87	BA-46 leakage due to line overpressure
116-87	7-30-87	RCS cooldown while on RHR
117-87	8-3-87	Unexplained C ₀ decrease
118-87	8-6-87	PW-A-78 limit switch cover ajar
119-87	8-7-87	Small Oil Spill into CW Discharge Forebay
120-87	8-12-87	Broken Manning Bolting on KV Head/Pee Vent System MEXS. motor operators
121-87	8-14-87	RCS cooldown while putting on RHR
122-87	8-16-87	High pH In The CST CST CANSLC ^{DEC} Intubation
123-87	8-17-87	Unexplained SFP level increase
124-87	8-17-87	PVS APD High Press. Sizing line plugged
125-87	8-20-87	CONTAMINATED RAGS, 800 mg/hr, FOUND IN WASTE DRUM AT CMT ACCESS.
126-87	8-22-87	HELCAP failed to withdraw
127-87	8-24-87	Main Feedwater Regulating Valves, Isolation valves FW 108, 208, 308 found shut
128-87	8-27-87	PAC STANDBY CONTROL/LUBE OIL PUMP AUTOSTART
129-87	9-1-87	FAILURE OF INVERTER #6 AND LOSS OF COMPUTER BEFORE TRANSFER TO ALTERNATE POWER SUPPLY
130-87	9-3-87	Pressurizer Degasification Path To VET isolated
131-87	9-10-87	P-25A INOPERABLE DUE TO BEARING OIL LEAK
132-87	9-11-87	ASP LOOP COLD LEG TEMP. IND. FOR LOOP 1 & 2 ^{IN-ORANGE}
133-87	9-14-87	ISOLATION OF 1 st POINT FEEDWATER HEATER (E-110) HI LEVEL ALARM TRANSMITTER RESULTS IN FEEDWATER HEATER SYS. OSCILLATION UNEXPECTED COMPUTER ALARM MESSAGES + CHA RPS LO FLOW
134-87	9-14-87	TRIP DURING COMPUTER DEPT. SURVEILLANCE.
135-87	9-15-87	RAD. PANEL ALARMS DUE TO ERRATIC SIGNAL FROM ^{OUT-OF-SEAR} MONITOR
136-87	9-16-87	Inadvertent use of P145

UNUSUAL OCCURRENCE REPORT LOG

YEAR 1987

Report No.	Date	Subject
138-87	9-17-87	Aux. Feed PP. (P-25B) DECLARED INOPERABLE.
139-87		
140-87	9/18/87	CHAN. A DT POWER SPIKE RESULTS IN MOMENTARY CHANNEL A SD TRIP, HI POWER TRIP, TM/LP TRIP
141-87	9/18/87	FAILURE OF CONTROL AIR DRIVER (FL30A)
142-87	9/20/87	FAILURE TO ENTER REMEDIAL ACTION OF PROPOSED T.S. 3.21 FOR P-7 INOPERABILITY
143-87	9/21/87	SMALL LEAK IN BODY OF DISCHARGE CHECK VALVE FOR LEWPP?
144	9/20/87 9/26/87	HIGH BORDON CONCENT. IN THE "A" TRAIN HPSI SUCTION LINE
145	9/26/87	CHANNEL "D" HI POWER, TM/LP & SD TRIPS DECLARED INOPERABLE
146	9/29/87	VACUUM LOSS DUE TO AIR LEAK AT THE S/G BLOWDOWN TANK
147	9/29/87	MISPOSITIONED VALVES ON QUENCH TANK LEVEL CONTROL
148	10/2/87	LOW STM. GEN. MARGIN TO SATUR. ALARMS DURING RPS SURVEILL.
149	10/2/87	RPS CHANNEL B SPURIOUS TRIPS ON TM/LP AND HI POWER
150 ^{ADD.}	10/3/87	#3 S/G CAD HIGH LEVEL INDICATION DURING RPS S/G LOW LEVEL SURV
150	10/3/87	SAME AS ABOVE ↗
151	10/5/87	Feed Train Transient Due To E-11B LoLv Alarm INABILITY TO DRIVE. CAUSE DUE TO FAILURE COIL POWER PROGRAMMER TIMER MODULE.
152-87	10/9/87	
153-87	10/11/87	RUST SYPHON HEATER LEAKAGE
154-87	10/13/87	DROPPED ROD # 55 (GROUP 1)
155-87	10/13/87	P-14A (Charging/HPSI Pump) Auto Start During ECCS ^{Routine} Testing
156-87	10/14/87	DROPPED ROD # 19 (GROUP 9)
157-87	10/21/87	MODCOMP Failure
158-87	10/20	P-7 SUCTION PRESS. TRIP FAILED.

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1987

REPORT NO.	DATE	SUBJECT
159-87	10/31/87	RUST HEATER RETURN LINE CRACK
160-87	10/31/87	WATER IN DIESEL STARTING MOTOR EXHAUST
161-87	10/30/87	LOW TRIP/LE VALVE ON CHANNEL A POS
162-87	11/2/87	BROKEN SHEAR PIN ON "C" TRAVELING WATER SPEED
163-87	11/4/87	TRIPPED ENGINEER'S VALVE. DESIG. REGR. AT CR. DR. VU
164-87	11/4/87	A LOCKED SHUT GAS VALVE (GS-103) FOUND COMPLETELY OPEN
165-87	11/8/87	JUST RESERVE POWER AVAILABLE/ TO BUSES 1&2.
166-87	11/11/87	UNMANAGED LEAD SHIELDS ON SEAL HD RETURN LINE 400 #3
167-87	11/15/87	Condenser Vacuum Loss due to Degraded Air Filter (CF 5174)
168-87	11/18/87	P-25 B SERVICE WATER PUMP BEARING LEAKS. H ₂ O BACKUP SUPPLY PUMP LOCATED.
169-87	11/23/87	ELECTRIC FIRE PUMP (C-4) DISCHARGES CHECK VALVES (ES-9) STUCK OPEN
170-87	11/24/87	DEGRADATION DIESEL GENERATOR) DETECTED IMMEDIATELY DUE TO FAULT IN STARTING SEQUENCE CIRCUITRY.
191-87	12/1?	VOID
172-87	12/1/87	PGC-M-43 FAILURE TO OPEN
193-87	12/13/87	LOW HPS1 SUCTION CR
194-87	12/14/87	DROPPED CGA #55 DURING CER EXERCISES
195-87	12/19/87	H51-M-57 TORQUE SWITCHES WIRING INCORRECT.
196-87	12/16/87	BLIND FLANGE ON PGC RETURN MEMBER FRONT STMT RECEIVE EBN VOLTAGES WITHIN CT BANDWIDTH BUT NOT C-T
197-87	12/18/87	TUNING DIEFFERENTIAL & WINDING DURING TUNING VALVE TESTING
198-87	12/9/87	Cover Plate for CI Valves Not Properly Locked
199-87	12/14/87	PGC LEAK ON #2 CDM COOLING EBN UNIT

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1988

REPORT NO.	DATE	SUBJECT
1-88	1/5/88	REACTOR TRIP DUE TO LOSS OF BOTH HIR. DR. PUMPS CEA #47 WOULD NOT DROP DURING RX TRIP BRASSER MANUAL TEST.
2-88	1/5/88	INABILITY TO WITHDRAW CEA #53
4-88	1/5/88	LOSS OF CONDENSER LEVEL CONTROL AND INSTRUMENTATIONAL LOSS OF COMMUNICATIONS TO DIRECT NRT, CEP, AND STATE POLICE PHONES.
5-88	1/7/88	
6-88	1/12/88	MISSED SURV. FDR COMSIP HA ANALYZER ADMINISTRATIVE CONTROL OF EGCS VALVES AS REQUIRED BY TECH. SPEC. 3-6.
7-88	UNKNOWN (1/15/88)	
8-88	1/16/88	PEAS TELEPHONE PROBLEM.
9-88	1/19/88	DROPPED CEA #34 DURING EXERCISES. POWER REDUCTION TO 2000 MUST TO COMPENSATE FOR CADMETRIC GAS.
10-88	1/27/88	
11-88	2/3/88	DROPPED ROD #55 (GROUP 1)
12-88	2/3/88	FAILED TURBINE BYPASS VALVE CONT. (MS-P-143)
13-88	2/4/88	MISALIGNED ROD #55 (GROUP 1)
14-88	2/4/88	TWO ENS (RED PHONE) LINES OUT OF SERVICE
15-88	2/4/88	EHG SYSTEM LEAK ON "D" MSR INTERCEPT VALVE LOSS OF PRIMARY AUXILIARY BUILDING PANEL PUMP/ARMS
16-88	2/4/88	
17-88	2/11/88	IMPROPER OH-M-1,87 TORQUE SWITCH SETTINGS
18-88	2/15/88	SL6 Blowdown Sample Sled
19-88	2/17/88	Loss of Comm. by ENS, State Police & A&T Lines
20-88	2/23/88	RUST SIPHON HEATER FLANGE LEAK RUST SIPHON HEATER RETURN LINE ISOLATION VALVE LEAK.
21-88	2/24/88	

UNUSUAL OCCURRENCE REPORT LOG

YEAR 1988

Report No.	Date	Subject
22-88	2/29/88	DROPPED CEA #55 DURING CEA EXERCISES
23-88	3/10/88	INADVERTANT PEAS ACTIVATION!
24-88	3/14/88	P-143 SUCTON PIPING AND PRESSURE CONTROLLER OVERPRESSURIZATION DUE TO LEAK BY CH-27 E CH-2.
25-88	3/14/88	INADVERTANT ORDUCE VALVE ACTIVATION FOR TRIP 1-11
26-88	3/18/88	PRIMARY VENT STACK AND PUMP TRIPPED & WOULD NOT RESTART.
27-88	3/23/88	CONT. LEAKAGE FROM OUTSIDE THE PAB INTO THE PAB SUMP.
28-88	4/2/88	LIQUID WASTE DISCHARGE IN EXCESS OF PRE REPORTED AMOUNT
29-88	4/6/88	FEEDWATER CHECK VALVE (FW-315) LEAK
29-88 A	4/12/88	CEA 51 DROPPED DURING CEA EXERCISING
30-88	4/14/88	INCORE MONITORING SYSTEM INOPERABLE
31-88	4/16/88	INADVERTANT PEAS ACTIVATION
32-88	4/20/88 4/18/88	P-143 FAILED TO TRIP ON HIGH PRESSURE AFTER AUTO START WHEN IN STANDBY.
33-88	4/26/88	RWST SIPHON HEATER RETURN LINE BREAK
34-88	4/27/88	AIR LEAK ON BD-T-146 (SG#3 B/D HELP VALVE)
35-88	4/29/88	SECURITY RED PHONE REPORT
37-88	5/5/88	COLLECTION OF WASTE OIL IN TURBINE HALL SUMP
38-88	5/17/88	MISSING VELOCITY TAGS ON 4PSI INLET LINES
39-88	5/22/88 5/20/88	OVERFILLING OF RWST COLLECTION BARREL ENS CALL TO NRC REF. 3
40-88	5/23/88	SOLENOID OPERATED VENT VALVES (CH-185-1225)
41-88	5/24/88	SCC-M-165 FAILURE
42-88	5/27/88	RWST SIPHON (LEAK) HEATER RETURN LINE ISOLATION VALVE

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1988

2517-14

REPORT NO.	DATE	SUBJECT
43-88	6/2/88	BORON WASTE STORAGE TANK DIPPED AHEAD SUMP DRAIN VALVE TO YARD STORM DRAIN FOUND OPEN
44-88	6/15/88	PANALARM R-4-4, INCORE TUBE LEAKAGE DISCONNECTED DURING 1980 OUTAGE
45-88	6/23/88	IMPROPER TAG-OUT OF CH-F-38 FOR SOLENOID REPLACEMENT
46-88	6/23/88	CH-F-38 TERM. BUCK NOT PROVEN QUALIFIED
47-88	6/23/88	FALSE IDENTIFICATION OF REACTOR POWER BY COMPUTER
48-88	6/26/88	HIGH PRESSURE DRAIN SYSTEM TAGGING VIOLATION
49-88	6/28/88	MOTOR OPERATED (176-18) OUTPUT BREAKER TRIPPED OPEN
50-88	7/5/88	FAILURE TO ENTER TECH SPEC. 3.12 REMEDIAL ACTION FOR HSI-M-50 INOPERABILITY
51-88	7/7/88	SEISMIC CONCERNS ON THE WEST SIPHON HR. (E 40) FOUNDATION ^{DU} TO ADJACENT EVACUATION
52-88	7/11/88	GRID VOLTAGE LOW
53-88	7/13/88	ASH BOY RECEIVED, CONTAINMENT GREATER THAN 10CFR LIMIT.
54-88	7/14/88	CONTAINMENT PERSONNEL HATCH UNLOCKED WITHOUT SECURITY PERSONNEL PRESENT
55-88	8/3/88	INCREASED LEAKAGE TO CONTAINMENT SUMP DUE TO LEAKAGE FROM SAFEGUARDS SUMP
56-88	8/1/88	RHODIUM ALARMS INOPERABLE
57-88	8/9/88	TEMP. JUMPER INSTALLED ON FN-5 4/OUT V. TAG
58-88	8/10/88	BUS 5 AND/OR BUS 6 LOW VOLTAGE COND.
59-88	8/11/88	176-19 ROOM HEAT DETECTOR ACTUATED
60-88	8/13/88	CEDS POWER FAILURE
61-88	8/13/88	REACTOR TRIP DUE TO FAULT IN X1A
62-88	8/16/88	MAN INJURED WHILE WORKING ON GENERATOR DURING HIGH POT TEST
63-88	8/17/88	ACTIVITY FOUND IN PRIMARY VEHT STACK CONDENSATE.

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1988

REPORT NO.	DATE	SUBJECT
64-88	8/17/88	STREAM LEAK ON HPD-4
65-88	8/19/88	UNEXPECTED GASEOUS RELEASE DURING F-3 DEMINERALIZER RESIN FILL
Adendum 65-88	8/22/88	Addendum to UOR 65-88
66-88	8/22/88	ADS GROUP B PAPER FAILURES
67-88	8/25/88	GAS LEAK AND CONTAMINATION RPD.
68-88	8/25/88	DRAIN DRUM RELEASES UNIT WASTE GAS RMS PBS
69-88	8/27/88	MAINT REPAIRED WOUNDS EVERY AIR CYLINDER
70-88	8/28/88	MAINT TRANSFORMER X-15(A) FAILURE DUE TO PHYSICAL
71-88	9/1/88	'C' CUM PUMP (P-262) LOW GROSS/CAVITATION
72-88	9/7/88	SPDS WILKING DISCREPANCY IMPROVED DEPENDENCY OF INDEPENDENT CHANNELS
73-88	9/7/88	RECEIVED INTERMITT. RPS CH. 'C' VARIABLE OVERPRESSURE TRIP
74-88	9/8/88	SG-#2 LEVEL TRANSDUCER CLOSE TO HIGH LEVEL TURBINE TRIP SETPOINT
75-88	9/13/88	PNS CALL FOR CONTROL ROOM VENT.
76-88	9/15/88	LOSS OF PANHANDLE SECTION "SS"
77-88	9/21/88	SMALL FIRE IN X-1A WHILE PERFORMING FOR SWANSON OFFSHORE. EXHAUST FOUNDS IN THE SHOWER ROOM OF THE SHOWER ROOM + ADDENDUM
78-88	9/28/88	CONTAMINANT IN THE RI ROOM ROOM + ADDENDUM
79-88	9/30/88	P-12A OIL FAILED SURVEILLANCE
80-88	9/30/88	TCE-4 Problems
81-88	10/2/88	PRESSURIZER LEVEL GUIDANCE DISCREPANCY DURING TE CONSIDERATION OPERATION
82-88	10/5/88	LOW VOLTAGE ALARM - 115KV SECT. 207
83-88	10/5/88	HP51 SUCT. SAMPLE VALVE LEFT OPEN.

6154M/OPS-MISC

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1988

REPORT NO.	DATE	SUBJECT
84-88	10/7/88	CONTAINMENT PURGE EXHAUST VALVES HANDWHEELS NOT CONNECTED
85-88	10/11/88	WORKER FROM BROWN BOYER WAS TRANSPORTED TO THE HOSPITAL, (HEAT SICKNESS?)
86-88	10/11/88	MINOR INSTRUM. LOSS CAUSED BY LIGHTNING STRIKE AT PLANT SITE.
87-88	10/15/88	#1 RCP VAPOR SEAL FAILURE
88-88	10/18/88	WHITE TAG ORDER VIOLATION (WORK COMMENCED BEFORE TAGS WERE HUNG)
89-88	10/20/88	Inadvertant Flooding from E-11A
90-88	10/20/88	SEC NON-SAFEGUARDS ISOLATION VALVE TRIPPED
90-88 Moderatum	10/21/88	SEC NON-SAFEGUARDS ISOLATION VALVE TRIPPED
91-88	10/21/88	Liquid Spill in Spray Building
92-88	10/22/88	Injured worker
93-88	10/23/88	SEC-A-461 Found open and inoperable SEC non safeguards return isolation
94-88	10/23/88	missing ees #1 Keyring
95-88	10/25/88	INCONSISTENCY BETWEEN FE DRAW. & FIELD CONFIGURATION
96-88	10/26/88	WR NI CH B INADVERTANTLY DEENERGIZED
97-88	10/28/88	lost spot level indication
98-88	10/29/88	Wrong cable cut in cable vault
99-88	10/29/88	RC-M-33 Mis-wired open switch
100-88	10/30/88	Loss of Telephone Communication
101-88	10/31/88	PC-M-43 Did not fully stroke UNDER PRESSURE DIFFERENTIAL
102-88	11/1/88	RHR TEMPERATURE DISCREPANCY DUE TO INCORRECT PEN
103-88	11/1/88	SUBCOOLING MARGIN MONITOR WIRING DISCREPANCY
Supplement	11/1/88	Supplement to ↗

6154M/OPS-MISC

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1988

REPORT NO.	DATE	SUBJECT
104-88	11/2/88	MAIN STEAM RMS & SMOKE DETECTOR FAILURES DUE TO RAIN IN LEAKAGE TO VALVE HOUSE
105-88	11/3/88	WIRING DISCREPANCY IDENTIFIED IN MEG H ₂ ANALYZER WIRING TO REORDERERS REVERSED
106-88	11/3/88	STEAM END SAFETY VALVE SURVIVAL FAILURES
107-88	11/4/88	SG LEAK DURING REMOVAL OF MAIN LINE OIL COOLER
108-88	11/4/88	X-15 TROUPE DURING BACKFEED FROM 345 KV VARD
109-88	11/4/88	SMALL FIRE AT H.P. TURBINE DUE TO CUTTING WITH AN INADEQUATELY TRAINED COMBUSTIBLE INSERTION
110-88	11/8/88	LACK OF ENVIRONMENTALLY QUALIFIED WIDE RANGE NUCLEAR POWER INDICATION
111-88	11/8/88	MOTOR OPERATOR REMOVED FROM VALVE WITH WHITE TAG ATTACHED
112-88	11/10/88	Breaker 718 Vipped Open W/O Testing Breaker Lock
113-88	11/10/88	Desertek Purup Fuel Tank Level Less than Tech Spec limit of 75 gallons
114-88	11/11/88	Loss of Power to BUS 8 & BUS 7 & MCCS
115-88	11/11/88	Improper Assembly of 480 Volt Breakers and Resulting Contact Finger Damage during Attempted Installation
116-88	11/12/88	DG-1A Fuel Oil Filter Improperly Assembled
117-88	11/13/88	Waking SCC Volume
118-88	11/14/88	TAPORE INSTRUMENT CABLE WIRING DISCREPANCIES
119-88	11/12/88	AC-M-13 LIMIT SWITCH FOUND MIS-WIRED
120-88	11/15/88	SECURITY SYSTEM 480V BREAKER TRIPPED
121-88	11/15/88	REFUELING MANHOLE DAMAGED
122-88	11/16/88	480 V SUPPLY BREAKER FAULTY DUE TO IMPROPER LATCH SETTING
123-88	11/17/88	Reburnished 480 V Breaker
124-88	11/17/88	MISSING TANTALUM TUBES MAIN TRANSFORMER DRAIN Sump pumpdown - milky liquid

UNUSUAL OCCURRENCE REPORT LOG

YEAR 1988

Report No.	Date	Subject
125-88	11/19/88	ALTERATION OF EMERGENCY BOTTLED PATH INCORRECT POWER SUPPLY TAPPED OUT DUE TO INCORRECT POWER IDENTIFICATION
126-88	11/30/88	REGULATION ACTUATION SIGNAL CHANNEL "A" DURING ROBOT DRAINING 36 SINS BIG BA FAILS TO REVERSE DURING SINS "AS LEFT" CAUTIONED
128-88	11/21/88	ADDENDUM
129-88	11/22/88	GMT SENTRY BALL WAVE (CS-103) FOUND MIS-POSITIONED EMERGENCY FEEL FROM NYC TO QUEBEC CITY DID NOT BEGET PLANT
130-88	11/05/88	MUSKIE LOUITE TAG FROM RC-M-33
131-88	11/28/88	CHEMICAL SPILL IN USED OIL STORAGE ROOM
132-88	11/29/88	CH-P-1516 FOUND NOT PROPERLY TAPPED
133-88	11/28/88	SMALL FIRE IN COMPRESSOR BAYS
133-88	12/2/88	WORDER INJURED BY VALVE OVERSIGHTS
134-88	12/5/88	LOSS OF POWER TO MGC SA
135-88	12/6/88	GOVERNMENT/NRC NOTIFICATION OF SSC SPILL
136-88	12/6/88	TYPICAL W/BLR-U-DRAWBACK/RECK #3 RCP UPPER SEAL FAILED
139-88	12/10/88	#3 RCP HRS INCREASED LEAK OFF FLOW
140-88	12/11/88	H51-M-50 HIGH OPERATING CURRENT WATER HAMMER BETWEEN HTR-DRAIN PUMP DISCHARGE AND MAIN FEED PUMP SUCTION DUE TO HD-A-180 CLOSURE
137-88		
138-88		
142-88	12/16/88	PLANT TRIP ON HI HTR-DRN TR Level
143-88	12/17/88	EXCEED W/IN CHARGED TO GMT FOLLOWING THE ESTABLISHMENT OF GMT INTEGRITY. QUICK OPERATOR INJURED BY SODIUM HYDROXIDE

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1989

REPORT NO.	DATE	SUBJECT
1-89 Addendum	12/31/88	PRC Manual Trip
2-89	1-3-89	Addendum to UOR. 2-89.
2-89	1/2/89	CRMT Hatch. Check Interval
3-89	1/3/89	FUSE BLOWN IN 1R/3R Control Circuit
4-89	1/4/89	FAULTED THRUST BEARING, THERMOCOPLES
5-89	1/9/89	DE-10 FIRE SUPPRESSION SYS. ACTIVATION - LOSS OF RED FURNACE FOR "LOSS OF 480V TO BATTERY CHARGER" (1-5)
8-89	1/10/89	CONDENSATE OVERRODDED VALVE (CD-10E) FAILURE
7-89	1/10/89	PILOT-TRIP-LOSS OF PRC SYSTEM CONTROL POWER
9-89	1/12/89	PRG. REDUCTION TO "DANGER" CLAS. TO AFD-POSITIONS G-514 MOTOR BEARING FAILURE (COND. CONTROL AIR COMPRESSOR)
10-89	1/25/89	TRANSMISSIBLE GASES TRANSDUCER PRESSURIZER DEFCS DATA FOUND-DEGRADED
11-89	1/26/89	CONV. TRANSFORMER FOR DC-117 FREQUENCY CONVERTOR ASSEMBLY FELL OFF DURING Monthly Supervisory
13-89	2/13/89	Comander Problem Stops CR Motion
14-89	2/6/89	
15-89	2/11/89	GROUND FROM 230VAC MAIN BUS DETECTION SYSTEM EQ DISCREPANCIES IDENTIFIED IN CONTAMINANT PINNACULAR AUTO SEALS H FOLLOW UP EN'S RETURN TO THE NRC
16-89 Addendum	2/14/89	
16-89	2/15/89	
89-17	2/16/89	POWDER RANGE N1 LEVEL I BISTABLES OUT OF SPEC HIGH
89-18	2/17/89	DR-M-10 AUTO OPEN SIGNAL LOCKED IN WHEN RCP'S SECURED
19-89	2/18/89	LEAKAGE PAST REACTOR HEAD VENT VALVE

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1989

REPORT NO.	DATE	SUBJECT
20-89	2/19/89	LEAKAGE IDENT. ON RH-M-1
21-89	2/20/89	ACOUSTICAL POSITION INDICATOR FOR DORY PR-3-15
22-89	2/22/89	SIG # 3 MAIN FLD REG. VALVE FAILURE (FW-E-307)
Addendum 22-89	2/22/89	SAME TITLE AS ABOVE
23-89	2/25/89	480 VOLT BUS GROUND ON BUS 7.
24-89	2/26/89	LOOSE NUTS AND PLATES ON STEEL BUILDING REACH RODS FLOOR PENETRATIONS
25-89	3/1/89	SERVICE AIR HEADER PRESSURE TRANSIENT
26-89	3/10/89	P-20 LOW SUCTION PRESSURE TRANSIENT
27-89	3/13/89	SIG # 2 PRESS. SIGMA CH. A PLUGGED HIGH
28-89	3/13/89	ELECTRICAL GRID TRANSIENT
29-89	3/14/89	C9000 COOLING FAN #1 FAILURE
30-89	3/27/89	FIRE PROTECTION SVS. VALVES NOT VERIFIED BY SURVEILLANCE, REV. 1
31-89	3/29/89	FIRE SYSTEM VALVES NOT CYCLED IN ACCORDANCE WITH TSCM SOP. 412F
32-89	4/1/89	LOW PRESSURE HTR. DRAIN SYSTEM OSC. DUE TO 2-15A NCV FAILURE
33-89	4/5/89	NIGHT TRIP - GENERATOR PROTECTIVE RELAYING ACTUATED CAUSING A LOSS OF LOAD (EGL in trip due to EIG)
34-89	4/5/89	DS-1A FUEL OIL DAY TANK OVERFILLED
35-89	4/6/89	OIL SHEEN DETECTED ON THE BACK RIVER
36-89	4/14/89	LOW IM/CP SETPOINT ON RPS CH. 'C' Signal
37-89	4/19/89	DR-A-6 (CT VALVE) INOPERABLE
38-89	4/29/89	P-26A START FAILURE FOU "A" WATERBOX BECKWITH
39-89	5/11/89	LOW IM/CP SETPOINT ON CH. "C"

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1989

REPORT NO.	DATE	SUBJECT
89-40	5/17/89	LOW IMP STEAMOT AND CHARGE "
89-41	5/17/89	#3 SIT IN LEAKAGE
89-42	5/24/89	RED OPERATIONS (S5-S9) 4 KV BUS PURSUE LOW VOLTAGE ACTIVATION
89-43	5/21/89	PRS. APD INTERLOCKS
89-44	5/28/89	FAILURE OF CONTROL AIR COMPRESSOR C.I.C.
89-45	5/28/89	FAILURE OF ALL CALL DRIP R SYSTEM P-62P QUENCH PRESSURE GUNSE AND PRESSURE CONTROL STROKED ARE NOMINATED TO GO TO
89-47	6/1/89	EXCESSIVE AND SEVERITY TOOL # 1304 CIRE HUBS OF DROPTIE VALVES (D-D-M-I) FOUND SUIT-TURNS PROXIMITY OF D BOX
89-49	6/8/89	ACTIVITY IN THE TURBINE HALL SOUND SIGNALING CONTAINER ARRIVED DURING PARD. AT VETS. PROVE NOT REQUESTED
89-50	6/9/89	SIG # 2 IS NOT MOD P-50
89-51	6/10/89	GOV. RDR VALVE OPERATIONS
89-52	6/10/89	CONT. #2 FD Rog. Valve Oscillations Red Panalarm (S5-S9) 4 KV BUS S/Y
89-53	6/19/89	LOW VOLTAGE ACTIVATION
89-54	6/23/89	RED DOWNHEM (S5-S9) 4KV BUS S/LEAD VOLTAGE ACTIVATION
89-55	7/2/89	REPORT OF PENS SIGNAL ACTIVATION AT BOOTHWAY
89-56	7/2/89	FALSE ACTIVATION OF THE PENS SIGNALS
89-57	7/7/89	CHUNKING TO H-T INDEXED BY POWER
89-58	7/7/89	KEY INOPERABLE DUE TO LOW OVERLY GAS PRESSURE
89-59	7/8/89	LIMIT SWITCH FAILURE DURING TURBINE WPTV TESTING FAILURE OF PPT FOR LS1-M-11 TO TRANSFER TO NORMAN DURING SURVEILLANCE
89-60	7/11/89	

UNUSUAL OCCURRENCE REPORT LOG

YEAR: _____

1989

REPORT NO.	DATE	SUBJECT
89-61	7/12/89	115 KV D ₁ CNDR BANK MODE FAILURE SECURITY (K-1) NOT IN AUTO MODE WITHIN 5 MINUTES TO BROKEN PAN TANK SUNDY FILTER (EL-306)
89-63	7/14/89	Comp. PUMP 115KV REPORT FAILURE BANK OPERATIONS
89-64	7/30/89	LOSS OF #1 CEDM COOLING FAN
89-65	7/31/89	SECURITY/TEMPERATURE INCIDENT
89-66	7/31/89	P-145 FAILED TO START + Addendum LUBR OIL LEAK INTO SPARE PACK FOR SEC-M-1155 VALVE ACTUATOR
89-67	8/1/89	CONTAMINANT CONTROL AIR HEATER LEAK
89-68	8/1/89	EMERGENCY Diesel GENERATOR GOVERNOR FAILURE
89-70	8/3/89	CR # 62 DROPPED DURING CR EYEVIDENCE
89-71	8/3/89	LIMIT SWITCH POSITION DURING TUGBOAT TAIL TESTING
89-72	8/11/89	4KV BUS 5/PHS TO LOW VOLTAGE ALARM
89-73	8/15/89	NO PHS GROUND DURING CR TESTING OF KCL RELAYS
89-74	8/21/89	TK-109 OVERFLOW DURING RESIN TRUNK-FILL
89-75	8/22/89	OVERFLOW OF SEWAGE INTO STEAM DEKAND
89-76	8/23/89	Comp. SECURITY MEASURES INSECURITY MISSED
89-77	8/24/89	P-355C LOW LUBR OIL PRESSURE
89-78	8/29/89	Addendum TO UDR 89-037
89-78	9/1/89	#2 main feed reg. valve failure,
89-79	9/1/89	High Sym. Offset delays Pur. Oscension
89-80	9/5/89	Knockage by HPSI Header Stop MOV's + Addendum

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1989

2547.3.5

REPORT NO.	DATE	SUBJECT
89-81	9/6/89	345 KV breakers to Maxey's Station tripped
89-82	9/6/89	INVERTANT OVERFILL OF WELL POINT TANKER
89-83	9/7/89	CMP Bomb Threat
89-84	9/8/89	P-14B INOPERABLE
89-85	9/13/89	SCC-M-165 DEGRADED DUE TO GREASE IN VALVE ACTUATOR SPRING PACK
89-86	9/14/89	FAILURE OF RPS AB MATRIX DURING TESTING
89-87	9/15/89	EFW/AFW LKD. VLV. CK. MTHLY. SURV. INTERVAL EXCEEDED 1 GALL. SLIGHTLY CONTAMINATED LIQUID DUMPED INTO WATER TREATMENT SUMP
89-88	9/25/89	STEAM & FLOW THERMAL POWER INDICATION MISMATCH ON THE PLANT COMPUTER
89-89	9/28/89	P-14A (CHARMING HOSE) LOW PUMP OIL PRESSURE
Addendum 89-90	10/8/89	P-14A Oil pump Relief Valve Stuck again
89-91	10/8/89	UNLOCKED DOOR FOR LOW LEVEL WASTE STORAGE BLDG. PLANT SHUTDOWN DUE TO FAILURE OF LEAKAGE TEST ON CONTAINMENT PURGE INLET PENETRATION
89-92	10/10/89	FAILURE OF KG1/375 TO OPEN
89-93	10/10/89	INDUSTRIAL SAFETY ACCIDENT IN A RAD CONTROL TENT
89-94	10/11/89	SCC-M-165 UNABLE TO OPEN FROM MCB CS-A-55 & 56 LEAK BY TO CONTAINMENT SUMP DURING SAFEGUARDS VALVE TESTING
89-95	10/14/89	LOSS OF PRESSURIZER LEVEL DUE TO LEAKAGE BY RH-7 DURING AHR SHUTDOWN
89-96	10/15/89	MAINT. PERFORMED ON VALVE PR-A-1 WHEN PR-A-2 WAS TAGGED VALVE TO BE WORKED
89-97	10/16/89	NN3 FLANGE ON DWST SAFETY CLASS 3 PIPING
89-98	10/16/89	
89-99	10/16/89	

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1989
BOOK 2 of 2

REPORT NO.	DATE	SUBJECT
89-100	10/16/89	5.3% Dry-Tail Waste Gas Degy Drum (TK-100)
89-101	10/19/89	TK-109 OVERFLOW - + Oddendum
89-102	10/20/89	FUEL OIL SPILL FROM STORAGE TANK FOR RUST ENVELOPE - FURNACE
89-103	10/30/89	SECURITY BADGE GIVEN TO THE IDRONIS INDIVIDUAL
89-104	10/26/89	SHORT CIRCUIT CAUSES LOSS OF ESS DRIVE
89-105	10/29/89	COMPUTER RECEIVING OUT PUSSES FROM ROD 4R
89-106	10/29/89	TOE LEASERS FIT TO SPRAY BUCKS
	Oddendum 10/30/89	
89-107	10/30/89	DROPPED CEN #48 WHITE SCRAMBLE MODUS POWER SWITCHES
89-108	11/2/89	REC #1 SEAL FAILURE NEG NOTIFICATION of modin. agent exist
89-109	11/8/89	RESEARCHABLE REC #1 SEAL SUITORS OF 11/10/89 REC-M743 EXHAUST VALVE, DEC-39, REACH ROD NOT CONNECTED
89-110	11/10/89	WHITE SWAMPING AIR HEAT EXCHANGERS, RES HEAT UP & GOLDENWATER AVES EXCEED TDO LIMITS
89-112	11/12/89	EXCESSIVE LEAKAGE PAST PC-M-11
89-113	11/14/89	RES TARD TINTERLOCK SETPOINT
89-114	11/14/89	SMALL AMOUNT OF INTRUSION FOUND IN PDS OFFICE
89-115	11/14/89	AD CONTAMINATED IN CONTAINMENT
89-116	11/17/89	INTERNAL OPERATION OF T-114 WITH K67 & K61375 CLOSED
89-117	11/19/89	UNCOMPENSATED AND UNACCOUNTED FOR AREA KEYS Security VTR
89-118	11/24/89	PLANT'S EIGHT COND PLANT PROPERTY
89-119	11/25/89	4KY BUS SUB LATED VOTRBE ALARM RECEIVED

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1989

REPORT NO.	DATE	SUBJECT
89-120	11/29/89	HPSI SUCTION Cb. Sample Low For Train B
89-121	12/2/89	FALSE BEAS SIREN
89-122	12/3/89	FAILURE OF PRESSURE RELIEF VALVE MO-5-2168 ON THE P-623B SECTION UNV.
89-123	12/4/89	PROBLEMS DURING CEFA EXERCISES
89-123	12/4/89	CEFA #9 UPPER ELECTRICAL LIMIT DID NOT CLEAR DURING CEFA EXERCISES
89-125	12/11/89	INADVERTANT ACTUATION OF THE LSA BUILDING DRY PIPE SPRINKLER SYSTEM
89-126	12/11/89	TRIP OF HPSI SECTION 2168 DUE TO LOSS OF PRESSURE RELIEF VALVE ON THE P-623B SECTION
89-127	12/11/89	TRIP OF HPSI SECTION 2168 DUE TO LOSS OF PRESSURE RELIEF VALVE ON THE P-623B SECTION
89-128	12/11/89	TRIP OF HPSI SECTION 2168 DUE TO LOSS OF PRESSURE RELIEF VALVE ON THE P-623B SECTION
89-129	12/19/89	PUBLIC CALL-INS OF PEA'S ACTUATION IN WEST BOOTH - W. DASH FIRE CHIEF TESTING SILENCE
89-130	12/20/89	GENERATOR CONDITION MONITOR ALARM SUBSEQUENT TO REMOVING P-51 FROM SERVICE
89-131	12/21/89	Emergency Battery 2 in Condition Outside Design Basis
89-134	12/7/89	AIR EJECTOR / CONDENSER PROBLEMS
89-132	12/27/89	Odd item to UOR 89-132
89-132	12/28/89	ENS PHONES NOT ON UNINTERRUPTED POWER SUPPLY (UPS) DURING A STATION BLACKOUT
89-133	12/22/89	POTENTIAL LOSS OF COOLING FLOW TO GENERATOR LEADS TO BUSHING

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1990

REPORT NO.	DATE	SUBJECT
90-001	12/29/89	CONT. SPRAY BLDG. VENT. IMPROPER ALIGNMENT
90-002	1/1/90	CEA 54 Dropped during Replacement of failed CEDS Power supply
90-003	1/11/90	Unplanned Release of Liquid Waste from "A" Test Tank during scheduled release of "B" Test Tank
90-004	1/12/90	Reactor Trip Breaker Failure
90-005	1/15/90	Condenser Vacuum Transient
90-006	1/15/90	Plt. Shutdown to Repair SCC-A-460 to meet stroke ^{time} req.
90-007	1/15/90	Hazardous Waste Spill
90-008	1/17/90	High Activity in PCC System
90-009	1/24/90	Uncompensated degradation in a security system
90-010	1/25/90	Repair of false FEBS Act 12.12
90-011	1/31/90	CEA #49 PRO during power supply testing (copies)
90-012	2/7/90	Steam leak on E-11A Heater drain line.
90-013	2/7/90	NRG notification due to failure of EIC Component Limit Switch for PS-A-20 (Primary Sample 12)
90-014	2/8/90	ES-19 Rockshaft Bound (nonreturn valve for B First Point Heater)
90-015	2-19-90	Improperly marked and/or control of safeguards information
90-016	02-21-90	Security computer failure
90-016	02-22-90	Addendum to 90-016 - ^{recommendation} for corrective actions
90-017	02-26-90	HD-A-353 Packing blown out during maintenance on Actuator
90-018	02-28-90	Sim. computer im. environmental control unit + humidifier drain

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1990

REPORT NO.	DATE	SUBJECT
90-019	3/1/90	Topped valve removed from isolated system (valve cooler E-3A)
90-020	3/7/90	Gas leak in PMS
90-021	3/10/90	Security Computer Failure
90-022	3/11/90	Failure of static dry cooling tower
90-023	3/12/90	Damage to water treatment system piping
90-024	3/12/90	Missing Check for Decon Room Area Detector (see also 90-026)
90-025	3/19/90	High Condensate Chlorides
90-026	3/13/90	Comsnp Sample Station Debris Cover
90-027	3/22/90	High conductivity Alarm
90-028	3/23/90	Electrical shock hazard
90-029	3/22/90	Activation of E-HR start system safety valve
90-030	3/23/90	Mercury spill in 1+L Shop
90-031	3/23/90	Injury due to wind striking Turbin Deck Shift
90-032	3/23/90	Presence of unknown substance at Plant Personnel Areas Security Station
90-033	3/27/90	RG5 Leakage. Greater than 1.6PM
90-034	3/29/90	"A" TT Release of liquid waste Runs out of service
90-035	4/2/90	Resin spill while Re on 3 Resin from TK-2
90-036	4/5/90	Local waste bay Runs meter Found Disconnected
90-037	4/5/90	Initiator EG procedure with PMS "B" Train Transmitter
90-037	4/6/90	Handdown to UCR 90-037
90-038	4/7/90	Transient during Turbine Over-speed Test

UNUSUAL OCCURRENCE REPORT LOG

EAR: 1990

REPORT NO.	DATE	SUBJECT
90-039	4/7/90	Possible wiring discrepancy with Pressure Zer Pressure Controllers
90-040	4/8/90	Outer Personnel Hatch Inoperable
90-041	4/8/90	Leakage Past P-12A Discharge Check Valve
90-042	4/7/90	Snubber CH-HSS-601 Failed Surveillance
90-043	4/7/90	#1 RCP Seal Failure and Leakage
90-044	4/10/90	Radiactive equipment left site without proper paperwork
90-045	4/9/90	Uncontaminated degradation of security Access for Valve House
90-046	4/11/90	Improper lead determined
90-047	4/14/90	Inadvertent Actuation MS175 while swapping vital AC buses
90-048	4/15/90	Sudden increase in indicated Reactor Vessel level
90-049	4/16/90	Failed ECCS operational Pump Flow Surveillance
90-050	4/18/90	Inadvertent Actuation of RAS while Testing
90-051	4/18/90	Small SCC Hazardous Waste Spill
90-052	4/18/90	Staff Building Feeder Breaker Problem
90-053	4/19/90	Drive motor for MS-M-101 Burned
90-054	4/21/90	CS-M-2 Failed ICFR-50 Appendix J Testing
90-055	4/22/90	Fuel Assembly N-17 Pulled out of Sequence
90-056	4/23/90	"For Cause" Testing not by Procedure
90-057		Cancelled
90-058	4/25/90	CS-M-1 Motor Damage due to Torque Switch Failure
90-059	4/27/90	RWSR Drain to PAB sump while clearing charging system tags

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1990

REPORT NO.	DATE	SUBJECT
90-060	4/27/90	Charging Pump P-14B Suction Blockage
90-061	4/16/90	DR-M-6 Limit Switch missing EG Seal
90-062	4/22/90	SLM-13 wet kayak Recirculation Spill
90-063	5/4/90	Fire Main Hot Station Isolation
90-064	5/4/90	Reactor Containment while Removing Reactor from CS1-32
90-065	5/5/90	Improper Maintenance Activity on RH-M-2
90-066	5/9/90	Improper 4160/480 Vlt Breaker Tagging
90-067	5/10/90	PR-M-17 Motor Operator Damage
90-068	5/15/90	Delivery of fuel oil for P-5 without chemistry testing
90-069	5/16/90	Unnecessary Loss of Reactor to MCC 8A
90-070	5/16/90	Miswiring of SLM-29 and SLM-40
90-071	5/21/90	Bomb Threat
90-072	5/24/90	Unauthorized Loss of Security Access Control
90-073	5/31/90	High Domestic Water RH
90-074	6/2/90	D-15 Hets Closure Timing Deficiency during Loss of MC Test
90-075	6/4/90	P-5 Failure during Surveillance Testing
90-076	6/4/90	Loss of Pressurizer Level Control during Reactor Vent and Fill Operation
90-077	6/6/90	Missing Service Connection Bolts on the 1C1 Rod Table
90-078	6/7/90	Stuck Rod # 53
90-079	6/12/90	Liquid Nitrogen Spill
90-080	6/17/90	Fuel Assembly Removed from Incorrect Core Location

6154M/OPS-MISC

UNUSUAL OCCURRENCE REPORT LOG

EAR: 1990

REPORT NO.	DATE	SUBJECT
90-091	6/20/90	Valve System Anti-Rotation Shaft Key for H51-M-41 Found ^{at 300 ft}
90-092	6/19/90	Discovery of Teflon Tape on ERT Transmitter #1098 in the 2 nd Ray Building
90-093	6/21/90	Stem Extension on CD-101 Found Bent
90-094	6/23/90	Lightning Strike
90-095	6/27/90	RCS Leak at LF-1044 Sightglass due to misvalving during Functional Testing
90-096	6/27/90	Blocking Device Left in Spring Hanger after Removal of Lead Shielding
90-097	6/27/90	Incorrect RCS sample Results due to improper Sample System Lineup
90-098	6/25/90	Operable Proportional Heaters
90-099	6/25/90	RCS Leakage Past PR-S-13 Attendance
90-090	7/2/90	Main Generator Voltage Regulator Anomaly ^{Added}
90-091	7/3/90	EHC System Power Supply Failures
90-092	7/4/90	Lightning Strike Causes Breaker Trip
90-093	7/5/90	Oil Leak from X-1B
90-094	7/18/90	Cable Tray Smoke Detector Fired for C7A7 ^(20th level)
90-095	7/31/90	Caustic Splashed Into Workers Eye
90-096	7/24/90	Electrical Storms Cause breakers to open in 345 ^{year}
90-097	7/25/90	Mispositioned Switch in Channel "D" Dual Line ^{Area}
90-098	7/31/90	Exhaust gas release from maint. of waste gas comp. ^{off the line}
90-099	8/3/90	Governor Valve Oscillations During Power Reduc ^{off the line}
90-100	8/3/90	RPS Channel Trip Concurrent w/ Zone 45 smoke
—	—	Detector Alarm

UNUSUAL OCCURRENCE REPORT LOG

EAR: 1990

REPORT NO.	DATE	SUBJECT
90-101	8/01/90	False Pears Activation
90-102	8/02/90	P-2A Trip on Overcurrent
90-103	8/4/90	Bearing #5 High Temperature
90-104	8/5/90	P-62A Trip
90-105	8/6/90	Radioactive Source Leak Test Not Performed
90-106	8/8/90	Broken Shaft Key on HSI-M-42
90-107	8/10/90	Increased RCS Activity + Addendum
90-108	8/13/90	Unexpected RCS Leakage Past HSI-S-47
90-109	8/14/90	"A" BWS Diked Area Drain Valve Found Cracked Open
90-110	8/14/90	Unusual Event Declared Due to RCS System Leak
90-111	8/14/90	Letdown Valve LD-M-2 Failure to Operate
90-112	8/16/90	PVS RMS Inoperable, Entry into Remedial Action
90-113	8/21/90	FFD ISSUE
90-114	8/20/90	Turbine Control Anomaly Causes Power Transient
90-115	8/21/90	Misaligned Control Rod During CEA Exercises
90-116	8/23/90	PVS Gas Release in Excess of Announced Level
90-117	8/23/90	NRC Notification of Release in Excess of ^{Previously} Announced Levels
90-118	8/24/90	Appendix R Requirements for Facilities Not Met
90-119	8/29/90	Non-Credible Threat Letter
90-120	8/30/90	P-10A Discharge Valve Found Mispositioned
90-121	9/06/90	Unintentional Entry Into Remedial Action due to Failure of C tmt. Integrity Valve MS-A-162

UNUSUAL OCCURRENCE REPORT LOG

EAR: 1990

REPORT NO.	DATE	SUBJECT
90-122	9/13/90	Unaccounted for Security Keys
90-123	9/17/90	Gascons Release to PAB While Bumping VCT
—	—	due to leak in the Waste Gas System.
90-124	9/19/90	SEA Tank leak in line to LT 3201
90-125	9/25/90	DC Bus #3 Ground During Reactor
—	—	Trip Breaker Testing

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1990

<u>REPORT NO.</u>	<u>DATE</u>	<u>SUBJECT</u>
<u>90-126</u>	<u>9/25/90</u>	<u>SNAP RINGS FOUND IN BOTTOM OF RTB CUBICLE</u>
<u>90-127</u>	<u>9/27/90</u>	<u>IMPROPER 345 KV SWITCHING SEQUENCE</u>
<u>90-128</u>	<u>9/29/90</u>	<u>SECURITY KEY NOT RETURNED FOLLOWING USE</u>
<u>90-129</u>	<u>9/30/90</u>	<u>PLANT SHUTDOWN DUE TO LOW TURBINE MAIN LUBE OIL PUMP DISCHARGE PRESSURE</u>
<u>90-130</u>	<u>10/01/90</u>	<u>ROD DROPS DURING REACTOR SHUTDOWN</u>
<u>90-131</u>	<u>10/09/90</u>	<u>FAILURE OF SCAT PRIMARY WATER FILL LINE</u>
<u>90-132</u>	<u>10/09/90</u>	<u>HIGH RAD (T.S. 5.12) DOOR FOUND UNLATCHED</u>
<u>90-133</u>	<u>10/10/90</u>	<u>HIGHER THAN PREDICTED GROUND SPEED MEASURED DURING ON SITE BLASTING</u>
<u>90-134</u>	<u>10/11/90</u>	<u>CONDENSATE PUMP AUTOSTART</u>
<u>90-135</u>	<u>10/16/90</u>	<u>MISALIGNED CEA DURING CEA EXERCISES</u>
<u>90-136</u>	<u>10/16/90</u>	<u>UNANNOUNCED LIQUID RELEASE - BWST DIKED AREA</u>
<u>90-137</u>	<u>10/17/90</u>	<u>CONTAINMENT ISOLATION VALVE PD-A-122 DECLARED INOPERABLE</u>
<u>90-138</u>	<u>10/17/90</u>	<u>DC BUS 1 & 3 GROUNDS DUE TO CMP TESTING OF K207-1</u>
<u>90-139</u>	<u>10/17/90</u>	<u>ENS NOTIFICATION OF EO LIMIT SWITCH FAILURE</u>
<u>90-140</u>	<u>10/17/90</u>	<u>LOCKED HIGH RAD DOOR ACCESSIBLE WITHOUT KEY</u>
<u>90-141</u>	<u>10/19/90</u>	<u>PLANT SHUTDOWN FOR GENERIC EO REPAIRS</u>
<u>90-142</u>	<u>10/20/90</u>	<u>RPS CHANNEL "D" REACTOR COOLANT LOW FAILED TO DEVELOP A TRIP</u>
<u>90-143</u>	<u>10/20/90</u>	<u>ENGINEERED SAFEGUARDS FEATURE LIGHT BOX MALFUNCTION</u>
<u>90-144</u>	<u>10/23/90</u>	<u>MAINE STATE POLICE (MSP) HOTLINE OUT OF SERVICE</u>
<u>90-145</u>	<u>10/26/90</u>	<u>P-14B DECLARED INOPERABLE</u>
<u>90-146</u>	<u>10/30/90</u>	<u>DG-1A OVERSPEED TRIP OCCURRED DURING TESTING + Addendum</u>
<u>90-147</u>	<u>11/01/90</u>	<u>FEEDWATER TEMPERATURE RTD AFFECTS CALORIMETRIC POWER INDICATION</u>

UNUSUAL OCCURRENCE REPORT LOG

YEAR: 1990

2547-11-10

REPORT NO.	DATE	SUBJECT
90-148	11/20/90	#4 GOVERNOR VALVE RAMPED OPEN & ADDENDUM
90-149	11/22/90	DG-1B SPELD LOWER THAN EXPECTED WHEN FIELD WAS FLASHED ON LOCAL START
90-150	11/11/90	DIESEL FIREPUMP P-5 INOPERABLE DUE TO GENERATOR FAILURE
90-151	11/24/90	FAILURE OF #3 MAIN STEAM STOP VALVE TO REOPEN DURING TURBINE VALVE TESTING
90-152	11/26/90	DOMESTIC WATER TANK HIGH Ph
90-153	11/27/90	REACTOR TRIP BREAKER FAILS TO RECLOSE DURING SURVEILLANCE TESTING
90-154	12/01/90	P-14B AUTOSTART WITHOUT APPARENT REASON AND WITHOUT ANY ALARMS
90-155	12/02/90	FAILURE OF PT-102Y
90-156	12/04/90	RTB UV ARMATURE OUT OF POSITION AND SNAP RING FAILURE
90-157	12/04/90	#4 GOVERNOR VALVE STARTED TO SHUT BY ITSELF + Addendum
90-158	12/05/90	HPSI Suction Low Boron Concentration
90-159	12/06/90	Control Room Ventilation "B" Train Damped Failure
90-160	12/10/90	DG-2 Fails to Start and Run
90-161	12/12/90	NRC ENS Phone Fand out of Service
90-162	12/16/90	High PUS Activity Discovered during Daily Grab Sample
90-163	12/17/90	Plant Shutdown Due to Steam Gen. ^{Tube} Leak
90-164	12/19/90	Gas release for 12/18 to 12/19 exceeded the
parm	"	Previously Announced Value.

UOR

Search

CONTENT

FIELDS 0

spill

RATE

NOCONDENSE

84

1

1

64

f:/Operational events (OEDB)/Operational events (OEDB)/1995 (March 26 thru December 31)/95-080

DIR_OEDB:[000000.1995]95-080.WP;1

1. TITLE: Radiological Spill in the CS Building 2. NUMBER: 95-080 3. TIME/DATE OF EVENT: 1100 / October 18,1995 4. PLANT CONDITIONS: REACTOR POWER : 0% PLANT TRIP? N OPERATING CONDITION (1-7): 1 5. DESCRIPTION OF OCCURRENCE: 10/17/95

Operations li

2

2

64

f:/Operational events (OEDB)/Operational events (OEDB)/1995 (March 26 thru December 31)/95-080

DIR_OEDB:[000000.1995]95-080.WP;1

6. OEDB SEARCH: KEY WORD: HITS: SIMILAR EVENTS: 1. SPILL-DRAIN 13 1 , UOR 91-100 VALVE 7. REPORTABILITY DETERMINATION: REPORTING CRITERIA; SHORT TERM PROC. 1-26-1; EMERGENCY PLAN PROC. 2.50.0; LER (EXPLAIN). There was no equipment in the CS buildi

3

2

64

f:/Operational events (OEDB)/Operational events (OEDB)/1995 (March 26 thru December 31)/95-088

DIR_OEDB:[000000.1995]95-088.WP;1

TING CRITERIA; SHORT TERM PROC. 1-26-1; EMERGENCY PLAN PROC. 2.50.0; LER (EXPLAIN). Both RHR trains remain operable. The spill did not result in inaccessible areas needed for operation of the plant. The design limits of 450 cc/hr, based on the FSA

4

1

64

f:/Operational events (OEDB)/Operational events (OEDB)/1996/96-001

DIR_OEDB:[000000.1996]96-001.PTE;1

1. TITLE: ASBESTOS SPILL IN CONTAINMENT 2. NUMBER: 96-001 4. PLANT CONDITIONS: 3. TIME/DATE OF EVENT: 0320/1-1-96 REACTOR POWER : 0% PLANT TRIP? N OPERATING CONDITION (1-7): 1 5. DESCRIPTION OF OCCURRENCE: 0320- Control room notified by maintenanc

5

1

64

f:/Operational events (OEDB)/Operational events (OEDB)/1996/96-034

DIR_OEDB:[000000.1996]96-034.PRW;1

OPERATIONS DEPARTMENT UNUSUAL OCCURENCE REPORT 1. TITLE: Oil Spill at Fire Training Site 2. NUMBER: 96-034 4. PLANT CONDITIONS: 3. TIME/DATE OF EVENT: 1340/5-2-96 REACTOR POWER :90% PLANT TRIP? N OPERATING CONDITION (1-7):7 5. DESCRIPTION OF OCCUR

6

1

64

f:/Operational events (OEDB)/Operational events (OEDB)/1996/96-081

DIR_OEDB:[000000.1996]96-081.WEJ;1

e. 0855 BD Tank Level alarm. AO observes BD tank pressure less than zero. 0858 Hotwell Low Level alarm. AO sent to check spill valve. 0859 Condenser B Hotwell Temperature alarm(PTID 291). Entered AOP 2-2, Degraded or Loss of Condenser Vacuum. Temp

7

1

64

f:/Operational events (OEDB)/Operational events (OEDB)/1995 (March 26 thru December 31)/95-093

DIR_oedb:[000000.1995]95-093.WP;1

NPOs to stop the turbine hall sump pump and dam the floor drains. The Hazardous Waste Coordinator was notified about the spill. The Hazardous Waste Coordinator assisted the Plant Services department with cleaning up the oil (which was determined t

8

2

64

f:/Operational events (OEDB)/Operational events (OEDB)/1995 (March 26 thru December 31)/95-093

DIR_oedb:[000000.1995]95-093.WP;1

RIA; SHORT TERM PROC. 1-26-1; EMERGENCY PLAN PROC. 2.50.0; LER (EXPLAIN). Not reportable IAW 1-26-1 and the Maine Yankee Spill Plan since the oil spill was contained by the turbine hall sump. The oil is non-hazardous. 8. FITNESS FOR DUTY: 8.1 FITN

9

2

64

f:/Operational events (OEDB)/Operational events (OEDB)/1995 (March 26 thru December 31)/95-096

DIR_oedb:[000000.1995]95-096.WP;1

6. OEDB SEARCH: KEY WORD: | HITS: SIMILAR EVENTS: | 1. Spill 63 UOR 90-062 and others described wet lay-up spills associated with #3 S/G. 2. S/G Fill 3 3 similar events including UOR 90-062 describe spills associated with wet lay-up. 7. REPORTABIL

10

1

64

f:/Operational events (OEDB)/Operational events (OEDB)/1995 (March 26 thru December 31)/95-097

DIR_oedb:[000000.1995]95-097.JPW;1

1. TITLE: Hydraulic Oil Spill 2. NUMBER: 95-097 4. PLANT CONDITIONS: 3. TIME/DATE OF EVENT: 1059 12/8/95 REACTOR POWER : 0% PLANT TRIP? N OPERATING CONDITION (1-7):1 5. DESCRIPTION OF OCCURRENCE: 1059 - Security notified Hazardous Waste Coordinato

11

2

64

f:/Operational events (OEDB)/Operational events (OEDB)/1995 (March 26 thru December 31)/95-097

DIR_oedb:[000000.1995]95-097.JPW;1

6. OEDB SEARCH: KEY WORD: | HITS: SIMILAR EVENTS: 1. Oil Spill 27 17 events resulted in oil released to the environment (ground or river); 7. REPORTABILITY DETERMINATION: REPORTING CRITERIA; SHORT TERM PROC. 1-26-1; EMERGENCY PLAN PROC. 2.50.0; LE

12

3

64

f:/Operational events (OEDB)/Operational events (OEDB)/1995 (March 26 thru December 31)/95-097

DIR_oedb:[000000.1995]95-097.JPW;1

ected transient, significant operator error, or equipment malfunction.(CRS-1) NO. DEPARTMENT ACTION ITEM 1. Tech Monitor spill site for future leaching of oil and remediation of soil. 2. Licensing Clarify the Spill Plan to define the ground as inc

13

1

64

f:/Operational events (OEDB)/Operational events (OEDB)/1996/96-063

DIR_oedb:[000000.1996]96-063.PTE;1

onse to the containment accident environment and, in the worst case, rupture the piping. PCC system inventory would then spill into containment and render the system inoperable. 1940 After discussion with engineering and management personnel, the

14

6

64

f:/Operational events (OEDB)/Operational events (OEDB)/1995 (March 26 thru December 31)/95-036 thru 95-049

dir_oedb:[1988expo]OEDB2.;1

SHEEN TO BE THE E STORM DRAIN OUTFALL ON THE NORTH SIDE OF THE CIRC WATER PUMPHOUSE. PLANT SERVICES WAS NOTIFIED AND THE SPILL TEAM RESPONDED. LEAVES IN THE STORM DRAIN OUTLET APPEARED TO BE BLOCKING AND FILTERING THE OIL. 1215 ABSORBENT PADS PLAC

15

20

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

NCE: RWST siphon heater flange on west side of RWST developed a leak similar to previous leak (refer to U.O.R. #159-87). Spill was contained and contamination was removed. Leak Repair Co. was contacted to repair leak. E-PLAN LEVEL ENS: n (Y/N) 7.

16

58

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: Caustic spill in water treatment area CAUSTIC SPILL IN WATER TREATMENT AREA 2. OEDB #: 457 UOR #: 016-87 LER #: OTHER: HPES #: PRCE #: 3. TIME/DATE OF EVENT: 1315/02/25/87 A

17

83

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: SCC spill during valve repair work at generator seal oil coolers due to inadequate system draining SCC SPILL AT SEAL OIL UNIT DUE TO INADEQUATE DRAINING 2. OEDB #: 482 UOR #

18

96

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: Overflowed Upender Pit resulting in spill to ICI sump OVERFLOWED UPENDER PIT TO ICI SUMP 2. OEDB #: 499 UOR #: 058-87 LER #: OTHER: HPES #: PRCE #: 3.

TIME/DATE OF EVENT: 04

19

97

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.
TITLE: Chromated water spill from Tanker CHROMATED WATER SPILL 2. OEDB #: 500
UOR #: 059-87 LER #: OTHER: HPES #: PRCE #: 3. TIME/DATE OF EVENT: 0440/05/11/87
ADDENDUM DATE 4. PLAN

20

154

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported
from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: Oil spill into CW discharge forebay (L10gal) SMALL (<10 GAL) OIL SPILL INTO
CW DISCHARGE FOREBAY 2. OEDB #: 559 UOR #: 119-87 LER #: OTHER: HPES #:
PRCE #: 3. TIME/DATE OF E

21

219

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported
from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

notified control room of overflow at tanker being filled from E-3A. E-3A drain was secured.

About 50 gallons of the PCC spill soaked into the ground by the fuel oil storage
bunker. However, the hazardous waste coordinator indicated that the spill w

22

316

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported
from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

parently the normal capacity makeup valve failed partly open and caused an increase in
condenser level, which caused the spill valve to open and drop P-2C suction pressure. E-PLAN
LEVEL ENS: n (Y/N) 7. REPORTABILITY DETERMINATION: REPORTING CRITER

23

365

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported
from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

OCCURENCE: Operators found that approximately 25 to 30 gallons of water had spilled from
the filter cover of TK-109. The spill was contained in the RCA storage area and cleaned up.

TK-109 overfilled because the high level cutout valve, WSS-A-28, d

24

698

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported

from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: Worker falls and cuts leg. LIQUID SPILL IN SPRAY BUILDING 2. OEDB #: 701

UOR #: 92-88 LER #: OTHER: HPES #: PRCE #: 3. TIME/DATE OF EVENT: 1430/10/22/88

ADDENDUM DATE 4. PLA

25

705

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

were able to retighten the union. The workers immediately notified their supervisors who notified the control room. The spill was wiped up and work stopped pending full drain of the SCC system. SCC-2-246 relieves to the SCC return header. At the t

26

707

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

cupied approximately 500 square feet. The Hazardous Waste Coordinator decided that because of the area involved, the oil spill should be reported to the Maine Dept. of Environmental Protection and the US Coast Guard. These reports were made at 0930

27

721

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

FROM OPERATIONAL EVENT DATABASE (OEDB) 1. TITLE: SCC leak from piping

outside near DWST. GENERAL NRC NOTIFICATION OF SCC SPILL 2. OEDB #: 725 UOR

#: 135-88 LER #: OTHER: HPES #: PRCE #: 3. TIME/DATE OF EVENT: 1520/12/5/88

ADDENDUM DATE 4. PLANT CO

28

732

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

NT DATABASE (OEDB) 1. TITLE: Waste solvents discarded into 55 gallon drum spilled in the lube oil storage room. CHEMICAL SPILL IN LUBE OIL STORAGE ROOM 2. OEDB #: 736

UOR #: 137-88 LER #: OTHER: HPES #: PRCE #: 3. TIME/DATE OF EVENT: 2330/11/29/88

29

813

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: Liquid spill in the spray building LIQUID SPILL IN SPRAY BUILDING 2. OEDB #: 816 UOR #: 091-88 LER #: OTHER: HPES #: PRCE #: 3. TIME/DATE OF EVENT: 1415/10/21/88 ADDENDUM DA

30

866

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

on the roof of the building through the tank vent. Oil was cleaned up in both areas. Absorbant pads were placed over the spill area on the roof because some of the fuel oil was absorbed into the roofing material. E-PLAN LEVEL ENS: n (Y/N) 7. REPOR

31

867

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

was detected on the Back River in the vicinity of the circ water pump house. Source was believed to be from the fuel oil spill on 4/5/89. The fuel oil was leached from the roofing material and carried to the river via the storm sewer. Ref UOR 89-0

32

913

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

S: OPERATING CONDITION (1-7): 7 5. DESCRIPTION OF OCCURENCE: While shifting from CST to DWST as surge volume, condensate spill was not isolated and water treatment piping was overpressurized. The PVC piping ruptured, spilling water in the water tr

33

1122

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: Caustic Spill in Water Treatment Area 2. OEDB #: 1131 UOR #: LER #: OTHER: HPES #: PRCE #: 158 3. TIME/DATE OF EVENT: 1315/2/25/87 ADDENDUM DATE 4. PLANT CONDITIONS: OPERATI

34

1191

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: Fuel Oil Spill from Storage Tank for RWST Enclosure Furnace FUEL OIL SPILL FROM STORAGE TANK FOR RWST ENCLOSURE FURNACE 2. OEDB #: 1199 UOR #: 89-102 LER #: OTHER: HPES #: P

35

1195

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

PING WELL POINTS IN ORDER TO SAMPLE THE WELL POINTS FOR OIL. -1210
HAZARDOUS WASTE COORDINATOR NOTIFIED MAINE DEP OF OIL SPILL. -1215
HAZARDOUS WASTE COORDINATOR NOTIFIED NATIONAL RESPONSE CENTER OF OIL SPILL. THESE CALLS WERE MADE AFTER JOINT DIS

36

1203

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

d the door in PSS office. A small amount of mercury spilled onto the floor. - The mercury was cleaned up using a Mercury Spill Kit. Approximately 1 teaspoon of mercury was retrieved. - An air sample taken in the PSS office at 2130 did not show pre

37

1238

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: HAZARDOUS WASTE SPILL HAZERDOUS WASTE SPILL 2. OEDB #: 1245 UOR #: 90-007 LER #: OTHER: HPES #: n PRCE #: n 3. TIME/DATE OF EVENT: 2239/1/15/90
ADDENDUM DATE 4. PLANT CONDIT

38

1261

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

06 Hotwell conductivity high alarm recieved in control room. "A" box conductivity rapidly increased off scale high. 1108 Spill valve isolated. Larson Lane and SLeD show increasing trend. 1125 Decision made to commence a power decrease at 15% per h

39

1266

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: Mercury Spill in I&C Shop MERCURY SPILL IN I+C SHOP 2. OEDB #: 1273 UOR #:

90-030 LER #: OTHER: HPES #: N PRCE #: 3. TIME/DATE OF EVENT: 1130/3/23/90

ADDENDUM DATE 4. PLANT

40

1273

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: RESIN SPILL WHILE REMOVING RESIN FROM TK-85 RESIN SPILL WHILE

REMOVING RESIN FROM TK-85 2. OEDB #: 1280 UOR #: 90-035 LER #: OTHER: HPES #:

N PRCE #: 3. TIME/DATE OF EVENT:

41

1289

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: SMALL SCC HAZARDOUS WASTE SPILL SMALL SCC HAZARDOUS WASTE

SPILL 2. OEDB #: 1296 UOR #: 90-051 LER #: OTHER: HPES #: Y PRCE #: 3. TIME/DATE

OF EVENT: 0230/4/18/90 ADDENDUM DA

42

1312

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: S/G #3 WET LAYUP RECIRCULATION SPILL S/G #3 WET LAYUP

RECIRCULATION SPILL 2. OEDB #: 1318 UOR #: 90-062 LER #: OTHER: HPES #: N

PRCE #: 3. TIME/DATE OF EVENT: 1330/5/2/90 AD

43

1360

✓ HAVE IT

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: A chemical spill on the Turbine Hall floor by the condensate pumps. Appears to have spilled from the Mezzanine level and removed paint from the condensate piping. Hazardous

44

1375

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: LIQUID NITROGEN SPILL LIQUID NITROGEN SPILL 2. OEDB #: 1382 UOR #: 90-079 LER #: OTHER: HPES #: 90-010 PRCE #: 3. TIME/DATE OF EVENT: 0705/6/12/90

ADDENDUM DATE 4. PLANT CON

45

1425

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

tion spilled onto the asphalt. 1730 - The Hazardous Waste Coordinator is called to the Control Room. He was on site. The spill was NOT contaminated. None of the spill went into the storm drain. 1800 - The PSS called Mason Station (Ralph Campbell)

46

1517

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: Hazardous Waste Spill From 55 Gallon Drum Hazardous waste spill from 55 gal. drums 2. OEDB #: 1505 UOR #: 91-032 LER #: OTHER: HPES #: PRCE #: 3. TIME/DATE OF EVENT: 1840/4/

47

1520

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: SCC SPILL FROM SERVICE AIR COMPRESSOR AFTERCOOLER E-21A SCC spill from service air compressor after cooler E-21A 2. OEDB #: 1507 UOR #: 91-034 LER #:

OTHER: HPES #: PRCE #:

48

1522

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: OIL SPILL IN BOOMED AREA OF THE CIRCULATING WATER INTAKE DUE TO LEAK ON TRASH RAKE Oil spill in boomed area of circulation water intake due to leak on

2. OEDB #: 1509 UOR #:

49

1523

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

0 minutes. * Inspection of X-1A transformer indicated a major transient, resulting in cracking the side, allowing oil to spill into a drain into the Back River. Called the Coast Guard and DEP for oil spill. * All safety systems responded correctly

50

1525

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

E-PLAN LEVEL ENS: Y (Y/N) 7. REPORTABILITY DETERMINATION: REPORTING CRITERIA; SHORT TERM PROC. 1-26-1; EMERGENCY PLAN PROC. 2.50.0; LER

(EXPLAIN) This oil leak was reportable IAW procedure 1-26-1 and the oil spill plan. QOD

TREND CODE: 00-0211-03

51

1566

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: SMALL (1qt) FUEL OIL SPILL DURING DG-2 TRANSFER 2. OEDB #: 1552 UOR

#: 91-061 LER #: OTHER: HPES #: PRCE #: 3. TIME/DATE OF EVENT: 0900/08/14/91

ADDENDUM DATE 4. PLANT CONDI

52

1599

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.
TITLE: SMALL DIESEL FUEL SPILL DG-2 PIPING 2. OEDB #: 1580 UOR #: 91-092 LER #:
OTHER: HPES #: PRCE #: 3. TIME/DATE OF EVENT: 1545/11/1/91 ADDENDUM DATE 4.
PLANT CONDITIONS: OPERAT

53

1608

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported
from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.
TITLE: SMALL SPILL WHILE DECHROMATING 2. OEDB #: 1588 UOR #: 91-100 LER #:
OTHER: HPES #: PRCE #: 3. TIME/DATE OF EVENT: 1100/12/16/91 ADDENDUM DATE
4. PLANT CONDITIONS: OPERATING

54

1647

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported
from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

T CONDITIONS: OPERATING CONDITION (1-7): 1 5. DESCRIPTION OF OCCURENCE:
1530 - Control Room receives report of minor oil spill at Circ Water Pumphouse from crane
operations during removal of sludge from "D"-Bay. 1600 - HAZ MAT Coordinator (S. Edge

55

1657

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported
from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.
TITLE: HAZARDOUS SUBSTANCE SPILL 2. OEDB #: 1632 UOR #: 92-037 LER #:
OTHER: HPES #: PRCE #: 3. TIME/DATE OF EVENT: 0645/03/15/92 ADDENDUM DATE
4. PLANT CONDITIONS: OPERATING CONDI

56

1671

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported
from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.
TITLE: SMALL (1/2 GALLON) SODIUM HYDROXIDE SPILL ON PAVEMENT. 2. OEDB
#: 1646 UOR #: 92-051 LER #: OTHER: HPES #: PRCE #: 3. TIME/DATE OF EVENT:
1045/04/15/92 ADDENDUM DATE 4. PLAN

57

1673

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database
dir_oedb:[1988expo]OEDBTXT.TXT;1

ted. Approx 1 gal of SCC fluid pooled on floor. No liquid entered floor drains (Nearest floor drain was about 10 ft from spill). 1920 - Maintenance notified of leak. 1930 - PSS confirmed that SCC system fluid, though highly diluted, is still to be

58

1723

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database
dir_oedb:[1988expo]OEDBTXT.TXT;1

y the circ pump house. PSS and Hazardous Waste Specialist investigated and determined the event to be reportable IAW the spill plan. Facilities instructed to contain oil with boom and collect it with absorbent sheets. Notifications made per the sp

59

1794

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database
dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.
TITLE: Turbine Lube Oil Spill 2. OEDB #: 1758 UOR #: 93-038 LER #: OTHER: HPES #:
PRCE #: 3. TIME/DATE OF EVENT: 1345/6/15/93 ADDENDUM DATE 4. PLANT
CONDITIONS: OPERATING CONDITION

60

1822

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database
dir_oedb:[1988expo]OEDBTXT.TXT;1

ordinator in consultation with the Environmental Engineering Group determined that the discharge constituted a Class "A" spill. Subsequently the original cleaning instructions provided by the hazardous waste coordinator were implemented. E-PLAN LE

61

1823

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database
dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.
TITLE: ASBESTOS SPILL in DG-1A ROOM resulting from GRINDING on
FLANGE\GASKET SURFACE 2. OEDB #: 1786 UOR #: 93-065 LER #: OTHER: HPES #:

PRCE #: 3. TIME/DATE OF EVENT: 1200/8\24\93

62

1826

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1.

TITLE: CHROMATED WATER SPILL in DG-1A ROOM 2. OEDB #: 1789 UOR #: 93-068

LER #: OTHER: HPES #: PRCE #: 3. TIME/DATE OF EVENT: 1215/8\26\93 ADDENDUM

DATE 4. PLANT CONDITIONS: OPERAT

63

1830

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

oil may have been P-26A which had oil marks on its discharge head and base. Notifications were made IAW the Maine Yankee Spill Plan. E-PLAN LEVEL ENS: Y (Y/N) 7. REPORTABILITY DETERMINATION: REPORTING CRITERIA; SHORT TERM PROC. 1-26-1; EMERGENCY P

64

1857

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

ll Level had already increased to +4" due to a pressure differential between the A and B Condensers NOTE: The Condensate Spill Valve (CD-A-87) is set to open at a level of +2" in the North (E-10B) Hotwell. Shortly thereafter the CRO received a rep

65

1860

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

RE READING ZERO). ACTIVITIES/EVENTS IN CONTROL ROOM: RECEIVED PANALARM F-1-9L (HOTWELL LEVEL LOW) SENT OPERATOR TO CHECK SPILL VALVE; FOUND SPILL VALVE SHUT, MAKE-UP VALVE OPEN. CONDENSER VACUUM DECREASING. OPERATOR CHECKED AIR EJECTOR OFFGAS FLOW

66

1919

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

maintenance on the water treatment area sump had discovered liner degradation and cracks underneath the sump floor. The spill plan was consulted. The sump area is exposed or has the potential to be exposed to a variety of caustic and acidic chemic

67

1938

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

river was estimated to be one pint. The Hazardous Material Response Team was activated and clean absorbent pads from the spill response kit were placed under the outfall. 1940- Hazardous Material Response Team on site and placed additional absorbe

68

1940

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

t materials were placed around storm sewer outlet. 0900 Notifications were made to offsite agencies IAW the Maine Yankee Spill Plan. E-PLAN LEVEL N/A ENS: Y (Y/N) 7.

REPORTABILITY DETERMINATION: REPORTING CRITERIA; SHORT TERM PROC. 1-26-1; EMERGEN

69

1945

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1. TITLE: SMALL KEROSENE OIL SPILL 2. OEDB #: 1891 UOR #: 94-043 LER #: OTHER: HPES #: PRCE #: 3. TIME/DATE OF EVENT: 0900/06/23/94 ADDENDUM DATE 4. PLANT CONDITIONS: OPERATING CONDIT

70

1950

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

estic Water use. The Wiscasset sewage treatment plant was notified about the presence of the Hydrazine. The Maine Yankee Spill Plan was consulted and notifications were made to the proper authorities. - Additional Search Criteria: "Domestic Water"

71

1951

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

ATION: REPORTING CRITERIA; SHORT TERM PROC. 1-26-1; EMERGENCY PLAN PROC. 2.50.0; LER (EXPLAIN) Reportable as a class "A" spill IAW Maine Yankee Spill Plan. UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) QOD TREND CODE: 1B-M211-E2

72

1952

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

THE OIL SHEEN WITH ABSORBENT PADS. 1600 FOLLOWING DAY: NOTIFICATIONS WERE MADE TO OFFSITE AGENCIES IAW THE MAINE YANKEE SPILL PLAN. DUE TO THE EXTREMELY SMALL SIZE OF THE OIL SHEEN, IT WAS NOT IMMEDIATELY APPARENT THAT NOTIFICATION WAS REQUIRED; T

73

1986

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

N: REPORTING CRITERIA; SHORT TERM PROC. 1-26-1; EMERGENCY PLAN PROC. 2.50.0; LER (EXPLAIN) Not reportable per 1-26-1, E-Plan, LER or Spill Plan. The equipment involved is NNS and did not threaten safety class equipment. QOD TREND CODE: 1f-o340-e3

74

2004

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

en the tanks which were still in the ground. No indication of leakage was observed. Control room personnell reviewed the Spill Plan and completed the required notifications per section 2.3 - Spill Reporting. E-PLAN LEVEL ENS: Y (Y/N) 7. REPORTABIL

75

2021

64

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

handle locking bolts in order to loosen them. 1230 Notified hazardous waste coordinator to evaluate reportability of oil spill and to initiate cleanup effort. 1320 Facilities personnel initiated cleanup of oil on roof. Approximately 3 to 5 gal of

76

710

40

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

C C-S-351;SCC-S-268;SCC-S-270;SCC-S-234;SCC-162. The system was drained back to reduce leakage. Less than 2 gallons were spilled overall. E-PLAN LEVEL ENS: N (Y/N) 7. REPORTABILITY DETERMINATION: REPORTING CRITERIA; SHORT TERM PROC. 1-26-1; EMERGE

77

1392

40

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

terminated that the material was not a potential problem. The oil that was collected will be stored for disposal. Some oil spilled into the bermed area surrounding the transformers. Approximately 5 gal. spilled from the transformer to the bermed are

78

2

36

f:/Operational events (OEDB)/Operational events (OEDB)/1995 (March 26 thru December 31)/95-052

DIR_OEDB:[000000.1995]95-052.REM;1

. 2.50.0; 10 CFR 21; LER (EXPLAIN). Not reportable. CARDOX operability not affected. No personal injury involved. No oil spilled to any release pathway. Any release of R-12 to atmosphere to be accounted for by vendor and evaluated by HAZ MAT SPEC.

79

7

36

f:/Operational events (OEDB)/Operational events (OEDB)/1995 (March 26 thru December 31)/95-036 thru 95-049

dir_oedb:[1988expo]OEDB2.;1

LOCATION ON LAND AT THE SOUTH SIDE OF THE CIRC WATER PUMP HOUSE. THEY DETERMINED THE SOURCE TO BE A LOCATION OF PREVIOUS SPILLS AND ACUMULATED OIL UNDER A CRANE. THEY CONCLUDED THAT THE RAIN THAT HAD BEEN FALLING FOR MOST OF THE DAY HAD CAUSED THE

80

902

36

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

UOR DATABASE - CONVERTED FROM OPERATIONAL EVENT DATABASE (OEDB) 1. TITLE: foreign material spilled into the reactor vessel 2. OEDB #: 906 UOR #: LER #: OTHER:

HPES #: PRCE #: 1 3. TIME/DATE OF EVENT: 1700/9/18/72 ADDENDUM DATE 4.

PLANT CONDITIONS:

81

1629

36

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

placement valve. Sewer pipe was pressure tested at service pressure and restored to operation at approx 1130 on 1/24/92. Spilled sewage was removed by commercial vacuum truck. At 1248, made 4-hour ENS notification call to NRC. E-PLAN LEVEL ENS: Y

82

1866

36

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

arrived at the diesel it had stopped(estimated time 4-5 minutes after executing emergency shutdown actions). All of the spilled oil was recovered. 2130 - DG-1A tagged out for gasket repair. (Cont'd) (Cont'd)(Cont'd) 2240 - Repairs completed; DG-1A

83

1910

36

f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

was notified and the radiation monitors did not indicate any gaseous release. It is estimated that 5-20 gallons of fluid spilled. All of the spillage was contained by the trench system. No one in the work crew was contaminated. E-PLAN LEVEL N/A EN

84

1602

12



f:/Operational events (OEDB)/Operational events (OEDB)/1988 thru March 25, 1995 (exported from OEDB)/OEDB, as exported from Nutshell database

dir_oedb:[1988expo]OEDBTXT.TXT;1

wrote was off-scale high. The PVS APD filter paper was found stopped. When fixed and returned to service, the PVS gas RMS spiked and then stabilized at a new higher level (see graph). The oscillation had ceased and the level began trending down. F

SCOPING SURVEY STATUS

(1 OF 2)




INDICATES AREAS OF THE SITE THAT HAVE BEEN SURVEYED / SAMPLED FOR RADIOACTIVE MATERIALS - NO DETECTABLE ACTIVITY FOUND

INDICATES AREAS OF THE SITE THAT HAVE BEEN SURVEYED / SAMPLED FOR RADIOACTIVE MATERIALS - MEASURABLE ACTIVITY FOUND

COMMENTS: Areas Evaluated by Scanning, Soil Sampling and Exposure Rate Readings


SCOPING SURVEY STATUS

(2 OF 2)



INDICATES AREAS OF THE SITE THAT HAVE BEEN SURVEYED / SAMPLED FOR RADIOACTIVE MATERIALS - NO DETECTABLE ACTIVITY

SOIL SAMPLING STATUS



INDICATES AREAS OF THE SITE THAT SOIL HAS BEEN SURVEYED / SAMPLED FOR RADIOACTIVE MATERIALS - NO DETECTABLE ACTIVITY



INDICATES AREAS OF THE SITE THAT SOIL HAS BEEN SURVEYED / SAMPLED FOR RADIOACTIVE MATERIALS - DETECTABLE ACTIVITY



INDICATES AREAS OF THE SITE THAT SOIL HAS BEEN SURVEYED / SAMPLED FOR RADIOACTIVE MATERIALS - ANALYSIS IN PROGRESS

Significant Radiological Contamination Events At Maine Yankee

MAINE YANKEE REPORT NUMBER	DATE OF OCCURRENCE	DESCRIPTION OF OCCURRENCE	REFERENCE DOCUMENTS
MN-88-107 MY-NRC	2/23/88	Leak in RWST siphon heat return line to ground	LER# UOR# RIR# YNSD Analysis
JHA-93-27	1992	Residual contaminated soil under yard crane (Wiscasset Wall) Former Waste Storage Area	JHA memo to R.H. Nelson of 7/21/92 J.W. Bisson memo to P.L. Anderson of 10/23/92, REG268/92, MYP#92-1173 F.X. Bellini memo to P.L. Anderson of 1/12/93, MYP#93-0054
MY to Div. of Health and Engineering 10/4/94	1992-08	Spreading of slightly contaminated silt from intake racks in accordance with Dredge Spoil Utilization Permit, S-20814-SS-A-N	J.W. Bisson memo to P.L. Anderson 9/23/94 REG 178/94

DATE: 06/17/97

PAGE: 1

FILE: RADIATION SPILLS UNUSAL OCCURENCE REPORT ERRODED
UNDERGROUND WASTE VEUTRALIZATION DISCHARGE PIPE

DOCUMENT TYPE: CORRESPONDENCE

DOCUMENT FORM: MI

DOCUMENT LOCATION: 2987-0003 *

TECHNICAL FILE NUMBER: 01.08.04.04

DOCUMENT NUMBER: 95-025

DOCUMENT DATE: 03/08/1995

ORIGINATOR: ADMINISTRATION

ACCESSION NUMBER: 97991

DATE entered: 05/08/96

user id: CHENEY

DATE MODIFIED: 05/08/96

TITLE: CONTAMINATED SOIL LEFT IN YARD AREA FERROUS
SULFATE TANK

DOCUMENT TYPE: CORRESPONDENCE
DOCUMENT FORM: MI
DOCUMENT LOCATION: 1726-0002
TECHNICAL FILE NUMBER: 01.08.04.02
DOCUMENT DATE: 04/12/1993
CLASSIFICATION TYPE: D
ORIGINATOR: ADMINISTRATION
ACCESSION NUMBER: 50819
DATE entered: 03/24/94
user id: HURLEY
DATE MODIFIED: 05/23/94




TITLE: CONTAMINATED SOIL AT MAINE YANKEE IN ACCORDANCE
WITH 10CFR20.302 A

DOCUMENT TYPE: CORRESPONDENCE
DOCUMENT FORM: MI
DOCUMENT LOCATION: 1726-0003
TECHNICAL FILE NUMBER: 01.08.04.02
DOCUMENT DATE: 11/02/1988
08/31/1989
CLASSIFICATION TYPE: D
ORIGINATOR: ADMINISTRATION
ACCESSION NUMBER: 50820
DATE entered: 03/24/94
user id: CHENEY
MODIFIED: 03/24/94



TITLE: SITE ASSESSMENT OF FERROUS SULFATE UNDERGROUND
STORAGE TANK

DOCUMENT TYPE: CORRESPONDENCE
DOCUMENT FORM: MI
DOCUMENT LOCATION: 1726-0008
TECHNICAL FILE NUMBER: 01.08.04.02
DOCUMENT DATE: 03/11/1991
05/31/1991
CLASSIFICATION TYPE: D
ORIGINATOR: ADMINISTRATION
ACCESSION NUMBER: 50824
DATE entered: 03/24/94
user id: HURLEY
DATE MODIFIED: 05/23/94



TITLE: FACILITY CLOSURE SITE ASSESSMENT UNDERGROUND
SULFATE STORAGE TANK

DOCUMENT TYPE: CORRESPONDENCE
DOCUMENT FORM: MI
DOCUMENT LOCATION: 1726-0009
TECHNICAL FILE NUMBER: 01.08.04.02
DOCUMENT DATE: 02/14/1992
06/04/1992
CLASSIFICATION TYPE: D



TECHNICAL FILE NUMBER: 01.08.04.05
DOCUMENT DATE: 11/29/1994
CLASSIFICATION TYPE: D
ORIGINATOR: CORP TREASURE
ACCESSION NUMBER: 72503
DATE entered: 05/16/95
user id: BLAKE
DATE MODIFIED: 05/16/95

TITLE: APPROVAL UNDER 10 CFR 20.302A FOR IN PLACE
DISPOSAL OF RESIDUAL CONTAMINATED SOLID AT MAINE
YANKEE TAG NO 71167

DOCUMENT TYPE: CORRESPONDENCE
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2505-0060
TECHNICAL FILE NUMBER: 01.08.04.02
DOCUMENT DATE: 08/31/1989
CLASSIFICATION TYPE: D
ORIGINATOR: ADMIN
ACCESSION NUMBER: 72597
DATE entered: 05/19/95
user id: CHENEY
DATE MODIFIED: 10/02/95

TITLE: REQUEST FOR IN PLACE DISPOSAL OF SLIGHTLY
CONTAMINATED SOIL IN ACCORDANCE WITH 10 CFR
20.302A

DOCUMENT TYPE: CORRESPONDENCE
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2505-0061
TECHNICAL FILE NUMBER: 01.08.04.02
DOCUMENT DATE: 11/02/1988
CLASSIFICATION TYPE: D
ORIGINATOR: ADMIN
ACCESSION NUMBER: 72598
DATE entered: 05/19/95
user id: CHENEY
DATE MODIFIED: 05/19/95

TITLE: KEROSENE LEAK SPARE GENERATOR ENCLOSURE STRUCTURE
FOLLOW UP REPORT

DOCUMENT TYPE: CORRESPONDENCE
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2505-0062
TECHNICAL FILE NUMBER: 01.08.04.02
DOCUMENT DATE: 09/21/1994
CLASSIFICATION TYPE: D
ORIGINATOR: ADMIN
ACCESSION NUMBER: 72599
DATE entered: 05/19/95
user id: CHENEY
DATE MODIFIED: 05/19/95

TITLE: LICENSED SILT SPREADING AREA
 DOCUMENT TYPE: CORRESPONDENCE
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2556-0037
 TECHNICAL FILE NUMBER: 01.08.04.02
 DOCUMENT DATE: 10/04/1994
 CLASSIFICATION TYPE: D
 ORIGINATOR: ADMIN
 ACCESSION NUMBER: 72600
 DATE entered: 05/19/95
 user id: CHENEY
 DATE MODIFIED: 08/01/95



TITLE: IN-SITU DECOMMISSIONING LOW LEVEL WASTE MANAGEMENT
 DOCUMENT TYPE: CORRESPONDENCE
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2505-0064
 TECHNICAL FILE NUMBER: 01.08.04.06
 DOCUMENT NUMBER: APTR-42
 DOCUMENT DATE: 01/01/1987
 CLASSIFICATION TYPE: D
 ORIGINATOR: ADMIN
 ACCESSION NUMBER: 72601
 DATE entered: 05/19/95
 user id: CHENEY
 DATE MODIFIED: 05/19/95



TITLE: POLYCHLORINATED BIPHENYLS PCBs FOR HANDLING AND
 DISPOSAL OF CAPACITOR AND TRANSFORMER GRADE ASK
 ARELS
 DOCUMENT TYPE: PROCEDURES
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2531-0001
 TECHNICAL FILE NUMBER: 01.08.04.08
 DOCUMENT DATE: 01/04/1971
 CLASSIFICATION TYPE: D
 ORIGINATOR: CENTRAL MAINE POWER COMPANY
 ACCESSION NUMBER: 72764
 DATE entered: 05/22/95
 user id: CHENEY
 DATE MODIFIED: 05/22/95



TITLE: POLYCHLORINATED BIPHENYLS PCBs
 DOCUMENT TYPE: CORRESPONDENCE
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2531-0002
 TECHNICAL FILE NUMBER: 01.08.04.08
 DOCUMENT DATE: 12/02/1976
 12/22/1994
 CLASSIFICATION TYPE: D
 ORIGINATOR: CENTRAL MAINE POWER COMPANY
 ACCESSION NUMBER: 72765
 DATE entered: 05/22/95



ORIGINATOR: MAINTENANCE
ACCESSION NUMBER: 72783
DATE entered: 05/22/95
user id: CHENEY
DATE MODIFIED: 05/22/95

TITLE: POLYCHLORINATED BIPHENYLS PCBS E1 SA-A
MAINTENANCE HISTORY

DOCUMENT TYPE: REQUESTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2531-0020
TECHNICAL FILE NUMBER: 01.08.04.08
DOCUMENT DATE: 07/14/1981
12/13/1990

CLASSIFICATION TYPE: D
ORIGINATOR: MAINTENANCE
ACCESSION NUMBER: 72784
DATE entered: 05/22/95
user id: CHENEY
DATE MODIFIED: 05/22/95

TITLE: POLYCHLORINATED BIPHENYLS PCBS M18 M-A P2C
TURBINE DRIVEN STEAM GENERATOR FEED PUMP
MAINTENANCE HISTORY FILES

DOCUMENT TYPE: REQUESTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2531-0021
TECHNICAL FILE NUMBER: 01.08.04.08
DOCUMENT DATE: 07/26/1984
04/10/1991

CLASSIFICATION TYPE: D
ORIGINATOR: MAINTENANCE
ACCESSION NUMBER: 72785
DATE entered: 05/22/95
user id: CHENEY
DATE MODIFIED: 05/22/95

TITLE: UNUSUAL OCCURRENCE REPORTS FOR OIL SPILL ✓

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2545-0002
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR83
DOCUMENT DATE: 03/29/1983
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73681
DATE entered: 06/19/95
user id: HURLEY
DATE MODIFIED: 06/19/95

? PIA

TITLE: UNUSUAL OCCURRENCE REPORTS FOR HEAT TRACE FAILURE

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2545-0003
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR83
DOCUMENT DATE: 12/20/1983
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73682
DATE entered: 06/19/95
user id: HURLEY
DATE MODIFIED: 06/19/95

TITLE: UNUSUAL OCCURRENCE REPORTS FOR POTENTIAL RELEASE
OF RADIOACTIVE LIQUID TO THE STORM SEWER ✓

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2545-0005
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR84
DOCUMENT DATE: 02/27/1984 ?
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73684
DATE entered: 06/19/95
user id: HURLEY
DATE MODIFIED: 06/19/95

TITLE: UNUSUAL OCCURRENCE REPORTS FOR RWST LEAK ✓

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2545-0006
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR84
DOCUMENT DATE: 03/30/1984 ?
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73685
DATE entered: 06/19/95
user id: HURLEY
DATE MODIFIED: 06/19/95

TITLE: UNUSUAL OCCURRENCE REPORTS X1A OIL SAFETY LIFT

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2545-0008

RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 11.14.06
 01.08.04.02 ✓
 DOCUMENT NUMBER: UOR85-042
 DOCUMENT DATE: 07/06/1985 ?
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 73687
 DATE entered: 06/19/95
 user id: HURLEY
 DATE MODIFIED: 06/19/95

*X-1A
 OIL SAFETY 1:24*

TITLE: UNUSUAL OCCURRENCE REPORTS MERCURY SPILL IN
 AUXILLARY BOILER ROOM ✓

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2545-0009
 RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 11.14.06
 01.08.04.02
 DOCUMENT NUMBER: UOR85-055
 DOCUMENT DATE: 08/14/1985 ?
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 73688
 DATE entered: 06/19/95
 user id: HURLEY
 DATE MODIFIED: 06/19/95

TITLE: UNUSUAL OCCURRENCE REPORTS PCC LEAK UNDERGROUND ✓

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2545-0010
 RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 11.14.06
 01.08.04.02
 DOCUMENT NUMBER: UOR85-079
 DOCUMENT DATE: 10/10/1985 ?
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 73689
 DATE entered: 06/19/95
 user id: HURLEY
 DATE MODIFIED: 06/19/95

TITLE: UNUSUAL OCCURRENCE REPORTS CHROMATED WATER SPILL
 FORM TANKER ✓

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2545-0012
 RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 11.14.06
 01.08.04.02

DOCUMENT NUMBER: UOR87-059
DOCUMENT DATE: 05/11/1987
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73691
DATE entered: 06/19/95
user id: HURLEY
DATE MODIFIED: 06/19/95

TITLE: UNUSUAL OCCURRENCE REPORTS RWST SIPHON HEATER
LEAKAGE

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2545-0013
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR87-153
DOCUMENT DATE: 10/11/1987
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73692
DATE entered: 06/19/95
user id: HURLEY
DATE MODIFIED: 06/19/95

TITLE: UNUSUAL OCCURRENCE REPORTS RWST HEATER RETURN
LINE CRACK

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2545-0014
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR87-159
DOCUMENT DATE: 10/24/1987
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73693
DATE entered: 06/19/95
user id: HURLEY
DATE MODIFIED: 06/22/95

TITLE: UNUSUAL OCCURRENCE REPORTS RWST SIPHON HEATER
FLANGE LEAK

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0001A783
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR88-020
DOCUMENT DATE: 02/23/1988

CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73961
DATE entered: 06/27/95
user id: RINES
DATE MODIFIED: 08/07/95

TITLE: UNUSUAL OCCURRENCE REPORTS RWST SIPHON HEATER
RETURN LINE ISOLATION VALVE LEAK ✓

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0002
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR88-021
DOCUMENT DATE: 02/24/1988 ?
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73962
DATE entered: 06/27/95
user id: RINES
DATE MODIFIED: 08/07/95

TITLE: UNUSUAL OCCURRENCE REPORTS RWST SIPHON HEATER
RETURN LINE LEAK ✓

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0002A7
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR88-033 ?
DOCUMENT DATE: 04/26/1988
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73963
DATE entered: 06/27/95
user id: RINES
DATE MODIFIED: 06/27/95

TITLE: UNUSUAL OCCURRENCE REPORTS OVERFILLING OF RWST
COLLECTION BARREL ✓

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0003
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR88-039 ?
DOCUMENT DATE: 05/22/1988
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS

SESSION NUMBER: 73964
DATE entered: 06/27/95
user id: RINES
DATE MODIFIED: 06/27/95

TITLE: UNUSUAL OCCURRENCE REPORTS RWST SIPHON HEATER
RETURN LINE ISOLATION VALVE LEAK

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0004 ✓
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR88-042
DOCUMENT DATE: 05/27/1988
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73965
DATE entered: 06/27/95
user id: RINES
DATE MODIFIED: 06/27/95

TITLE: UNUSUAL OCCURRENCE REPORTS BORON WASTE STORAGE
TANK DIKED AREA SUMP DRAIN VALVES TO YARD STORM
DRAIN FOUND OPEN ✓

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0005
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR88-043
DOCUMENT DATE: 06/02/1988 ?
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73966
DATE entered: 06/27/95
user id: RINES
DATE MODIFIED: 06/27/95

TITLE: UNUSUAL OCCURRENCE REPORTS MAIN TRANSFORMER DRAIN
SUMP PUMPDOWN MILKY LIQUID

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0006 ✓
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR88-124
DOCUMENT DATE: 11/17/1988 ?
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73967

DATE entered: 06/27/95
user id: RINES
DATE MODIFIED: 06/27/95

TITLE: UNUSUAL OCCURRENCE REPORTS GOVERNMENT NRC
NOTIFICATION OF SCC SPILL

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0007
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR88-135
DOCUMENT DATE: 12/05/1988
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73968
DATE entered: 06/27/95
user id: RINES
DATE MODIFIED: 06/27/95

TITLE: UNUSUAL OCCURRENCE REPORTS FUEL OIL SPILL FROM
STORAGE TANK FOR RWST ENCLOSURE FURNACE

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0009
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR89-102
DOCUMENT DATE: 10/20/1989
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73970
DATE entered: 06/27/95
user id: RINES
DATE MODIFIED: 06/27/95

TITLE: UNUSUAL OCCURRENCE REPORTS OIL LEAKAGE INTO SPRAY
BUILDING UOR89-106 AND ADDENDUM

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0010
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR89-106
DOCUMENT DATE: 10/29/1989
10/30/1989
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73971
DATE entered: 06/27/95

user id: RINES
DATE MODIFIED: 06/27/95

TITLE: UNUSUAL OCCURENCE REPORTS HAZARDOUS WASTE SPILL
DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0012
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06

01.08.04.02 ✓
DOCUMENT NUMBER: UOR90-007
DOCUMENT DATE: 01/15/1990 ?
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73973
DATE entered: 06/27/95
user id: RINES
DATE MODIFIED: 06/27/95

TITLE: UNUSUAL OCCURENCE REPORTS MERCURY SPILL IN I+C
SHOP

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0013
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06

01.08.04.02 ✓
DOCUMENT NUMBER: UOR90-030
DOCUMENT DATE: 03/23/1990 ?
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73974
DATE entered: 06/27/95
user id: RINES
DATE MODIFIED: 06/27/95

TITLE: UNUSUAL OCCURENCE REPORTS SMALL SCC HAZARDOUS
WASTE SPILL

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0014
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06

01.08.04.02 ✓
DOCUMENT NUMBER: UOR90-051
DOCUMENT DATE: 04/18/1990 ?
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73975
DATE entered: 06/27/95
user id: RINES
DATE MODIFIED: 06/27/95

TITLE: UNUSUAL OCCURENCE REPORTS OIL LEAK FROM X-1B

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0015
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR90-093
DOCUMENT DATE: 07/05/1990
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73976
DATE entered: 06/27/95
user id: RINES
DATE MODIFIED: 06/27/95



TITLE: UNUSUAL OCCURENCE REPORTS SCAT TANK LEAK IN LINE
TO LT 3201

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0016
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR90-124
DOCUMENT DATE: 09/19/1990
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73977
DATE entered: 06/27/95
user id: RINES
DATE MODIFIED: 06/27/95



TITLE: UNUSUAL OCCURENCE REPORTS A BORON WASTE STORAGE
TANK TK-13A HEATER FLANGE LEAK

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 2547-0018
RETENTION PERIOD: 99
TECHNICAL FILE NUMBER: 11.14.06
01.08.04.02

DOCUMENT NUMBER: UOR91-005
DOCUMENT DATE: 01/09/1991
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 73979
DATE entered: 06/27/95
user id: RINES
DATE MODIFIED: 06/27/95



TITLE: UNUSUAL OCCURENCE REPORTS A BORON WASTE STORAGE
TANK TK-13A HEATER FLANGE LEAK
DOCUMENT TYPE: REPORTS

DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2547-0019
 RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 11.14.06
 01.08.04.02
 DOCUMENT NUMBER: UOR91-019
 DOCUMENT DATE: 02/18/1991
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 73980
 DATE entered: 06/27/95
 user id: RINES
 DATE MODIFIED: 06/27/95



TITLE: UNUSUAL OCCURENCE REPORTS OIL LEAK FROM OIL
 PROCESSING TRAILER

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2547-0020
 RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 11.14.06
 01.08.04.02
 DOCUMENT NUMBER: UOR91-039
 DOCUMENT DATE: 05/09/1991
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 73981
 DATE entered: 06/27/95
 user id: RINES
 DATE MODIFIED: 06/27/95



TITLE: UNUSUAL OCCURENCE REPORTS SMALL ONE QUART FUEL
 OIL SPILL DURING DG-2 TRANSFER

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2547-0021
 RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 11.14.06
 01.08.04.02
 DOCUMENT NUMBER: UOR91-061
 DOCUMENT DATE: 08/14/1991
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 73982
 DATE entered: 06/27/95
 user id: RINES
 DATE MODIFIED: 06/27/95



TITLE: UNUSUAL OCCURENCE REPORTS SMALL DIESEL FUEL SPILL
 DG-2 PIPING

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2547-0022

RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 11.14.06
~~01.08.04.02~~
 DOCUMENT NUMBER: UOR91-092
 DOCUMENT DATE: 11/01/1991 ?
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 73983
 DATE entered: 06/27/95
 user id: RINES
 DATE MODIFIED: 06/27/95



TITLE: UNUSUAL OCCURENCE REPORTS GASOLINE TANK GROUND
 WATER SAMPLE EXCEEDENCE

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2547-0023
 RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 11.14.06
~~01.08.04.02~~
 DOCUMENT NUMBER: UOR91-098
 DOCUMENT DATE: 12/06/1991 ?
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 73984
 DATE entered: 06/27/95
 user id: RINES
 DATE MODIFIED: 06/27/95



TITLE: UNUSUAL OCCURENCE REPORTS LEAKAGE PAST REACTOR
 HEAD VENT VALVE

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: HC-VAULT
 2547-0008
 RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 11.14.06
~~01.08.04.02~~
 DOCUMENT NUMBER: UOR89-019
 DOCUMENT DATE: 02/18/1989 ?
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 73985
 DATE entered: 06/27/95
 user id: HURLEY
 DATE MODIFIED: 04/11/97

TITLE: UNUSUAL OCCURENCE REPORTS AIR EJECTOR CONDENSER
 PROBLEMS

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: HC-VAULT
 2547-0008

RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 11.14.06
~~01.08.04.02~~
 DOCUMENT NUMBER: UOR89-124
 DOCUMENT DATE: 12/07/1989
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 73986
 DATE entered: 06/27/95
 user id: HURLEY
 DATE MODIFIED: 04/11/97

TITLE: UNUSUAL OCCURENCE REPORTS SANITARY SEWER LINE
 LEAK ON MAINE YANKEE PROPERTY

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2554-0002
 RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 01.08.04.02
~~11.14.06~~

DOCUMENT NUMBER: UOR92-011
 DOCUMENT DATE: 01/23/1992
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 74572
 DATE entered: 07/10/95
 user id: RINES
 DATE MODIFIED: 07/10/95

TITLE: UNUSUAL OCCURENCE REPORTS MINOR OIL SPILL DURING
 CW PUMPHOUSE MAINTENANCE

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2554-0003
 RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 01.08.04.02
~~11.14.06~~

DOCUMENT NUMBER: UOR92-028
 DOCUMENT DATE: 02/21/1992
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 74573
 DATE entered: 07/10/95
 user id: RINES
 DATE MODIFIED: 07/10/95

TITLE: UNUSUAL OCCURENCE REPORTS OIL LEAKAGE ONTO GROUND
 UNDER FUEL TRUCK

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2554-0004
 RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 01.08.04.02

11.14.06
 DOCUMENT NUMBER: UOR92-034
 DOCUMENT DATE: 03/06/1992
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 74574
 DATE entered: 07/10/95
 user id: RINES
 DATE MODIFIED: 07/10/95

TITLE: UNUSUAL OCCURENCE REPORTS HAZARDOUS SUBSTANCE
 SPILL

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2554-0005
 RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 01.08.04.02

11.14.06
 DOCUMENT NUMBER: UOR92-037
 DOCUMENT DATE: 03/15/1992
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 74575
 DATE entered: 07/10/95
 user id: RINES
 DATE MODIFIED: 07/10/95

E: UNUSUAL OCCURENCE REPORTS SMALL ONE HALF GALLON
 SODIUM HYDROXIDE SPILL ON PAVEMENT

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2554-0006
 RETENTION PERIOD: 99
 TECHNICAL FILE NUMBER: 01.08.04.02

11.14.06
 DOCUMENT NUMBER: UOR92-051
 DOCUMENT DATE: 04/15/1992
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 74576
 DATE entered: 07/10/95
 user id: RINES
 DATE MODIFIED: 07/10/95

TITLE: RADIATION SPILLS UNUSAL OCCURENCE REPORT ERRODED
 UNDERGROUND WASTE VEUTRALIZATION DISCHARGE PIPE

DOCUMENT TYPE: CORRESPONDENCE
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 2987-0003
 TECHNICAL FILE NUMBER: 01.08.04.04
 DOCUMENT NUMBER: 95-025
 DOCUMENT DATE: 03/08/1995
 ORIGINATOR: ADMINISTRATION

TECHNICAL FILE NUMBER: 01.08.04.02
 DOCUMENT NUMBER: UOR94-040
 DOCUMENT DATE: 06/18/1994
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 112951
 DATE entered: 02/26/97
 user id: HURLEY
 DATE MODIFIED: 02/26/97



TITLE: UNUSUAL OCCURRENCE REPORTS SERVICE WATER HEADER
 OUTFALL LEAK

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 3511-0007
 TECHNICAL FILE NUMBER: 01.08.04.02
 DOCUMENT NUMBER: UOR94-041
 DOCUMENT DATE: 06/19/1994
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 112952
 DATE entered: 02/26/97
 user id: HURLEY
 DATE MODIFIED: 02/26/97



TITLE: UNUSUAL OCCURRENCE REPORTS SERVICE SMALL KEROSENE
 OIL SPILL

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 3511-0008
 TECHNICAL FILE NUMBER: 01.08.04.02
 DOCUMENT NUMBER: UOR94-043
 DOCUMENT DATE: 06/23/1994
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 112953
 DATE entered: 02/26/97
 user id: HURLEY
 DATE MODIFIED: 02/26/97



TITLE: UNUSUAL OCCURRENCE REPORTS OIL SHEEN AT
 CIRCULATING WATER INTAKE STRUCTURE

DOCUMENT TYPE: REPORTS
 DOCUMENT FORM: MI
 DOCUMENT LOCATION: 3511-0009
 TECHNICAL FILE NUMBER: 01.08.04.02
 DOCUMENT NUMBER: UOR94-047
 DOCUMENT DATE: 06/30/1994
 CLASSIFICATION TYPE: D
 ORIGINATOR: OPERATIONS
 ACCESSION NUMBER: 112954
 DATE entered: 02/26/97
 user id: HURLEY



DATE: 06/17/97

DATE MODIFIED: 02/26/97

TITLE: UNUSUAL OCCURRENCE REPORTS OIL SHEEN ON STANDING WATER AT FUEL OIL STORAGE TANK REMOVAL SITE

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 3511-0010
TECHNICAL FILE NUMBER: 01.08.04.02
DOCUMENT NUMBER: UOR94-093
DOCUMENT DATE: 10/27/1994
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 112955
DATE entered: 02/26/97
user id: HURLEY
DATE MODIFIED: 02/26/97

TITLE: UNUSUAL OCCURRENCE REPORTS VAPOR EXTRATOR EJ-5 OIL DISCHARGE TO TURBINE BUILDING ROOF

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 3511-0011
TECHNICAL FILE NUMBER: 01.08.04.02
DOCUMENT NUMBER: UOR94-105
DOCUMENT DATE: 11/29/1994
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 112956
DATE entered: 02/26/97
user id: HURLEY
DATE MODIFIED: 02/26/97

TITLE: UNUSUAL OCCURRENCE REPORTS ERRODED UNDERGROUND WASTE NEUTRALIZATION DISCHARGE PIPE

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 3511-0012
TECHNICAL FILE NUMBER: 01.08.04.02
DOCUMENT NUMBER: UOR95-025
DOCUMENT DATE: 03/08/1995
CLASSIFICATION TYPE: D
ORIGINATOR: OPERATIONS
ACCESSION NUMBER: 112957
DATE entered: 02/26/97
user id: HURLEY
DATE MODIFIED: 02/26/97

TITLE: UNUSUAL OCCURRENCE REPORTS OIL SHEEN ON BACK RIVER

DOCUMENT TYPE: REPORTS
DOCUMENT FORM: MI
DOCUMENT LOCATION: 3511-0013
TECHNICAL FILE NUMBER: 01.08.04.02
DOCUMENT NUMBER: UOR95-039

From O.L.B.M.

FFS

0EDB1131/PCEFS8

Spill Search

Spill:

89-102	89-106	89-114	90-007	90-030	90-035	90-051	90-062	0EDB1367	90-079	90-093	90-124	91-032	91-034	891604	91-036	91-037	91-039	91-061	91-092	91-100	92-028	92-037	138	88	91	0EDB860	89-34	89-35		
89-102	89-106	89-114	90-007	90-030	90-035	90-051	90-062	0EDB1367	90-079	90-093	90-124	91-032	91-034	891604	91-036	91-037	91-039	91-061	91-092	91-100	92-028	92-037	138	88	91	0EDB860	89-34	89-35		
20-88	16-87	42-87	58-87	59-87	88-87	119-87	139-87	46-86	10-86	0EDB#175	42-85	55-85	107-88	124-88	117-88	135-88	137	88	88	88	88	88	88	88	88	88	88	88	88	88

10K

93-064

93-068

93-072

93-013

9-038

94-043

94-046

94-047

94-093

94-105

95-080

-088

-093

-076

-097

96-001

030

034

063

081

HSA ID# 96

MAINE YANKEE MEMORANDUM**Reliable Electricity for Maine Since 1972**

To: Lee McCabe **Date:** November 15, 1996

CC: Pamela Bacon
Steve Evans
Pat Lydon
John Arnold

From: David Asherman, ext. 4367 **File:** DWA-96-021

Subject: Flood Relief Panel Drainage Project
Disposal of Surplus Soil
(a) Memo From D. Asherman Dated 11/4/96

Background:

Item (a) above provides a summary of regulatory issues associated with the proposed project. On 11/4/96, a composite soil sample was collected from four locations along the center line of the proposed 13' wide paved trench. The sample was split and analyzed by Maine Environmental Laboratory for Oil & Grease and by the Yankee Atomic electric Company Environmental Laboratory for radionuclides.

Test Results:

1. Composite sample contains 0.04 % Oil & Grease. The analytical Method Detection Limit is 0.01%. Chapter 405 of the Maine Solid Waste Regulations establish an Oil & Grease threshold of 0.25% Oil & Grease for disposal of dredge spoils as inert fill (meaning clean and not restricted). Therefore disposal of the surplus soil from the proposed project is not limited by Oil & Grease.
2. Composite sample only contains naturally occurring nuclides; no plant-related radionuclides were detected. Therefore soil is not contaminated and disposal is not restricted.

Concerns/Issues:

1. It is presently anticipated that the surplus soils will be disposed of on the contractors parking lot. Expansion of the parking lot was approved by permit from the Maine Department of Environmental Protection in May 1992. That approval was for expansion, regrading and stripping the parking lot. Conditions of approval included:
 - Initiation of construction within two years of permit issuance. It is assumed

that this condition has been met.


- Completion of project within five years. The completion date is to be by May 1997. If the project is not completed by that date, an extension should be obtained.
 - Project construction must in accordance with plans submitted as part of the permit application including limits on the extent of the parking lot expansion and adherence to erosion and sedimentation control plans.
2. This project can be constructed without obtaining prior MDEP approval using the 30,000 sq. ft. exemption. EHS/EP will prepare and submit appropriate notification.
 3. If an alternative disposal location(s) is planned, please contact EHS/EP prior to placement of soil to ensure environmental regulations are complied with.

N.T.S.

Composite soil sample collected following protocol developed by Robert G. Gerber, Inc. for Maine Yankee Dredge Material Land Application. Station redesignated by YAE Environmental Lab.

Four discrete samples collected & composited into sample M-SE-07. Sample analyzed by Maine Environmental Laboratory for Oil & Grease and by Bolton for radionuclides (split sample).

Original Chain of Custody in Landspreading file.



MAINE ENVIRONMENTAL LABORATORY

198 Main Street • Yarmouth, Maine 04096-1690 • (207) 846-6569 • FAX (207) 846-9066
Chain of Custody

ANALYTICAL PARAMETERS

PROJECT MANAGER **David Asherman** TELEPHONE **798-4367** FAX # **798-4230**

COMPANY **Maine Yankee** PURCHASE ORDER # **Reg # 36502**

ADDRESS **Old Bath Rd, Brunswick, ME**

PROJECT NAME **Flood Relief Pond Drainage / Dredge Material Land Application** SAMPLER NAME **David Asherman**

PH, Potassium, magnesium, calcium, cadmium,
 Chromium, copper, lead, mercury, nickel
 Zinc, iron, total P, Solids
 210 & 210

SAMPLE IDENTIFICATION	# CONTAINERS	TYPE OF CONTAINERS	FIELD FILTRATION		SAMPLE MATRIX	GRAB	COMP.	METHOD PRESERVED	SAMPLING		DATE	TIME	RECEIVED BY: [Signature]	RECEIVED BY: [Signature]
			YES	NO					DATE	TIME				
11-4-96-001	1	IR		✓	Soil		X	N/A	11/4/96	1550	✓	✓	11/4/96	1702
M-52-02	1	IR		✓	Soil		X	N/A	11/4/96	1500	✓		11/4/96	1702

TURNAROUND REQUEST
 11-4-96-001 Standard
 Priority (SURCHARGE) M-52-02

Received within hold time yes no
 Received in good condition yes no
 Temp. Blank °C / Frozen ice packs.
 Samples received preserved yes no

REMARKS
 Quote # _____

RELINQUISHED BY SAMPLER: [Signature]
 RELINQUISHED BY: [Signature]
 RECEIVED BY LABORATORY: [Signature]

Key 36502

MAINE YANKEE MEMORANDUM

Reliable Electricity for Maine Since 1972

To: File **Date:** November 4, 1996
From: D. Asherman, ext. 4367 **File:** DWA-96- 017
Subject: Analytical Services Procurement

Procurement of analytical services is required for two MY projects as described below.
Vendor for services will be:

Attn: Herbert S. Kodis, Laboratory Director
 Maine Environmental Laboratory
 198 Main Street
 Yarmouth, ME 04096-1690
 (207) 846-4673/FAX (207) 846-9066

1. Analysis of one composite soil sample for Oil & Grease for the purpose of disposal of surplus excavated soil generated by the Flood Relief Drainage Project. Sample to be collected from the yard area north of the Turbine Hall.

Cost per sample	\$55.00	# of samples = 1	Total	\$55.00
Ten-day turn around surcharge %50				<u>x 1.5</u>
Total				\$82.00

2. Analysis of one composite soil sample from the landspreading area for pH, CEC, potassium, phosphorus, magnesium, calcium, cadmium, chromium, copper, lead, mercury, nickel, zinc, and arsenic. Analysis required annually for permit condition compliance by the Maine Department of Environmental Protection.

Cost per sample	\$231.00
# of samples =	<u>x 1</u>
Total	\$231.00

Total for this requisition \$313.00

MAILED

NOV 14 1996

Yankee Atomic Electric Company
 Environmental Laboratory

YAEC
 ENVIRONMENTAL LAB.

Analysis Report

Customer: Maine Yankee Atomic Power Station
 Attention: Mr. Roger R. O'Clair
 Mr. Edward Cumming

Report Date: 11/14/96
 Analysis Date: 11/14/96
 Receipt Date: 11/06/96
 Reference Date: 11/04/96

Sediment

Station No: 07 Turbine Hall (N)

Sample Amount: 0.653 kg-dry
 Elapsed Time: 10.1226 days
 Comment: Soil Composite Yard Area

Lab Sample #: G32682
 Sample Code: MSE 07 4596
 Analyses Req: G

Nuclide	Decay Correction	Conc. $\pm \sigma$		MDC
		[picroCurie / kg - dry]		
				Activity
Co-57	9.74E-01	(-41 \pm 21)	E 00	79E 00
Ce-144	9.75E-01	(-13 \pm 16)	E 01	56E 01
Ce-141	8.05E-01	(2 \pm 41)	E 00	14E 01
Mo-99	7.79E-02	(-41 \pm 25)	E 02	12E 03
Se-75	9.43E-01	(25 \pm 35)	E 00	12E 01
Cr-51	7.76E-01	(6 \pm 27)	E 01	96E 01
I-131	4.17E-01	(-87 \pm 59)	E 00	25E 01
Be-7	8.76E-01	(-12 \pm 27)	E 01	11E 02
Ru-103	8.36E-01	(9 \pm 28)	E 00	10E 01
XI-133				
Ba-140	5.77E-01	(-43 \pm 43)	E 00	23E 01
Cs-134	9.90E-01	(-4 \pm 26)	E 00	99E 00
Ru-106	9.81E-01	(15 \pm 28)	E 01	10E 02
Cs-137	9.99E-01	(79 \pm 44)	E 00	14E 01
Ag-110M	9.72E-01	(-3 \pm 40)	E 00	16E 01
Zr-95	8.96E-01	(55 \pm 53)	E 00	18E 01
Co-58	9.05E-01	(-10 \pm 30)	E 00	12E 01
Mn-54	9.77E-01	(37 \pm 35)	E 00	12E 01
* AcTh228	1.00E 00	(69 \pm 17)	E 01	48E 01
TeI-132	1.16E-01	(12 \pm 27)	E 01	10E 02
Fe-59	8.54E-01	(83 \pm 94)	E 00	34E 01
Zn-65	9.71E-01	(27 \pm 16)	E 01	59E 01
Co-60	9.96E-01	(-12 \pm 38)	E 00	16E 01
* K-40	1.00E 00	(183 \pm 16)	E 02	17E 02
Sb-124	8.90E-01	(-37 \pm 33)	E 00	25E 01

Notes:

- * Activity greater than 3 standard deviations
- + Peak is found
- x Decay correction is less than .01

Reporting level ratio: 0.000

Approved by


 E. M. Moreno

HSA ID# 97

Map#: MSC-001 Date: 11-17-97 Time: 17:00 Reactor Pwr %: \emptyset Tech File Number: RWP's Used: N/A Dose Received: \emptyset mSv

Surveyor Name: (Printed) **W. Stover** Surveyor Name: (Signature) *[Signature]* Location/Job Description: **Northend Conference Room**
MAINE Yankee Information Center


Required R.P. Review / Date: Required ALARA Supervisor Review / Date: REASON FOR SURVEY

ROUTINE' JOB-COVERAGE' OTHER' (Specify): **Requested**

SHIELDING^{1,2}


INSTRUMENTS USED				CONTAMINATION RESULTS								KEY:
MODEL	SERIAL #	CAL DUE	MDA	SAMPLE #	RESULTS	SAMPLE #	RESULTS	SAMPLE #	RESULTS	SAMPLE #	RESULTS	
Model 3	72455-91	3-23-98	N/A	N/A		N/A		N/A		N/A		• Contact exposure rates denoted by: *
Model 5	132261	12-14-97	N/A	N/A		N/A		N/A		N/A		• Smear locations denoted by: ⊙
N/A				N/A		N/A		N/A		N/A		• Boundaries or barriers denoted by: -x-x-
N/A				N/A		N/A		N/A		N/A		• Dose rates denoted by: $\frac{\mu}{hr}$
N/A				N/A		N/A		N/A		N/A		• Large area smears denoted by: $\frac{\mu}{ft^2}$
N/A				N/A		N/A		N/A		N/A		• Air sample location denoted by: CAS-#

Sample Continuation Sheet Used: YES



#1 → 5000 ccpm
 2 → 3000
 3 → 1000

#1 → 60 μ R/hr.



Note: At \approx 18:30, Build. posted as:
 Notify Radiation Protection
 Prior to Entry.


#1 SAMPLE POINT Extracted,
 isotopic Analysis performed.

Map#: MSC-001	Date: 11/18/97	Time: 0815	Reactor Pwr %: SHUTDOWN	Tech File Number: N/A	RWP's Used: N/A	Dose Received: 0
Revision#: 00	Surveyor Name: (Printed) Paul Lee Mercer		Surveyor Name: (Signature) Ed J. Thundro		Location/Job Description: Survey of Info Center	

Required R.P. Review / Date	Required ALARA Supervisor Review / Date	REASON FOR SURVEY <input type="checkbox"/> ROUTINE' <input type="checkbox"/> JOB-COVERAGE' <input checked="" type="checkbox"/> OTHER' (Specify):
-----------------------------	---	---

INSTRUMENTS USED				CONTAMINATION RESULTS								KEY:
MODEL	SERIAL #	CAL DUE	MDA	SAMPLE #	RESULTS	SAMPLE #	RESULTS	SAMPLE #	RESULTS	SAMPLE #	RESULTS	
MOD 3	7234-91	2-19-98	1K	1	<MDA	6	<MDA	11	<MDA	16	<MDA	• Contact exposure rates denoted by: *
BC-4	883-94	1-17-98	165.1	2	<MDA	7	<MDA	12	<MDA			• Smear locations denoted by: ⊙
				3	<MDA	8	<MDA	13	<MDA			• Boundaries or barriers denoted by: -x-x-
				4	<MDA	9	<MDA	14	<MDA			• Dose rates denoted by: $\frac{\mu}{hr}$
				5	<MDA	10	<MDA	15	<MDA			• Large area smears denoted by: \square
												• Air sample location denoted by: \square AIR

Note:
Smear #'s 6-14 were taken on Natural Radioactivity Display cases
Other smears were taken on Desk, TABLES, CABINETS



Air piece of CARPET was removed and bagged for isotopics in Restricted Area
Floor under carpet was surveyed,
- No Fixed Activity was detected
- No Smearable Activity was detected per Large Area Maximum smear.

Air sample was taken in copter Rm. info ctr.
From 11-17-97 - 20:19 to 11-18-97 - 0700
Air sample was counted on BC-4 + Isotopic analysis was performed
ISO # 012314
1 - 18-NOV-97 - 09:22
1c # 100 - INFO CENTER
No Activity was found.

Vacuum used in info center was surveyed
- No Loose or Fixed Activity was detected.
Vacuum bag was confiscated and sent to Restricted Area for isotopic analysis.

ISOTOPICS REVEALED ALL activity to be NATURAL.
INFORMATION CENTER WAS deposited.

Direct Frisk of carpet in Rooms of Info Center was performed, No increase above background was detected except in North Room (Computer Room).

3 AREAS detected by Paul Stover
1 - 5000 ccpm see Survey
2 - 3000 ccpm 11-17-97/1700
3 - 1000 ccpm
ISO 11-17-97/
FILE # 100 (174)
(INFO CENTER)
SAMPLE 1

3 AREAS were detected by Tim Huff + Ed Thundro
300-600 ccpm
Survey 11-18-97 0830
150 File-100
18-NOV-97 13:17 EIF CARPET 1
13.37 EIF CARPET 2
14:30 EIF CARPET 3

2 AREAS detected by Ed Mercer
Survey in HAND.
ISOTOPICS
1) 1000 ccpm CARPET 1 File 100
2) 900 ccpm CARPET 2 File 100
11-19-97 02:35

Display CABINETS
URANIUM ROCKS were removed from Display cabinets and isotopic analysis was performed in Restricted Area.
FILE # 100 - ISO'S 18-NOV-97
08:22, 08:23, 11:20, + 12:36

Map#: MSC001	Date: 11-18-97	Time: 0830	Reactor Pwr %: SD	Tech File Number: N/A	RWP's Used: 97-00001	Dose Received: 0 mR
Revision#: 00						
Surveyor Name: (Printed) Johnnie Timothy HUFF	Surveyor Name: (Signature) <i>[Signature]</i>	Location/Job Description: Visitor Center Direct frisk of carpets				
Wired R.P. Review / Date <i>[Signature]</i> 11/18/97	Required ALARA Supervisor Review / Date		REASON FOR SURVEY <input type="checkbox"/> ROUTINE ¹ <input type="checkbox"/> JOB-COVERAGE ¹ <input type="checkbox"/> SHIELDING ^{1,2} <input checked="" type="checkbox"/> OTHER ¹ (Specify):			

INSTRUMENTS USED				CONTAMINATION RESULTS								KEY:
MODEL	SERIAL #	CAL DUE	MDA	SAMPLE #	RESULTS	SAMPLE #	RESULTS	SAMPLE #	RESULTS	SAMPLE #	RESULTS	
3	72622-91	2-19-98	1000 dpm									● Contact exposure rates denoted by: *
3	72455-91	3-23-98	1000 dpm									● Smear locations denoted by: ⊙
												● Boundaries or barriers denoted by: -x-x-
												● Dose rates denoted by: $\frac{\mu}{h}$
												● Large area smears denoted by: \square
												● Air sample location denoted by: AS-2
												Sample Continuation Sheet Used. <input type="checkbox"/> YES

Direct frisk of carpeting in computer rooms, conference room, and main rooms showed \leq BKdg except in large computer room (middle of floor) found 3 spots showing 300-600 cpm direct frisk per probe area. These 3 spots were cut out of carpet and taken into plant to do ISO on them. Results will be attached to this survey. Areas were ~ 80% floor surface surveyed.

*
* GAMMA SPECTRUM ANALYSIS *
*

CANBERRA APOGEE V2.4

Canberra Industries, Inc.

18-NOV-97 13:17:45

ANALYSIS PARAMETERS

Spectrum file number : 100.0 Sample no. : 1.0
MCA unit number : 2 ADC unit number : 3.0
Detector number : 3 Geometry number : 2

Search threshold 1 : 2.0 Search threshold 2 : 3.0
Search FROM channel : 50 Search TO channel : 4095
Id energy tolerance : 1.0 Order of background : linear
Smoothing factor : 0 Random sum corr : disabled
BRA parameter : 0 Baseline channels : disabled

Confidence threshold index : 0.100
Confidence levels LLD : 1.645 (95.0%) MDA : 1.645 (95.0%)

Analysis library : SPF#LIBRARY:SPFANL.LIB;1
Background subtract : enabled

Sample description : EIF CARPET #1 JM Analyzed by: JNM

Sample size : 1.000000E+00 EA Conv. factor : 1.000
Standard size : 1.000000E+00 EA

Sample taken on : 18-NOV-97 at 11:30:00
Collect started on : 18-NOV-97 at 13:00:24
Decay time : 90.4 minutes

live time : 1000.0 seconds real time : 1000.0 seconds
dead time : 0.00 %

Energy calibration used done on 11 / 18 / 1997
Efficiency calibration used done on 11 / 15 / 1996

*** P E A K F I T R E P O R T *** 18-NOV-97 13:17:45

peak no.	nuclide(s)	centroid channel	energy keV	FWHM keV	net area counts	error %	gammas per second	err %
M 1	PB-214 NATURAL	149.46	74.82	1.09	83.4	14.91	4.8	18.
M 2	PB-214	154.02	77.10	1.09	119.2	11.79	6.7	15.
3	NP-237 EU-155	174.26	87.20	1.18	45.5	21.65	2.2	22.
	NATURAL CD-109							
4	NATURAL NATURAL	372.85	186.30	1.58	89.1	12.65	4.7	13.
B 4			186.30		3.6	16.28		
5		484.48	242.03	1.28	98.9	12.07	6.8	12.
6	PB-214	590.91	295.17	1.37	208.6	7.34	17.7	8.
7	PB-214	704.82	352.05	1.38	327.2	5.73	33.7	6.
8	BI-214	1219.75	609.28	1.60	233.9	6.79	44.5	7.
9	BI-214	2242.22	1120.12	1.88	36.4	18.47	13.2	18.

M - Peak is a multiplet

B - Environmental background peak. Will be subtracted from the peak above.

Background subtraction performed using file SPF\$DATA:BK0003.MC2
background description: 25K SEC BKG 4/20/97

Sample description : EIF CARPET #1 JM
 analyzed by : JNM

number	nuclide	conf.value	Activity (uCi/EA)	
			measured	decay corrected
1. Fission gases				
	total	0.00E+00	total	0.00E+00
2. Iodines				
	total	0.00E+00	total	0.00E+00
3. Particulates				
1	CD-109 ?	0.8936	1.68E-03 +-3.75E-04	1.69E-03 +-3.75E-04
2	EU-155 ?	0.3304	1.78E-04 +-3.97E-05	1.78E-04 +-3.97E-05
3	NP-237 ?	0.6593	4.81E-04 +-1.07E-04	4.81E-04 +-1.07E-04
	total	2.34E-03	total	2.34E-03

? = nuclides with a common single line, cannot identify which one is present

These peaks were not identified

number	channel	energy	peak intensity (cps)		
1	149.5	74.82	4.8239E+00 +-8.93E-01	PB-214	NATURAL
2	154.0	77.10	6.6544E+00 +-1.01E+00	PB-214	
4	372.8	186.30	4.5440E+00 +-6.26E-01	NATURAL	NATURAL
5	484.5	242.03	6.7854E+00 +-8.67E-01		
6	590.9	295.17	1.7689E+01 +-1.44E+00	PB-214	
7	704.8	352.05	3.3667E+01 +-2.19E+00	PB-214	
8	1219.7	609.28	4.4494E+01 +-3.40E+00	BI-214	
9	2242.2	1120.12	1.3225E+01 +-2.47E+00	BI-214	

Errors quoted at 1.000 sigma (68.3%)

*** MDA CALCULATION REPORT ***

18-NOV-97 13:17:45

Sample description : EIF CARPET #1 JM
 Analyzed by : JNM

		----- MDA (uCi/EA) -----	
		measured	decay corrected
NA-24	:	MDA : 1.80E-04	1.93E-04
AR-41	:	MDA : 2.07E-04	3.67E-04
CR-51	:	MDA : 8.36E-04	8.38E-04
MN-54	:	MDA : 1.50E-04	1.50E-04
MN-56	:	MDA : 1.11E-04	1.67E-04
CO-57	:	MDA : 5.89E-05	5.89E-05
CO-58	:	MDA : 1.50E-04	1.50E-04
FE-59	:	MDA : 2.56E-04	2.56E-04
CO-60	:	MDA : 1.94E-04	1.94E-04
CU-64	:	MDA : 4.69E-02	5.09E-02
NI-65	:	MDA : 7.78E-04	1.18E-03
ZN-65	:	MDA : 4.82E-04	4.82E-04
SE-75	:	MDA : 9.37E-05	9.38E-05
BR-84	:	MDA : 4.19E-04	3.01E-03
KR-85	:	MDA : 2.59E-02	2.59E-02
SR-85	:	MDA : 1.13E-04	1.13E-04
KR-85M	:	MDA : 7.77E-05	9.80E-05
-87	:	MDA : 1.81E-04	4.12E-04
-88	:	MDA : 2.45E-04	3.53E-04
Y-88	:	MDA : 1.50E-04	1.50E-04
RB-88	:	MDA : 6.94E-04	2.35E-02
RB-89	:	MDA : 3.22E-04	1.87E-02
KR-89	:	MDA : 1.29E-03	5.29E+05
Y-91M	:	MDA : 1.27E-04	4.49E-04
SR-91	:	MDA : 5.46E-04	6.10E-04
Y-92	:	MDA : 1.49E-03	2.01E-03
SR-92	:	MDA : 3.30E-04	4.86E-04
Y-93	:	MDA : 1.07E-03	1.19E-03
Y-94	:	MDA : 3.13E-04	8.92E-03
Y-95	:	MDA : 8.53E-04	3.74E-01
NB-95	:	MDA : 2.02E-04	2.03E-04
NB-95M	:	MDA : 3.04E-04	3.08E-04
ZR-95	:	MDA : 2.05E-04	2.05E-04
ZR-97	:	MDA : 2.02E-03	2.15E-03
NB-97	:	MDA : 9.05E-05	2.16E-04
MO-99	:	MDA : 9.98E-04	1.01E-03
TC-99M	:	MDA : 7.03E-05	7.14E-05
MO-101	:	MDA : 3.22E-04	2.35E-02
TC-101	:	MDA : 7.53E-05	6.22E-03
TC-102M	:	MDA : 3.34E-04	6.02E+02
RU-103	:	MDA : 1.20E-04	1.20E-04
TC-104	:	MDA : 1.07E-04	3.41E-03
H-105	:	MDA : 4.31E-04	4.44E-04
-105	:	MDA : 2.85E-04	3.60E-04
-106	:	MDA : 8.06E-04	8.06E-04
RU-106	:	MDA : 8.06E-04	8.06E-04
AG-108M	:	MDA : 9.91E-05	9.91E-05

CD-109	:	MDA	:	2.32E-03	2.32E-03
AG-110M	:	MDA	:	9.40E-05	9.40E-05
SN-113	:	MDA	:	1.61E-04	1.61E-04
CB-122	:	MDA	:	1.86E-04	1.89E-04
-124	:	MDA	:	1.37E-04	1.37E-04
-125	:	MDA	:	3.79E-04	3.79E-04
-131M	:	MDA	:	4.68E-04	4.85E-04
XE-131M	:	MDA	:	3.19E-03	3.20E-03
SB-131	:	MDA	:	2.98E-04	4.53E-03
I-131	:	MDA	:	1.06E-04	1.07E-04
TE-131	:	MDA	:	8.74E-05	1.07E-03
I-132	:	MDA	:	1.41E-04	2.23E-04
TE-132	:	MDA	:	7.92E-05	8.03E-05
BA-133	:	MDA	:	3.35E-04	3.35E-04
TE-133	:	MDA	:	1.03E-04	1.57E-02
I-133	:	MDA	:	1.15E-04	1.20E-04
XE-133M	:	MDA	:	7.17E-04	7.31E-04
XE-133	:	MDA	:	3.01E-04	3.04E-04
TE-133M	:	MDA	:	2.19E-04	6.80E-04
TE-134	:	MDA	:	3.32E-04	1.49E-03
I-134	:	MDA	:	1.22E-04	4.02E-04
CS-134	:	MDA	:	1.57E-04	1.57E-04
I-135	:	MDA	:	7.77E-04	9.10E-04
XE-135M	:	MDA	:	1.27E-04	7.50E-03
XE-135	:	MDA	:	8.69E-05	9.75E-05
CS-136	:	MDA	:	1.59E-04	1.60E-04
CS-137	:	MDA	:	1.10E-04	1.10E-04
CS-138	:	MDA	:	2.16E-04	1.51E-03
XE-138	:	MDA	:	2.48E-04	2.09E-02
CS-139	:	MDA	:	2.91E-03	2.29E+00
-139	:	MDA	:	3.52E-04	7.48E-04
-138M	:	MDA	:	1.20E-03	2.91E+06
CE-139	:	MDA	:	7.49E-05	7.49E-05
BA-140	:	MDA	:	4.48E-04	4.49E-04
LA-140	:	MDA	:	2.12E-04	2.12E-04
BA-141	:	MDA	:	1.61E-04	4.97E-03
LA-141	:	MDA	:	1.02E-02	1.33E-02
CE-141	:	MDA	:	1.22E-04	1.22E-04
BA-142	:	MDA	:	3.91E-04	1.37E-01
LA-142	:	MDA	:	2.54E-04	4.90E-04
CE-143	:	MDA	:	4.17E-04	4.30E-04
PR-144	:	MDA	:	9.47E-03	9.47E-03
CE-144	:	MDA	:	5.12E-04	5.12E-04
PR-146	:	MDA	:	2.27E-04	3.09E-03
CE-146	:	MDA	:	1.48E-04	1.35E-02
ND-147	:	MDA	:	2.77E-04	2.78E-04
PR-147	:	MDA	:	3.24E-04	3.25E-02
PM-149	:	MDA	:	2.66E-03	2.71E-03
EU-152	:	MDA	:	1.83E-04	1.83E-04
HF-181	:	MDA	:	1.20E-04	1.20E-04
W-187	:	MDA	:	4.32E-04	4.51E-04
HG-203	:	MDA	:	1.01E-04	1.01E-04
NP-237	:	MDA	:	6.69E-04	6.69E-04
U-237	:	MDA	:	2.18E-04	2.19E-04
NP-239	:	MDA	:	2.13E-04	2.17E-04
M-241	:	MDA	:	3.23E-04	3.23E-04
-154	:	MDA	:	1.33E-04	1.33E-04
-155	:	MDA	:	2.47E-04	2.47E-04
NB-94	:	MDA	:	1.45E-04	1.45E-04

*
* GAMMA SPECTRUM ANALYSIS *
*

LANBERRA APOGEE V2.4

Canberra Industries, Inc.

18-NOV-97 13:37:59

A N A L Y S I S P A R A M E T E R S

Spectrum file number : 100.0 Sample no. : 1.0
MCA unit number : 2 ADC unit number : 3.0
Detector number : 3 Geometry number : 2

Search threshold 1 : 2.0 Search threshold 2 : 3.0
Search FROM channel : 50 Search TO channel : 4095
Id energy tolerance : 1.0 Order of background : linear
Smoothing factor : 0 Random sum corr : disabled
GRA parameter : 0 Baseline channels : disabled

Confidence threshold index : 0.100
Confidence levels LLD : 1.645 (95.0%) MDA : 1.645 (95.0%)

Analysis library : SPF#LIBRARY:SPFANL.LIB;1
Background subtract : enabled

Sample description : EIC SAMPLE #2 JM Analyzed by: JNM

Sample size : 1.000000E+00 EA Conv. factor : 1.000
Standard size : 1.000000E+00 EA

Sample taken on : 18-NOV-97 at 11:35:00
Collect started on : 18-NOV-97 at 13:20:37
Decay time : 105.6 minutes

live time : 1000.0 seconds real time : 1000.0 seconds
dead time : 0.00 %

Energy calibration used done on 11 / 18 / 1997
Efficiency calibration used done on 11 / 15 / 1996

*** P E A K F I T R E P O R T *** 18-NOV-97 13:37:55

peak no.	nuclide(s)	centroid channel	energy keV	FWHM keV	net area counts	error %	gammas per second	err %
M 1	PB-214 NATURAL	149.49	74.84	1.09	71.5	16.79	4.1	20.
M 2	PB-214	153.97	77.08	1.09	102.0	13.60	5.7	16.
3	NATURAL	184.90	92.50	1.31	45.4	23.97	2.1	24.
B 3			92.50		5.6	12.49		
4	NATURAL NATURAL	372.44	186.10	1.31	105.7	11.92	5.6	12.
B 4			186.10		3.6	16.28		
5	I-134	471.63	235.61	1.21	20.1	34.84	1.3	35.
6		484.52	242.05	1.32	86.5	12.58	5.9	13.
7	PB-214	591.06	295.24	1.39	176.1	8.26	14.7	9.
8	PB-214	704.53	351.91	1.32	346.7	5.60	35.7	6.
9	BI-214	1219.81	609.31	1.63	218.6	7.02	41.6	7.
10	BI-214	2242.49	1120.25	1.97	39.6	17.39	14.4	17.

M - Peak is a multiplet

B - Environmental background peak. Will be subtracted from the peak above.

Background subtraction performed using file SPF#DATA:BK0003.MC2
background description: 25K SEC BKG 4/20/97

sample description :EIC SAMPLE #2 JM
analyzed by :JNM

number	nuclide	conf.value	----- measured	Activity (uCi/EA) ----- decay corrected
1. Fission gases				
	total		0.00E+00	total 0.00E+00
2. Iodines				
	total		0.00E+00	total 0.00E+00
3. Particulates				
1	NB-95M	0.9991	1.45E-04 +-5.09E-05	1.47E-04 +-5.16E-05
	total		1.45E-04	total 1.47E-04

These peaks were not identified

number	channel	energy	peak intensity (cps)		
1	149.5	74.84	4.1308E+00 +-8.28E-01	PB-214	NATURAL
2	154.0	77.08	5.6917E+00 +-9.46E-01	PB-214	
3	184.9	92.50	1.8798E+00 +-5.20E-01	NATURAL	
4	372.4	186.10	5.4218E+00 +-7.03E-01	NATURAL	NATURAL
6	484.5	242.05	5.9361E+00 +-7.87E-01		
7	591.1	295.24	1.4917E+01 +-1.34E+00	PB-214	
8	704.5	351.91	3.5658E+01 +-2.28E+00	PB-214	
9	1219.8	609.31	4.1589E+01 +-3.26E+00	BI-214	
10	2242.5	1120.25	1.4369E+01 +-2.53E+00	BI-214	

Errors quoted at 1.000 sigma (68.3%)

*** M D A C A L C U L A T I O N R E P O R T ***

18-NOV-97

13:37:59

Sample description : EIC SAMPLE #2 JM
 Analyzed by : JNM

		----- MDA (uCi/EA) -----	
		measured	decay corrected
NA-24	:	MDA : 2.17E-04	2.36E-04
AR-41	:	MDA : 1.81E-04	3.54E-04
CR-51	:	MDA : 8.63E-04	8.65E-04
MN-54	:	MDA : 1.50E-04	1.50E-04
MN-56	:	MDA : 1.45E-04	2.32E-04
CO-57	:	MDA : 7.05E-05	7.05E-05
CO-58	:	MDA : 1.73E-04	1.73E-04
FE-59	:	MDA : 2.23E-04	2.24E-04
CO-60	:	MDA : 2.07E-04	2.07E-04
CU-64	:	MDA : 3.82E-02	4.20E-02
NI-65	:	MDA : 9.61E-04	1.56E-03
ZN-65	:	MDA : 4.82E-04	4.82E-04
SE-75	:	MDA : 1.02E-04	1.02E-04
BR-84	:	MDA : 3.43E-04	3.43E-03
KR-85	:	MDA : 2.96E-02	2.96E-02
SR-85	:	MDA : 1.30E-04	1.30E-04
KR-85M	:	MDA : 8.18E-05	1.07E-04
-87	:	MDA : 2.37E-04	6.18E-04
R-88	:	MDA : 2.61E-04	4.02E-04
Y-88	:	MDA : 1.73E-04	1.73E-04
RB-88	:	MDA : 8.05E-04	4.92E-02
RB-89	:	MDA : 2.82E-04	3.23E-02
KR-89	:	MDA : 1.35E-03	1.55E+07
Y-91M	:	MDA : 1.20E-04	5.24E-04
SR-91	:	MDA : 5.54E-04	6.30E-04
Y-92	:	MDA : 1.28E-03	1.81E-03
SR-92	:	MDA : 3.44E-04	5.39E-04
Y-93	:	MDA : 1.12E-03	1.26E-03
Y-94	:	MDA : 2.27E-04	1.14E-02
Y-95	:	MDA : 8.24E-04	1.01E+00
NB-95	:	MDA : 2.22E-04	2.22E-04
ZR-95	:	MDA : 2.37E-04	2.37E-04
ZR-97	:	MDA : 2.33E-03	2.50E-03
NB-97	:	MDA : 1.37E-04	3.78E-04
MO-99	:	MDA : 1.04E-03	1.05E-03
TC-99M	:	MDA : 7.49E-05	7.63E-05
MO-101	:	MDA : 3.35E-04	5.02E-02
TC-101	:	MDA : 1.01E-04	1.75E-02
TC-102M	:	MDA : 3.85E-04	7.85E+03
RU-103	:	MDA : 1.03E-04	1.04E-04
TC-104	:	MDA : 1.34E-04	7.67E-03
RH-105	:	MDA : 4.36E-04	4.51E-04
U-105	:	MDA : 3.05E-04	4.01E-04
-106	:	MDA : 9.35E-04	9.35E-04
J-106	:	MDA : 9.35E-04	9.35E-04
AG-108M	:	MDA : 1.03E-04	1.03E-04
CD-109	:	MDA : 2.61E-03	2.61E-03

AG-110M	:	MDA	:	1.42E-04	1.42E-04
SN-113	:	MDA	:	1.74E-04	1.74E-04
SB-122	:	MDA	:	1.61E-04	1.64E-04
PR-124	:	MDA	:	1.30E-04	1.30E-04
-125	:	MDA	:	3.71E-04	3.71E-04
E-131M	:	MDA	:	5.41E-04	5.64E-04
E-131M	:	MDA	:	3.29E-03	3.31E-03
SB-131	:	MDA	:	2.98E-04	7.15E-03
I-131	:	MDA	:	1.18E-04	1.19E-04
TE-131	:	MDA	:	8.74E-05	1.63E-03
I-132	:	MDA	:	1.16E-04	1.98E-04
TE-132	:	MDA	:	8.20E-05	8.33E-05
BA-133	:	MDA	:	3.28E-04	3.28E-04
TE-133	:	MDA	:	1.12E-04	4.00E-02
I-133	:	MDA	:	1.25E-04	1.33E-04
XE-133M	:	MDA	:	7.95E-04	8.13E-04
XE-133	:	MDA	:	2.95E-04	2.98E-04
TE-133M	:	MDA	:	1.66E-04	6.21E-04
TE-134	:	MDA	:	3.16E-04	1.82E-03
I-134	:	MDA	:	1.55E-04	6.23E-04
CS-134	:	MDA	:	1.51E-04	1.52E-04
I-135	:	MDA	:	6.61E-04	7.95E-04
XE-135M	:	MDA	:	1.32E-04	1.56E-02
XE-135	:	MDA	:	8.38E-05	9.58E-05
CS-136	:	MDA	:	1.55E-04	1.56E-04
CS-137	:	MDA	:	1.55E-04	1.55E-04
CS-138	:	MDA	:	2.32E-04	2.26E-03
XE-138	:	MDA	:	2.30E-04	4.10E-02
CS-139	:	MDA	:	2.80E-03	6.75E+00
RA-139	:	MDA	:	3.78E-04	9.12E-04
-139M	:	MDA	:	1.29E-03	1.19E+08
-139	:	MDA	:	8.04E-05	8.04E-05
BA-140	:	MDA	:	4.73E-04	4.75E-04
LA-140	:	MDA	:	1.92E-04	1.92E-04
BA-141	:	MDA	:	1.79E-04	9.84E-03
LA-141	:	MDA	:	6.39E-03	8.71E-03
CE-141	:	MDA	:	1.35E-04	1.35E-04
BA-142	:	MDA	:	3.69E-04	3.45E-01
LA-142	:	MDA	:	2.69E-04	5.80E-04
CE-143	:	MDA	:	4.13E-04	4.28E-04
PR-144	:	MDA	:	1.11E-02	1.11E-02
CE-144	:	MDA	:	5.66E-04	5.66E-04
PR-146	:	MDA	:	2.39E-04	5.05E-03
CE-146	:	MDA	:	1.45E-04	2.80E-02
ND-147	:	MDA	:	3.45E-04	3.46E-04
PR-147	:	MDA	:	3.63E-04	7.89E-02
PM-149	:	MDA	:	2.76E-03	2.83E-03
EU-152	:	MDA	:	2.06E-04	2.06E-04
HF-181	:	MDA	:	1.33E-04	1.33E-04
W-187	:	MDA	:	4.85E-04	5.11E-04
HB-203	:	MDA	:	1.04E-04	1.04E-04
NP-237	:	MDA	:	7.49E-04	7.49E-04
U-237	:	MDA	:	2.44E-04	2.46E-04
NP-239	:	MDA	:	2.65E-04	2.71E-04
AM-241	:	MDA	:	3.60E-04	3.60E-04
U-154	:	MDA	:	1.41E-04	1.41E-04
-155	:	MDA	:	2.78E-04	2.78E-04
-94	:	MDA	:	1.38E-04	1.38E-04

 *
 * GAMMA SPECTRUM ANALYSIS *
 *

LANBERRA APOSEE V2.4

Canberra Industries, Inc.

18-NOV-97 14:30:59

A N A L Y S I S P A R A M E T E R S

Spectrum file number	:	100.0	Sample no.	:	1.0
MCA unit number	:	2	ADC unit number	:	3.0
Detector number	:	3	Geometry number	:	2
Search threshold 1	:	2.0	Search threshold 2	:	3.0
Search FROM channel	:	50	Search TO channel	:	4095
Id energy tolerance	:	1.0	Order of background	:	linear
Smoothing factor	:	0	Random sum corr	:	disabled
GRA parameter	:	0	Baseline channels	:	disabled

Confidence threshold index : 0.100
 Confidence levels LLD : 1.645 (95.0%) MDA : 1.645 (95.0%)

Analysis library : SPF\$LIBRARY:SPFANL.LIB;1
 Background subtract : enabled

Sample description : EIC CARPET #3 JM Analyzed by: JNM

Sample size : 1.000000E+00 EA Conv. factor : 1.000
 Standard size : 1.000000E+00 EA

Sample taken on : 18-NOV-97 at 11:40:00
 Collect started on : 18-NOV-97 at 14:13:37
 Decay time : 153.6 minutes

live time : 1000.0 seconds real time : 1000.0 seconds
 dead time : 0.00 %

Energy calibration used done on 11 / 18 / 1997
 Efficiency calibration used done on 11 / 15 / 1996

*** P E A K F I T R E P O R T *** 18-NOV-97 14:30:59

peak no.	nuclide(s)	centroid channel	energy keV	FWHM keV	net area counts	error %	gammas per second	err %
M 1	PB-214 NATURAL	149.36	74.77	1.09	46.7	21.62	2.7	24.0
M 2	PB-214	153.87	77.02	1.09	102.8	12.81	5.7	16.0
3	NATURAL NATURAL	372.53	186.14	1.28	72.2	15.13	3.8	15.0
B 3			186.14		3.6	16.28		
4		484.64	242.11	1.49	74.0	13.12	5.1	13.0
5	PB-214	591.00	295.21	1.41	140.6	9.01	11.9	9.0
6	PB-214	704.87	352.08	1.48	262.8	6.45	27.0	7.0
7	BI-214	1219.57	609.19	1.70	148.9	8.54	28.3	9.0

M - Peak is a multiplet

B - Environmental background peak. Will be subtracted from the peak above.

Background subtraction performed using file SPF#DATA:BK0003.MC2
background description: 25K SEC BKG 4/20/97

INF: no found peak matched with library lines

Sample description : EIC CARPET #3 JM
 Analyzed by : JNM

number	nuclide	conf.value	-----	Activity (uCi/EA)	-----
			measured				decay corrected

These peaks were not identified

number	channel	energy	peak	intensity (cps)		
1	149.4	74.77	2.7027E+00	+/-6.56E-01	PB-214	NATURAL
2	153.9	77.02	5.7458E+00	+/-9.20E-01	PB-214	
3	372.5	186.14	3.6419E+00	+/-5.98E-01	NATURAL	NATURAL
4	484.6	242.11	5.0786E+00	+/-6.99E-01		
5	591.0	295.21	1.1910E+01	+/-1.15E+00	PB-214	
6	704.9	352.08	2.7050E+01	+/-1.94E+00	PB-214	
7	1219.6	609.19	2.8315E+01	+/-2.61E+00	BI-214	

Errors quoted at 1.000 sigma (68.3%)

Sample description : EIC CARPET #3 JM
 Analyzed by : JNM

----- MDA (uCi/EA) -----
 measured decay corrected

NA-24	:	MDA :	1.57E-04	1.77E-04
AR-41	:	MDA :	1.99E-04	5.26E-04
CR-51	:	MDA :	8.18E-04	8.20E-04
MN-54	:	MDA :	1.58E-04	1.58E-04
MN-56	:	MDA :	1.54E-04	3.06E-04
CO-57	:	MDA :	6.23E-05	6.24E-05
CO-58	:	MDA :	1.37E-04	1.38E-04
FE-59	:	MDA :	2.05E-04	2.05E-04
CO-60	:	MDA :	2.07E-04	2.07E-04
CU-64	:	MDA :	3.39E-02	3.90E-02
NI-65	:	MDA :	7.24E-04	1.46E-03
ZN-65	:	MDA :	5.74E-04	5.74E-04
SE-75	:	MDA :	7.55E-05	7.56E-05
BR-84	:	MDA :	3.43E-04	9.77E-03
KR-85	:	MDA :	2.50E-02	2.50E-02
SR-85	:	MDA :	1.09E-04	1.09E-04
KR-85M	:	MDA :	7.28E-05	1.08E-04
-87	:	MDA :	1.84E-04	7.43E-04
K-88	:	MDA :	2.12E-04	3.96E-04
Y-88	:	MDA :	1.19E-04	1.19E-04
RB-88	:	MDA :	5.50E-04	2.18E-01
RB-89	:	MDA :	2.93E-04	2.89E-01
KR-89	:	MDA :	1.26E-03	5.41E+11
Y-91M	:	MDA :	1.34E-04	1.14E-03
SR-91	:	MDA :	5.71E-04	6.88E-04
Y-92	:	MDA :	1.31E-03	2.17E-03
SR-92	:	MDA :	2.24E-04	4.32E-04
Y-93	:	MDA :	1.07E-03	1.28E-03
Y-94	:	MDA :	2.59E-04	7.70E-02
Y-95	:	MDA :	7.30E-04	2.25E+01
NB-95	:	MDA :	1.89E-04	1.89E-04
NB-95M	:	MDA :	2.90E-04	2.96E-04
ZR-95	:	MDA :	2.44E-04	2.44E-04
ZR-97	:	MDA :	2.02E-03	2.24E-03
NB-97	:	MDA :	9.05E-05	3.96E-04
MD-99	:	MDA :	9.59E-04	9.85E-04
TC-99M	:	MDA :	6.53E-05	6.71E-05
MD-101	:	MDA :	2.69E-04	3.93E-01
TC-101	:	MDA :	8.10E-05	1.46E-01
TC-102M	:	MDA :	3.52E-04	1.50E+07
RU-103	:	MDA :	1.06E-04	1.06E-04
TC-104	:	MDA :	1.05E-04	3.75E-02
H-105	:	MDA :	4.40E-04	4.63E-04
-105	:	MDA :	2.63E-04	3.92E-04
A-106	:	MDA :	1.08E-03	1.08E-03
RU-106	:	MDA :	1.08E-03	1.08E-03
AG-108M	:	MDA :	9.73E-05	9.73E-05

CD-109	:	MDA	:	2.27E-03	2.27E-03
AG-110M	:	MDA	:	9.40E-05	9.40E-05
SN-113	:	MDA	:	1.61E-04	1.61E-04
SB-122	:	MDA	:	1.46E-04	1.50E-04
I-124	:	MDA	:	1.27E-04	1.27E-04
R-125	:	MDA	:	3.23E-04	3.23E-04
L-131M	:	MDA	:	4.99E-04	5.30E-04
XE-131M	:	MDA	:	2.72E-03	2.73E-03
SB-131	:	MDA	:	3.48E-04	3.55E-02
I-131	:	MDA	:	1.02E-04	1.03E-04
TE-131	:	MDA	:	7.78E-05	5.51E-03
I-132	:	MDA	:	1.29E-04	2.81E-04
TE-132	:	MDA	:	8.31E-05	8.50E-05
BA-133	:	MDA	:	3.14E-04	3.14E-04
TE-133	:	MDA	:	1.01E-04	5.24E-01
I-133	:	MDA	:	1.25E-04	1.36E-04
XE-133M	:	MDA	:	7.12E-04	7.36E-04
XE-133	:	MDA	:	2.82E-04	2.86E-04
TE-133M	:	MDA	:	1.84E-04	1.26E-03
TE-134	:	MDA	:	2.89E-04	3.70E-03
I-134	:	MDA	:	1.64E-04	1.24E-03
CS-134	:	MDA	:	1.67E-04	1.67E-04
I-135	:	MDA	:	5.80E-04	7.59E-04
XE-135M	:	MDA	:	1.15E-04	1.18E-01
XE-135	:	MDA	:	6.53E-05	7.93E-05
CS-136	:	MDA	:	1.62E-04	1.63E-04
CS-137	:	MDA	:	1.37E-04	1.37E-04
CS-138	:	MDA	:	2.47E-04	6.75E-03
XE-138	:	MDA	:	2.40E-04	4.50E-01
CS-139	:	MDA	:	2.91E-03	2.42E+02
A-139	:	MDA	:	3.00E-04	1.08E-03
J-139M	:	MDA	:	1.11E-03	9.83E+12
CE-139	:	MDA	:	6.39E-05	6.40E-05
BA-140	:	MDA	:	4.21E-04	4.23E-04
LA-140	:	MDA	:	1.08E-04	1.08E-04
BA-141	:	MDA	:	1.40E-04	4.75E-02
LA-141	:	MDA	:	7.55E-03	1.18E-02
CE-141	:	MDA	:	1.17E-04	1.17E-04
BA-142	:	MDA	:	3.76E-04	7.90E+00
LA-142	:	MDA	:	2.27E-04	6.92E-04
CE-143	:	MDA	:	3.55E-04	3.75E-04
PR-144	:	MDA	:	8.36E-03	8.37E-03
CE-144	:	MDA	:	4.44E-04	4.44E-04
PR-146	:	MDA	:	1.89E-04	1.60E-02
CE-146	:	MDA	:	1.57E-04	3.33E-01
ND-147	:	MDA	:	3.00E-04	3.02E-04
PR-147	:	MDA	:	3.59E-04	9.01E-01
PM-149	:	MDA	:	2.38E-03	2.46E-03
EU-152	:	MDA	:	1.87E-04	1.87E-04
HF-181	:	MDA	:	1.07E-04	1.08E-04
W-187	:	MDA	:	4.32E-04	4.65E-04
HG-203	:	MDA	:	8.97E-05	8.98E-05
NP-237	:	MDA	:	6.30E-04	6.30E-04
U-237	:	MDA	:	1.87E-04	1.89E-04
NP-239	:	MDA	:	2.04E-04	2.11E-04
M-241	:	MDA	:	2.91E-04	2.91E-04
-154	:	MDA	:	1.33E-04	1.33E-04
J-155	:	MDA	:	2.33E-04	2.33E-04
NB-94	:	MDA	:	1.32E-04	1.32E-04

*** P E A K F I T R E P O R T ***

17-NOV-97

17:47:16

peak no.	nuclide(s)	centroid channel	energy keV	FWHM keV	net area counts	error %	gammas per second	error %
	1 NATURAL	126.30	63.27	1.10	497.2	7.39	18.3	22.1
M	2 PB-214 NATURAL	149.44	74.82	1.09	1254.9	3.84	36.3	11.6
M	3 PB-214	154.09	77.13	1.09	2254.8	2.75	62.9	9.9
M	4 CE-144 I-131 TL-201 etc.	161.94	81.05	1.10	56.6	56.10	1.5	56.5
M	5	167.47	83.81	1.10	277.3	12.10	7.1	13.4
M	6 NP-237 EU-155 NATURAL CD-109	174.37	87.25	1.10	737.4	5.35	18.2	7.4
M	7	179.63	89.88	1.10	334.0	10.12	8.0	11.0
M	8 NATURAL	184.95	92.54	1.11	1281.6	3.72	30.2	5.5
B	8		92.54		11.1	12.49		
	9 NP-239	197.20	98.65	1.44	160.2	16.66	3.6	17.0
	10	226.19	113.11	0.88	117.5	22.48	2.5	22.8
	11 NATURAL	288.17	144.04	1.27	262.0	11.31	5.8	11.8
	12 XE-138	308.26	154.07	1.03	106.5	25.24	2.4	25.5
	13	346.83	173.32	0.79	24.7	94.08	0.6	94.1
	14 NATURAL NATURAL	372.30	186.03	1.26	1818.7	2.78	48.3	4.7
B	14		186.03		7.2	16.28		
	15 I-134	472.22	235.92	1.14	149.9	15.07	5.0	15.6
	16	484.44	242.02	1.22	1707.6	2.73	58.6	4.5
M	17	538.80	269.16	1.26	160.2	13.33	6.1	13.8
M	18	543.06	271.28	1.26	109.2	18.78	4.2	19.1
	19 PB-214	591.05	295.25	1.32	3501.1	1.80	148.3	4.0
	20 PB-214	704.63	351.96	1.35	5499.5	1.41	282.9	3.4
	21	778.86	389.04	1.41	86.8	19.55	5.0	19.8
M	22 KR-87	804.52	401.85	1.37	63.5	25.01	3.8	25.2
M	23 I-134	810.90	405.04	1.37	66.5	24.96	4.0	25.1
	24 BI-214	1219.84	609.34	1.56	3810.5	1.67	362.5	3.8
	25 CE-143	1331.75	665.26	1.78	123.6	11.49	12.9	11.9
	26	1365.61	682.17	1.39	24.2	39.15	2.6	39.2
	27 NB-94	1406.81	702.76	1.64	46.2	24.52	5.1	24.7
	28	1537.99	768.31	1.76	318.9	6.39	39.0	7.0
	29 BI-212	1573.15	785.88	1.94	66.9	17.93	8.4	18.1
	30	1614.02	806.30	1.69	71.9	17.06	9.3	17.2
	31 Y-92	1869.62	934.02	1.97	147.7	10.10	22.2	10.4
	32 NATURAL	2004.25	1001.29	1.90	66.0	17.18	10.7	17.0
	33 BI-214	2242.58	1120.35	2.06	703.8	3.98	127.7	4.8
	34	2311.91	1154.98	1.97	79.1	14.58	14.8	14.8
	35 BI-214 CO-56	2478.57	1238.21	2.05	258.2	6.94	51.8	7.5
	36	2564.32	1281.03	2.01	67.3	16.29	14.0	16.5
	37 BI-214	2757.89	1377.67	2.08	150.1	9.72	33.5	10.1
M	38	2806.09	1401.72	2.07	45.7	20.83	10.4	21.0
M	39 EU-152	2818.39	1407.86	2.08	105.9	11.65	24.2	12.0
	40	3021.17	1509.04	1.86	89.3	13.22	21.8	13.5
	41	3462.45	1729.07	2.62	93.5	11.54	26.1	12.0
	42 BI-214	3532.33	1763.89	2.59	402.5	5.14	114.6	6.2
	43	3698.09	1846.45	2.34	60.3	14.51	17.9	15.1

- Peak is a multiplet

B - Environmental background peak. Will be subtracted from the peak above.

Background subtraction performed using file SPFDATA#BK0003.MCZ
Background description: 25K SEC BKG 4/20/97

 * GAMMA SPECTRUM ANALYSIS *
 *

CANBERRA APOGEE V2.4

Canberra Industries, Inc.

17-NOV-97 17:47:16

A N A L Y S I S P A R A M E T E R S

Spectrum file number	: 100.0	Sample no.	: 1.0
MCA unit number	: 2	ADC unit number	: 3.0
Detector number	: 3	Geometry number	: 2
Search threshold 1	: 2.0	Search threshold 2	: 3.0
Search FROM channel	: 50	Search TO channel	: 4095
Id energy tolerance	: 1.0	Order of background	: linear
Smoothing factor	: 0	Random sum corr	: disabled
GRA parameter	: 0	Baseline channels	: disabled

Confidence threshold index : 0.100
 Confidence levels LLD : 1.645 (95.0%) MDA : 1.645 (95.0%)

Analysis library : SPF\$LIBRARY:SPFANL.LIB;1
 Background subtract : enabled

Sample description : INFO CENTER Analyzed by: 5
Sample #1

Sample size : 1.000000E+00 EA Conv. factor : 1.000
 Standard size : 1.000000E+00 EA

Sample taken on : 17-NOV-97 at 17:00:00
 Collect started on : 17-NOV-97 at 17:15:00
 Decay time : 15.0 minutes

live time : 2000.0 seconds real time : 2003.0 seconds
 dead time : 0.15 %

Energy calibration used done on 11 / 17 / 1997
 Efficiency calibration used done on 11 / 15 / 1996

Sample description : INFO CENTER
 Analyzed by : S

number	nuclide	conf.value	Activity (uCi/EA)	
			measured	decay corrected
1. Fission gases				
1	KR-87	0.5995	2.40E-04 +-6.05E-05	2.75E-04 +-6.94E-05
	total		2.40E-04	2.75E-04
2. Iodines				
	total		0.00E+00	0.00E+00
3. Particulates				
2	Y-92	0.2719	4.56E-03 +-4.75E-04	4.79E-03 +-4.98E-04
3	NB-94	0.1969	1.39E-04 +-3.44E-05	1.39E-04 +-3.44E-05
4	NB-95M	0.9918	5.43E-04 +-8.49E-05	5.44E-04 +-8.51E-05
5	CD-109 ?	0.9072	1.37E-02 +-1.01E-03	1.37E-02 +-1.01E-03
6	EU-155 ?	0.3185	1.45E-03 +-1.07E-04	1.45E-03 +-1.07E-04
7	NP-237 ?	0.6472	3.90E-03 +-2.89E-04	3.90E-03 +-2.89E-04
	total		2.42E-02	2.45E-02

⌋ = nuclides with a common single line, cannot identify which one is present

These peaks were not identified

number	channel	energy	peak intensity (cps)	
1	126.3	63.27	1.8296E+01 +-4.08E+00	NATURAL
2	149.4	74.82	3.6290E+01 +-4.22E+00	PB-214 NATURAL
3	154.1	77.13	6.2878E+01 +-6.24E+00	PB-214
4	161.9	81.05	1.4965E+00 +-8.47E-01	CE-144 I-131 TL-201
5	167.5	83.81	7.0889E+00 +-9.66E-01	
7	179.6	89.88	8.0426E+00 +-8.90E-01	
8	185.0	92.54	2.9942E+01 +-1.65E+00	NATURAL
9	197.2	98.65	3.4301E+00 +-6.20E-01	NP-239
10	226.2	113.11	2.5327E+00 +-5.79E-01	
11	288.2	144.04	5.7946E+00 +-6.89E-01	NATURAL
12	308.3	154.07	2.4342E+00 +-6.21E-01	XE-138
13	346.8	173.32	6.1598E-01 +-5.80E-01	
14	372.3	186.03	4.8069E+01 +-2.31E+00	NATURAL NATURAL
16	484.4	242.02	5.8563E+01 +-2.92E+00	
17	538.8	269.16	6.1421E+00 +-8.53E-01	
18	543.1	271.28	4.2242E+00 +-8.10E-01	
19	591.0	295.25	1.4833E+02 +-5.94E+00	PB-214
20	704.6	351.96	2.8289E+02 +-9.64E+00	PB-214
21	778.9	389.04	4.9962E+00 +-9.89E-01	
23	810.9	405.04	4.0036E+00 +-1.01E+00	I-134
24	1219.8	609.34	3.6251E+02 +-1.41E+01	BI-214
25	1331.8	665.26	1.2947E+01 +-1.55E+00	CE-143
26	1365.6	682.17	2.6076E+00 +-1.02E+00	

28	1538.0	768.31	3.9046E+01	+-2.74E+00	
29	1573.1	785.88	8.3944E+00	+-1.52E+00	BI-212
30	1614.0	806.30	9.2722E+00	+-1.60E+00	
32	2004.3	1001.29	1.0685E+01	+-1.85E+00	NATURAL
33	2242.6	1120.35	1.2773E+02	+-6.17E+00	BI-214
34	2311.9	1154.98	1.4809E+01	+-2.20E+00	
35	2478.6	1238.21	5.1840E+01	+-3.91E+00	BI-214 CO-56
36	2564.3	1281.03	1.3971E+01	+-2.31E+00	
37	2757.9	1377.67	3.3514E+01	+-3.41E+00	BI-214
38	2806.1	1401.72	1.0380E+01	+-2.18E+00	
39	2818.4	1407.86	2.4155E+01	+-2.91E+00	EU-152
40	3021.2	1509.04	2.1820E+01	+-2.96E+00	
41	3462.4	1729.07	2.6093E+01	+-3.13E+00	
42	3532.3	1763.89	1.1457E+02	+-7.14E+00	BI-214
43	3698.1	1846.45	1.7943E+01	+-2.71E+00	

Errors quoted at 1.000 sigma (68.3%)

*** NEW 10CFR20 REPORT ***
Inhalation DAC Values

17-NOV-97 17:47:16

nuclide	activity uCi/EA	Inhalation DAC uCi/ML	fraction of Inhalation DAC
KR-87	2.7510E-04	5.0000E-06	5.5020E+01
Y-92	4.7904E-03	3.0000E-06	1.5968E+03
NB-95M	5.4383E-04	9.0000E-07	6.0426E+02
NB-94	no entry in the library!		-----
		total	2.2561E+03

GAMMA SPECTRUM ANALYSIS

CANLERRA APOGEE V2.4

Canberra Industries, Inc.

18-NOV-97 06:58:28

ANALYSIS PARAMETERS

Spectrum file number : 100.0 Sample no. : 1.0
MCA unit number : 1 ADC unit number : 2.0
Detector number : 2 Geometry number : 2
Search threshold 1 : 2.0 Search threshold 2 : 3.0
Search FROM channel : 50 Search TO channel : 4095
Id energy tolerance : 0.7 Order of background : linear
Smoothing factor : 0 Random sum corr : disabled
GRA parameter : 0 Baseline channels : disabled

Confidence threshold index : 0.100
Confidence levels LLD : 1.645 (95.0%) MDA : 1.645 (95.0%)

Analysis library : SPF\$LIBRARY:SPFANL.LIB;1
Background subtract : enabled

Sample description : INFO CTR S-1 Analyzed by: ELM

Sample size : 1.000000E+00 EA Conv. factor : 1.000
Standard size : 1.000000E+00 EA

Sample taken on : 17-NOV-97 at 17:00:00
Collect started on : 18-NOV-97 at 06:06:12
Decay time : 786.2 minutes

live time : 3000.0 seconds real time : 3011.0 seconds
dead time : 0.37 %

Energy calibration used done on 11 / 16 / 1997
Efficiency calibration used done on 11 / 7 / 1996

*** P E A K F I T R E P O R T *** 18-NOV-97 06:58:28

ak no.	nuclide(s)	centroid channel	energy keV	FWHM keV	net area counts	error %	gammas per second	error %
1		93.51	46.45	1.06	1626.5	4.31	32.5	48.17
2	NATURAL	106.96	53.18	0.94	747.0	8.57	12.2	35.89
3	NATURAL	127.09	63.25	1.07	4949.6	2.00	66.3	21.11
4		135.54	67.48	1.12	594.0	11.18	7.5	20.13
M 5	PB-214 NATURAL	150.06	74.74	1.05	10541.6	1.21	122.5	11.07
M 6	PB-214	154.60	77.01	1.06	18597.8	0.83	212.0	9.62
M 7	AG-108M	159.00	79.22	1.06	1499.2	4.91	16.8	9.69
M 8	BA-133 XE-133	162.68	81.06	1.06	1392.4	5.27	15.4	9.12
M 9		168.24	83.84	1.06	3368.0	2.66	36.6	6.80
M 10	NP-237 EU-155 NATURAL	174.78	87.11	1.06	6053.2	1.72	64.7	5.44
M 11		180.34	89.89	1.07	2469.7	3.15	26.1	5.48
M 12	NATURAL	185.55	92.50	1.07	9569.7	1.20	100.2	4.22
B 12			92.50		12.8	14.10		
M 13		190.36	94.90	1.07	1065.6	5.77	11.1	6.92
M 14		197.35	98.40	1.07	936.3	6.43	9.7	7.42
15		225.86	112.67	1.00	508.1	10.96	5.2	11.74
16	NATURAL	268.23	143.88	1.12	1575.5	4.18	17.4	5.54
17	XE-138	308.86	154.20	1.11	839.3	7.09	9.7	7.97
18	BA-140 NATURAL XE131M	327.15	163.35	1.08	522.5	10.69	6.3	11.55
19	NATURAL NATURAL	372.44	186.01	1.19	12180.3	1.02	162.0	4.02
19			186.01		6.9	22.04		
20	KR-88	392.71	196.15	0.93	176.0	27.37	2.4	27.65
21		411.09	205.35	1.26	497.6	9.83	7.2	10.64
22	I-134	472.40	236.03	1.18	955.3	5.32	15.6	6.77
23		484.36	242.01	1.18	11098.3	1.04	185.4	4.29
M 24		512.53	256.11	1.18	524.2	8.18	9.2	9.13
M 25	XE-138	517.91	258.80	1.18	721.0	6.40	12.8	7.56
M 26		539.01	269.35	1.19	1140.3	4.35	21.1	5.84
M 27		543.04	271.37	1.19	814.7	5.52	15.2	6.74
M 28		549.50	274.61	1.19	376.0	10.76	7.1	11.42
29	PM-149	572.42	286.07	1.21	124.3	29.21	2.4	29.44
30	PB-214	590.65	295.20	1.21	22864.2	0.69	462.2	3.62
? 31	NATURAL	600.28	300.01	1.08	249.1	15.35	5.1	15.75
32		648.00	323.89	1.01	269.5	13.29	6.0	13.68
33		660.06	329.93	1.32	254.4	14.02	5.7	14.38
34	PB-214	704.00	351.91	1.29	37934.3	0.53	914.9	3.13
M 35		773.62	386.75	1.27	245.1	13.98	6.5	14.31
M 36		777.78	388.83	1.27	298.5	12.16	8.0	12.55
M 37	KR-87	804.06	401.98	1.28	394.4	9.52	10.9	10.01
M 38	I-134	810.66	405.29	1.28	235.0	16.11	6.5	16.40
39	XE-137	909.93	454.96	1.18	180.4	16.47	5.7	16.80
40		961.13	480.58	1.40	267.9	11.01	8.9	11.53
41	TE-129	974.38	487.21	1.29	276.8	10.85	9.3	11.38
42		1019.31	509.70	1.31	139.8	18.29	4.9	18.62
43		1067.51	533.82	1.78	167.7	15.06	6.2	15.47
44		1160.17	580.18	1.24	170.0	14.87	6.8	15.28
45	BI-214	1218.43	609.34	1.40	25049.9	0.65	1060.0	3.53
46		1330.76	665.54	1.38	677.0	4.88	31.3	5.89
47	NB-94	1405.93	703.15	1.74	223.5	10.93	10.9	11.37
48		1439.31	719.86	1.48	189.0	12.45	9.4	12.82

49		1467.89	734.16	1.34	40.9	46.87	2.1	46.97
50	ZR-97	1485.14	742.79	1.66	151.6	14.86	7.8	15.16
51		1505.03	752.74	1.53	87.4	23.15	4.6	23.33
52		1536.37	768.42	1.50	2177.9	2.41	116.1	3.74
53	BI-212	1571.36	785.93	1.46	520.9	5.94	28.4	6.56
54		1597.07	798.79	1.41	45.2	43.38	2.5	43.47
55		1612.02	806.27	1.57	530.3	5.80	29.6	6.41
56		1642.10	821.32	1.47	87.4	24.41	5.0	24.55
57		1677.51	839.04	1.50	225.1	11.12	13.1	11.43
58	Y-92	1867.62	934.15	1.56	1079.3	3.70	69.6	4.45
59	EU-152	1927.36	964.04	1.32	128.1	17.02	8.5	17.20
60	NATURAL	2001.56	1001.16	1.63	302.3	8.44	20.8	8.80
61		2103.20	1052.01	1.72	139.9	14.13	10.1	14.36
62		2139.91	1070.37	1.61	75.2	24.19	5.5	24.33
63	BI-214	2239.92	1120.39	1.70	4881.2	1.50	373.5	3.10
64		2309.74	1155.32	1.75	558.0	5.21	43.9	5.91
65		2363.61	1182.26	1.86	94.2	19.21	7.6	19.42
66		2414.96	1207.94	1.70	94.2	19.53	7.7	19.74
67	BI-214	2475.51	1238.22	1.82	1690.0	2.65	142.0	3.95
68		2560.93	1280.94	1.84	417.5	6.16	36.2	6.84
69	BI-214	2754.51	1377.74	1.87	1243.5	3.14	115.3	4.35
70		2769.41	1385.19	2.02	185.3	10.70	17.3	11.11
M 71		2802.08	1401.52	1.84	305.0	7.58	28.7	8.16
M 72	EU-152	2815.23	1408.09	1.84	634.9	4.73	60.0	5.60
73		3017.45	1509.19	1.82	571.9	5.14	57.6	5.92
74		3086.33	1543.62	1.85	98.4	18.69	10.1	18.92
75		3165.47	1583.17	1.94	193.7	9.75	20.4	10.18
76		3197.74	1599.30	1.81	48.9	30.09	5.2	30.24
77		3321.52	1661.16	2.19	234.8	7.86	25.9	8.42
78		3458.37	1729.53	1.94	847.8	3.62	96.9	4.89
79	BI-214	3528.11	1764.37	2.07	3609.2	1.69	420.0	3.88
80		3675.85	1838.17	2.28	63.9	18.00	7.7	18.47
81		3693.98	1847.23	2.00	503.2	4.85	61.1	6.42

M - Peak is a multiplet

? - Poor goodness-of-fit value.

B - Environmental background peak. Will be subtracted from the peak above.

Background subtraction performed using file SPF#DATA:BK0002.MC1
background description: 25K LUB OIL BLK 11/1

Sample description : INFO CTR S-1
 Analyzed by : ELM

number	nuclide	conf.value	Activity (uCi/EA)			
			measured		decay	corrected
1. Fission gases						
1	KR-87	0.3498	7.41E-04	+/-7.42E-05	9.37E-01	+/-9.38E-02
5	XE-131M	0.9257	8.68E-03	+/-1.00E-03	8.97E-03	+/-1.04E-03
6	XE-133	0.9991	1.14E-03	+/-1.04E-04	1.22E-03	+/-1.11E-04
			-----		-----	
	total		1.06E-02		total	9.47E-01
2. Iodines						
			-----		-----	
	total		0.00E+00		total	0.00E+00
3. Particulates						
2	Y-92	0.2620	1.47E-02	+/-6.52E-04	1.91E-01	+/-8.48E-03
3	NB-94	0.1390	2.96E-04	+/-3.36E-05	2.96E-04	+/-3.36E-05
4	NB-95M	0.9741	1.69E-03	+/-1.15E-04	1.88E-03	+/-1.27E-04
7	PM-149	0.9993	2.32E-03	+/-6.84E-04	2.76E-03	+/-8.11E-04
8	EU-155 ?	0.3255	5.15E-03	+/-2.80E-04	5.15E-03	+/-2.80E-04
9	NP-237 ?	0.6537	1.39E-02	+/-7.55E-04	1.39E-02	+/-7.55E-04
			-----		-----	
	total		3.80E-02		total	2.15E-01

? = nuclides with a common single line, cannot identify which one is present

These peaks were not identified

number	channel	energy	peak intensity (cps)		
1	93.5	46.45	3.2450E+01	+/-1.56E+01	
2	107.0	53.18	1.2240E+01	+/-4.39E+00	NATURAL
3	127.1	63.25	6.6258E+01	+/-1.40E+01	NATURAL
4	135.5	67.48	7.4817E+00	+/-1.51E+00	
5	150.1	74.74	1.2254E+02	+/-1.36E+01	PB-214 NATURAL
6	154.6	77.01	2.1195E+02	+/-2.04E+01	PB-214
7	159.0	79.22	1.6797E+01	+/-1.63E+00	AG-108M
9	168.2	83.84	3.6623E+01	+/-2.49E+00	
11	180.3	89.89	2.6102E+01	+/-1.43E+00	
12	185.5	92.50	1.0010E+02	+/-4.23E+00	NATURAL
13	190.4	94.90	1.1086E+01	+/-7.67E-01	
14	197.3	98.40	9.6679E+00	+/-7.17E-01	
15	225.9	112.67	5.2141E+00	+/-6.12E-01	
16	288.2	143.88	1.7446E+01	+/-9.66E-01	NATURAL
17	308.9	154.20	9.6924E+00	+/-7.73E-01	XE-138
19	372.4	186.01	1.6192E+02	+/-6.51E+00	NATURAL NATURAL
20	392.7	196.15	2.4445E+00	+/-6.76E-01	KR-88
	411.1	205.35	7.1798E+00	+/-7.64E-01	
23	484.4	242.01	1.8541E+02	+/-7.95E+00	
24	512.5	256.11	9.2350E+00	+/-8.43E-01	
25	517.9	258.80	1.2829E+01	+/-9.70E-01	XE-138

26	539.0	269.35	2.1081E+01	+ -1.23E+00	
27	543.0	271.37	1.5170E+01	+ -1.02E+00	
28	549.5	274.61	7.0819E+00	+ -8.09E-01	
29	590.7	295.20	4.6222E+02	+ -1.68E+01	PB-214
30	600.3	300.01	5.1177E+00	+ -8.06E-01	NATURAL
31	648.0	323.89	5.9758E+00	+ -8.18E-01	
32	660.1	329.93	5.7483E+00	+ -8.27E-01	
34	704.0	351.91	9.1490E+02	+ -2.86E+01	PB-214
35	773.6	386.75	6.5091E+00	+ -9.32E-01	
36	777.8	388.83	7.9718E+00	+ -1.00E+00	
38	810.7	405.29	6.5500E+00	+ -1.07E+00	I-134
39	909.9	454.96	5.6619E+00	+ -9.51E-01	XE-137
40	961.1	480.58	8.8972E+00	+ -1.03E+00	
41	974.4	487.21	9.3221E+00	+ -1.06E+00	TE-129
42	1019.3	509.70	4.9312E+00	+ -9.18E-01	
43	1067.5	533.82	6.2036E+00	+ -9.60E-01	
44	1160.2	580.18	6.8442E+00	+ -1.05E+00	
45	1218.4	609.34	1.0600E+03	+ -3.74E+01	BI-214
46	1330.8	665.54	3.1304E+01	+ -1.84E+00	
48	1439.3	719.86	9.4481E+00	+ -1.21E+00	
49	1467.9	734.16	2.0833E+00	+ -9.79E-01	
50	1485.1	742.79	7.8175E+00	+ -1.18E+00	ZR-97
51	1505.0	752.74	4.5689E+00	+ -1.07E+00	
52	1536.4	768.42	1.1614E+02	+ -4.35E+00	
53	1571.4	785.93	2.8398E+01	+ -1.86E+00	BI-212
54	1597.1	798.79	2.5044E+00	+ -1.09E+00	
55	1612.0	806.27	2.9643E+01	+ -1.90E+00	
56	1642.1	821.32	4.9728E+00	+ -1.22E+00	
57	1677.5	839.04	1.3081E+01	+ -1.49E+00	
59	1927.4	964.04	8.5090E+00	+ -1.46E+00	EU-152
60	2001.6	1001.16	2.0806E+01	+ -1.83E+00	NATURAL
61	2103.2	1052.01	1.0094E+01	+ -1.45E+00	
62	2139.9	1070.37	5.5163E+00	+ -1.34E+00	
63	2239.9	1120.39	3.7354E+02	+ -1.16E+01	BI-214
64	2309.7	1155.32	4.3943E+01	+ -2.60E+00	
65	2363.6	1182.26	7.5793E+00	+ -1.47E+00	
66	2415.0	1207.94	7.7295E+00	+ -1.53E+00	
67	2475.5	1238.22	1.4195E+02	+ -5.60E+00	BI-214 CO-56
68	2560.9	1280.94	3.6183E+01	+ -2.47E+00	
69	2754.5	1377.74	1.1527E+02	+ -5.01E+00	BI-214
70	2769.4	1385.19	1.7263E+01	+ -1.92E+00	
71	2802.1	1401.52	2.8717E+01	+ -2.34E+00	
72	2815.2	1408.09	6.0048E+01	+ -3.36E+00	EU-152
73	3017.5	1509.19	5.7646E+01	+ -3.41E+00	
74	3086.3	1543.62	1.0122E+01	+ -1.92E+00	
75	3165.5	1583.17	2.0402E+01	+ -2.08E+00	
76	3197.7	1599.30	5.2007E+00	+ -1.57E+00	
77	3321.5	1661.16	2.5852E+01	+ -2.18E+00	
78	3458.4	1729.53	9.6868E+01	+ -4.74E+00	
79	3528.1	1764.37	4.2003E+02	+ -1.63E+01	BI-214
80	3675.9	1838.17	7.7229E+00	+ -1.43E+00	
81	3694.0	1847.23	6.1102E+01	+ -3.92E+00	

Errors quoted at 1.000 sigma (68.3%)

*** M D A C A L C U L A T I O N R E P O R T ***

18-NOV-97 06:58:28

Sample description : INFO CTR S-1
 Analyzed by : ELM

	----- MDA (uCi/EA) -----	
	measured	decay corrected
NA-24	MDA : 2.96E-04	5.42E-04
AR-41	MDA : 2.77E-04	3.99E-02
CR-51	MDA : 1.49E-03	1.51E-03
MN-54	MDA : 2.60E-04	2.60E-04
MN-56	MDA : 2.42E-04	8.19E-03
CO-57	MDA : 1.24E-04	1.24E-04
CO-58	MDA : 2.83E-04	2.84E-04
FE-59	MDA : 4.93E-04	4.97E-04
CO-60	MDA : 2.84E-04	2.84E-04
CU-64	MDA : 6.07E-02	1.24E-01
NI-65	MDA : 1.38E-03	5.06E-02
ZN-65	MDA : 9.86E-04	9.88E-04
SE-75	MDA : 1.87E-04	1.87E-04
BR-84	MDA : 6.32E-04	1.75E+04
KR-85	MDA : 4.25E-02	4.25E-02
SR-85	MDA : 1.86E-04	1.87E-04
KR-85M	MDA : 1.63E-04	1.23E-03
Y-89	MDA : 5.18E-04	1.27E-02
Y-89	MDA : 2.53E-04	2.54E-04
RB-88	MDA : 2.67E-03	5.29E+10
RB-89	MDA : 1.14E-03	2.42E+12
KR-89	MDA : 6.87E-03	> 1.00E+20
Y-91M	MDA : 1.86E-04	1.07E+01
SR-91	MDA : 7.99E-04	2.08E-03
SR-92	MDA : 5.86E-04	1.67E-02
Y-93	MDA : 2.03E-03	4.98E-03
Y-94	MDA : 1.04E-03	4.69E+09
Y-95	MDA : 4.99E-03	> 1.00E+20
NB-95	MDA : 3.87E-04	3.91E-04
ZR-95	MDA : 3.96E-04	3.99E-04
ZR-97	MDA : 3.37E-03	5.76E-03
NB-97	MDA : 1.98E-04	3.80E-01
MO-99	MDA : 1.76E-03	2.02E-03
TC-99M	MDA : 1.47E-04	1.68E-04
MO-101	MDA : 1.80E-03	2.85E+13
TC-101	MDA : 4.56E-04	2.12E+13
TC-102M	MDA : 1.58E-03	> 1.00E+20
RU-103	MDA : 1.89E-04	1.90E-04
TC-104	MDA : 4.16E-04	4.95E+09
RH-105	MDA : 7.62E-04	9.85E-04
RU-105	MDA : 4.57E-04	3.53E-03
RH-106	MDA : 1.93E-03	1.93E-03
F-106	MDA : 1.93E-03	1.93E-03
OSM	MDA : 1.90E-04	1.90E-04
OSM	MDA : 5.31E-03	5.32E-03
AG-110M	MDA : 2.06E-04	2.06E-04
SN-113	MDA : 2.91E-04	2.92E-04

SB-122	:	MDA	:	2.57E-04	2.96E-04
SB-124	:	MDA	:	2.12E-04	2.13E-04
SB-125	:	MDA	:	6.63E-04	6.63E-04
TF 131M	:	MDA	:	9.24E-04	1.25E-03
f 131	:	MDA	:	1.16E-03	2.18E+07
i 1	:	MDA	:	1.96E-04	2.06E-04
TE-131	:	MDA	:	3.25E-04	9.52E+05
I-132	:	MDA	:	2.48E-04	1.32E-02
TE-132	:	MDA	:	1.44E-04	1.61E-04
BA-133	:	MDA	:	6.73E-04	6.73E-04
TE-133	:	MDA	:	6.27E-04	6.41E+15
I-133	:	MDA	:	2.01E-04	3.10E-04
XE-133M	:	MDA	:	1.26E-03	1.49E-03
TE-133M	:	MDA	:	3.06E-04	5.72E+00
TE-134	:	MDA	:	5.78E-04	2.66E+02
I-134	:	MDA	:	2.51E-04	7.92E+00
CS-134	:	MDA	:	2.68E-04	2.69E-04
I-135	:	MDA	:	1.04E-03	4.13E-03
XE-135M	:	MDA	:	5.38E-04	1.38E+12
XE-135	:	MDA	:	1.39E-04	3.78E-04
CS-136	:	MDA	:	2.41E-04	2.48E-04
CS-137	:	MDA	:	2.54E-04	2.54E-04
CS-138	:	MDA	:	3.89E-04	8.71E+03
XE-138	:	MDA	:	1.28E-03	7.18E+13
CS-139	:	MDA	:	1.89E-02	> 1.00E+20
BA-139	:	MDA	:	7.41E-04	5.22E-01
CS-138M	:	MDA	:	7.94E-03	> 1.00E+20
CE-139	:	MDA	:	1.58E-04	1.58E-04
BA-140	:	MDA	:	7.51E-04	7.73E-04
L ^ 140	:	MDA	:	3.27E-04	3.37E-04
i 41	:	MDA	:	6.82E-04	6.14E+09
LA 41	:	MDA	:	1.13E-02	1.13E-01
CE-141	:	MDA	:	2.69E-04	2.72E-04
BA-142	:	MDA	:	2.57E-03	> 1.00E+20
LA-142	:	MDA	:	3.57E-04	1.08E-01
CE-143	:	MDA	:	9.61E-04	1.27E-03
PR-144	:	MDA	:	1.49E-02	1.49E-02
CE-144	:	MDA	:	1.01E-03	1.01E-03
PR-146	:	MDA	:	7.06E-04	5.13E+06
CE-146	:	MDA	:	7.69E-04	8.17E+13
ND-147	:	MDA	:	7.65E-04	7.92E-04
PR-147	:	MDA	:	1.87E-03	4.73E+14
EU-152	:	MDA	:	3.71E-04	3.71E-04
HF-181	:	MDA	:	2.13E-04	2.15E-04
W-187	:	MDA	:	7.60E-04	1.11E-03
HG-203	:	MDA	:	1.63E-04	1.64E-04
NP-237	:	MDA	:	1.53E-03	1.53E-03
U-237	:	MDA	:	4.53E-04	4.79E-04
NP-239	:	MDA	:	4.72E-04	5.54E-04
AM-241	:	MDA	:	5.07E-04	5.07E-04
EU-154	:	MDA	:	2.63E-04	2.63E-04
EU-155	:	MDA	:	5.22E-04	5.22E-04

 * GAMMA SPECTRUM ANALYSIS *
 *

INBERRA APOGEE V2.4

Canberra Industries, Inc.

19-NOV-97 02:35:23

A N A L Y S I S P A R A M E T E R S

Spectrum file number	: 100.0	Sample no.	: 1.0
MCA unit number	: 2	ADC unit number	: 3.0
Detector number	: 3	Geometry number	: 2
Search threshold 1	: 2.0	Search threshold 2	: 3.0
Search FROM channel	: 50	Search TO channel	: 4095
Id energy tolerance	: 1.0	Order of background	: linear
Smoothing factor	: 0	Random sum corr	: disabled
GRA parameter	: 0	Baseline channels	: disabled

Confidence threshold index : 0.100
 Confidence levels LLD : 1.645 (95.0%) MDA : 1.645 (95.0%)

Analysis library : SPF#LIBRARY:SPFANL.LIB;1
 Background subtract : enabled

Sample description : CARPET 2 Analyzed by: ELM

Sample size : 1.000000E+00 EA Conv. factor : 1.000
 Standard size : 1.000000E+00 EA

Sample taken on : 18-NOV-97 at 07:05:00
 Collect started on : 19-NOV-97 at 01:43:58
 Decay time : 1119.0 minutes

live time : 3000.0 seconds real time : 3001.0 seconds
 dead time : 0.03 %

Energy calibration used done on 11 / 18 / 1997
 Efficiency calibration used done on 11 / 15 / 1996

*** P E A K F I T R E P O R T *** 19-NOV-97 02:35:20

peak no.	nuclide(s)	centroid channel	energy keV	FWHM keV	net area counts	error %	gammas per second	err %
	1 NATURAL	126.44	63.34	1.08	328.3	8.66	8.0	22.0
M 2	PB-214 NATURAL	149.39	74.79	1.09	621.7	5.59	12.0	12.0
M 3	PB-214	154.11	77.14	1.09	1177.7	3.77	21.9	10.0
M 4	BA-133 XE-133	162.24	81.20	1.10	81.2	30.84	1.4	31.0
M 5		167.57	83.86	1.10	220.2	12.41	3.8	13.0
M 6	NP-237 EU-155 NATURAL CD-109	174.20	87.17	1.10	420.4	7.19	6.9	8.0
M 7		179.60	89.86	1.10	173.3	14.79	2.8	15.0
M 8	NATURAL	185.06	92.58	1.11	927.1	4.25	14.6	5.0
B 8			92.58		16.7	12.49		
	9 NATURAL	288.29	144.10	1.19	192.5	12.01	2.8	12.0
10	NATURAL NATURAL	372.13	185.95	1.28	1276.9	3.23	22.6	5.0
B 10			185.95		10.8	16.28		
11	I-134	472.45	236.03	1.40	99.9	17.65	2.2	18.0
12		484.50	242.04	1.23	1037.1	3.48	23.7	5.0
13		539.52	269.51	1.76	119.0	14.53	3.0	15.0
M 14	PB-214	591.00	295.21	1.28	2093.0	2.31	59.1	4.0
M 15	NATURAL	600.11	299.76	1.28	33.7	40.44	1.0	40.0
16	PB-214	704.52	351.90	1.31	3347.8	1.81	114.8	3.0
17	BI-214	1219.77	609.29	1.51	2270.2	2.16	144.0	4.0
18	CE-143 SB-126	1332.35	665.54	1.59	41.2	24.62	2.9	24.0
19		1537.50	768.19	1.75	199.6	8.04	16.3	8.0
20	Y-92	1869.73	934.04	1.88	98.0	12.94	9.8	13.0
21	BI-214	2242.44	1120.23	1.89	429.7	5.18	52.0	5.0
22		2312.52	1155.23	1.84	28.3	30.12	3.5	30.0
23		2329.81	1163.86	2.17	19.2	36.89	2.4	37.0
24	BI-214 CO-56	2478.06	1237.89	1.91	130.1	10.27	17.4	10.0
25		2564.67	1281.13	1.86	34.2	22.53	4.7	22.0
26	BI-214	2757.83	1377.55	2.18	80.0	13.67	11.9	14.0
27		3021.80	1509.24	2.42	56.4	16.41	9.2	16.0
28		3462.14	1728.74	2.67	56.6	15.04	10.5	15.0
29	BI-214	3532.42	1763.75	2.31	281.8	6.20	53.5	7.0

M - Peak is a multiplet

B - Environmental background peak. Will be subtracted from the peak above.

Background subtraction performed using file SPF#DATA:BK0003.MC2
background description: 25K SEC BKG 4/20/97

sample description : CARPET 2
analyzed by : ELM

number	nuclide	conf.value	measured	Activity (uCi/EA)	decay corrected
1. Fission gases					
4	XE-133	0.9932	1.05E-04	+-3.34E-05	1.17E-04 +-3.70E-05
	total		1.05E-04	total	1.17E-04
2. Iodines					
	total		0.00E+00	total	0.00E+00
3. Particulates					
1	Y-92	0.2380	2.07E-03	+-2.73E-04	7.98E-02 +-1.05E-02
2	NB-95M	0.9818	2.41E-04	+-4.38E-05	2.80E-04 +-5.09E-05
3	CD-109 ?	0.8869	5.19E-03	+-4.59E-04	5.20E-03 +-4.60E-04
5	EU-155 ?	0.3356	5.50E-04	+-4.86E-05	5.50E-04 +-4.86E-05
6	NP-237 ?	0.6646	1.48E-03	+-1.31E-04	1.48E-03 +-1.31E-04
	total		9.54E-03	total	8.74E-02

= nuclides with a common single line, cannot identify which one is present

These peaks were not identified

number	channel	energy	peak intensity (cps)	
1	126.4	63.34	8.0406E+00 +-1.82E+00	NATURAL
2	149.4	74.79	1.1991E+01 +-1.48E+00	PB-214 NATURAL
3	154.1	77.14	2.1893E+01 +-2.24E+00	PB-214
5	167.6	83.86	3.7513E+00 +-5.22E-01	
7	179.6	89.86	2.7826E+00 +-4.30E-01	
8	185.1	92.58	1.4300E+01 +-8.48E-01	NATURAL
9	288.3	144.10	2.8392E+00 +-3.56E-01	NATURAL
10	372.1	185.95	2.2387E+01 +-1.14E+00	NATURAL NATURAL
12	484.5	242.04	2.3713E+01 +-1.29E+00	
13	539.5	269.51	3.0460E+00 +-4.58E-01	
14	591.0	295.21	5.9107E+01 +-2.52E+00	PB-214
15	600.1	299.76	9.6885E-01 +-3.93E-01	NATURAL
16	704.5	351.90	1.1478E+02 +-4.12E+00	PB-214
17	1219.8	609.29	1.4397E+02 +-5.93E+00	BI-214
18	1332.3	665.54	2.8798E+00 +-7.16E-01	CE-143 SB-126
19	1537.8	768.19	1.6290E+01 +-1.39E+00	
21	2242.4	1120.23	5.1994E+01 +-3.04E+00	BI-214
22	2312.5	1155.23	3.5264E+00 +-1.07E+00	
23	2329.8	1163.86	2.4162E+00 +-8.94E-01	
24	2478.1	1237.89	1.7410E+01 +-1.86E+00	BI-214 CO-56
25	2564.7	1281.13	4.7343E+00 +-1.08E+00	
26	2757.8	1377.55	1.1913E+01 +-1.67E+00	BI-214
27	3021.8	1509.24	9.1898E+00 +-1.53E+00	
28	3462.1	1728.74	1.0532E+01 +-1.62E+00	

29 3532.4 1763.75 5.3470E+01 +-3.81E+00 BI-214

Errors quoted at 1.000 sigma (68.3%)

Sample description : CARPET 2
 Analyzed by : ELM

----- MDA (uCi/EA) -----
 measured decay corrected

NA-24	:	MDA :	1.78E-04	4.22E-04
AR-41	:	MDA :	1.64E-04	1.94E-01
CR-51	:	MDA :	7.67E-04	7.82E-04
MN-54	:	MDA :	1.48E-04	1.48E-04
MN-56	:	MDA :	1.52E-04	2.29E-02
CO-57	:	MDA :	6.08E-05	6.09E-05
CO-58	:	MDA :	1.57E-04	1.58E-04
FE-59	:	MDA :	2.86E-04	2.90E-04
CO-60	:	MDA :	1.75E-04	1.75E-04
CU-64	:	MDA :	3.51E-02	9.72E-02
NI-65	:	MDA :	8.34E-04	1.41E-01
ZN-65	:	MDA :	4.77E-04	4.78E-04
SE-75	:	MDA :	9.00E-05	9.04E-05
BR-84	:	MDA :	3.62E-04	1.42E+07
KR-85	:	MDA :	2.43E-02	2.43E-02
SR-85	:	MDA :	1.06E-04	1.07E-04
KR-85M	:	MDA :	7.45E-05	1.33E-03
-87	:	MDA :	2.11E-04	5.48E+00
-88	:	MDA :	2.37E-04	2.25E-02
Y-88	:	MDA :	1.32E-04	1.32E-04
RB-88	:	MDA :	1.39E-03	1.17E+16
RB-89	:	MDA :	7.15E-04	> 1.00E+20
KR-89	:	MDA :	3.45E-03	> 1.00E+20
Y-91M	:	MDA :	1.06E-04	6.34E+02
SR-91	:	MDA :	4.77E-04	1.86E-03
SR-92	:	MDA :	2.89E-04	3.41E-02
Y-93	:	MDA :	1.09E-03	3.90E-03
Y-94	:	MDA :	5.96E-04	6.14E+14
Y-95	:	MDA :	2.62E-03	> 1.00E+20
NB-95	:	MDA :	1.94E-04	1.97E-04
ZR-95	:	MDA :	2.12E-04	2.13E-04
ZR-97	:	MDA :	1.99E-03	4.28E-03
NB-97	:	MDA :	1.10E-04	5.18E+00
MO-99	:	MDA :	9.51E-04	1.16E-03
TC-99M	:	MDA :	6.88E-05	8.36E-05
MO-101	:	MDA :	8.25E-04	> 1.00E+20
TC-101	:	MDA :	2.15E-04	> 1.00E+20
TC-102M	:	MDA :	9.11E-04	> 1.00E+20
RU-103	:	MDA :	1.03E-04	1.04E-04
TC-104	:	MDA :	2.47E-04	1.01E+15
RH-105	:	MDA :	4.05E-04	5.83E-04
RU-105	:	MDA :	2.59E-04	4.75E-03
H-106	:	MDA :	1.02E-03	1.02E-03
-106	:	MDA :	1.02E-03	1.02E-03
AG-108M	:	MDA :	1.05E-04	1.05E-04
CD-109	:	MDA :	2.65E-03	2.65E-03
AG-110M	:	MDA :	1.14E-04	1.15E-04

SN-113	:	MDA	:	1.52E-04	1.52E-04
SB-122	:	MDA	:	1.52E-04	1.56E-04
SB-124	:	MDA	:	1.14E-04	1.15E-04
SB-125	:	MDA	:	3.58E-04	3.58E-04
-131M	:	MDA	:	4.98E-04	7.66E-04
-131M	:	MDA	:	2.95E-03	3.09E-03
J-131	:	MDA	:	6.70E-04	2.83E+11
I-131	:	MDA	:	1.04E-04	1.12E-04
TE-131	:	MDA	:	1.48E-04	4.41E+09
I-132	:	MDA	:	1.28E-04	3.69E-02
TE-132	:	MDA	:	7.37E-05	8.69E-05
BA-133	:	MDA	:	3.35E-04	3.35E-04
TE-133	:	MDA	:	3.02E-04	> 1.00E+20
I-133	:	MDA	:	1.08E-04	2.01E-04
XE-133M	:	MDA	:	6.91E-04	8.83E-04
TE-133M	:	MDA	:	1.85E-04	2.23E+02
TE-134	:	MDA	:	2.89E-04	3.30E+04
I-134	:	MDA	:	1.57E-04	3.97E+02
CS-134	:	MDA	:	1.67E-04	1.67E-04
I-135	:	MDA	:	5.57E-04	3.94E-03
XE-135M	:	MDA	:	2.98E-04	> 1.00E+20
XE-135	:	MDA	:	7.57E-05	3.13E-04
CS-136	:	MDA	:	1.45E-04	1.51E-04
CS-137	:	MDA	:	1.40E-04	1.40E-04
CS-138	:	MDA	:	2.39E-04	6.91E+06
XE-138	:	MDA	:	6.28E-04	> 1.00E+20
CS-139	:	MDA	:	1.03E-02	> 1.00E+20
BA-139	:	MDA	:	3.36E-04	3.80E+00
CS-138M	:	MDA	:	3.63E-03	> 1.00E+20
CE-139	:	MDA	:	7.14E-05	7.17E-05
-140	:	MDA	:	3.98E-04	4.15E-04
-140	:	MDA	:	1.70E-04	1.78E-04
BA-141	:	MDA	:	3.68E-04	1.01E+15
LA-141	:	MDA	:	6.33E-03	1.68E-01
CE-141	:	MDA	:	1.25E-04	1.27E-04
BA-142	:	MDA	:	1.32E-03	> 1.00E+20
LA-142	:	MDA	:	1.88E-04	6.37E-01
CE-143	:	MDA	:	4.19E-04	6.21E-04
PR-144	:	MDA	:	8.81E-03	8.83E-03
CE-144	:	MDA	:	4.91E-04	4.92E-04
PR-146	:	MDA	:	3.89E-04	4.21E+10
CE-146	:	MDA	:	4.01E-04	> 1.00E+20
ND-147	:	MDA	:	3.72E-04	3.91E-04
PR-147	:	MDA	:	9.40E-04	> 1.00E+20
PM-149	:	MDA	:	2.54E-03	3.24E-03
EU-152	:	MDA	:	1.82E-04	1.82E-04
HF-181	:	MDA	:	1.16E-04	1.17E-04
W-187	:	MDA	:	3.93E-04	6.77E-04
HG-203	:	MDA	:	8.99E-05	9.09E-05
NP-237	:	MDA	:	7.57E-04	7.57E-04
U-237	:	MDA	:	2.29E-04	2.48E-04
NP-239	:	MDA	:	2.33E-04	2.93E-04
AM-241	:	MDA	:	3.35E-04	3.35E-04
EU-154	:	MDA	:	1.30E-04	1.30E-04
EU-155	:	MDA	:	2.60E-04	2.60E-04
B-94	:	MDA	:	1.22E-04	1.22E-04

 * GAMMA SPECTRUM ANALYSIS *
 *

INBERRA APOGEE V2.4

Canberra Industries, Inc.

19-NOV-97 02:35:40

A N A L Y S I S P A R A M E T E R S

Spectrum file number	: 100.0	Sample no.	: 1.0
MCA unit number	: 2	ADC unit number	: 4.0
Detector number	: 4	Geometry number	: 2
Search threshold 1	: 2.0	Search threshold 2	: 3.0
Search FROM channel	: 50	Search TO channel	: 4095
Id energy tolerance	: 0.8	Order of background	: linear
Smoothing factor	: 0	Random sum corr	: disabled
GRA parameter	: 0	Baseline channels	: disabled

Confidence threshold index : 0.100
 Confidence levels LLD : 1.645 (95.0%) MDA : 1.645 (95.0%)

Analysis library : SPF\$LIBRARY:SPFANL.LIB;1
 Background subtract : enabled

Sample description : CARPET 1 Analyzed by: ELM

Sample size : 1.000000E+00 EA Conv. factor : 1.000
 Standard size : 1.000000E+00 EA

Sample taken on : 18-NOV-97 at 07:00:00
 Collect started on : 19-NOV-97 at 01:43:11
 Decay time : 1123.2 minutes

live time : 3000.0 seconds real time : 3003.0 seconds
 dead time : 0.10 %

Energy calibration used done on 11 / 18 / 1997
 Efficiency calibration used done on 11 / 8 / 1996