October 19, 2001

Mr. David A. Christian Sr. Vice President - Nuclear Virginia Electric and Power Company Innsbrook Technical Center Glen Allen, Virginia 23060

SUBJECT: SURRY POWER STATION UNITS 1 AND 2 - BASES CHANGES FOR AUXILIARY VENTILATION REQUIREMENTS (TAC NOS. MB0899 AND MB0900)

Dear Mr. Christian:

By letter dated December 21, 2000, you submitted for our information your proposed Technical Specifications (TS) Bases change for TS 3.22, "Auxiliary Ventilation Exhaust Filter Trains." This change was made to clarify the auxiliary filtration requirements. The specific changes made in the Bases: 1) reflect that auxiliary filtration is required during refueling operations, or while handling fuel assemblies or heavy loads with recently irradiated fuel in the spent fuel pool; and 2) define recently irradiated fuel as fuel that has decayed less than 30 days since reactor shutdown.

Title 10 of the *Code of Federal Regulations* Part 50 (10 CFR 50), Section 59, permits licensees to make changes in the facility as described in the safety analysis report, without prior Commission approval, unless the proposed change involves a change in the TS incorporated in the license or an unreviewed safety question. Your letter stated that it has been determined that these proposed changes do not involve an unreviewed safety question, as defined in 10 CFR 50.59. Accordingly, the regulations authorize you to make the proposed TS Bases change without our review. Your changes to the Bases may be subject to our future inspections or audits.

This completes our effort under TAC Nos. MB0899 and MB0900 and the TACs are closed.

If you have any questions, please call me at (301) 415-1448.

Sincerely,

/RA/

Gordon E. Edison, Senior Project Manager, Section 1 Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket Nos. 50-280 and 50-281

cc: See next page

Mr. David A. Christian

Sr. Vice President - Nuclear Virginia Electric and Power Company Innsbrook Technical Center Glen Allen, Virginia 23060

SUBJECT: SURRY POWER STATION UNITS 1 AND 2 - BASES CHANGES FOR AUXILIARY VENTILATION REQUIREMENTS (TAC NOS. MB0899 AND MB0900)

Dear Mr. Christian:

By letter dated December 21, 2000, you submitted for our information your proposed Technical Specifications (TS) Bases change for TS 3.22, "Auxiliary Ventilation Exhaust Filter Trains." This change was made to clarify the auxiliary filtration requirements. The specific changes made in the Bases: 1) reflect that auxiliary filtration is required during refueling operations, or while handling fuel assemblies or heavy loads with recently irradiated fuel in the spent fuel pool; and 2) define recently irradiated fuel as fuel that has decayed less than 30 days since reactor shutdown.

Title 10 of the *Code of Federal Regulations* Part 50 (10 CFR 50), Section 59, permits licensees to make changes in the facility as described in the safety analysis report, without prior Commission approval, unless the proposed change involves a change in the TS incorporated in the license or an unreviewed safety question. Your letter stated that it has been determined that these proposed changes do not involve an unreviewed safety question, as defined in 10 CFR 50.59. Accordingly, the regulations authorize you to make the proposed TS Bases change without our review. Your changes to the Bases may be subject to our future inspections or audits.

This completes our effort under TAC Nos. MB0899 and MB0900 and the TACs are closed.

If you have any questions, please call me at (301) 415-1448.

Sincerely, /**RA**/ Gordon E. Edison, Senior Project Manager, Section 1 Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket Nos. 50-280 and 50-281

cc: See next page

DATE	10/17/01	10/17/01	10/19/01
NAME	GEdison	EDunnington	RLaufer
OFFICE	PM:PDII-1	LA:PDII-2	ASC:PDII-1
DISTRIBUTION: PUBLIC PDII-1 RF HBerkow Accession Number:	WBeckner RCorreia GEdison ML012830292	EDunnington K. Landis, RII GHill (4)	OGC ACRS

OFFICIAL RECORD COPY

Mr. David A. Christian Virginia Electric and Power Company

CC:

Mr. Donald P. Irwin, Esq. Hunton and Williams Riverfront Plaza, East Tower 951 E. Byrd Street Richmond, Virginia 23219

Mr. Richard H. Blount, II Site Vice President Surry Power Station Virginia Electric and Power Company 5570 Hog Island Road Surry, Virginia 23883-0315

Senior Resident Inspector Surry Power Station U. S. Nuclear Regulatory Commission 5850 Hog Island Road Surry, Virginia 23883

Chairman Board of Supervisors of Surry County Surry County Courthouse Surry, Virginia 23683

Dr. W. T. Lough Virginia State Corporation Commission Division of Energy Regulation P. O. Box 1197 Richmond, Virginia 23209

Robert B. Strobe, M.D., M.P.H. State Health Commissioner Office of the Commissioner Virginia Department of Health P.O. Box 2448 Richmond, Virginia 23218 Surry Power Station

Office of the Attorney General Commonwealth of Virginia 900 East Main Street Richmond, Virginia 23219

Mr. Stephen P. Sarver, Director Nuclear Licensing & Operations Support Innsbrook Technical Center Virginia Electric and Power Company 5000 Dominion Blvd. Glen Allen, Virginia 23060-6711

Mr. David A. Heacock Site Vice President North Anna Power Station Virginia Electric and Power Company P. O. Box 402 Mineral, Virginia 23117-0402

Mr. William R. Matthews Vice President - Nuclear Operations Virginia Electric and Power Company Innsbrook Technical Center 5000 Dominion Boulevard Glen Allen, Virginia 23060-6711