PEACH BOTTOM/LIMERICK SIREN MAINTENANCE AT

Presentation to NRC Region I October 1, 2001

TOPICS

- Apparent Violations
 - G. Vanderheyden: Vice President, Operations Support
- **◆** Timeline
 - D. Tailleart: Emergency Preparedness Manager
- ◆ Investigation Approach/Causes/CorrectiveActions/ Effectiveness
 - G. Vanderheyden: Vice President, Operations Support
- ◆ Siren Criteria/Siren Performance/Significance Determination
 - M. Gallagher: Director, Licensing & Reg. Affairs
- ◆ Closing
 - J. Hagan: Senior Vice President, MAROG

APPARENT VIOLATIONS

- ◆ Failure to meet the emergency preparedness function to notify the public of needed action, in case of an emergency, through ANS as required by 10 CFR 50.47(b)(5).
- ◆ Failure to adequately maintain and test the sirens as required by 10 CFR 50.47(b)(8).
- ◆ Failure to maintain complete and accurate maintenance and testing records as required by 10 CFR 50.9.

TIMELINE

♦ 9/15/00	PECO Energy Security Notifies NQA of Information Received From Employee Regarding Operability of Some Sirens Around LGS and PBAPS.
◆ 9/15/00	Sampling Plan Developed to Determine Extent of Problem.
◆ 9/16/00	Small Sample of Sirens Tested for Operability (Visual Test).
◆ 9/18/00	Investigation Reveals Use of Jumpers of the Detection Circuits in Some Individual Sirens.
◆ 9/21/00	Operability Testing of Remaining Sirens Initiated. Repairs Made To Sirens As Needed.
◆ 9/21/00	State and Local Agencies Notified About PBAPS Sirens.
9/22/00	State and Local Agencies Notified About LGS Sirens.
9/23/00	Testing Completed.
◆ 9/25/00	Root Cause Evaluation Team Formed.
◆ 9/28/00	Increased Testing Frequency Initiated.

INVESTIGATION APPROACH

◆ Investigation Team

◆ Full Root Cause Analysis

CAUSES/CORRECTIVE ACTIONS

- ◆ Lack of Technician Oversight by Contractor and Utility Personnel.
 - Developed Training Program and Procedure for Contract Owners.
- Failure to Enforce Contractual Requirements.
 - Strengthened Licensee Procedures to Invoke Contractual Penalties.
 - Strengthened Contract Terms by Inclusion of More Significant Penalties.
- Over Reliance on the Failure Detection System.
 - Developed Guidelines for Monitoring Contracts Concerning Work Performed Independent of Direct Utility Supervision.
- ◆ Lack of Adequate Oversight/Self-Assessment.
 - Developed a Siren Program Manual that Includes Self-Assessment Criteria and Activities.
 - Corrected PI Data Submitted to the NRC.

EFFECTIVENESS

- ◆ Closer Scrutiny of Siren Maintenance
- ◆ Improving Performance Indicator Data
 - Limerick @ 98.3%
 - Peach Bottom @ 98.0%
- ◆ Improved Site Ownership of EP Program and Equipment, Including Siren Systems
- ◆ Random In-field Verifications Initiated to Confirm Maintenance Activities and Siren Operability

SIREN CRITERIA

◆ Siren Design Criteria

◆ Performance Criteria

◆ Population Coverage Analysis

SIREN CRITERIA

DESIGN

- Radiological Emergency Plans
- ◆ NUREG-0654/ FEMA-REP-1 Rev. 1
 - Alert Signal throughout the EPZ within 15 minutes
 - Essentially 100% Population Coverage within 5 miles
 - Special Arrangements for 100% Coverage within 45 minutes
- ◆ Emergency Planning Final Rule Supplementary Information (45 Federal Register 55402 (1980))
 - Not every individual would be reached by Alert Notification System (ANS).

SIREN CRITERIA

PERFORMANCE

◆ FEMA-REP-10

- Siren reliability remains at or above 90% averaged over a 12 month period.
- Commitment in our Emergency Plan is to meet NUREG-0654/FEMA-REP-1 and FEMA-REP-10.

◆ NRC Alert and Notification System Reliability PI

- Percentage of ANS sirens that are capable of performing their function, as measured by periodic siren testing in the previous 12 months.
 - » > 94% ANS reliability GREEN
 - » 90% < ANS reliability < 94% WHITE
 - » < 90 % ANS reliability YELLOW

◆ Emergency Planning Routine Test Procedures

 The requirements of the above documents have been incorporated into our Routine Testing procedures for the sirens.

◆ 2000 and 2001 PI Results


- Corrections were made to previously submitted PI data based on the discovery of the event and resulted in the indicator changing from GREEN to WHITE for Peach Bottom.
- NRC Performance Indicators (rolling 4 quarter average)
 - LGS: lowest value reported is 94.9%
 - PBAPS: lowest value reported is 92.3%
- FEMA Performance Value (calendar year)

LGS: 97.49% (2000)

Lowest 12 month rolling value: 94.5%

PBAPS: 96.83% (2000)

Lowest 12 month rolling value: 91.2%



LGS SIREN POPULATION COVERAGE ANALYSIS (9/21/00)

Siren No.	Failed Condition	Detection Operable (Yes or No) (If Yes, then Route Alerting Credited)	Population Affected	Location
6	Siren Sounds w/o Rotation	Yes Yes		(in Miles
7	Siren Sounds w/o Rotation	Yes	0	5-10
10	Siren would not Sound	Yes	0	0-5
11	Siren would not Sound	Yes	0	5-10
13	Siren Sounds w/o Rotation	No	0	5-10
16	Siren Sounds w/o Rotation		229	5-10
21	Siren would not Sound	Yes	0	0-5,5-10
46	Siren Sounds at Reduced Volume	Yes	0	0-5
54	Siren Sounds at Reduced Volume	Yes	00	0-5
61	Siren Sounds w/o Rotation	Yes	0	0-5
65	No Status Feedback	Yes	0	0-5
69	Siren Sounds at Reduced Volume	Yes	0	5-10
71	Siren Sounds w/o Rotation	Yes	0	0-5
75		Yes	0	0-5
81	Siren would not Sound	Yes	0	5-10
88	Siren Sounds w/o Rotation	No	0	5-10
100	Siren would not Sound	Yes	0	5-10
129	Siren Sounds w/o Rotation	No	0	5-10
140	Siren would not Sound	Yes	0	5-10
143	Siren Sounds w/o Rotation	No	0	5-10
140	No Status Feedback	Yes	0	5-10

Total Population Affected =

229

Estimated Total LGS EPZ Population =

205247

% Coverage 0-5 miles =

100.00%

Total Coverage of 10 mile EPZ =

99.89%

PBAPS SIREN POPULATION COVERAGE ANALYSIS (9/22/00)

Based on National Average Background

Siren No.	Failed Conditions	Detection Operable (Yes or No) (If Yes, then Route Alerting Credited)	Population Affected	Location (in Miles)
12	Siren Sounds w/o Rotation	No		
13	Siren Sounds w/o Rotation	No	180	5-10
14	Siren would not Sound	No	523	5-10
15	Siren would not Sound			5-10
16	No Status Feedback	No No		5-10
26	Siren Sounds w/o Rotation	Yes	0	5-10
33	Siren Sounds w/o Rotation	No	222	5-10
36	Siren Sounds w/o Rotation	No	41	0-5
43	Siren Sounds w/o Rotation	No	128	5-10
44	No Status Feedback	Yes	0	5-10
51		Yes	0	5-10
66	Siren would not Sound	Yes	0	0-5
	Siren would not Sound	No	622	5-10
75	Siren would not Sound	No	12	
76	Siren would not Sound	No		0-5
85	No Status Feedback	Yes	68	0-5
86	Siren Sounds w/o Rotation	Yes	0	5-10
88	Siren would not Sound		0	5-10
90	Siren would not Sound	Yes	0	5-10
	The state that double	Yes Total Population Affected =	0	5-10

Total Population Affected = 1795 Estimated Total EPZ Population = 44516

% Coverage 0-5 miles = 98.17% Total Coverage of 10 mile EPZ = 95.97%

PBAPS SIREN POPULATION COVERAGE ANALYSIS (9/22/00)

Based on Measured Background

Siren No.	Failed Condition	Detection Operable (Yes or No) (If Yes, then Route Alerting Credited)	Population Affected	Location
12	Siren Sounds w/o Rotation	No	 	(in Miles
13	Siren Sounds w/o Rotation	No	85	5-10
14	Siren would not Sound	No	380	5-10
15	Siren would not Sound	No		5-10
16	No Status Feedback	Yes		5-10
26	Siren Sounds w/o Rotation		0	5-10
33	Siren Sounds w/o Rotation	No	74	5-10
36	Siren Sounds w/o Rotation	No	30	0-5
43	Siren Sounds w/o Rotation	No	65	5-10
44	No Status Feedback	Yes	0	5-10
51	Siren would not Sound	Yes	0	5-10
66	Siren would not Sound	Yes	0	0-5
75	Siren would not Sound	No	340	5-10
76	Siren would not Sound	No	15	0-5
85		No	45	0-5
86	No Status Feedback	Yes	0	5-10
88	Siren Sounds w/o Rotation	Yes	0	5-10
	Siren would not Sound	Yes	0	5-10
90	Siren would not Sound	Yes	0	5-10


Total Population Affected = 1034 Estimated Total EPZ Population = 44516

% Coverage 0-5 miles = 98.63% Total Coverage of 10 mile EPZ = 97.68%


CONCLUSION

- ◆ The design of the Alert/Notification System meets the requirements outlined in NUREG-0654/FEMA-REP-1, Rev. 1 and FEMA-REP-10.
- ◆ The siren performance, determined through testing, also met established performance requirements as outlined in NUREG-0654/FEMA-REP-1, Rev. 1 and FEMA-REP-10.
- ◆ Procedures were in place to assure that equipment was maintained and repaired as required by 10 CFR 50.47 (b)(8).
- ◆ The sirens around LGS and PBAPS were not degraded to the extent that their availability and functionality impacted the implementation of the Emergency Plan.
- ◆ Based on population coverage analysis, safety significance of this issue is low.
- ◆ The requirements of 10 CFR 50.47 (b)(5) and 10 CFR 50.47 (b)(8) were met.

SIGNIFICANCE DETERMINATION



SIGNIFICANCE DETERMINATION



CLOSING

- Public Protection Maintained
- ◆ Self Identified
- In-Depth Root Cause Analysis
- ◆ Prompt and Comprehensive Corrective Actions
- Performance Indicator Data Corrected
- ◆ Contract Oversight Strengthened