

PLANT SYSTEMS

EMERGENCY FEEDWATER SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.1.2 Three emergency feedwater (EFW) pumps and two flow paths shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- a. With one steam supply to the turbine-driven EFW pump inoperable, restore the steam supply to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- b. With one steam supply to the turbine-driven EFW pump and one motor-driven EFW pump inoperable and the EFW flow paths able to deliver at least 100% flow to their respective steam generators, restore the steam supply or motor-driven EFW pump to OPERABLE status within 24 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- c. With one steam supply to the turbine-driven EFW pump and both motor-driven EFW pumps inoperable and the EFW flow paths able to deliver at least 100% flow to their respective steam generators, be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- d. With the EFW system inoperable for reasons other than those described in ACTION (a), (b), or (c), and able to deliver at least 100% flow to either steam generator, restore the EFW system to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- e. With the EFW system inoperable for reasons other than those described in ACTION (a), (b), or (c), and able to deliver at least 100% combined flow to the steam generators, be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- f. With the EFW system inoperable and unable to deliver at least 100% combined flow to the steam generators, immediately initiate action to restore the ability to deliver at least 100% combined flow to the steam generators. LCO 3.0.3 and all other LCO ACTIONS requiring MODE changes are suspended until the EFW system is capable of delivering at least 100% combined flow to the steam generators.

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS

4.7.1.2 The emergency feedwater system shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying that each manual, power-operated, and automatic valve in each water flow path and in both steam supply flow paths to the turbine-driven EFW pump steam turbine, that is not locked, sealed, or otherwise secured in position, is in its correct position.
- b. At least once per 92 days on a STAGGERED TEST BASIS by testing the EFW pumps pursuant to Specification 4.0.5. This surveillance requirement is not required to be performed for the turbine-driven EFW pump until 24 hours after exceeding 750 psig in the steam generators.
- c. At least once per 18 months by:

1. Verifying that each automatic valve in the flow path actuates to its correct position upon receipt of an actual or simulated actuation signal.

NOTE: This surveillance requirement is not required to be performed for the turbine-driven EFW pump until 24 hours after exceeding 750 psig in the steam generators.

2. Verifying that each EFW pump starts automatically upon receipt of an actual or simulated actuation signal.
- d. Prior to entering MODE 2, whenever the plant has been in MODE 4, 5, 6 or defueled, for 30 days or longer, or whenever feedwater line cleaning through the emergency feedwater line has been performed, by verifying flow from the condensate storage pool through both parallel flow legs to each steam generator.