

JUL 10 1981

DCS-MW-016

DISTRIBUTION:

Docket File
 NRC-PDR
 L PDR
 NSIC
 TERA
 ORB#3 Rdg
 DEisenhut
 JOlshinski
 PMKreutzer (3)
 Project Manager

GDeegan (4)
 ACRS (10)
 CMiles, OPA
 SECY
 RDiggs
 JHeltemes
 Gray File
 I&E (3)
 OELD
 RAClark



Docket No. 50-336

Mr. W. G. Council, Vice President
 Nuclear Engineering & Operations
 Northeast Nuclear Energy Company
 P. O. Box 270
 Hartford, Connecticut 06101

Dear Mr. Council:

The Commission has issued the enclosed Order for confirming your commitments for TMI related requirements for the Millstone Nuclear Power Station, Unit No. 2. This Order is based on your letters dated December 15 and 31, 1980, and February 13, 19, and 27, and March 4 and 18, 1981 and the references stated therein, to implement those requirements set forth in NUREG-0737 for which the staff requested completion before June 30, 1981. Explicit statements of these requirements are set forth in the Attachment to the Order.

It is the Commission's intent in issuing this Order to encourage completion of items consistent with the staff's recommended schedule. However, certain of your proposed schedule exceptions are acceptable. Therefore, you should proceed with implementation of these items in accordance with your proposed schedule. Your proposed technical and schedule exceptions for other items contained in NUREG-0737 will be the subject of future correspondence.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

Original signed by
 Robert A. Clark

Robert A. Clark, Chief
 Operating Reactors Branch #3
 Division of Licensing

CP
2

Enclosure:
Order

cc w/enclosure:
See next page

JUL 28 1981

8107220268 810710
 PDR ADOCK 05000336
 PDR

*Denotes previous concurrence. See attached.

OFFICE	ORB#3:DL*	ORB#3:DL	ORB#3:DL	OR:AD:DL	ORAB	OELD	D:DL
SURNAME	PMKreutzer	ELConner	RAClark	TMNovak	JOlshinski	SPMurray	DEisenhut
DATE	4/08/81	4/10/81	4/10/81	4/13/81	4/14/81	4/15/81	4/16/81

Docket No. 50-336

Mr. W. G. Council, Vice President
Nuclear Engineering & Operations
Northeast Nuclear Energy Company
P. O. Box 270
Hartford, Connecticut 06101

DISTRIBUTION:

Docket File	GDeegan (8)
NRC PDR	ACRS (10)
L PDR	CMiles, OPA
NSIC	SECY
TERA	RDiggs
ORB#3 Rdg	JHeltemes
DEisenhut	Gray File
JOlshinski	I&E (3)
PMKreutzer (3)	OELD
Project Manager	RAClark

Dear Mr. Council:

The Commission has issued the enclosed Order for confirming your commitments for TMI related requirements for the Millstone Nuclear Power Station, Unit No. 2. This Order is based on your letters dated December 15 and 31, 1980, and February 13, 19, and 27, and March 4 and 18, 1981, to implement those requirements set forth in NUREG-0737 for which the staff requested completion before June 30, 1981. Explicit statements of these requirements are set forth in the Attachment to the Order.

It is the Commission's intent in issuing this Order to encourage completion of items consistent with the staff's recommended schedule. However, certain of your proposed schedule exceptions are acceptable. Therefore, you should proceed with implementation of these items in accordance with your proposed schedule. Your proposed technical and schedule exceptions for other items contained in NUREG-0737 will be the subject of future correspondence.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosure:
Order

cc w/enclosure:
See next page

OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL	OR:AD:DL	ORAB	OELD	D:DL
SURNAME	PKreutzer	ELConner/pn	RAClark	TMNovak	JOlshinski		DEisenhut
DATE	4/8/81	4/ /81	4/ /81	4/ /81	4/ /81	4/ /81	4/ /81



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUL 10 1981

Docket No. 50-336

Mr. W. G. Council, Vice President
Nuclear Engineering & Operations
Northeast Nuclear Energy Company
P. O. Box 270
Hartford, Connecticut 06101


Dear Mr. Council:

The Commission has issued the enclosed Order for confirming your commitments for TMI related requirements for the Millstone Nuclear Power Station, Unit No. 2. This Order is based on your letters dated December 15 and 31, 1980, and February 13, 19, and 27, and March 4 and 18, 1981 and the references stated therein, to implement those requirements set forth in NUREG-0737 for which the staff requested completion before June 30, 1981. Explicit statements of these requirements are set forth in the Attachment to the Order.

It is the Commission's intent in issuing this Order to encourage completion of items consistent with the staff's recommended schedule. However, certain of your proposed schedule exceptions are acceptable. Therefore, you should proceed with implementation of these items in accordance with your proposed schedule. Your proposed technical and schedule exceptions for other items contained in NUREG-0737 will be the subject of future correspondence.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,


Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosure:
Order

cc w/enclosure:
See next page

Northeast Nuclear Energy Company

cc:

William H. Cuddy, Esquire
Day, Berry & Howard
Counselors at Law
One Constitution Plaza
Hartford, Connecticut 06103

Natural Resources Defense Council
917 15th Street, N.W.
Washington, D. C. 20005

Mr. Lawrence Bettencourt, First Selectman
Town of Waterford
Hall of Records - 200 Boston Post Road
Waterford, Connecticut 06385

Northeast Nuclear Energy Company
ATTN: Superintendent
Millstone Plant
Post Office Box 128
Waterford, Connecticut 06385

Waterford Public Library
Rope Ferry Road, Route 156
Waterford, Connecticut 06385

U. S. Environmental Protection Agency
Region I Office
ATTN: EIS COORDINATOR
John F. Kennedy Federal Building
Boston, Massachusetts 02203

Northeast Utilities Service Company
ATTN: Mr. James R. Himmelwright
Nuclear Engineering and Operations
P. O. Box 270
Hartford, Connecticut 06101

Mr. John Shedlosky
Resident Inspector/Millstone
c/o U.S.N.R.C.
P. O. Drawer KK
Niantic, CT 06357

Mr. Charles Brinkman
Manager - Washington Nuclear
Operations
C-E Power Systems
Combustion Engineering, Inc.
4853 Cordell Aven., Suite A-1
Bethesda, MD 20014

Connecticut Energy Agency
ATTN: Assistant Director, Research
and Policy Development
Department of Planning and Energy
Policy
20 Grand Street
Hartford, CT 06106

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)	Docket No. 50-336
)	
THE CONNECTICUT LIGHT & POWER COMPANY)	
THE HARTFORD ELECTRIC LIGHT COMPANY)	
WESTERN MASSACHUSETTS ELECTRIC COMPANY)	
NORTHEAST NUCLEAR ENERGY COMPANY)	
)	
(Millstone Nuclear Power Station,)	
Unit No. 2))	

ORDER CONFIRMING LICENSEE COMMITMENTS ON
POST-TMI RELATED ISSUES

I.

The Northeast Nuclear Energy Company, et al. (the licensee) is the holder of Facility Operating License No. DPR-65, which authorizes the operation of the Millstone Nuclear Power Station, Unit No. 2, (the facility) at steady-state power levels not in excess of 2700 megawatts thermal. The facility consists of a pressurized water reactor (PWR) located at the licensee's site in Waterford, Connecticut.

II.

Following the accident at Three Mile Island Unit No. 2 (TMI-2) on March 28, 1979, the Nuclear Regulatory Commission (NRC) staff developed a number of proposed requirements to be implemented on operating reactors and on plants under construction. These requirements include Operational Safety, Siting and Design, and Emergency Preparedness and are intended to provide substantial additional protection for the operation of nuclear facilities based on the

- 2 -

experience from the accident at TMI-2 and the official studies and investigations of the accident. The staff's proposed requirements and schedule for implementation are set forth in NUREG-0737, "Clarification of TMI Action Plan Requirements." Among these requirements are a number of items, consisting of hardware modifications, administrative procedure implementation and specific information to be submitted by the licensee, scheduled to be completed on or before June 30, 1981 (see the Attachment to this Order). NUREG-0737 was transmitted to each licensee and applicant by an NRC letter from my office dated October 31, 1980, which is hereby incorporated by reference. In that letter, it was indicated that although the NRC staff expected each requirement to be implemented in accordance with the schedule set forth in NUREG-0737, the staff would consider licensee requests for relief from staff proposed requirements and their associated implementation dates.

III.

The licensee's submittals dated December 15 and 31, 1980, February 13, 19, and 27, and March 4 and 18, 1981, and the references stated therein, which are incorporated herein by reference, committed to complete each of the actions specified in the Attachment. The licensee's submittals included a modified schedule for submittal of certain information. The staff has reviewed the licensee's submittals and determined that the licensee's modified schedule is acceptable based on the following:

- 3 -

The licensee's schedule for submittal of information in some instances does not meet the staff's specified submittal dates. Most of the information requested by the staff describes how the licensee is meeting the guidance of NUREG-0737. Therefore, this deferral of the licensee submittal will not alter the implementation of plant modifications. Therefore, plant safety is not affected by this modification in schedule for the submittal of information.

I have determined that these commitments are required in the interest of public health and safety, and therefore, should be confirmed by ORDER.

IV.

Accordingly, pursuant to Sections 103, 161i, 161o, and 182 of the Atomic Energy Act of 1954, as amended, and the Commission's regulations in 10 CFR Parts 2 and 50, IT IS HEREBY ORDERED EFFECTIVE IMMEDIATELY THAT the licensee shall comply with the following conditions:

The licensee shall satisfy the specific requirements described in the Attachment to this Order (as appropriate to the licensee's facility) as early as practicable but no later than 30 days after the effective date of the ORDER.

- 4 -

V.

Any person who has an interest affected by this Order may request a hearing within 20 days of the date of publication of this Order in the Federal Register. Any request for a hearing shall be addressed to the Director, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555. A copy shall also be sent to the Executive Legal Director at the same address. If a hearing is requested by a person other than the licensee, that person shall describe, in accordance with 10 CFR 2.714(a)(2), the nature of the person's interest and the manner in which the interest is affected by this Order. A REQUEST FOR HEARING SHALL NOT STAY THE IMMEDIATE EFFECTIVENESS OF THIS ORDER.

If a hearing is requested by the licensee or other persons who have an interest affected by this Order, the Commission will issue an Order designating the time and place of any such hearing.


If a hearing is held concerning this Order, the issue to be considered at the hearing shall be whether, on the basis of the information set forth in Sections II and III of this Order, the licensee should comply with the conditions set forth in Section IV of this Order.

- 5 -

This request for information was approved by OMB under clearance number 3150-0065 which expires June 30, 1983. Comments on burden and duplication may be directed to the Office of Management and Budget, Reports Management, Room 3208, New Executive Office Building, Washington, D. C.

This Order is effective upon issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Dated at Bethesda, Maryland
this 10th day of July ,
1981

Attachment:
NUREG-0737 Requirements

ATTACHMENT

NUREG 0737 REQUIREMENTS

<u>Item</u>	<u>Title</u>	<u>Applicability</u>	<u>Specific Requirement</u>	<u>Impl/Doc Subm Due Dates</u>
I.A.1.1	STA	ALL	(a) Provide STA coverage by degreed individuals (or equivalent), trained to licensee's program.	1/1/81
			(b) Submit description of current training program and demonstrate compliance with 10-30-79 letter.	1/1/81
			(c) Submit description of long term training program.	1/1/81
I.A.2.1	Reactor Operator Qualification	ALL	Submit description of and implement Upgraded Training Program.	8/1/80
I.C.1	Accident Procedures	ALL	(a) Submit reanalyses of inadequate core cooling and propose guidelines for emergency procedures, OR propose schedule and justify delays.	1/1/81
			(b) Submit reanalysis of transients and accidents for emergency procedures, OR propose schedule and justify delays.	1/1/81
I.C.5	Feedback of Operating Experience	ALL	Implement procedures for feedback of operating experience (no documentation submittal is required).	1/1/81
I.C.6	Correct Performance or Operating Activities	ALL	Implement procedures to verify correct performance of operating activities (no documentation submittal is required).	1/1/81

<u>Item</u>	<u>Title</u>	<u>Applicability</u>	<u>Specific Requirement</u>	<u>Impl/Doc Subm Due Dates</u>
II.B.2	Shielding	ALL	(a) Have available design details for vital area modifications.	1/1/81
			(b) Submit technical deviations to staff positions.	1/1/81
II.B.3	Post-Accident Sampling	ALL	Submit description of deviations from staff positions.	1/1/81
II.B.4	Training to Mitigate Core Damage	ALL	(a) Have available for review a training program for mitigating core damage (no documentation submittal required)	1/1/81
			(b) Implement training program (no documentation submittal required).	4/1/81
II.D.1	Performance Testing of RV/SRV's	ALL	(a) Submit test program (both BWR/PWR's).	7/1/80 (PWRs) 10/1/80 (BWRs)
			(b) Submit qualification program for PWR's block valve.	1/1/81 (PWRs)
II.E.1.2	Aux Feed Initiation and Flow	PWRs	(a) Submit final design and documentation on safety grade flow indication.	1/1/81
			(b) Submit final design and documentation on safety grade flow initiation.	1/1/81
II.E.4.2	Containment Isolation	ALL	(a) Submit documentation justifying minimum containment pressure setpoint for isolation of non-essential penetrations.	1/1/81
			(b) Submit statement that purge valves not meeting CSB 6-4 (or interim position) are sealed and verification is performed every 31 days.	1/1/81

<u>Item</u>	<u>Title</u>	<u>Applicability</u>	<u>Specific Requirement</u>	<u>Impl/Doc Subm Due Dates</u>
II.F.1	Post-Accident Monitoring	ALL	a. For noble gas monitor and Iodine/particulate sampling and analysis submit description and justification for deviations from staff requirements.	1/1/81
			b. Have available the final design information for noble gas monitor and iodine/particulate sampling and analysis.	1/1/81
II.F.2	Inst. for Inadequate Core Cooling	ALL	Submit a report detailing the planned instrumentation system for monitoring inadequate core cooling.	1/1/81
II.K.2.10	Antic. Trip on LOFW and TT	B&W	Submit final design for anticipatory trip as described in NUREG 0737.	1/1/81
II.K.2.13	Thermal Mechanical Report	B&W	Submit report on effects of Hi Pressure Injection on vessel integrity for SB LOCA with no Aux Feedwater.	1/1/81
II.K.3.2	PORV/SV Failures	PWR	Submit report on SB LOCA and probability of failure of PORV/SV/RV.	1/1/81
II.K.3.3	SRV/SV Failures & Challenges	ALL	Submit report (historical and annually thereafter) of SRV/SV failures and challenges.	1/1/81
II.K.3.7	PORV Opening Probability	B&W	Submit report on the probability of a PORV opening during an over-pressurization transient.	1/1/81
II.K.3.9	PID Controller Modification	Selected <u>W</u> plants	Modify the Proportional Integral Derivative Controller (as recommended by <u>W</u>). Advise NRC when modification is completed.	12/1/80
II.K.3.12	Anticipatory Trip on Turbine Trip	<u>W</u>	Submit confirmation of Anticipatory Trip. If not currently implemented, submit modification design and schedule for implementation.	1/1/81

<u>Item</u>	<u>Title</u>	<u>Applicability</u>	<u>Specific Requirement</u>	<u>Impl/Doc Subm Dates</u>
II.K.3.13	Separation of HPCI/RCIC Initiation Levels; Auto Restart of RCIC	BWRs w/HPCI/RCIC	Submit results of evaluation and proposed modification as appropriate.	1/1/81
II.K.3.16	Reduce Challenges to RV's	BWR	Submit report on actions planned to reduce RV challenges.	4/1/81
II.K.3.17	ECCS System Outages	ALL	Submit report on ECCS outages and propose changes to reduce outages.	1/1/81
II.K.3.18	ADS Logic Modifications	BWR	Submit report of feasibility of ADS system logic changes to eliminate need for manual actuation.	4/1/81
II.K.3.21	CSS/CPCI Restart	BWR	Submit report of evaluation, proposed modifications and analysis to satisfy staff positions.	1/1/81
II.K.3.22	RCIC Suction	BWR w/RCIC	Implement procedures and document verification of this change.	1/1/81
II.K.3.27	Common Reference for H ₂ O Level Instruments	BWR	Implement change and submit documentation of changes.	1/1/81
II.K.3.29	Isolation Condensor Performance	BWR w/ICs	Submit evaluation of I.C. performance.	4/1/81
II.K.3.30	SB LOCA Methods	ALL	Submit outline of program for model.	11/15/80
II.K.3.44	Fuel Failure	BWR	Submit evaluation to verify no fuel failure.	1/1/81
II.K.3.45	Manual Depressurization	BWR	Submit evaluation on other than ADS method for depressurization.	1/1/81

<u>Item</u>	<u>Title</u>	<u>Applicability</u>	<u>Specific Requirement</u>	<u>Impl/Doc Subm Due Dates</u>
III.D.3.3	Improved Inplant Iodine Monitoring	ALL	Have available means to accurately measure airborne radioiodine inplant during an accident.	1/1/81
III.D.3.4	Control Room Habitability	ALL	a. Submit control room habitability evaluation information. b. Submit modifications necessary to assure CR habitability with a schedule for completion.	1/1/81 1/1/81