

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.1.1.1	Perform required visual examinations and leakage rate testing except for primary containment air lock testing, in accordance with the Primary Containment Leakage Rate Testing Program.	In accordance with the Primary Containment Leakage Rate Testing Program.
SR 3.6.1.1.2	Verify that the drywell-to-suppression chamber bypass leakage is less than 0.00535 ft ² at an initial differential pressure of ≥ 4.3 psi.	<p>When performing 10 CFR 50 Appendix J, Type A testing, in accordance with the Primary Containment Leakage Rate Testing Program.</p> <p><u>AND</u></p> <p>-----Note-----</p> <p>Only required after two consecutive tests fail and continues until two consecutive tests pass</p> <p>-----</p> <p>24 months</p>