

TECHNICAL SPECIFICATIONS

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
1.0	General Information	1
1.1	Definitions	2
1.2	Exclusion Distance and Restricted Area	3
1.3	Principal Activities	3
2.0	Reactor Facility Design Performance Requirements	4
2.5	Electrical Power Supply	4
2.10.2	Fuel Storage	4
2.11	Fire Protection	5
3.0	Administrative and Procedural Safeguards	5
3.1	Responsibility	5
3.2	Organization	6
3.3	Operating Instructions and Procedures	7
4.0	Operating Limitations	8
4.1	General	8
4.1.7	Radiation Protection Program	9
4.1.8	DELETED	9
4.1.9	Spent Fuel Storage and Handling	9
5.0	Maintenance	10
5.1	General	10
5.2	Testing	11
5.3	Spent Fuel Storage Pool Sampling	11
5.4	Sealed Sources	11
6.0	Plant Reporting Requirements	12
6.1	Routine Reports and Reportable Occurrences	12
6.2	Special Reports	15
6.3	Reportable Event Action	15

4.1.7 Radiation Protection Program

Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

4.1.8 DELETED

4.1.9 Spent Fuel Storage and Handling

- 4.1.9.1 All irradiated fuel shall be stored in the racks provided in the Fuel Handling Building Storage pools, with sufficient shielding that ensures that the radiation level on the operating deck is ≤ 15 mr/hr. Should the radiation level be found to be above 15 mr/hr, corrective action shall be initiated to restore the level to ≤ 15 mr/hr.