

## TABLE OF CONTENTS (Cont'd)

<u>Section</u>	<u>Title</u>	<u>Page</u>
6.5	Review and Audit	6-3
6.6	Reportable Event Action	6-3
6.7	Safety Limit Violation	6-4
6.8	Procedures and Programs	6-4
6.9	Reporting Requirements	6-5
6.10	Record Retention	6-11
6.11	Radiation Protection Program	6-12
6.12	DELETED	
6.13	Environmental Qualification	6-12
6.14	Process Control Program (PCP)	6-13
6.15	Offsite Dose Calculation Manual (ODCM)	6-13
6.16	Major Changes to Radioactive Liquid, Gaseous and Solid Waste Systems	6-14

6.11 RADIATION PROTECTION PROGRAM

Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

6.12 DELETED

6.13 ENVIRONMENTAL QUALIFICATION

6.13.1 By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines), or NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment," December 1979. Copies of these documents are attached to Order for Modification of License No. DPR-26 dated October 24, 1980.

6.13.2 By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.