

DCS MS-016

March 2, 1983

Docket No. 50-336

DISTRIBUTION:  
✓ Docket File  
NRC PDR  
L PDR  
NSIC  
ORB#3 Rdg  
DEisenhut  
JHeltemes  
PMKreutzer-3  
RAClark  
PLeech  
OELD  
SECY  
LJHarmon-2

TBarnhart-4  
LSchneider  
DBrinkman  
ACRS-10  
OPA-CMiles  
RDiggs  
ASLAB  
TElsasser-Reg. I  
GHolahan  
Gray File

Mr. W. C. Council, Vice President  
Nuclear Engineering & Operations  
Northeast Nuclear Energy Company  
P. O. Box 270  
Hartford, Connecticut 06101

Dear Mr. Council:

This confirms our telephoned authorization given yesterday (March 1, 1983) for a change in Technical Specifications for Millstone Nuclear Power Station Unit 2, as requested by your telecopy dated March 1, 1983. Facility Operating License No. DPR-65 was amended on that date by making the following Technical Specifications change:

Paragraph 3.4.6.2 Action requirement b was modified by adding a footnote as follows:

b. With any Reactor Coolant System leakage greater than any one of the above limits, excluding PRESSURE BOUNDARY LEAKAGE, reduce the leakage rate to within limits within 4 hours or be in COLD SHUTDOWN within the next 36 hours.\*\*

\*\*For the shutdown commencing on March 1, 1983, the unit shall be placed in HOT STANDBY within the next 6 hours and COLD SHUTDOWN within the next 54 hours.

Copies of the license amendment, our evaluation and Federal Register Notice for this Technical Specification change will be sent to you when completed.

Sincerely,

Original signed by

Gus C. Lainas, Assistant Director  
for Operating Reactors  
Division of Licensing

cc: See next page

8303160668 830302  
PDR ADOCK 05000336  
P PDR

OFFICE	ORB#3:DL PMKreutzer	ORB#3:DL PLeech/pn	ORB#3:DL RAClark	AD:OR:DL GCLainas			
SURNAME							
DATE	3/2/83	3/2/83	3/2/83	3/2/83			

Spot Evaluation Report  
for  
Millsstone 2 Technical Specification  
Change to Specification 3.4.6.2

Background

The Millsstone 2 unidentified leakage limit of 1.0

GPM was recorded at 2 PM on March 1,

(calculated)

1983. The measured leakage was found to be 1.3

GPM. The Action statement for Technical

Specification 3.4.6.2 b. requires the plant to

be in Cold Shutdown <sup>within</sup> 36 hours if the leakage

is not reduced to below 1 gpm within the first

24 hours. The licensee has requested a

one-time Technical Specification change to

extend the time to Cold Shutdown to 60

hours. This will allow time to identify the

2

source of the leakage and put in place a collection system so the leakage can continue to be considered as Identified Leakage (for which the limit is 10 gpm).

### Evaluation

The licensee will place the plant in Hot Shutdown thereby mitigating the consequences of any events which could be associated with excessive unidentified leakage (ie LOCA).

The licensee will confirm the current expectation that the leakage is associated with valve stem leakage (PORV Block Valve, stem leakage).

If the licensee's investigation indicates that there is any Pressure Boundary Leakage, the plant will be taken to Cold Shutdown.

The licensee actions will meet the intent of the Technical Specification in that any Pressure Boundary Leakage will result in a Cold Shutdown; and leakage below 10 gpm which can be classified as Identified Leakage will not require a shutdown at all. In addition, if the licensee investigation determines that some of the leakage is Pressure Boundary Leakage, the period of exposure to such a condition will be short (a maximum of 60 hours vs the current 36 hour Specification) and the plant will already have been placed in Hot Shutdown.

#### Conclusion

Therefore the proposed actions do not constitute a significant change in the currently allowed plant conditions and will not result in any

under risk to the health and safety of the public.

SE prepared by Harry Holahan, Section Leader, ORRB, DL  
concerned in by Paul H. Book, Project Manager, ORRB-3, DL

March, 1983

Northeast Nuclear Energy Company

cc:

William H. Cuddy, Esquire  
Day, Berry & Howard  
Counselors at Law  
One Constitution Plaza  
Hartford, Connecticut 06103

Mr. Charles Brinkman  
Manager - Washington Nuclear  
Operations  
C-E Power Systems  
Combustion Engineering, Inc.  
7910 Woodmont Avenue  
Bethesda, MD 20814

Mr. Lawrence Bettencourt, First Selectman  
Town of Waterford  
Hall of Records - 200 Boston Post Road  
Waterford, Connecticut 06385

Northeast Nuclear Energy Company  
ATTN: Superintendent  
Millstone Plant  
Post Office Box 128  
Waterford, Connecticut 06385

U. S. Environmental Protection Agency  
Region I Office  
ATTN: Regional Radiation  
Representative  
John F. Kennedy Federal Building  
Boston, Massachusetts 02203

Northeast Utilities Service Company  
ATTN: Mr. Richard T. Laudenat, Manager  
Generation Facilities Licensing  
P. O. Box 270  
Hartford, Connecticut 06101

Mr. John Shedlosky  
Resident Inspector/Millstone  
c/o U.S.N.R.C.  
P. O. Drawer KK  
Niantic, CT 06357

Regional Administrator  
Nuclear Regulatory Commission, Region I  
Office of Executive Director for Operation  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

John F. Opeka  
System Superintendent  
Northeast Utilities Service Company  
P. O. Box 270  
Hartford, Connecticut 06101

Office of Policy & Management  
ATTN: Under Secretary Energy  
Division  
80 Washington Street  
Hartford, Connecticut 06115