

DATE	12/ /76	12/ /76	12/ /76
SURNAME	Twambach:mjt	Daffe	Glear
OFFICE	ORB #1	ORB #3	ORB #3

*count
p 3*

cc w/enc: See page 2

Enclosure: Specification 4.7.11.2

Original signed by
George Lear, Chief
Operating Reactors Branch #3
Division of Operating Reactors

Sincerely,

We are enclosing a corrected Specification 4.7.11.2 that has been sent to you as part of the Standard Technical Specifications (STS) for fire protection by letter dated December 2, 1976.

RE: HILLSTONE NUCLEAR POWER STATION UNITS NOS. 1 AND 2

Gentlemen:

Northeast Nuclear Energy Company
ATTN: Mr. Donald C. Switzer
President
P. O. Box 270
Hartford, Connecticut 06101

- ✓ Docket
- ORB #3
- Local PDR
- NRC PDR
- VStello
- TJCarter
- KGoller
- Glear
- CParrish
- Twambach
- Daffe
- Attorney, OELD
- ØXXØ
- OIAE (3)
- DEisenhut
- TBabernathy
- JRBuchanan
- ACRS (16)

Dockets Nos. 50-245 and 50-336

Distribution

DEC 1 6 1976

Northeast Nuclear Energy Company - 2 -

cc: William H. Cuddy, Esquire
Day, Berry & Howard
Counselors At Law
One Constitution Plaza
Hartford, Connecticut 06103

Mr. J. R. McCormick, President
The Hartford Electric Light Company
P. O. Box 2370
Hartford, Connecticut 06101

Anthony Z. Roisman, Esquire
Roisman, Kessler and Cashdan
1025 15th Street, N. W.
5th Floor
Washington, D. C. 20005

Waterford Public Library
Rope Ferry Road, Route 156
Waterford, Connecticut 06385

NOV 03 1976

PLANT SYSTEMS

SPRAY AND/OR SPRINKLER SYSTEMS

LIMITING CONDITION FOR OPERATION

3.7.11.2 The spray and/or sprinkler systems located in the following areas shall be OPERABLE:

a.

b.

(Plant dependent)

c.

APPLICABILITY: All modes

ACTIONS:

With a spray and/or sprinkler system inoperable establish a continuous fire watch with backup fire suppression equipment in the unprotected area(s), and

1. In MODES 1, 2, 3 or 4 restore the system to OPERABLE status within 7 days or be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.
2. In MODES 5 or 6 restore the system to OPERABLE status within 7 days or prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within the next 10 days outlining the cause of inoperability and the plans for restoring the system to OPERABLE status.

SURVEILLANCE REQUIREMENTS

4.7.11.2 The spray and/or sprinkler systems shall be demonstrated to be OPERABLE:

a. At least once per 92 days by cycling each testable valve through one complete cycle.

b. At least once per 12 months:

1. By performing a system functional test which includes simulated automatic actuation of the system and verifying that the automatic valves in the flow path actuate to their correct positions.

2. By inspection of spray headers to verify their integrity

3. By inspection of each nozzle to verify no blockage.

c. At least once per 5 years by an air flow test of the open head spray and/or sprinkler system.