

## CONTAINMENT SYSTEMS

### INTERNAL PRESSURE

#### LIMITING CONDITION FOR OPERATION

---

3.6.1.4 Primary containment internal pressure shall be maintained less than 27 inches H<sub>2</sub>O gauge and greater than 14.275 psia.

APPLICABILITY: MODES 1, 2, 3, and 4.

#### ACTION:

With the containment internal pressure outside of the limits above, restore the internal pressure to within the limits within 1 hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.6.1.4 The primary containment internal pressure shall be determined to be within the limits at least once per 12 hours.