

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.6.1.3.6	Verify each automatic PCIV actuates to the isolation position on an actual or simulated isolation signal.	24 months
SR 3.6.1.3.7	Verify a representative sample of reactor instrumentation line EFCVs actuate to the isolation position on an actual or simulated instrument line break signal.	24 months
SR 3.6.1.3.8	Remove and test the explosive squib from each shear isolation valve of the TIP System.	In accordance with the Inservice Testing Program
SR 3.6.1.3.9	Verify leakage rate through each MSIV is ≤ 11.5 scfh when tested at ≥ 25 psig.	In accordance with the Primary Containment Leakage Rate Testing Program

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.6.1.3.6	Verify each automatic PCIV actuates to the isolation position on an actual or simulated isolation signal.	24 months
SR 3.6.1.3.7	Verify a representative sample of reactor instrumentation line EFCVs actuate to the isolation position on an actual or simulated instrument line break signal.	24 months
SR 3.6.1.3.8	Remove and test the explosive squib from each shear isolation valve of the TIP System.	In accordance with the Inservice Testing Program
SR 3.6.1.3.9	Verify leakage rate through each MSIV is ≤ 11.5 scfh when tested at ≥ 25 psig.	In accordance with the Primary Containment Leakage Rate Testing Program