

June 30, 1992

Docket No. 50-336

Mr. John F. Opeka  
Executive Vice President, Nuclear  
Connecticut Yankee Atomic Power Company  
Northeast Nuclear Energy Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

Distribution:

Docket File CGrimes  
NRC & Local PDRs JNorberg  
PD I-4 Plant JRaleigh  
SVarga JRajan  
JCalvo ACRS (10)  
SNorris OPA  
GVissing OC/LFMB  
OGC RBrough, RI  
DHagan  
GHill (4)  
Wanda Jones

Dear Mr. Opeka:

SUBJECT: AMENDMENT NO. 160 - CORRECTION (TAC NO. M82750)

On June 16, 1992, the Commission issued Amendment No. 160 to Facility Operating License No. DPR-65 for the Millstone Nuclear Power Station, Unit No. 2. The amendment was issued in response to your application dated February 3, 1992, as supplemented April 1, 1992, relating to Snubber Visual Inspection Intervals.

It has come to our attention that the updated Technical Specification page 3/4 7-32 was not included with the amendment. Please remove the old page 3/4 7-32 and insert the enclosed updated page 3/4 7-32.

Sincerely,

/s/

Guy S. Vissing, Senior Project Manager  
Project Directorate I-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosure:  
Technical Specification page 3/4 7-32

cc w/enclosure:  
See next page

**NRC FILE CENTER COPY**

OFFICIAL RECORD COPY

Document Name: CORTN

OFC	:LA:PDI-4	:PM:PDI-4	:D:PDI-4	:	:	:	:
NAME	:SNorris	:GVissing:cn:JStolz	:	:	:	:	:
DATE	:6/30/92	:6/30/92	:6/30/92	:	:	:	:

9207070403 920630  
PDR ADDCK 05000336  
P PDR

CP-1  
JFOL  
11

Mr. John F. Opeka  
Northeast Nuclear Energy Company

Millstone Nuclear Power Station  
Unit 2

cc:

Gerald Garfield, Esquire  
Day, Berry and Howard  
Counselors at Law  
City Place  
Hartford, Connecticut 06103-3499

R. M. Kacich, Director  
Nuclear Licensing  
Northeast Utilities Service Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

W. D. Romberg, Vice President  
Nuclear, Operations Services  
Northeast Utilities Service Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

D. O. Nordquist  
Director of Quality Services  
Northeast Utilities Service Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

Kevin McCarthy, Director  
Radiation Control Unit  
Department of Environmental Protection  
State Office Building  
Hartford, Connecticut 06106

Regional Administrator  
Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406

Bradford S. Chase, Under Secretary  
Energy Division  
Office of Policy and Management  
80 Washington Street  
Hartford, Connecticut 06106

First Selectmen  
Town of Waterford  
Hall of Records  
200 Boston Post Road  
Waterford, Connecticut 06385

S. E. Scace, Nuclear Station Director  
Millstone Nuclear Power Station  
Northeast Nuclear Energy Company  
Post Office Box 128  
Waterford, Connecticut 06385

W. J. Raymond, Resident Inspector  
Millstone Nuclear Power Station  
c/o U.S. Nuclear Regulatory Commission  
Post Office Box 376  
Waterford, Connecticut 06385-0376

J. S. Keenan, Nuclear Unit Director  
Millstone Unit No. 2  
Northeast Nuclear Energy Company  
Post Office Box 128  
Waterford, Connecticut 06385

Charles Brinkman, Manager  
Washington Nuclear Operations  
ABB Combustion Engineering  
Nuclear Power  
12300 Twinbrook Pkwy, Suite 330  
Rockville, Maryland 20852

Nicholas S. Reynolds  
Winston & Strawn  
1400 L Street, NW  
Washington, DC 20005-3502

TABLE 4.7-3  
 SNUBBER VISUAL INSPECTION INTERVAL

Population or Category (Notes 1 and 2)	NUMBER OF UNACCEPTABLE SNUBBERS		
	Column A Extend Interval (Notes 3 and 6)	Column B Repeat Interval (Notes 4 and 6)	Column C Reduce Interval (Notes 5 and 6)
1	0	0	1
80	0	0	2
100	0	1	4
150	0	3	8
200	2	5	13
300	5	12	25

Note 1: The next visual inspection interval for a snubber population or category size shall be determined based upon the previous inspection interval and the number of unacceptable snubbers found during that interval. Snubbers may be categorized, based upon their accessibility during power operation, as accessible or inaccessible. These categories may be examined separately or jointly. However, that decision must be made and documented before any inspection and that decision shall be used as the basis upon which to determine the next inspection interval for that category.

Note 2: Interpolation between population or category sizes and the number of unacceptable snubbers is permissible. Use next lower integer for the value of the limit for Columns A, B, or C if that integer includes a fractional value of unacceptable snubbers as determined by interpolation.

Note 3: If the number of unacceptable snubbers is equal to or less than the number in Column A, the next inspection interval may be twice the previous interval but not greater than 48 months.

Note 4: If the number of unacceptable snubbers is equal to or less than the number in Column B but greater than the number in Column A, the next inspection interval shall be the same as the previous interval.

Note 5: If the number of unacceptable snubbers is equal to or greater than the number in Column C, the next inspection interval shall be two-thirds of the previous interval. However, if the number of unacceptable snubbers is less than the number in Column C but greater than the number in Column B, the next interval shall be reduced proportionally by interpolation, that is, the previous interval shall be reduced by a factor that is one-third of the ratio of the difference between the number of unacceptable snubbers found during the previous interval and the number in Column B to the difference in the numbers in Columns B and C.

9207070406 920630  
 PDR ADDCK 05000336  
 P PDR

cification 4.0.2 are applicable for all inspection intervals up to and including

MILLSTONE - UNIT 2  
0018

3/4 7-32

Amendment No. 77, §§, 10