

June 16, 1992

Docket No. 50-336

Mr. John F. Opeka
Executive Vice President, Nuclear
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Distribution:

Docket File	Wanda Jones
NRC & Local PDRs	CGrimes
PD I-4 Plant	JNorberg
SVarga	ACRS (10)
JCalvo	OPA
SNorris	OC/LFMB
GVising	RBlough, RI
OGC	JRaleigh
DHagan	JRajan
GHill (4)	

Dear Mr. Opeka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M82750)

The Commission has issued the enclosed Amendment No. 160 to Facility Operating License No. DPR-65 for Millstone Nuclear Power Station, Unit No. 2, in response to your application dated February 3, 1992, as supplemented by letter dated April 1, 1992.

The amendment changes the action statement and the visual inspection surveillance requirements (Technical Specifications 3.7.8 and 4.7.8) associated with the snubbers. The changes provide an alternate method for determining the next interval for the visual inspection of snubbers.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/s/

Guy S. Vissing, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 160 to DPR-65
2. Safety Evaluation

cc w/enclosures:
See next page

OFFICIAL RECORD COPY

Document Name: SNUBBERS

CP1

OFC	:LA:PDI-4	:PM:PDI-4	:D:PDI-4	: OGC	:
NAME	:SNorris	:GVising	:GStolz	: <i>Handwritten</i>	:
DATE	:6/2/92	:6/2/92	:6/2/92	:6/5/92	:

Handwritten signature

9206170259 920616
PDR ADOCK 05000336
PDR

NRC FILE CENTER COPY

Mr. John F. Opeka
Northeast Nuclear Energy Company

Millstone Nuclear Power Station
Unit 2

cc:

Gerald Garfield, Esquire
Day, Berry and Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

R. M. Kacich, Director
Nuclear Licensing
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

W. D. Romberg, Vice President
Nuclear, Operations Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

D. O. Nordquist
Director of Quality Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Kevin McCarthy, Director
Radiation Control Unit
Department of Environmental Protection
State Office Building
Hartford, Connecticut 06106

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Bradford S. Chase, Under Secretary
Energy Division
Office of Policy and Management
80 Washington Street
Hartford, Connecticut 06106

First Selectmen
Town of Waterford
Hall of Records
200 Boston Post Road
Waterford, Connecticut 06385

S. E. Scace, Nuclear Station Director
Millstone Nuclear Power Station
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

W. J. Raymond, Resident Inspector
Millstone Nuclear Power Station
c/o U.S. Nuclear Regulatory Commission
Post Office Box 376
Waterford, Connecticut 06385-0376

J. S. Keenan, Nuclear Unit Director
Millstone Unit No. 2
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

Charles Brinkman, Manager
Washington Nuclear Operations
ABB Combustion Engineering
Nuclear Power
12300 Twinbrook Pkwy, Suite 330
Rockville, Maryland 20852

Nicholas S. Reynolds
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

NORTHEAST NUCLEAR ENERGY COMPANY
THE CONNECTICUT LIGHT AND POWER COMPANY
THE WESTERN MASSACHUSETTS ELECTRIC COMPANY
DOCKET NO. 50-336
MILLSTONE NUCLEAR POWER STATION, UNIT NO. 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 160
License No. DPR-65

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Northeast Nuclear Energy Company, et al. (the licensee) dated February 3, 1992, supplemented by letter dated April 1, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-65 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 160 are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance, to be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Director
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 16, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 160

FACILITY OPERATING LICENSE NO. DPR-65

DOCKET NO. 50-336

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove

3/4 7-21
3/4 7-22
3/4 7-22a

3/4 7-32

Insert

3/4 7-21
3/4 7-22
3/4 7-22a
3/4 7-22b
3/4 7-32

PLANT SYSTEMS

3/4.7.8 SNUBBERS

LIMITING CONDITION FOR OPERATION

3.7.8 All snubbers shall be OPERABLE. The only snubbers excluded from the requirements are those installed on nonsafety-related systems and then only if their failure or failure of the system on which they are installed would have no adverse effect on any safety-related system.

APPLICABILITY: MODES 1, 2, 3, and 4. MODES 5 and 6 for snubbers located on systems required OPERABLE in those MODES.

ACTION:

With one or more snubbers inoperable within 72 hours replace or restore the inoperable snubber(s) to OPERABLE status and perform an engineering evaluation per Specification 4.7.8.d on the attached component or declare the attached system inoperable and follow the appropriate ACTION statement for the system.

SURVEILLANCE REQUIREMENTS

4.7.8 Each snubber shall be demonstrated OPERABLE by performance of the following augmented inservice inspection program and the requirements of Specification 4.0.5.

a. Inspection Types

As used in this specification, "type of snubber" shall mean snubbers of the same design and manufacturer, irrespective of capacity.

b. Visual Inspections

Snubbers are categorized as inaccessible or accessible during reactor operation. Each of these categories (inaccessible and accessible) may be inspected independently according to the schedule determined by Table 4.7-3. The visual inspection interval for each type of snubber shall be determined based upon the criteria provided in Table 4.7-3 and the first inspection interval determined using this criteria shall be based upon the previous inspection interval as established by the requirements in effect before Amendment ____.

c. Visual Inspection Acceptance Criteria

Visual inspections shall verify that (1) the snubber has no visible indications of damage or impaired OPERABILITY, (2) attachments to the foundation or supporting structure are functional, and (3) fasteners for the attachment of the snubber to the component and to the snubber anchorage are functional. Snubbers which appear inoperable as a result of visual inspections shall be classified as unacceptable and may be reclassified acceptable for the purpose of establishing the next visual inspection interval, provided that (1) the cause of the rejection is clearly established and remedied for that particular snubber and for other snubbers irrespective of type

PLANT SYSTEMS

SURVEILLANCE REQUIREMENT (Continued)

that may be generically susceptible; and (2) the affected snubber is functionally tested in the as-found condition and determined OPERABLE per Specification 4.7.8.e or 4.7.8.f, as applicable. All snubbers found connected to an inoperable common hydraulic fluid reservoir shall be counted as unacceptable for determining the next inspection interval. A review and evaluation shall be performed and documented to justify continued operation with an unacceptable snubber. If continued operation cannot be justified, the snubber shall be declared inoperable and the ACTION requirements shall be met.

d. Snubber Tests

At least once per eighteen (18) months during shutdown, a representative sample (10% of the total of each type of snubber, mechanical and hydraulic, except steam generator hydraulic snubbers in use in the plant) shall be tested either in place or in a bench test. For each snubber that does not meet the test acceptance criteria of Specification 4.7.8.e or 4.7.8.f, as applicable, an additional 5% of that type of snubber shall be tested.

Testing shall continue until no additional inoperable snubbers are found within a sample or until all snubbers have been tested. The representative sample selected for testing shall include the various configurations, and the range of size and capacity of snubbers.

Snubbers identified as "Especially Difficult to Remove" or in "High Radiation Zones During Shutdown" shall also be included in the representative sample.*

In addition to the regular sample, in locations where snubbers had failed the previous test due to operational or environmental conditions (excessive vibration, water hammer, high radiation, extreme heat or humidity, etc.), the snubbers currently installed in these locations shall be tested during the next test period. Test results of these snubbers may not be included for the resampling. All replacement snubbers shall have been tested prior to installation.

All steam generator hydraulic snubbers shall be tested and refurbished every seven years or less in accordance with the preventative maintenance program, in lieu of the functional test requirements of this specification.

*Permanent or other exemptions from functional testing for individual snubbers in these categories may be granted by the Commission only if a justifiable basis for exemption is presented.

PLANT SYSTEMS

SURVEILLANCE REQUIREMENT (Continued)

If any snubber selected for testing either fails to lock-up or fails to move (i.e., frozen in place), the cause will be evaluated and if caused by manufacturer design deficiency, all snubbers of the same design subject to the same defect shall be tested regardless of location or difficulty or removal. This testing requirement shall be independent of the requirements stated above for snubbers not meeting the test acceptance criteria.

For the snubber(s) found inoperable, an engineering evaluation shall be performed on the components which are supported by the snubber(s). The purpose of this engineering evaluation shall be to determine if the components supported by the snubber(s) were adversely affected by the inoperability of the snubber(s) in order to ensure that the supported component remains capable of meeting the designed service.

e. Hydraulic Snubbers Functional Test Acceptance Criteria

The hydraulic snubber functional test shall verify that:

1. Activation (restraining action) is achieved within the specified range of velocity or acceleration in both tension and compression.
2. Snubber bleed, or release rate, where required, is within the specified range in compression or tension.

f. Mechanical Snubbers Functional Test Acceptance Criteria*

The mechanical snubber functional test shall verify that:

1. The force that initiates free movement of the snubber rod in either tension or compression is less than the specified maximum drag force.
2. Activation (restraining action) is achieved within the specified range of velocity or acceleration in both tension and compression.

g. Snubber Service Life Monitoring

A record of the service life of each snubber, the date at which the designated service life commences and the installation and maintenance records on which the designated service life is based shall be maintained as required by Specification 6.10.2.h

*Mechanical snubber functional test acceptance criteria shall become effective upon installation of snubber testing equipment but not later than June 30, 1985.

PLANT SYSTEMS

SURVEILLANCE REQUIREMENT (Continued)

Concurrent with the first inservice visual inspection and at least once per 18 months thereafter, the installation and maintenance records for each snubber shall be reviewed to verify that the indicated service life has not been exceeded or will not be exceeded prior to the next scheduled snubber service life review. If the indicated service life will be exceeded prior to the next scheduled service life review, the snubber service life shall be reevaluated or the snubber shall be replaced or reconditioned so as to extend its service life beyond the date of the next scheduled service life review. This reevaluation, replacement or reconditioning shall be indicated in the records.

TABLE 4.7-3
 SNUBBER VISUAL INSPECTION INTERVAL

Population or Category (Notes 1 and 2)	Column A Extend Interval (Notes 3 and 6)	Column B Repeat Interval (Notes 4 and 6)	Column C Reduce Interval (Notes 5 and 6)
1	0	0	1
80	0	0	2
100	0	1	4
150	0	3	8
200	2	5	13
300	5	12	25

Note 1: The next visual inspection interval for a snubber population or category size shall be determined based upon the previous inspection interval and the number of unacceptable snubbers found during that interval. Snubbers may be categorized, based upon their accessibility during power operation, as accessible or inaccessible. These categories may be examined separately or jointly. However, that decision must be made and documented before any inspection and that decision shall be used as the basis upon which to determine the next inspection interval for that category.

Note 2: Interpolation between population or category sizes and the number of unacceptable snubbers is permissible. Use next lower integer for the value of the limit for Columns A, B, or C if that integer includes a fractional value of unacceptable snubbers as determined by interpolation.

Note 3: If the number of unacceptable snubbers is equal to or less than the number in Column A, the next inspection interval may be twice the previous interval but not greater than 48 months.

Note 4: If the number of unacceptable snubbers is equal to or less than the number in Column B but greater than the number in Column A, the next inspection interval shall be the same as the previous interval.

Note 5: If the number of unacceptable snubbers is equal to or greater than the number in Column C, the next inspection interval shall be two-thirds of the previous interval. However, if the number of unacceptable snubbers is less than the number in Column C but greater than the number in Column B, the next interval shall be reduced proportionally by interpolation, that is, the previous interval shall be reduced by a factor that is one-third of the ratio of the difference between the number of unacceptable snubbers found during the previous interval and the number in Column B to the difference in the numbers in Columns B and C.

Note 6: The provisions of Specification 4.0.2 are applicable for all inspection intervals up to and including 48 months.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 160

TO FACILITY OPERATING LICENSE NO. DPR-65

NORTHEAST NUCLEAR ENERGY COMPANY, ET AL.

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 2

DOCKET NO. 50-336

1.0 INTRODUCTION

By letter dated February 3, 1992, as supplemented by letter dated April 1, 1992, the Northeast Nuclear Energy Company (the licensee), submitted a request for an amendment to the Millstone Nuclear Power Station, Unit No. 2 Technical Specifications (TS). The requested amendment would remove the snubber visual examination schedule in the existing Technical Specifications and replace it with a refueling outage based visual examination schedule, Table 4.7-2 of the Generic Letter 90-09 dated December 11, 1990, to all holders of operating licenses or construction permits for nuclear power reactors.

2.0 EVALUATION

The snubber visual examination schedule in the existing Technical Specification, is based on the permissible number of inoperable snubbers found during the visual examination. Because the existing snubber visual examination schedule is based only on the absolute number of inoperable snubbers found during the visual examination irrespective of the total population of snubbers, licensees with a large snubber population find the visual examination schedule excessively restrictive. The purpose of the alternative visual examination schedule is to allow the licensee to perform visual examinations and corrective actions during plant outages without reduction of the confidence level provided by the existing visual examination schedule. The new visual examination schedule specifies the permissible number of inoperable snubbers for various snubber populations. The basic examination interval is the normal fuel cycle up to 24 months. This interval may be extended to as long as twice the fuel cycle or reduced to as small as two thirds of the fuel cycle depending on the number of unacceptable snubbers found during the visual examination. The examination interval may vary by ± 25 percent to coincide with the actual outage.

In the event one or more snubbers are found inoperable during a visual examination, the Limiting Conditions for Operation (LCO) in the present TS require the licensee to restore or replace the inoperable snubber(s) to operable status within 72 hours or declare the attached system inoperable and

follow the appropriate action statement for that system. This LCO will remain in the TS; however, the permissible number of inoperable snubber(s) and the subsequent visual examination interval will now be determined in accordance with the new visual examination schedule (Table 4.7-2 of Generic Letter 90-09 dated December 11, 1990). As noted in the guidance for this line item TS improvement, certain corrective actions may have to be performed depending on the number of inoperable snubbers found. All requirements, for corrective actions and evaluations associated with the use of visual examination schedule and stated in the footnotes 1 through 6, (Table 4.7-2 of Generic Letter 90-09) shall be included in the TS.

The licensee has proposed changes to Specifications 3.7.8 and 4.7.8 that are consistent with the guidance provided in Generic Letter 90-09 for the replacement of the snubber visual examination schedule with Table 4.7-2 (including footnotes 1 through 6) of the Generic Letter 90-09. On the basis of its review of this matter, the staff finds that the proposed changes to the TS for Millstone Unit No. 2 are acceptable.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Connecticut State official was notified of the proposed issuance of the amendment. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes surveillance requirements. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluent that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (57 FR 18176). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such

activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: J. Rajan

Date: June 16, 1992