Docket No. 50-336

Mr. Edward J. Mroczka Senior Vice President Nuclear Engineering and Operations Connecticut Yankee Atomic Power Company Northeast Nuclear Energy Company P. O. Box 270 Hartford, Connecticut 06141-0270

Dear Mr. Mroczka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. 76398)

The Commission has issued the enclosed Amendment No.145 to Facility Operating License No. DPR-65 for Millstone Nuclear Power Station, Unit No. 2, in response to your application dated March 21, 1990.

The amendment adds a new Technical Specification Section 3/4.7.11 "Ultimate Heat Sink" by a requirement to maintain an average water temperature less than or equal to $75^{\circ}F$ at the intake structure except when the reactor is in the cold shutdown or refueling condition.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly <u>Federal Register</u> notice.

Sincerely,

/s/

Guy S. Vissing, Senior Project Manager Project Directorate I-4 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 145to DPR-65

2. Safety Evaluation

cc w/enclosures: See next page

OFC	:LA:PDI-4	:PM:PDI-4	:SPLBpg	:PD:PDI-4	:0GC 276 :
NAME	SNorris	:GViseing:Im	:CMcCracken	:JStolz	EHOLLER
DATE	5/15/90	5/15/90	5116190	: <i>6 11/ 1</i> 90	
	OFFICIAL Document	RECORD COPY Name: AMEND/76398	3		\bigcap
		9006260250 90 PDR ADOCK 05 P	00612 5000336 PDC		V col
					111

DATED: June 12, 1990

. .

AMENDMENT NO. 145 TO FACILITY OPERATING LICENSE NO. DPR-65

DISTRIBUTION Docket File NRC & Local PDR Plant File S. Varga (14E4) B. Boger (14A2) J. Stolz S. Norris G. Vissing OGC D. Hagan (MNBB 3302) E. Jordan (MNBB 3302) G. Hill(4) (P1-137) W. Jones (P-130A) C. McCracken (8D1) J. Calvo (11F23) ACRS (10) GPA/PA ARM/LFMB

cc: Licensee/Applicant Service List



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

NORTHEAST NUCLEAR ENERGY COMPANY

THE CONNECTICUT LIGHT AND POWER COMPANY

THE WESTERN MASSACHUSETTS ELECTRIC COMPANY

DOCKET NO. 50-336

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No.145 License No. DPR-65

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Northeast Nuclear Energy Company, et al. (the licensee), dated March 21, 1989 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9006260252 900612 PDR ADOCK 05000336 PDC PDC

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-65 is hereby amended to read as follows:
 - (2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No.145, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance, to be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

John F. Stolz, Director Project Directorate I-4 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: June 12, 1990

- 2 -

ATTACHMENT TO LICENSE AMENDMENT NO.145

FACILITY OPERATING LICENSE NO. DPR-65

DOCKET NO. 50-336

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change. The corresponding overleaf pages are provided to maintain document completeness.

Remove	Insert
VIII	VIII
XIII	XIII
	3/4 7-42
B 3/4 7-7	B 3/4 7-7

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

SECTION		*: *:* PAGE
<u>3/4.6 C</u>	ONTAINMENT SYSTEMS	•
3/4.6.1	PRIMARY CONTAINMENT	3/4 6-1
	Containment Integrity	3/4 6-1
	Containment Leakage	3/4 6-2
	Containment Air Locks	3/4 6-6
	Internal Pressure	3/4 6-8
-	Air Tempersture	3/4 6-9
	Containment Structural Integrity	3/4 6-10
3/4.6.2	DEPRESSURIZATION AND COOLING SYSTEMS	3/4 6-12
	Containment Spray System	3/4 6-12
	Containment Air Recirculation System	3/4 6-14-
3/4.6.3	CONTAINMENT ISOLATION VALVES	3/4 6-15
3/4.6.4	COMBUSTIBLE GAS CONTROL	3/4 6-20
	Hydrogen Analyzers	3/4 6-20
	Electric Hydrogen Recombiners - <u>W</u>	3/4 6-21
	Hydrogen Purge System	3/4 6-23
	Post-Incident Recirculation Systems	3/4 6-24
3/4.6.5	SECONDARY CONTAINMENT	3/4 6-25
	Enclosure Building Filtration System	3/4 6-25
	Enclosure Building Integrity	3/4 6-28

IIV

MILLSTONE - UNIT 2

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

SECTION		
<u>3/4.7 Pl</u>	LANT SYSTEMS	<u> </u>
3/4.7.1	TURBINE CYCLE	3/4 7-1
	Safety Valves	3/4 7-1
	Auxiliary Feedwater Pumps	3/4 7-4
	Condensate Storage Tank	3/4 7-6
	Activity	3/4 7-7
	Main Steam Line Isolation Valves	3/4 7-9
3/4.7.2	STEAM GENERATOR PRESSURE/TEMPERATURE LIMITATION	3/4 7-1
3/4.7.3	REACTOR BUILDING CLOSED COOLING WATER SYSTEM	3/4 7-1
3/4.7.4	SERVICE WATER SYSTEM	3/4 7-1
3/4.7.5	FLOOD LEVEL	3/4 7-1
3/4.7.6	CONTROL ROOM EMERGENCY VENTILATION SYSTEM	3/4 7-1
3/4.7.7	SEALED SOURCE CONTAMINATION	3/4 7-1
3/4.7.8	SNUBBERS	3/4 7-2
3/4.7.9	FIRE SUPPRESSION SYSTEMS	3/4 7-3
	Fire Suppression Water System	3/4 7-3
	Spray and/or Sprinkler Systems	3/4 7-3
	Fire Hose Stations	3/4 7-3
3/4.7.10	PENETRATION FIRE BARRIERS	3/4 7-4
3/4.7.11	ULTIMATE HEAT SINK	3/4 7-4
<u>3/4.8 EL</u>	ECTRICAL POWER SYSTEMS	
3/4.8.1	A.C. SOURCES	3/4 8-1
	Operating	3/4 8-1
	Shutdown	3/4 8-5
3/4.8.2	ONSITE POWER DISTRIBUTION SYSTEMS	3/4 8-6
	A.C. Distribution - Operating	3/4 8-6
	A.C. Distribution - Shutdown	3/4 8-7
	D.C. Distribution - Operating	3/4 8-8
	D.C. Distribution - Shutdown	3/4 8-1

MILLSTONE - UNIT 2

<u>SECTION</u>			PAGE	
3/4.7	PLANT_SYSTEMS			
3/4.7.1	TURBINE CYCLE	B	3/4	7-1
3/4.7.2	STEAM GENERATOR PRESSURE/TEMPERATURE LIMITATION	B	3/4	7-3
3/4.7.3	REACTOR BUILDING CLOSED COOLING WATER SYSTEM	B	3/4	7-3
3/4.7.4	SERVICE WATER SYSTEM	В	3/4	7-4
3/4.7.5	FLOOD LEVEL	В	3/4	7-4
3/4.7.6	CONTROL ROOM EMERGENCY VENTILATION SYSTEM	B	3/4	7-4
3/4.7.7	SEALED SOURCE CONTAMINATION	B	3/4	7-5
3/4.7.8	SNUBBERS	B	3/4	7-5
3/4.7.9	FIRE SUPPRESSION SYSTEMS	B	3/4	7-6
3/4.7.10	PENETRATION FIRE BARRIERS	B	3/4	7-7
3/4.7.11	ULTIMATE HEAT SINK	B	3/4	7-7
<u>3/4.8</u> E	<u>_ECTRICAL_POWER_SYSTEMS</u>	В	3/4	8-1
3/4.9 RE	FUELING OPERATIONS			
3/4.9.1	BORON CONCENTRATION	B	3/4	9-1
3/4.9.2	INSTRUMENTATION	B	3/4	9-1
3/4.9.3	DECAY TIME	B	3/4	9-1
3/4.9.4	CONAINMENT PENETRATIONS	В	3/4	9-1
3/4.9.5	COMMUNICATIONS	B	3/4	9-1
3/4.9.6	CRANE OPERABILITYCONTAINMENT BUILDING	B	3/4	9-2
3/4.9.7	CRANE TRAVELSPENT FUEL STORAGE BUILDING	В	3/4	9-2
3/4.9.8	SHUTDOWN COOLING AND COOLING RECIRCULATION	B	3/4	9-2

•

BASES

11	INDEX	
BASES		
<u>SECTI</u>	<u>N</u>	DAGE
3/4.9	9 AND 3/4.9.10 CONTAINMENT AND RADIATION MONITORING AND CONTAINMENT PURGE VALVE ISOLATION SYSTEM	B 3/A C 2
3/4.9	11 AND 3/4.9.12 WATER LEVEL - REACTOR VESSEL AND STORAGE POOL WATER LEVEL	B 3/4 9-2
3/4.9	13 STORAGE POOL RADIATION MONITORING.	B 2/4 0 0
3/4.9.	14 AND 3/4.9.15 STORAGE POOL AREA VENTILATION SYSTEM	• • 5/4 9-3
3/4.9.	16 SHIELDED CASK	· b 3/4 9-3
3/4.9.	17 MOVEMENT OF FUEL OVER REGION II RACKS	B 3/4 9-3
3/4.9.	18 SPENT FUEL POOL	. B 3/4 9-3
3/4.9.	19 SPENT FUEL POOL	B 3/4 9-3
3/4.10	SPECIAL TEST EXCEPTIONS	·
3/4.10	I SHUTDOWN MARGIN.	D 0/4 10 1
3/4.10	2 GROUP HEIGHT AND INSERTION LIMITS	B 3/4 10-1
.3/4 . 10.	3 PRESSURE/TEMPERATURE LIMITATION - REACTOR CRITICALITY	B 3/4 10-1
3/4.10.	4 PHYSICS TESTS	B 3/4 10-1
3/4.10.	5 CENTER CEA MISALIGNMENT	B 3/4 10-1
3/4.11	RADIOACTIVE EFFLUENTS	
3/4.11.	I LIQUID EFFLUENTS	B 2/4 13 3
3/4.11.	2 GASEOUS EFFLUENTS	D 3/4 11-1
3/4.11.	3 TOTAL DOSE	D 3/4 11-2
		0 3/4 11-4
ILLSTON	E - UNIT 2 XIV Amendment No. \$9,194,189,	117

PLANT SYSTEMS

3/4.7-11 ULTIMATE HEAT SINK

LIMITING CONDITION FOR OPERATION

3.7.11 The ultimate heat sink shall be OPERABLE with an average water temperature of less than or equal to 75°F at the Unit 2 intake structure.

APPLICABILITY: MODES 1, 2, 3, AND 4

ACTION:

With the requirements of the above specification not satisfied, be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

- 4.7.11 The ultimate heat sink shall be determined OPERABLE:
 - a. At least once per 24 hours by verifying the average water temperature at the Unit 2 intake structure to be within limits.
 - b. At least once per 6 hours by verifying the average water temperature at the Unit 2 intake structure to be within limits when the average water temperature exceeds 70°F.

PLANT SYSTEMS

BASES

suppression system consists of the water system, spray and/or sprinklers and fire hose stations. The collective capability of the fire suppression systems is adequate to minimize potential damage to safety related equipment and is a major element in the facility fire protection program.

In the event that portions of the fire suppression systems are inoperable, alternate backup fire fighting equipment is required to be made available in the affected areas until the inoperable equipment is restored to service.

In the event the fire suppression water system becomes inoperable, immediate corrective measures must be taken since this system provides the major fire suppression capability of the plant. The requirement for a twenty-four hour report to the Commission provides for prompt evaluation of the acceptability of the corrective measures to provide adequate fire suppression capability for the continued protection of the nuclear plant.

3.4.7.10 PENETRATION FIRE BARRIERS

The functional integrity of the penetration fire barriers ensures that fires will be confined or adequately retarded from spreading to adjacent portions of the facility. This design feature minimizes the possibility of a single fire rapidly involving several areas of the facility prior to detection and extinguishment. The penetration fire barriers are a passive element in the facility fire protection program and are subject to periodic inspections.

During period of time when a barrier is not functional, alternate measures are taken to prevent the possible spread of fire. These measures include verifying the operability of fire detection or suppression systems on <u>both</u> sides of the affected barrier and establishing a fire watch patrol, or posting a continuous fire watch in the vicinity of the affected barrier, or installation of a temporary fire stop pending restoration of the permanent seal.

3/4.7.11 ULTIMATE HEAT SINK

The limitations on the ultimate heat sink temperature ensure that sufficient cooling capacity is available to either,

1) provide normal cooldown of the facility, or 2) to mitigate the effects of accident conditions within acceptable limits.

The limitations on maximum temperature are based on a 30-day cooling water supply to safety related equipment without exceeding their design basis temperature.



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 145

TO FACILITY OPERATING LICENSE NO. DPR-65

NORTHEAST NUCLEAR ENERGY COMPANY, ET AL.

MILLSTONE NUCLEAR POWER STATION, UNIT. NO. 2

DOCKET NO. 50-336

1.0 INTRODUCTION

By application for license amendment dated March 21, 1990, Northeast Nuclear Energy Company (the licensee) requested changes to the Technical Specifications (TS) for Millstone Nuclear Power Station, Unit 2. The proposed change would add a new requirement on the ultimate heat sink for the reactor and containment cooling system by specifying an average water temperature of less than or equal to 75 degrees F at the intake structure except when Millstone 2 is in cold shutdown or in the refueling condition.

2.0 EVALUATION

The ultimate heat sink (Long Island Sound) provides the cooling water necessary to ensure the cooling capacity to provide for the removal of the normal heat loads and normal cooldown loads and to mitigate the effects of accidents within acceptable limits. By placing a limit on the maximum temperature of the ultimate heat sink for plant operation, the licensee will assure that sufficient heat removal capacity is available. The intake structure draws water from the ultimate heat sink for circulation by the service water system. The service water system provides cooling for the Reactor Building Component Cooling Water (RBCCW) System heat exchangers. The Final Safety Analysis Report states that the RBCCW system heat exchangers are cooled by service water up to a maximum temperature of 75 degrees F. Therefore, by adding this new requirement to the TS the licensee will ensure that the design basis for the ultimate heat sink is not violated. The staff finds the proposed change, an additional restriction not presently in the TS, to be acceptable.

3.0 ENVIRONMENTAL CONSIDERATION

This amendment changes a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes surveillance requirements. We have determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. the staff has previously published a proposed finding that the amendment involves

9006260254 900612 PDR ADOCK 05000336 P PDC PDC no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

4.0 CONCLUSION

We have concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or the health and safety of the public.

Dated: June 12, 1990

Principal Contributor: G. Vissing