

December 8, 1986

MEMORANDUM FOR: Sholly Coordinator  
FROM: Ashok C. Thadani, Director  
PWR Project Directorate #8  
Division of PWR Licensing-B  
SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE - NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

Distribution  
Docket File PKreutzer  
NRC/Local PDR DJaffe  
Sholly File  
OGC-Beth

Northeast Nuclear Energy Company, et al., Docket No. 50-336, Millstone  
Nuclear Power Station Unit No. 2, Town of Waterford, Connecticut

Date of applications for amendment: October 20, October 24 and October 27,  
1986.

Brief description of amendment: This amendment modified the Technical Specifications (TS) for Millstone Unit No. 2. The proposed changes to the TS provide for: (1) revised temperature/pressure limits in TS 3.4.4.9, "Pressure/Temperature Limits" and TS Figure 3.4-2, "Reactor Coolant System Pressure Temperature Limitations for 12 Full Power Years," (2) a change to the surveillance frequency for determining reactor coolant system (RCS) flow rate in TS 4.2.6, "DNB Margin," and (3) changes to several TS associated with RCS flow and reactor power peaking limits.

Date of issuance: December 8, 1986

Effective date: December 8, 1986

Amendment No.: 113

Facility Operating License No. DPR-65. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: November 4, 1986 (51 FR 40096)

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated

8612110188 861208  
PDR ADDCK 05000336  
P PDR

No significant hazards consideration comments received: No.

Local Public Document Room location: Waterford Public Library, Rope Ferry  
Road, Waterford, Connecticut.

D. H. Jaffe signed for

Ashok C. Thadani, Director  
PWR Project Directorate #8  
Division of PWR Licensing-B

PBD-8:  
PK  
12/2/86

PBD-8:  
DJaffe:jch  
12/2/86

OGC  
Baehmann  
12/3/86

AT  
PBD-8:  
AThadani  
12/8/86

12/3/86