

**Dave Morey**  
Vice President  
Farley Project

**Southern Nuclear  
Operating Company, Inc.**  
Post Office Box 1295  
Birmingham, Alabama 35201  
Tel 205.992.5131



*Energy to Serve Your World<sup>SM</sup>*

October 9, 2001

Docket No. 50-364

NEL-01-0252

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555 - 0001

**Supplemental Response to Bulletin 2001-01**  
**Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles**

Ladies and Gentlemen:

On October 5, 2001, a telephone call was held between Senior Management of Farley Nuclear Plant (FNP) and Senior Management from the office of Nuclear Reactor Regulation (NRR) concerning the FNP response to NRC Bulletin 2001-01, "Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles." As a result of this telephone call, FNP is supplementing its Bulletin 2001-01 response with the following clarification. For Unit 2, FNP will perform either an effective remote visual inspection of the metal surface of the 69 CRDM nozzles and head vent nozzle at the next scheduled refueling outage beginning in September 2002 or the inspections described in our Bulletin 2001-01 response letter dated August 31, 2001.

This letter contains a NRC commitment for future head inspection as specified above. Should you have any questions, please advise.

Respectfully submitted,

A handwritten signature in black ink that reads "Dave Morey". The signature is written in a cursive, flowing style.

Dave Morey

MJA/kaw: rspnbul2001.01.doc

Aoss

Page 2  
U. S. Nuclear Regulatory Commission

cc:

Southern Nuclear Operating Company  
Mr. L. M. Stinson, General Manager - Farley

U. S. Nuclear Regulatory Commission, Washington, D. C.  
Mr. F. Rinaldi, Licensing Project Manager - Farley

U. S. Nuclear Regulatory Commission, Region II  
Mr. L. A. Reyes, Regional Administrator  
Mr. T. P. Johnson, Senior Resident Inspector – Farley