

## UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

## TXU ELECTRIC COMPANY

## DOCKET NO. 50-445

## COMANCHE PEAK STEAM ELECTRIC STATION, UNIT NO. 1

## FACILITY OPERATING LICENSE

License No. NPF-87

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for a license filed by TXU Electric Company (TXU Electric) (licensee), complies with the standards and requirements of the Atomic Energy | Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I, and all required notifications to other agencies or bodies have been duly made;
  - B. Construction of the Comanche Peak Steam Electric Station, Unit No. 1 (the facility), has been substantially completed in conformity with Construction Permit No. CPPR-126 and the application, as amended, the provisions of the Act, and the regulations of the Commission;
  - C. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission (except as exempted from compliance in Section 2.D below);
  - D. There is reasonable assurance: (i) that the activities authorized by this operating license can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I, except as exempted from compliance in Section 2.D below;

I

Amendment No. 68, 89

- E. TXU Electric is technically qualified to engage in the activities authorized by this operating license in accordance with the Commission's regulations set forth in 10 CFR Chapter I;
- F. The licensee has satisfied the applicable provisions of 10 CFR 140, "Financial Protection Requirements and Indemnity Agreements," of the Commission's regulations;
- G. The issuance of this license will not be inimical to the common defense and security or to the health and safety of the public;
- H. After weighing the environmental, economic, technical, and other benefits of the facility against environmental and other costs and considering available alternatives, the issuance of Facility Operating License No. NPF-87 subject to the conditions for protection of the environment set forth herein, is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied; and
- I. The receipt, possession, and use of source, byproduct, and special nuclear material as authorized by this license will be in accordance with the Commission's regulations in 10 CFR Parts 30, 40, and 70, except that an exemption to the provisions of 70.24 is granted as described in paragraph 2.D below.
- 2. Based on the foregoing findings regarding this facility, Facility Operating License No. NPF-87 is hereby issued to the licensee, to read as follows:
  - A. This license applies to the Comanche Peak Steam Electric Station, Unit No. 1, a pressurized-water nuclear reactor and associated equipment (the facility), owned by the licensee. The facility is located on Squaw Creek Reservoir in Somervell County, Texas about 5 miles north-northwest of Glen Rose, Texas, and about 40 miles southwest of Fort Worth in north-central Texas and is described in the licensee's Final Safety Analysis Report, as supplemented and amended, and the licensee's Environmental Report, as supplemented and amended.
  - B. Subject to the conditions and requirements incorporated herein, the Commission hereby licenses:
    - (1) Pursuant to Section 103 of the Act and 10 CFR Part 50, "Domestic Licensing and Production and Utilization Facilities," TXU Electric to possess, use, and operate the facility at the designated location in Somervell County, Texas in accordance with the procedures and limitations set forth in this license;
    - (2) NOT USED

Amendment No. 68, 89

1

I

1

1

- (3) TXU Electric, pursuant to the Act and 10 CFR Part 70, to receive, possess and use at any time, special nuclear material as reactor fuel, in accordance with the limitations for storage and amounts required for reactor operation, and described in the Final Safety Analysis Report, as supplemented and amended;
- (4) TXU Electric, pursuant to the Act and 10 CFR Parts 30, 40 and 70, to receive, possess, and use, at any time, any byproduct, source, and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
- (5) TXU Electric, pursuant to the Act and 10 CFR Parts 30, 40 and 70, to receive, possess, and use in amounts as required, any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
- (6) TXU Electric, pursuant to the Act and 10 CFR Parts 30, 40 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.
- C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:
  - (1) <u>Maximum Power Level</u>

TXU Electric is authorized to operate the facility at reactor core power levels not in excess of 3458 megawatts thermal in accordance with the conditions specified herein.

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 89, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into this license. TXU Electric shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

(3) <u>Antitrust Conditions</u>

Applicants as defined in Appendix C shall comply with the antitrust conditions delineated in Appendix C to this license; Appendix C is hereby incorporated into this license.

Amendment No. 68, 89

ł.

I

- I. The licensee shall have and maintain financial protection of such type and in such amounts as the Commission shall require in accordance with Section 170 of the Atomic Energy Act of 1954, as amended, to cover public liability claims.
- J. NOT USED
- K. This license is effective as of the date of issuance and shall expire at Midnight on February 8, 2030.

FOR THE NUCLEAR REGULATORY COMMISSION

original signed by:

Thomas E. Murley, Director Office of Nuclear Reactor Regulation

Attachments/Appendices:

- 1. Appendix A Technical Specifications (NUREG-1399)
- 2. Appendix B Environmental Protection Plan
- 3. Appendix C Antitrust Conditions

Date of Issuance: April 17, 1990

Т



# UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

## TXU ELECTRIC COMPANY

## DOCKET NO. 50-446

#### COMANCHE PEAK STEAM ELECTRIC STATION, UNIT NO. 2

## FACILITY OPERATING LICENSE

License No. NPF-89

1

ł

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for a license filed by TXU Electric Company (TXU Electric) (licensee), complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I, and all required notifications to other agencies or bodies have been duly made;
  - B. Construction of the Comanche Peak Steam Electric Station, Unit No. 2 (the facility), has been substantially completed in conformity with Construction Permit No. CPPR-127 and the application, as amended, the provisions of the Act, and the regulations of the Commission;
  - C. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission (except as exempted from compliance in Section 2.D below);
  - D. There is reasonable assurance: (i) that the activities authorized by this operating license can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I, except as exempted from compliance in Section 2.D. below;
  - E. TXU Electric is technically qualified to engage in the activities authorized by this operating license in accordance with the Commission's regulations set forth in 10 CFR Chapter I;

Amendment No. 68, 89

- F. The licensee has satisfied the applicable provisions of 10 CFR 140, "Financial Protection Requirements and Indemnity Agreements," of the Commission's regulations;
- G. The issuance of this license will not be inimical to the common defense and security or to the health and safety of the public;
- H. After weighing the environmental, economic, technical, and other benefits of the facility against environmental and other costs and considering available alternatives, the issuance of Facility Operating License No. NPF-89 subject to the conditions for protection of the environment set forth herein, is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied; and
- 1. The receipt, possession, and use of source, byproduct, and special nuclear material as authorized by this license will be in accordance with the Commission's regulations in 10 CFR Parts 30, 40, and 70, except that an exemption to the provisions of 70.24 is granted as described in paragraph 2.D below.
- 2. Pursuant to approval by the Nuclear Regulatory Commission at a meeting on April 6, 1993, the License for Fuel Loading and Low Power Testing, License No. NPF-88, issued on February 2, 1993, is superseded by Facility Operating License No. NPF-89 hereby issued to the licensee, to read as follows:
  - A. This license applies to the Comanche Peak Steam Electric Station, Unit No. 2, a pressurized-water nuclear reactor and associated equipment (the facility), owned by the licensee. The facility is located on Squaw Creek Reservoir in Somervell County, Texas about 5 miles north-northwest of Glen Rose, Texas, and about 40 miles southwest of Fort Worth in north-central Texas and is described in the licensee's Final Safety Analysis Report, as supplemented and amended, and the licensee's Environmental Report, as supplemented and amended.
  - B. Subject to the conditions and requirements incorporated herein, the Commission hereby licenses:
    - (1) Pursuant to Section 103 of the Act and 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities," TXU Electric to possess, use, and operate the facility at the designated location in Somervell County, Texas in accordance with the procedures and limitations set forth in this license;
    - (2) NOT USED

I

L

- (3) TXU Electric, pursuant to the Act and 10 CFR Part 70, to receive, possess and use at any time, special nuclear material as reactor fuel, in accordance with the limitations for storage and amounts required for reactor operation, and described in the Final Safety Analysis Report, as supplemented and amended;
- (4) TXU Electric, pursuant to the Act and 10 CFR Parts 30, 40 and 70, to receive, possess, and use, at any time, any byproduct, source, and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
- (5) TXU Electric, pursuant to the Act and 10 CFR Parts 30, 40 and 70, to receive, possess, and use in amounts as required, any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
- (6) TXU Electric, pursuant to the Act and 10 CFR Parts 30, 40 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.
- C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:
  - (1) Maximum Power Level

TXU Electric is authorized to operate the facility at reactor core power levels not in excess of 3458 megawatts thermal in accordance with the conditions specified herein.

(2) <u>Technical Specifications and Environmental Protection Plan</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No.89, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into this license. TXU Electric shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

(3) Antitrust Conditions

Applicants as defined in Appendix C shall comply with the antitrust conditions delineated in Appendix C to this license; Appendix C is hereby incorporated into this license.

I.

- (2) For the unowned subsurface mineral rights within the exclusion area not covered in item (1), TXU Electric will prohibit the exploration and/or exercise of mineral rights until and unless the licensee and the owners of the mineral rights enter into an agreement which gives TXU Electric absolute authority to determine all activities -- including times of arrival and locations of personnel and the authority to remove personnel and equipment -- in event of emergency. If the mineral rights owners attempt to exercise their rights within this area without first entering into such an agreement, TXU Electric must immediately institute immediately effective condemnation proceedings to obtain the mineral rights in this area.
- (3) TXU Electric shall promptly notify the NRC of any attempts by subsurface mineral rights owners to exercise mineral rights, including any legal proceeding initiated by mineral rights owners against TXU Electric.
- G. TXU Electric shall implement and maintain in effect all provisions of the approved fire protection program as described in the Final Safety Analysis Report through Amendment 87 and as approved in the SER (NUREG-0797) and its supplements through SSER 27, subject to the following provision:

TXU Electric may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

- H. TXU Electric shall fully implement and maintain in effect all provisions of the physical security, guard training and qualification, and safeguards contingency plans, previously approved by the Commission, and all amendments made pursuant to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The plans, which contain safeguards information protected under 10 CFR 73.21, are entitled: "Comanche Peak Steam Electric Station Physical Security Plan" with revisions submitted through August 30, 2000, with limited approvals as provided for in the Safety Evaluation by the Office of Nuclear Reactor Regulation dated December 5, 2000; "Comanche Peak Steam Electric Station Security Training and Qualification Plan" with revisions submitted through May 18, 2000; and "Comanche Peak Steam Electric Station Safeguards Contingency Plan" with revisions submitted through April 9, 1999.
- I. The licensee shall have and maintain financial protection of such type and in such amounts as the Commission shall require in accordance with Section 170 of the Atomic Energy Act of 1954, as amended, to cover public liability claims.

L

- J. NOT USED
- K. This license is effective as of the date of issuance and shall expire at Midnight on February 2, 2033.

#### FOR THE NUCLEAR REGULATORY COMMISSION

Thomas E. Murley, Director Office of Nuclear Reactor Regulation

Attachments/Appendices:

- 1. Appendix A Technical Specifications (NUREG-1468)
- Appendix B Environmental Protection Plan
  Appendix C Antitrust Conditions

Date of Issuance: April 6, 1993

Amendment No. 68, 89

I

## 1.1 Definitions (continued)

QUADRANT POWER TILT RATIO (QPTR)	QPTR shall be the ratio of the maximum upper excore detector calibrated output to the average of the upper excore detector calibrated outputs, or the ratio of the maximum lower excore detector calibrated output to the average of the lower excore detector calibrated outputs, whichever is greater.				
RATED THERMAL POWER (RTP)	RTP shall be a total reactor core heat transfer rate to the reactor coolant of 3458 Mwt.				
REACTOR TRIP SYSTEM (RTS) RESPONSE TIME	The RTS RESPONSE TIME shall be that time interval from when the monitored parameter exceeds its RTS trip setpoint at the channel sensor until loss of stationary gripper coil voltage. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured. In lieu of measurement, response time may be verified for selected components provided that the components and methodology for verification have been previously reviewed and approved by the NRC.				
SHUTDOWN MARGIN (SDM)	SDM shall be the instantaneous amount of reactivity by which the reactor is subcritical or would be subcritical from its present condition assuming:				
	a.	All rod cluster control assemblies (RCCAs) are fully inserted except for the single RCCA of highest reactivity worth, which is assumed to be fully withdrawn. With any RCCA not capable of being fully inserted, the reactivity worth of the RCCA must be accounted for in the determination of SDM; and			
	b.	In MODES 1 and 2, the fuel and moderator temperatures are changed to the hot zero power temperatures.			

(continued)

-						
	FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE <sup>(a)</sup>
1.	Manual Reactor Trip	1,2	2	В	SR 3.3.1.14	NA
		3(b), 4(b), 5(b)	2	С	SR 3.3.1.14	NA
2.	Power Range Neutron Flux					
	a. High	1.2	4	D	SR 3.3.1.1 SR 3.3.1.2 SR 3.3.1.7 SR 3.3.1.11 SR 3.3.1.16	≤ 110.8% RTP
	b. Low	1 <sup>(C)</sup> , 2	4	E	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11 SR 3.3.1.16	≤ 27.7% RTP
3.	Power Range Neutron Flux Rate High Positive Rate	1,2	4	E	SR 3.3.1.7 SR 3.3.1.11	≤ 6.3 % RTP with time constant ≥ 2 sec
4.	Intermediate Range Neutron Flux	1(c) <sub>, 2</sub> (d)	2	F,G	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	≤ 31.5% RTP
5.	Source Range Neutron Flux	2(e)	2	l,J	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	≤ 1.4 E5 cps
		3(b), 4(b), 5(b)	2	J,K	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.11	≤ 1.4 E5 cps

#### Table 3.3.1-1 (page 1 of 6) Reactor Trip System Instrumentation

(continued)

The Allowable Value defines the limiting safety system setting. See the Bases for the Trip Setpoints. With Rod Control System capable of rod withdrawal or one or more rods not fully inserted. Below the P-10 (Power Range Neutron Flux) interlock. Above the P-6 (Intermediate Range Neutron Flux) interlock. Below the P-6 (Intermediate Range Neutron Flux) interlock. (a) (b) (c) (d) (e)

# RTS Instrumentation 3.3.1

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE <sup>(a)</sup>
6. Overtemperature N-16	1,2	4	E	SR 3.3.1.1 SR 3.3.1.2 SR 3.3.1.3 SR 3.3.1.6 SR 3.3.1.7 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.16	Refer to Note 1
7. Overpower N-16	1,2	4	E	SR 3.3.1.1 SR 3.3.1.2 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.16	≤ 112.9% RTP
8. Pressurizer					
a. Low	1 (g)	4	М	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.16	≥ 1863.6 psig (Unit 1) ≥ 1865.2 psig (Unit 2)
b. High	1,2	4	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.16	≤ 2400.8 psig (Unit 1) ≤ 2401.4 psig (Unit 2)
9. Pressurizer Water Level - High	1(g)	3	Μ	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	≤ 93.9% of instrument span

### Table 3.3.1-1 (page 2 of 6) Reactor Trip System Instrumentation

(continued)

I

(a) The Allowable Value defines the limiting safety system setting. See the Bases for the Trip Setpoints.(g) Above the P-7 (Low Power Reactor Trips Block) interlock.

#### 5.6 Reporting Requirements

#### 5.6.5 Core Operating Limits Report (COLR)

- a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:
  - 1) Moderator temperature coefficient limits for Specification 3.1.3,
  - 2) Shutdown Rod Insertion Limit for Specification 3.1.5,
  - 3) Control Rod Insertion Limits for Specification 3.1.6,
  - 4) AXIAL FLUX DIFFERENCE Limits and target band for Specification 3.2.3,
  - 5) Heat Flux Hot Channel Factor, K(Z), W(Z), F<sub>Q</sub><sup>RTP</sup>, and the F<sub>Q</sub><sup>C</sup>(Z) allowances for Specification 3.2.1,
  - 6) Nuclear Enthalpy Rise Hot Channel Factor Limit and the Power Factor Multiplier for Specification 3.2.2.
  - 7) SHUTDOWN MARGIN values in Specifications 3.1.1, 3.1.4, 3.1.5, 3.1.6 and 3.1.8.
  - 8) Refueling Boron Concentration limits in Specification 3.9.1.
  - 9) Overtemperature N-16 Trip Setpoint in Specification 3.3.1.
  - 10) Reactor Coolant System pressure, temperature, and flow in Specification 3.4.1.

11) Reactor Core Safety Limits (Safety Limit 2.1.1)

b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC. When an initial assumed power level of 102 percent of rated power is specified in a previously approved method, 100.6 percent of rated power may be used only when feedwater flow measurement (used as input for reactor thermal power measurement) is provided by the leading edge flowmeter (LEFM√) as described in document number 20 listed below. When feedwater flow measurements from the LEFM√ are not available, the originally approved initial power level of 102 percent of rated thermal power shall be used.

Future revisions of approved analytical methods listed in this technical specification that currently assume 102 percent of rated power shall include the condition given above

(continued)

L

I

I

T

#### 5.6 Reporting Requirements

#### 5.6.5 <u>Core Operating Limits Report (COLR)</u> (continued)

allowing use of 100.6 percent of rated power in safety analysis methodology when the LEFM is used for feedwater flow measurement.

The approved analytical methods are described in the following documents:

- 1) WCAP-9272-P-A, "WESTINGHOUSE RELOAD SAFETY EVALUATION METHODOLOGY," July 1985 (W Proprietary).
- 2) WCAP-8385, "POWER DISTRIBUTION CONTROL AND LOAD FOLLOWING PROCEDURES TOPICAL REPORT," September 1974 (W Proprietary).
- T. M. Anderson To K. Kniel (Chief of Core Performance Branch, NRC) January 31, 1980--Attachment: Operation and Safety Analysis Aspects of an Improved Load Follow Package.
- 4) NUREG-0800, Standard Review Plan, U.S. Nuclear Regulatory Commission, Section 4.3, Nuclear Design, July 1981. Branch Technical Position CPB 4.3-1, Westinghouse Constant Axial Offset Control (CAOC), Rev. 2, July 1981.
- WCAP-10216-P-A, Revision 1A, "RELAXATION OF CONSTANT AXIAL OFFSET CONTROL F<sub>a</sub> SURVEILLANCE TECHNICAL SPECIFICATION," February 1994 (<u>W</u> Proprietary).
- 6) WCAP-10079-P-A, "NOTRUMP, A NODAL TRANSIENT SMALL BREAK AND GENERAL NETWORK CODE," August 1985, (W Proprietary).
- 7) WCAP-10054-P-A, "WESTINGHOUSE SMALL BREAK ECCS EVALUATION MODEL USING THE NOTRUMP CODE", August 1985, (<u>W</u> Proprietary).
- 8) WCAP-11145-P-A, "WESTINGHOUSE SMALL BREAK LOCA ECCS EVALUATION MODEL GENERIC STUDY WITH THE NOTRUMP CODE", October 1986, (W Proprietary).
- RXE-90-006-P-A, "Power Distribution Control Analysis and Overtemperature N-16 and Overpower N-16 Trip Setpoint Methodology," June 1994.

(continued)

#### 5.6 Reporting Requirements

#### 5.6.5 Core Operating Limits Report (COLR) (continued)

- 10) RXE-88-102-P-A, "TUE-1 Departure from Nucleate Boiling Correlation", July 1992.
- 11) RXE-88-102-P, Sup. 1, "TUE-1 DNB Correlation Supplement 1", December 1990.
- 12) RXE-89-002-A, "VIPRE-01 Core Thermal-Hydraulic Analysis Methods for Comanche Peak Steam Electric Station Licensing Applications", September 1993.
- 13) RXE-91-001-A, "Transient Analysis Methods for Comanche Peak Steam Electric Station Licensing Applications", October 1993.
- 14) RXE-91-002-A, "Reactivity Anomaly Events Methodology", October 1993.
- 15) ERX-2000-002-P, "Revised Large Break Loss of Coolant Accident Analysis Methodology," March 2000.
- 16) TXX-88306, "Steam Generator Tube Rupture Analysis", March 15, 1988.
- 17) RXE-91-005-A, "Methodology for Reactor Core Response to Steamline Break Events," February 1994.
- 18) RXE-94-001-A, "Safety Analysis of Postulated Inadvertent Boron Dilution Event in Modes 3,4, and 5," February 1994.
- 19) RXE-95-001-P-A, "Small Break Loss of Coolant Accident Analysis Methodology," September 1996.
- 20) Caldon, Inc. Engineering Report-80P, "Improving Thermal Power Accuracy and Plant Safety While Increasing Operating Power Level Using the LEFM√ System," Revision 0, March 1997 and Caldon Engineering Report - 160P, "Supplement to Topical Report ER-80P: Basis for a Power Uprate With the LEFM√<sup>tm</sup> System," Revision 0, May 2000.
- c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal mechanical limits, core thermal hydraulic limits, Emergency Core Cooling Systems (ECCS) limits, nuclear limits such as SDM, transient analysis limits, and accident analysis limits) of the safety analysis are met.
- d. The COLR, including any midcycle revisions or supplements, shall be provided upon issuance for each reload cycle to the NRC.

(continued)