



**North
Atlantic**

North Atlantic Energy Service Corporation
P.O. Box 300
Seabrook, NH 03874
(603) 474-9521

The Northeast Utilities System

October 9, 2001
Docket No. 50-443
NYN-01084
CR 01-00098-09

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

Seabrook Station
September 2001 Monthly Operating Report

Enclosed please find Monthly Operating Report 01-09. This report addresses the operating and shutdown experience relating to Seabrook Station Unit 1 for the month of September, 2001 and is submitted in accordance with the requirements of Seabrook Station Technical Specification 6.8.1.5.

Should you require further information regarding this matter, please contact Mr. James M. Peschel, Manager - Regulatory Programs, at (603) 773-7194.

Very truly yours,

NORTH ATLANTIC ENERGY SERVICE CORP.

Gene F. St. Pierre
Station Director

cc:

H. J. Miller, NRC Region I Administrator
G. F. Wunder, NRC Project Manager, Project Directorate 1-2
G.T. Dentel, NRC Senior Resident Inspector

IE24

OPERATING DATA REPORT

DOCKET NO. 50-443
UNIT Seabrook 1
DATE October 1, 2001
COMPLETED BY P.E. Nardone
TELEPHONE (603) 773-7074

<u>OPERATING STATUS</u>				
1.	Unit Name:	Seabrook Station Unit 1		
2.	Reporting Period:	SEPTEMBER 2001		
3.	Licensed Thermal Power (MWt):	3411.0		
4.	Design Electrical Rating (Net MWe):	1148.0		
5.	Maximum Dependable Capacity (Net MWe):	1155.3		
6.	If Changes Occur in Capacity Ratings (Items Number 3 through 5) Since Last Report, Give Reasons:	Not Applicable		
		This Month	Yr-to-Date	Cumulative
7.	Number of Hours Reactor Was Critical	720.0	5701.4	84395.9
8.	Hours Generator On-Line	720.0	5606.7	81610.9
9.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
10.	Net Electrical Energy Generated (MWH)	834856	6305131	91498423

OPERATING SUMMARY

The unit operated at 100% Rated Thermal Power (RTP) for the entire month. This yielded an availability factor of 100% and a capacity factor of 100.37% based on the Maximum Dependable Capacity (MDC) value of 1155.3 Net MWe.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-443
 UNIT Seabrook 1
 DATE October 1, 2001
 COMPLETED BY P.E. Nardone
 TELEPHONE (603) 773-7074

MONTH: SEPTEMBER 2001

NO.	DATE	TYPE ¹	DURATION (HOURS)	REASON ²	METHOD OF SHUTTING DOWN REACTOR ³	CAUSE / CORRECTIVE ACTIONS COMMENTS
						No entries for this month
¹ F: Forced S: Scheduled		² Reason: A - Equipment Failure (Explain) B - Maintenance or Test C - Refueling D - Regulatory Restriction E - Operator Training / License Examination F - Administrative G - Operational Error (Explain) H - Other (Explain)			³ Method: 1 - Manual 2 - Manual Trip 3 - Automatic Trip 4 - Continued from previous month 5 - Other (Explain)	