

35A

SECY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DOCKETED
RELATED CORRESPONDENCE

AUG 24 1984

'84 SEP 17 P2:38

Docket No. 50-336 *OL*

Mr. W. G. Council, Senior Vice President
Nuclear Engineering and Operations
Northeast Nuclear Energy Company
P. O. Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Council:

The Commission has issued the enclosed Amendment No. 97 to Facility Operating License No. DPR-65 for Millstone Nuclear Power Station, Unit 2, in response to your application dated October 12, 1983 as supplemented May 16, 1984.

This amendment changes the Technical Specifications to:

- Revise the pressurizer level band to a wider range during periods of normal operation, and
- Impose more restrictive operability requirements for the pressurizer heaters.

A copy of our Safety Evaluation is enclosed. The notice of issuance will be included in the Commission's next monthly Federal Register notice.

Sincerely,

D. B. Osborne

D. B. Osborne, Project Manager
Operating Reactors Branch #3
Division of Licensing

Enclosures:

1. Amendment No. 97 to DPR-65
2. Safety Evaluation

8502200229 840824
PDR ADOCK 05000336
P PDR