Robert G. Byram Senior Vice President and Chief Nuclear Officer PPL Susquehanna, LLC Two North Ninth Street Allentown, PA 18101-1179 Tel. 610.774.7502 Fax 610.774.6092 rgbyram@pplweb.com



OCT 1 1 2001

U. S. Nuclear Regulatory Commission Attn.: Document Control Desk Mail Stop OP1-17 Washington, D. C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION REVISION NOS. 18 FOR UNIT 1 AND 15 FOR UNIT 2 TO THE INSERVICE INSPECTION PROGRAM PLAN FOR PUMP AND VALVE OPERATIONAL TESTING PLA-5351

Docket Nos. 50-387 and 50-388

In accordance with ASME Boiler and pressure Vessel Code Section XI, paragraph IWA-1400, attached for your review and concurrence are Revisions 18 and 14 to the Inservice Inspection Program for Pump and Valve Operational testing for Susquehanna Units 1 and 2. The following is a summary of the changes in these revisions:

PAGE	DESCRIPTION OF REVISION
LEP-1 thru LEP-10	Corrected the date of revision for various revision references
1VT-5	Added Biocide Injection System check valves 011193A/B
1VT-9	Added Biocide Injection System check valves 012807A/B
1VT-67, 1VT-68	Corrected Safety Position for valves HV149F059, HV149F062 and HV149F084 from O/C to C. Only the Closed safety position is applicable.
1VT-87, 1VT-88	Corrected Relief Request reference number for 152F036A,B,C,D
1VT-98	Corrected Safety Position for valves HV155F066, HV155F075 and HV155F079 from O/C to C. Only the Closed safety position is applicable.
1VT-120	Corrected Tests Required for TV08612B to indicate that Stroke Time (ST) testing is required.

PAGE	DESCRIPTION OF REVISION
1RJ17-1, 1RJ17-2	Corrected first paragraph of Basis for Deferment, which was typed incorrectly in the previous revision. Page 1RJ17-2 had no changes.
1RJ20-1, 1RJ20-2	Refuel Outage Test Justification was withdrawn. Scope of this testing is now included in Relief Request #23, which was previously approved on 4/11/2001 via NRC TAC NOS. MB0424 and MB0428. Page 1RJ20-2 was deleted.
1RR06-1, 1RR06-2, 1RR06-3	Revised Class designation for CRD valves 147114-001 through 147114-185, 147115-001 through 147115-185 and 147138-001 through 147138-185 from Class 2 to Class S (Non-Code). Pages 1RR06-2, and 1RR06-3 had no changes.
1RR23-1 thru 1RR23-7	Relief Request was previously approved on 4/11/2001 via NRC TAC NOS. MB0424 and MB0428.
2VT-20	Corrected ASME Class designation for 241F029A,B,C,D
2VT-52	Added footnote, which was inadvertently deleted in the previous revision.
2VT-57, 2VT-58	Corrected Safety Position for valves HV249F059, HV249F062 and HV249F084 from O/C to C. Only the Closed safety position was applicable.
2VT-88	Corrected Safety Position for valves HV255F066, HV255F075 and HV255F079 from O/C to C. Only the Closed safety position was applicable.
2RJ20-1	Refuel Outage Test Justification was withdrawn. Scope of this testing is now included in Relief Request #23, which was previously approved on 4/11/2001 via NRC TAC NOS. MB0424 and MB0428.
2RR06-1, 2RR06-2, 2RR06-3	Revised Class designation for CRD valves 247114-001 through 247114-185, 247115-001 through 247115-185 and 247138-001 through 247138-185 from Class 2 to Class S (Non-Code). Pages 2RR06-2, and 2RR06-3 had no changes.
2RR23-1 thru 2RR23-6	Relief Request was previously approved on 4/11/2001 via NRC TAC NOS. MB0424 and MB0428.

If you have any questions, please contact Mr. C. T. Coddington at (610) 774-4019.

Very truly yours, Robert G. Byram

Attachment

copy: NRC Region I Mr. S. L. Hansell, NRC Sr. Resident Inspector Mr. R. G. Schaaf, NRC Project Manager

SUSQUEHANNA STEAM ELECTRIC STATION

UNIT 1

INSERVICE INSPECTION PROGRAM PLAN

FOR

PUMP AND VALVE OPERATIONAL TESTING

Rev.	Description	Prepared by:	Approved by:	Date
8	Responses to NRC Comments	Signatures on File		
9	Addition of Water Level Backfill Valves	Signatures on File		
10	10 Year ASME Code Update	Signatures on File		
11	Corrections to Valve Tables	Signatures on File		
12	Addition of Fuel Pool Cooling Valves	Signatures on File		
13	Responses to NRC Comments and Additional Changes	Signatures on File		
14	Response to NRC Comments on RR#23 Excess Flow Check Valves	Signatures on File		
15	Response to NRC Comments on ROJ-21 FPC Manual Valves	Signatures on File		
16	Miscellaneous Changes	Signatures on File		
17	Incorporate Improved Tech Spec/TRM and Miscellaneous Changes	Signatures on File		
18	Incorporate Revision to RR23 Excess Check Valves and Miscellaneous Changes	Becky Mattern	Ja Bingunte	7/27/01

SUSQUEHANNA STEAM ELECTRIC STATION UNIT 1 PUMP AND VALVE INSERVICE INSPECTION TESTING PROGRAM

TABLE OF CONTENTS			
	Revision	Dated	
TITLE:			
Page 1T-1	17	06/99	
DESCRIPTION:			
Page 1D-1	17	06/99	
Page 1D-2	17	06/99	
Page 1D-3	17	06/99	
Page 1D-4	17	06/99	
Page 1D-5	17	06/99	
LEGENDS:			
Page 1LP-1	10	05/94	
Page 1LV-1	17	06/99	
Page 1LV-2	17	06/99	
Page 1LV-3	17	06/99	
PUMP TABLES:			
Page 1PT-1	10	05/94	
Page 1PT-2	13	03/96	
Page 1PT-3	10	05/94	
Page 1PT-4	10	05/94	
Page 1PT-5	17	06/99	
Page 1PT-6	13	03/96	

LEP-1

06/01

	Revision	Dated
VALVE TABLES:		
Page 1VT-1	10	05/94
Page 1VT-2a	16	02/98
Page IVT -2b	16	02/98
Page 1VT-3	13	03/96
Page 1VT-4	17	06/99
Page 1VT-5	18	06/01
Page 1VT-6	13	03/96
Page 1VT-7	13	03/96
Page 1VT-8	10	05/94
Page 1VT-9	18	06/01
Page 1VT-10	10	05/94
Page 1VT-11	11	12/94
Page 1VT-12	10	05/94
Page 1VT-13	10	05/94
Page 1VT-14	10	05/04
Page 1VT-15	10	05/94
Page 1VT-16	10	05/94
Page 1VT-17	10	05/94
Page 1VT-18	17	06/99
Page 1VT-19	16	02/98
Page 1VT-20	16	02/98
Page 1VT-21	16	02/98
Page 1VT-22	13	03/96
Page 1VT-23	10	05/94
Page 1VT-24	13	03/96

	Revision	Dated
Page 1VT-25	16	02/98
Page 1VT-26	16	02/98
Page 1VT-27	16	02/98
Page 1VT-28	16	02/98
Page 1VT-29	16	02/98
Page 1VT-30	10	05/94
Page 1VT-31	10	05/94
Page 1VT-32	10	05/94
Page 1VT-33	16	02/98
Page 1VT-34	13	03/96
Page 1VT-35	13	03/96
Page 1VT-36	16	02/98
Page 1VT-37	16	02/98
Page 1VT-38	16	02/98
Page 1VT-39	16	02/98
Page 1VT-40	13	03/96
Page 1VT-41	13	03/96
Page 1VT-42	13	03/96
Page 1VT-43	13	03/96
Page 1VT-44	10	05/94
Page 1VT-45	13	03/96
Page 1VT-46	10	05/94
Page 1VT-47	13	03/96
Page 1VT-48	13	03/96
Page 1VT-49	13	03/96
Page 1VT-50	13	03/96

	Revision	Dated
Page 1VT-51	16	02/98
Page 1VT-52	10	05/94
Page 1VT-53	13	03/96
Page 1VT-54	13	03/96
Page 1VT-55	13	03/96
Page 1VT-56	13	03/96
Page 1VT-57	13	03/96
Page 1VT-58	10	05/94
Page 1VT-59	13	03/96
Page 1VT-60	13	03/96
Page 1VT-61	13	03/96
Page 1VT-62	17	06/99
Page 1VT-63	10	05/94
Page 1VT-64	13	03/96
Page 1VT-65	10	05/94
Page 1VT-66	13	03/96
Page 1VT-67	18	06/01
Page 1VT-68	18	06/01
Page 1VT-69	13	03/96
Page 1VT-70	10	05/94
Page 1VT-71	10	05/94
Page 1VT-72	15	05/96
Page 1VT-73	13	03/96
Page 1VT-74	11	12/94
Page 1VT-75	11	12/94
Page 1VT-76	11	12/94

LEP-4

	Revision	Dated
Page 1VT-77	13	03/96
Page 1VT-78	16	02/98
Page 1VT-79	15	05/96
Page 1VT-80	13	03/96
Page 1VT-81	11	12/94
Page 1VT-82	11	12/94
Page 1VT-83	11	12/94
Page 1VT-84	13	03/96
Page 1VT-85	16	02/98
Page 1VT-86	15	05/96
Page 1VT-87	18	06/01
Page 1VT-88	18	06/01
Page 1VT-89	10	05/94
Page 1VT-90	13	03/96
Page 1VT-91	13	03/96
Page 1VT-92	10	05/94
Page 1VT-93	15	05/96
Page 1VT-94	13	03/96
Page 1VT-95	10	05/94
Page 1VT-96	10	05/94
Page 1VT-97	13	03/96
Page 1VT-98	18	06/01
Page 1VT-99	13	03/96
Page 1VT-100	10	05/94
Page 1VT-101	10	05/94
Page 1VT-102	13	03/96

LEP-5'

	Revision	Dated
Page 1VT-103	13	03/96
Page 1VT-104	13	03/96
Page 1VT-105	10	05/94
Page 1VT-106	16	02/98
Page 1VT-107	16	02/98
Page 1VT-108	16	02/98
Page 1VT-109	16	02/98
Page 1VT-110	16	02/98
Page 1VT-111	16	02/98
Page 1VT-112	16	02/98
Page 1VT-113	16	02/98
Page 1VT-114	16	02/98
Page 1VT-115	16	02/98
Page 1VT-116	13	03/96
Page 1VT-117	13	03/96
Page 1VT-118	13	03/96
Page 1VT-119	13	03/96
Page 1VT-120	18	06/01
Page 1VT-121	10	05/94
Page 1VT-122	10	05/94
Page 1VT-123	13	03/96
Page 1VT-124	13	03/96
Page 1VT-125	13	03/96
Page 1VT-126	13	03/96
Page 1VT-127	16	02/98
Page 1VT-128	16	02/98

	Revision	Dated	
Page 1VT-129	10	05/94	
COLD SHUTDOWN TEST JUSTIFICATIONS:			
Page 1CJT-1	10	05/94	
Page 1CJ01-1	10	05/94	
Page 1CJ02-1	10	05/94	
Page 1CJ03-1	17	06/99	
Page 1CJ04-1	16	02/98	
Page 1CJ05-1	16	02/98	
Page 1CJ06-1	13	03/96	
Page 1CJ07-1	17	06/99	
Page 1CJ08-1	13	03/96	
Page 1CJ09-1	13	03/96	
Page 1CJ10-1	13	03/96	
Page 1CJ11-1	10	05/94	
Page 1CJ12-1	17	06/99	
Page 1CJ13-1	10	05/94	
REFUELING OUTAGE TEST JUSTIFICA	TIONS:		
Page 1RJT-1	10	05/94	
Page 1RJ01-1	10	05/94	
Page 1RJ01-2	10	05/94	
Page 1RJ02-1	13	03/96	
Page 1RJ02-2	16	02/98	
Page 1RJ03-1	13	03/96	
Page 1RJ04-1	10	05/94	
Page 1RJ05-1	10	05/94	
Page 1RJ05-2	10	05/94	

~

	Revision	Dated
Page 1RJ06-1	17	06/99
Page 1RJ06-2	17	06/99
Page 1RJ07-1	10	05/94
Page 1RJ08-1	16	02/98
Page 1RJ09-1	10	05/94
Page 1RJ10-1	10	05/94
Page 1RJ11-1	17	06/99
Page 1RJ11-2	17	06/99
Page 1RJ12-1	17	06/99
Page 1RJ13-1	16	02/98
Page 1RJ14-1	. 16	02/98
Page 1RJ15-1	16	02/98
Page 1RJ16-1	16	02/98
Page 1RJ17-1	18	06/01
Page 1RJ17-2	18	06/01
Page 1RJ18-1	17	06/99
Page 1RJ18-2	17	06/99
Page 1RJ19-1	16	02/98
Page 1RJ20-1	18	06/01
Page 1RJ21-1	15	05/96
RELIEF REQUESTS:		
Page 1RRT-1	10	05/94
	10	00/00

Page 1RR01-1	16	02/98
Page 1RR02-1	16	02/98
Page 1RR03-1	17	06/99

•

	Revision	Dated
Page 1RR03-2	17	06/99
Page 1RR04-1	16	02/98
Page 1RR05-1	17	06/99
Page 1RR05-2	17	06/99
Page 1RR06-1	18	06/01
Page 1RR06-2	18	06/01
Page 1RR06-3	18	06/01
Page 1RR07-1	13	03/96
Page 1RR08-1	13	03/96
Page 1RR08-2	16	02/98
Page 1RR09-1	16	02/98
Page 1RR10-1	17	06/99
Page 1RR11-1	13	03/96
Page 1RR12-1	10	05/94
Page 1RR13-1	13	03/96
Page 1RR14-1	10	05/94
Page 1RR14-2	10	05/94
Page 1RR15-1	17	06/99
Page 1RR16-1	16	02/98
Page 1RR17-1	16	02/98
Page 1RR18-1	16	02/98
Page 1RR19-1	16	02/98
Page 1RR20-1	16	02/98
Page 1RR21-1	13	03/96
Page 1RR22-1	10	05/94
Page 1RR23-1	18	06/01

	Revision	Dated
Page 1RR23-2	18	06/01
Page 1RR23-3	18	06/01
Page 1RR23-4	18	06/01
Page 1RR23-5	18	06/01
Page 1RR23-6	18	06/01
Page 1RR23-7	18	06/01
Page 1RR24-1	16	02/98
Page 1RR24-2	16	02/98
Page 1RR25-1	13	03/96
Page 1RR25-2	16	02/98
Page 1RR26-1	16	02/98
Page 1RR27-1	16	02/98
Page 1RR28-1	16	02/98
Page 1RR29-1	16	02/98
Page 1RR30-1	13	03/96
Page 1RR31-1	13	03/96
Page 1RR32-1	13	03/96
Page 1RR33-1	15	05/96
Page 1RR33-2	15	05/96
Page 1RR33-3	15	05/96
Page 1RR34-1	16	02/98
Page 1RR34-2	16	02/98
Page 1RR34-3	16	02/98
Page 1RR34-4	16	02/98

06/01

|--|

Valve Number	P&ID Coordinates	ASME Class	ASME Category	Active/Passive	Valve Size (inches)	Valve Type	Actuator Type	Remote Position Indication	Safety Position	Tests Required	Tests Performed	Test Frequency	CS/RO Justification	Relief Request(s)	
011038	C-6	3	С	A	8	СК	SÁ		O/C	FS FS	PS FS	Q SD		RR02 RR02	
011039	C-8	3	С	A	8	СК	SA		0/C	FS FS	PS FS	Q SD		RR02 RR02	
011040	C-9	3	С	A	8	СК	SA		0/C	FS FS	PS FS	Q SD		RR02 RR02	
011193A	F-4	3	С	A	1	СК	SA		С	FS	FS	Q			
011193B	F-6	3	С	A	1	СК	SA		С	FS	FS	Q			
TV-01124A	C-2	3	В	A	3	GB	НО		0	FS FT	FS FT	Q Q			
TV-01124B	C-7	3	В	A	3	GB	НО		0	FS FT	FS FT	Q Q			
TV-01124C	C-5	3	В	A	3	GB	НО		0	FS FT	FS FT	Q Q			
TV-01124D	C-9	3	В	A	3	GB	НО		0	FS FT	FS FT	Q Q			

Rev. 18 06/01

							<u> </u>		
HV-112F073A	HV-11215B	HV-11215A	HV-11210B	HV-11210A	112003	112001	012807B	012807A	Valve
A-3	ې &	C-8	G-5	င ဗ	G-2	C-2	F-2	C-2	P&ID Coordinates
ω	ω	ω	ω	ω	ω	ω	ω	ы	ASME Class
σ	σ	B	B	B	ဂ	c	c	c	ASME Category
Þ	A	А	A	A	A	A	A	A	Active/Passive
o	20	20	20	20	20	20		-	Valve Size (inches)
GT	쀽	BF	망	BF	ÇĶ	CK	С <u>К</u>	СК	Valve Type
MO	MO	MO	MO	MO	SA	SA	SA	SA	Actuator Type
×	×	×	×	×	1	1	1	1	Remote Position Indication
ဂ	0	0	0	0	0/C	0/C	റ	C	Safety Position
PI ST ST	PI ST	PI ST PI	PI ST FS	PI FS	FS	FS	FS	FS	Tests Required
PI ST PI	PI FS	FS ST PI	FS PI	PI ST FS	PS	FS	FS	FS	Tests Performed
aaç	aay	20 X	aag	220 Yoo	۵	Q	a	۵	Test Frequency
		111	111		-	1	;	1	CS/RO Justification
111	111	111	1 1 1		I	ł	I	ı	Relief Request(s)

6-⊤√٢

Rev. 18

REACTOR CO	OREIS	OLA 10	DN CO	OLING	M-149 (Contin	ued)								
Valve	P&ID Coordinates	ASME Class	ASME Category	Active/Passive	Valve Size (inches)	Valve Type	Actuator Type	Remote Position Indication	Safety Position	Tests Required	Tests Performed	Test Frequency	CS/RO Justification	Relief Request(s)	
 HV-149F025	F-8	2	B	А	ح	GB	AO	×	0/C	FS ST PI	FS ST PI	27 Q Q	1 1 1	1	
 HV-149F026	G-8	2	Φ	A	-	GB	AO	×	O/C	FS PI FI	P ST PI	2700	111	111	
 HV-149F031	H-2	N	σ	A	0	GT	MO	×	0/C	PI ST	FS ST PI	aa¥ 1	1 1 1 1	1111	T. S. Approved Amendment #
 HV-149F059	G-3	N	>	Þ	10	GT	MO	×	C	L P ST FS	FS PI L	22200		1 1 1	

1			and the second s		
REACTOR CO	Valve	HV-149F060	HV-149F062	HV-149F084	HV-149F088
RE ISO	P&ID Coordinates	G-3	F-4	۲ نئ	င္ မ
	ASME Class	N	2	2	ب
	ASME Category	≻	Þ	₽	A
ING M-	Active/Passive	A	А	Þ	A
149 (C	Valve Size (inches)	2	2	N	-
ontinue	Valve Type	GB	GT	GT	GB
ď	Actuator Type	MO	MO	MO	AO
	Remote Position Indication	×	×	×	×
	Safety Position	0/c	C	C	0/C
	Tests Required	E P S FS	E P ST FS	E P ST FS	FS PI ST
	Tests Performed	L PH ST	E P ST ST	E P ST ST	E P ST FS
	Test Frequency	22200	27 27 27	22200	22200
	CS/RO Justification				1 1 1 1
	Relief Request(s)	1 1	1 1 1 1	1 1	1 1
	Remarks				Rapid acting valve.

89-TV1

Rev. 18

CORE SPRAY M-152 (Continued)

	P&ID Coordinates	ASME Class	ASME Category	Active/Passive	Valve Size (inches)	Valve Type	Actuator Type	Remote Position Indication	Safety Position	Tests Required	Tests Performed	Test Frequency	CS/RO Justification	Relief Request(s)	
152005	E-8	2	с	A	3	ск	SA		с	FS		0		RR08	Periodic inspection.
152F003A	E-5	2	с	A	12	ск	SA		0/C	FS	FS	Q			
152F003B	E-8	2	с	A	12	ск	SA		0/C	FS	FS_	Q			
152F003C	E-6	2	с	A	12	ск	SA		0/C	FS	FS	Q			
152F003D	E-9	2	с	A	12	ск	SA		O/C	FS	FS	Q			
152F029A	A-6	2	с	А	2	ск	SA		с	FS	FS	RF		RR24	Closure test only.
152F029B	A-6	2	с	A	2	СК	SA		с	FS	FS	RF		RR24	Closure test only.
152F030A	A-6	2	с	A	2	СК	SA		с	FS	FS	RF		RR24	Closure test only.
152F030B	A-5	2	с	А	2	ск	SA		с	FS	FS	RF		RR24	Closure test only.
152F036A	E-5	2	С	A	3	ск	SA		0	FS FS	PS FS	Q SD		 RR27	Open test only.
152F036B	E-8	2	С	A	3	СК	SA		0	FS FS	PS FS	Q SD		 RR27	Open test only.

HV-152F004A	HV-152F001B	HV-152F001A	152F036D	152F036C	Valve	CORE SPRAY M-
D 4	T T	H-3	E-9	ா	P&ID Coordinates	-152 (0
2	N	N	N	N	ASME Class	ontinue
σ	æ	B	0	C	ASME Category	d)
≻	Þ	A	A	A	Active/Passive	
12	16	16	ω	ω	Valve Size (inches)	
GT	GT	GT	ç	С <u></u>	Valve Type	
MO	MO	MO	SA	SA	Actuator Type	
×	×	×		1	Remote Position Indication	
0/C	ი	ი	0	0	Safety Position	
P ST FS	I PSFS	P ST	FS	FS	Tests Required	
PI ST	I P ST FS	- P ST FS	PS FS	FS PS	Tests Performed	
200 Y	aa¥1	aa⊻ ı	SDQ	S Q	Test Frequency	
1 1 1		1		1 1	CS/RO Justification	
1 1 1			 RR27	 RR27	Relief Request(s)	
	T. S. Approved Amendment #149.	T. S. Approved Amendment #149.	Open test only.	Open test only.		

88-TV1

Rev. 18 ٥٥/٥١

Rev. 18

ſ	1	1	T		1
HV-155F100	HV-155F079	HV-155F075 ,	HV-155F066	Valve	HIGH PRESSU
B-3	F-3	F-4	G-3	P&ID Coordinates	RE CC
<u>ــ</u>	2	N	N	ASME Class	OLAN
≻	⊳	≻	⊳	ASME Category	IT INJE
⊳	⊳	⊳	₽	Active/Passive	CTION
	ω	ယ	20	Valve Size (inches)	V M-15
GB	GT	GT	GT	Valve Type	5 (Conti
AO	MO	MO	MO	Actuator Type	nued)
×	×	×	×	Remote Position Indication	
O/C	C	C	C ·	Safety Position	
E P ST FS	FS ST PI	FS FS	FS ST FI	Tests Required	
FS FS	FS PI ST	FS ST PI	FS ST PI LJ	Tests Performed	
22 22 00	00 Y Y	22 PQ	22 P2	Test Frequency	
1 1 1 1	1 1 1 1	1 1 1 1		CS/RO Justification	
	1111	1	1 1 1 1	Relief Request(s)	
Rapid acting valve.					

Valve Number	P&ID Coordinates	ASME Class	ASME Category	Active/Passive	Valve Size (inches)	Valve Type	Actuator Type	Remote Position Indication	Safety Position	Tests Required	Tests Performed	Test Frequency	CS/RO Justification	Relief Request(s)	Remarks
TV-08612B	B-5	3	В	A	6	GT	МО		Т	FS ST	FS ST	Q Q			
TV-08643B	G-8	S	В	A	3	GT	МО		Т	FS ST	FS 	Q 			Modulating control valve. Non-code valve.
.TV-08652B	C-9	S	В	A	3	GT	мо		Т	FS ST	FS 	Q 			Modulating control valve. Non-code valve.
TV-08662B	A-9	S	В	A	3	GT	мо		Т	FS ST	FS 	Q 			Modulating control valve. Non-code valve.

CONTROL STRUCTURE CHILLED WATER M-186 Sheet 2 (Continued)

REFUELING OUTAGE TEST JUSTIFICATION NUMBER 17

,

System:	Control Structure Chilled Water and Emergency Service Water
P&ID:	M-186 and M-111
Valves:	086018 086118 111144 111145
Category:	С
Class:	3
Function:	Condenser and Chilled Water Flowpath
Impractical Test Requirement:	Exercise valves once per 92 days.
Basis for Deferment:	The ultimate function of these valves is providing chilled water to the cooling coils of the Control Structure HVAC system. Rather than individually testing each valve for proper functioning, operation of the chilled water loop with cooling supplied by the emergency condenser loop (cooled by ESW) provides a functional system test which is indicative of proper operation of all system components. As this is an auxiliary support system rather than a water-supply system, this testing provides more meaningful results than individual valve testing. Individual exercise testing of the check valves in these subsystems is not feasible. System interlocks require initiation and startup of circulating pumps and/or chiller, after which the valves automatically actuate.
	Check valves 086018 and 086118 are installed in the emergency condenser water circulating pump discharge line of each chiller. Check valves 111144 and 111145 are installed in the Emergency Service Water supply line to the emergency condenser of each chiller. Flow through each of these lines is controlled by a temperature control valve, whose internal geometry reduces flow through the line as cooling water temperature decreases below its straight-through full flow setpoint. Maximum required accident condition flow of 740 gpm through each line is normally achieved only once each 36 month period, during performance of Emergency Service Water System flow balancing, by defeating electrical control of each of the temperature control valves.

REFUELING OUTAGE TEST JUSTIFICATION NUMBER 17 (Cont'd.)

Alternative Testing:

As part of each quarterly chilled water flow verification test, monitor the chilled water loop chiller discharge temperature and verify that the specified discharge temperatures are maintained. In conjunction with this testing perform "partial" opening exercise tests of check valves 086018, 086118, 111144 and 111145. In conjunction with Emergency Service Water System Flow Balance Testing, conducted at least once each 36 month period, perform "full" opening exercise tests of check valves 086018, 086118, 111144 and 111145, with required maximum accident condition flow through 111144 and 111145 measured with the permanent installed flow rate instrument and the temperature control valve disabled in its non-recirculation position.

REFUELING OUTAGE TEST JUSTIFICATION NUMBER 20

REFUELING OUTAGE TEST JUSTIFICATION HAS BEEN WITHDRAWN

Class

Category

RELIEF REQUEST NUMBER 06

System:

Control Rod Drive

P&ID:

Valves

M-147

С	S
С	S
В	2
В	2
С	S
	C C B C

Function:

Control Rod Scram

Impractical Test Requirement:

Exercise valves once per 92 days and measure stroke times.

Basis for Relief:

These valves, located on the hydraulic control units for the 185 control rod drives, perform the active safety function of rapidly inserting the control rods into the reactor core, upon receipt of a reactor scram signal from the reactor protection system. Exercising these valves quarterly during power operations could result in the rapid insertion of one or more control rods more frequently than desired. Where testing could result in the rapid insertion of control rods, thereby causing rapid reactivity transients and wear of the control rod drive mechanisms, the control rod scram test frequency identified in the Plant Technical Specifications will be utilized as the valve testing frequency.

Normal control rod motion has been shown to be an indicator that the associated cooling water header check valve (147138 -001 through -185) moves to its safety position (closed). Normal control rod motion may not occur if this check valve were to fail in the open position. An additional positive test of the closure of this valve can be provided by venting of the cooling water header during Primary Containment Integrated Leakage Testing, conducted per TS 5.5.12.

Normal control rod motion does not serve as an indicator that any scram discharge header check valve (147114 -001 through -185) moves to its safety position (open), however. Since this check valve is moved to its open position only by scram exhaust flow, a positive test of the opening of the valve can only be provided by the periodic scram testing and control rod insertion timing specified by SR 3.1.3.4.

Verification that any charging water header check valve (147115 -001 through -185) moves to its safety position (closed), requires that the control rod drive pumps be stopped to depressurize the charging water header. This test cannot be performed during power operations because stopping the pumps would result in loss of cooling water to all control rod drive mechanisms and seal damage could result. This test cannot be performed during each cold shutdown because the control rod drive pumps supply seal water to the reactor recirculation pumps and one of the recirculation pumps might be kept running, thus continuing to need its seal water supply. The HCU accumulator pressure decay test, specified by TRS 3.1.4.3, provides verification of the closure of its charging water header check valve.

The scram inlet valves (XV-147126 -001 through -185) and the scram exhaust valves (XV-147127 -001 through -185) are air operated valves that full-stroke in milliseconds and are not equipped with position indication, thereby rendering measurement of their full-stroke times impractical. Verifying that the control rod associated with each pair of these valves meets the periodic scram testing rod insertion time limits, specified by SR 3.1.3.4, is an acceptable alternate method of detecting degradation of these valves. Since these measurements of control rod insertion times are subject to the conservative limitations of SR 3.1.4.1, 3.1.4.2, 3.1.4.3 and 3.1.4.4, and because these measurements cannot be meaningfully correlated with the full-stroke times of the scram inlet and exhaust valves, trending of these scrams time measurements in any manner comparable to that of valve stroke times is both impractical and unnecessary.

These bases for relief from applicable code testing requirements for these individual control rod scram valves are intended to conform to those provided as guidance by NRC Generic Letter 89-04 (Position #7).

- Alternative Testing: Proper functioning of the scram discharge header check valves (147114-XXX), of the scram inlet valves (XV-17126-XXX), and of the scram exhaust valves (XV-147127-XXX) will be verified by periodic scram testing and control rod insertion timing, with reactor pressure \geq 950 psig, conducted per SR 3.1.3.4 and SR's 3.1.4.1, 3.1.4.2, 3.1.4.3 and 3.1.4.4:
 - a) For all control rods prior to thermal power exceeding 40% of rated thermal power, following core alternations or after a reactor shutdown that is greater than 120 days.
 - b) For specifically affected individual control rods, following maintenance or modification to the control rod or control rod drive system, which could affect the scram insertion time of those specific control rods.
 - c) For a representative sample of the control rods, at least once per 120 days of power operation.
 - d) For specifically affected individual control rods, prior to thermal power exceeding 40% of rated thermal power, following maintenance or modification to the control rod or control rod drive system, which could affect the scram insertion time of those specific control rods.

Proper closure of the charging water header check valves (147115-XXX) will be verified by the demonstration that each individual accumulator check valve maintains its associated accumulator pressure above the alarm set point for ≥ 10 minutes, with no CRD pump operating, at least once per 24 months, conducted per TRS 3.1.4.3.

Proper closure of the cooling water header check valves (147138-XXX) will be verified by venting of the cooling water header during Primary Containment Integrated Leakage Testing, conducted per TS 5.5.12.

RELIEF REQUEST NUMBER 23

System	P&ID	Valve	System	P&ID	Valve
RPV	M-141	XV-141F009	RPV (cont'd)	M-142	XV-142F051B
Main Steam	M-141	XV-141F070A			XV-142F051C
		XV-141F070B			XV-142F051D
		XV-141F070C			XV-142F053A
		XV-141F070D			XV-142F053B
		XV-141F071A			XV-142F053C
		XV-141F071B			XV-142F053D
		XV-141F071C			XV-142F055
		XV-141F071D			XV-142F057
		XV-141F072A			XV-142F059A
		XV-141F072B			XV-142F059B
		XV-141F072C			XV-142F059C
· · · · · · · · · · · · · · · · · · ·		XV-141F072D			XV-142F059D
		XV-141F073A			XV-142F059E
		XV-141F073B			XV-142F059F
		XV-141F073C			XV-142F059G
		XV-141F073D			XV-142F059H
RPV	M-142	XV-14201			XV-142F059L
		XV-14202			XV-142F059M
		XV-142F041			XV-142F059N
		XV-142F043A			XV-142F059P
		XV-142F043B			XV-142F059R
		XV-142F045A			XV-142F059S
		XV-142F045B			XV-142F059T
		XV-142F047A			XV-142F059U
		XV-142F047B			XV-142F061
		XV-142F051A			

System	P&ID	Valve	System	P&ID	Valve
RXR	M-143	XV-143F003A	RWCU	M-144	XV-14411A
		XV-143F003B			XV-14411B
		XV-143F004A			XV-14411C
		XV-143F004B	·····		XV-14411D
		XV-143F009A			XV-144F046
		XV-143F009B	RCIC	M-149	XV-149F044A
		XV-143F009C			XV-149F044B
		XV-143F009D			XV-149F044C
		XV-143F010A			XV-149F044D
		XV-143F010B	HPCI	M-155	XV-155F024A
		XV-143F010C			XV-155F024B
		XV-143F010D			XV-155F024C
		XV-143F011A			XV-155F024D
		XV-143F011B	RHR	M-151	XV-15109A
		XV-143F011C			XV-15109B
		XV-143F011D			XV-15109C
	· · · · · · · · · · · · · · · · · · ·	XV-143F012A			XV-15109D
		XV-143F012B	CORE SPRAY	M-152	XV-152F018A
		XV-143F012C			XV-152F018B
		XV-143F012D			
		XV-143F040A			
		XV-143F040B			
		XV-143F040C			
		XV-143F040D			
		XV-143F057A			
		XV-143F057B			

ï

Category:	С		
Class:	1		
Function:	Conta	ainment	Isolation
Impractical Test Require	ment:	1.	Exercise test valve one per 92 days. (OMa – 1988 Part 10 paragraph 4.3.2)
		2.	Valve Position Verification once every 2 years (OMa - 1988 Part 10 Paragraph 4.1)
Basis for Deferment:		Exces peneti 1.11. will be ruptur not re require	s flow check valves are installed on instrument lines rating containment in accordance with Regulatory Guide The lines are sized and/or orificed such that off-site doses substantially below 10CFR100 limits in the event of a e. Therefore, individual leak rate testing of these valves is quired for conformance with 10CFR50, Appendix J ements.
		The expopped popped suffici- testing side of differed spring is required design Check and te	Access flow check valve is a simple device; the major openats are a poppet and spring. The spring holds the st open under static conditions. The valve will close upon ent differential pressure across the poppet. Functional g of the valve is accomplished by venting the instrument f the tube. The resultant increase in flow imposes a ential pressure across the poppet, which compresses the and decreases flow through the valve. Functional testing uired by Technical Specification SR 3.6.1.3.9. Systems in does not include test taps upstream of the Excess Flow & Valves. For this reason, the EFCV's cannot be isolated ested using a pressure source other than reactor pressure.

The testing described above requires the removal of the associated instrument or instruments from service. Since these instruments are in use during plant operation, removal of any of these instruments from service may cause a spurious signal which could result in a plant trip or an unnecessary challenge to safety systems. Additionally, process liquid will be contaminated to some degree, requiring special measures to collect flow from the vented instrument side and also will contribute to an increase in personnel radiation exposure.

Industry experience as documented in NEDO-32977-A indicates that EFCVs have a very low failure rate. At Susquehanna the SR failure rate has been approximately 1%. Only half of these SR failures have resulted in replacement of the EFCV. The Susquehanna test history shows no evidence of common mode failure. This Susquehanna test experience is consistent with the findings of the NEDO. The NEDO indicates similarly that many reported test failures at other plants were related to test methodologies and not actual EFCV failures. Thus, the EFCVs at Susquehanna, consistent with the industry, have exhibited a high degree of reliability, availability, and provide an acceptable level of quality and safety.

Therefore, PPL Susquehanna LLC requests relief pursuant to 10CFR50.55a(a)(3)(i) to test excess flow check valves at the frequency specified in the Susquehanna Technical Specifications Surveillance Requirements (SR) 3.6.1.3.9. As discussed in the Technical Specification Bases for this SR, this test provides assurance that each valve actuates to check flow on a simulated instrument line break.

ISI-T-100.0

RELIEF REQUEST NUMBER 23 (Cont'd)

Testing on a Cold Shutdown frequency is impractical considering the large number of valves to be tested and the condition that reactor pressure >500 psig is needed for testing. NUREG-1482 allows test deferrals to refueling outages if it is impractical to test quarterly or during cold shutdowns. In this instance, considering the large number of valves to be tested and the conditions required for testing (Reactor pressure), it is also a hardship to test all these valves during refueling outages. Recent improvements in Refueling Outage schedules (i.e. shorter outages) minimized the time that is planned for Refueling and testing activities during the outages. The appropriate time for performing these excess flow check valves tests during refueling outages is in conjunction with vessel hydrostatic testing. As a result of shorter outages, decay heat levels during hydrostatic tests are higher than in the past. If the hydrostatic test was extended to test all EFCV's, the vessel could require depressurization several times to avoid exceeding the maximum bulk coolant temperature limit. This is an evolution which challenges the reactor operators and thermally cycles the reactor vessel and should be avoided if possible. Also, based on past experience, excess flow check valve testing during hydrostatic testing becomes the outage critical path and could possibly extend the outage by 2 days if all EFCV's were to be tested during this time frame.

	A proposed alternative to testing all EFCVs during the refueling outage would be to test certain excess flow check valves immediately preceding the refueling outage while the reactor is at power, while also instituting the appropriate administrative and scheduling controls. This provides the appropriate conditions for testing (Reactor pressure >500 psig), while also providing an acceptable level of quality and safety. Performance of the excess flow check valve testing prior to the outage will be scheduled such that, in the event of a failure, the resulting action statement and limiting condition of operation will encompass the planned shutdown for the refueling outage. Using this strategy, unplanned, unnecessary plant shutdowns as a result of excess flow check valve testing will be avoided.
	In summary, considering the extremely low failure rate, personnel and plant safety concerns, the hardship of testing during refueling outages, EFCV testing during refueling outages for all EFCVs is impractical and results in a hardship without a compensating increase in the level of safety.
Alternate Testing:	Functional testing with verification that flow is checked will be performed per TS 3.6.1.3.9, either immediately preceding a planned Refueling Outage or during the Refueling Outage. For those valves tested prior to the Refueling Outage appropriate administrative and scheduling controls will be established.
	SR 3.6.1.3.9 allows a "representative sample" of EFCVs to be tested every 24 months, such that each EFCV will be tested at least once every 10 years (nominal).
	The EFCVs have position indication in the control room. Check valve remote position indication is excluded from Regulatory Guide 1.97 as a required parameter for evaluating containment isolation. The remote position indication will be verified in the closed direction at the same frequency as the exercise test, which will be performed at the frequency prescribed in Technical Specification Surveillance Requirement 3.6.1.3.9. After the close position test, the valves will be reset, and the remote open position indication will be verified. Although inadvertent actuation of an EFCV during operation is highly unlikely due to the spring- poppet design, Susquehanna verifies the EFCVs indicate open in the control room at a frequency greater than once every 2 years.

SUSQUEHANNA STEAM ELECTRIC STATION

UNIT 2

INSERVICE INSPECTION PROGRAM PLAN

FOR

PUMP AND VALVE OPERATIONAL TESTING

Rev.	Description	Prepared by:	Approved by:	Date
5	Responses to NRC Comments	Signatures on File		
6	Addition of Water Level Backfill Valves	Signatures on File		
7	10 Year ASME Code Update	Signatures on File		
8	Corrections to Valve Tables	Signatures on File		
9	Addition of Fuel Pool Cooling Valves	Signatures on File		
10	Responses to NRC Comments and Additional Changes	Signatures on File		
11	Response to NRC Comments on RR#23 Excess Flow Check Valves	Signatures on File		
12	Response to NRC Comments on ROJ-21 FPC Manual Valves	Signatures on File		
13	Miscellaneous changes	Signatures on File		
14	Incorporate Improved Tech Spec/TRM and Miscellaneous Changes	Signatures on File		
15	Incorporate Revision to RR23 Excess Flow Check Valves and Miscellaneous Changes	BeckyMattern	Jo Buyyoul	10/12/10

ISI-T-200.0

SUSQUEHANNA STEAM ELECTRIC STATION UNIT 2 PUMP AND VALVE INSERVICE INSPECTION TESTING PROGRAM

TABLE OF CONTENTS		
	Revision	Dated
TITLE:		
Page 2T-1	14	06/99
DESCRIPTION:		
Page 2D-1	14	06/99
Page 2D-2	14	06/99
Page 2D-3	14	06/99
Page 2D-4	14	06/99
Page 2D-5	14	06/99
LEGENDS:		
Page 2LP-1	7	05/94
Page 2LV-1	14	06/99
Page 2LV-2	14	06/99
Page 2LV-3	14	06/99
PUMP TABLES:		
Page 2PT-1	7	05/94
Page 2PT-2	10	04/96
Page 2PT-3	7	05/94
Page 2PT-4	7	05/94

	Revision	Dated
VALVE TABLES:		
Page 2VT-1	7	05/94
Page 2VT-2a	10	04/96
Page 2VT-2b	10	04/96
Page 2VT-3	10	04/96
Page 2VT-4	10	04/96
Page 2VT-5	7	05/94
Page 2VT-6	7	05/94
Page 2VT-7	7	05/94
Page 2VT-8	8	12/94
Page 2VT-9	7	05/94
Page 2VT-10	7	05/94
Page 2VT-11	14	06/99
Page 2VT-12	13	02/98
Page 2VT-13	13	02/98
Page 2VT-14	13	02/98
Page 2VT-15	10	04/96
Page 2VT-16	10	04/96
Page 2VT-17	10	04/96
Page 2VT-18	10	04/96
Page 2VT-19	10	04/96
Page 2VT-20	15	06/01
Page 2VT-21	. 7	05/94
Page 2VT-22	7	05/94
Page 2VT-23	13 .	02/98
Page 2VT-24	10	04/96
Page 2VT-25	10	04/96

LEP-2

	Revision	Dated
Page 2VT-26	7	05/94
Page 2VT-27	7	05/94
Page 2VT-28	10	04/96
Page 2VT-29	7	05/94
Page 2VT-30	10	04/96
Page 2VT-31	10	04/96
Page 2VT-32	10	04/96
Page 2VT-33	10	04/96
Page 2VT-34	14	06/99
Page 2VT-35	14	06/99
Page 2VT-36	7	05/94
Page 2VT-37	10	04/96
Page 2VT-38	10	04/96
Page 2VT-39	10	04/96
Page 2VT-40	10	04/96
Page 2VT-41	13	02/98
Page 2VT-42	13	02/98
Page 2VT-43	10	04/96
Page 2VT-44	10	04/96
Page 2VT-45	10	04/96
Page 2VT-46	10	04/96
Page 2VT-47	10	04/96
Page 2VT-48	7	05/94
Page 2VT-49	10	04/96
Page 2VT-50	10	04/96
Page 2VT-51	10	04/96
Page 2VT-52	. 15	06/01

LEP-3

÷1

	Revision	Dated
Page 2VT-53	7	05/94
Page 2VT-54	10	04/96
Page 2VT-55	7	05/94
Page 2VT-56	10	04/96
Page 2VT-57	15	06/01
Page 2VT-58	15	06/01
Page 2VT-59	10	04/96
Page 2VT-60	12	05/96
Page 2VT-61	7	05/94
Page 2VT-62	12	05/96
Page 2VT-63	10	04/96
Page 2VT-64	8	12/94
Page 2VT-65	8	12/94
Page 2VT-66	8	12/94
Page 2VT-67	8	12/94
Page 2VT-68	13	02/98
Page 2VT-69	12	05/96
Page 2VT-70	10	04/96
Page 2VT-71	8	12/94
Page 2VT-72	8	12/94
Page 2VT-73	8	12/94
Page 2VT-74	8	12/94
Page 2VT-75	10	04/96
Page 2VT-76	13	02/98
Page 2VT-77	10	04/96
Page 2VT-78	10	04/96
Page 2VT-79	. 7	05/94

	Revision	Dated
Page 2VT-80	10	04/96
Page 2VT-81	10	04/96
Page 2VT-82	7	05/94
Page 2VT-83	12	05/96
Page 2VT-84	10	04/96
Page 2VT-85	7	05/94
Page 2VT-86	8	12/94
Page 2VT-87	10	04/96
Page 2VT-88	15	06/01
Page 2VT-89	10	04/96
Page 2VT-90	. 7	05/94
Page 2VT-91	7	05/94
Page 2VT-92	10	04/96
Page 2VT-93	10	04/96
Page 2VT-94	10	04/96
Page 2VT-95	7	05/94
Page 2VT-96	13	02/98
Page 2VT-97	13	02/98
Page 2VT-98	13	02/98
Page 2VT-99	13	02/98
Page 2VT-100	13	02/98
Page 2VT-101	13	02/98
Page 2VT-102	13	02/98
Page 2VT-103	13	02/98
Page 2VT-104	13	02/98
Page 2VT-105	13	02/98
Page 2VT-106	. 10	04/96

•

LEADINE	Dated
10	04/96
10	04/96
10	04/96
10	04/96
10	04/96
13	02/98
13	02/98
7	05/94
ATIONS:	
7	05/94
7	05/94
7	05/94
14	06/99
10	04/96
10	04/96
10	04/96
14	06/99
10	04/96
10	04/96
10	04/96
7	05/94
14	06/99
7	05/94
	10 10 10 10 10 10 10 10 10 10 10 10 13 7 7 7 7 7 7 7 7 7 7 14 10 10 10 10 10 10 14 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 7 14 7

REFUELING OUTAGE TEST JUSTIFICATIONS:

Page 2RJT-1	7	05/94
Page 2RJ01-1	7	05/94
Page 2RJ01-2	. 7	05/94

	Revision	Dated
Page 2RJ02-1	10	04/96
Page 2RJ02-2	13	02/98
Page 2RJ03-1	7	05/94
Page 2RJ04-1	14	06/99
Page 2RJ05-1	7	05/94
Page 2RJ05-2	7	05/94
Page 2RJ06-1	14	06/99
Page 2RJ06-2	14	06/99
Page 2RJ07-1	7	05/94
Page 2RJ08-1	13	02/98
Page 2RJ09-1	7	05/94
Page 2RJ10-1	7	05/94
Page 2RJ11-1	14	06/99
Page 2RJ11-2	14	06/99
Page 2RJ12-1	14	06/99
Page 2RJ13-1	13	02/98
Page 2RJ14-1	13	02/98
Page 2RJ15-1	14	06/99
Page 2RJ16-1	13	02/98
Page 2RJ17-1	7	05/94
Page 2RJ18-1	14	06/99
Page 2RJ18-2	14	06/99
Page 2RJ19-1	13	02/98
Page 2RJ20-1	15	06/01
Page 2RJ21-1	12	05/96

	Revision	Dated
RELIEF REQUESTS:	· · · · · · · · · · · · · · · · · · ·	
Page 2RRT-1	7	05/94
Page 2RR01-1	7 .	05/94
Page 2RR02-1	7	05/94
Page 2RR03-1	7	05/94
Page 2RR04-1	10	04/96
Page 2RR05-1	14	06/99
Page 2RR05-2	14	06/99
Page 2RR06-1	15	06/01
Page 2RR06-2	15	06/01
Page 2RR06-3	15	06/01
Page 2RR07-1	10	04/96
Page 2RR08-1	10	04/96
Page 2RR08-2	13	02/98
Page 2RR09-1	13	02/98
Page 2RR10-1	14	06/99
Page 2RR11-1	10	04/96
Page 2RR12-1	7	05/94
Page 2RR13-1	7	05/94
Page 2RR14-1	7	05/94
Page 2RR15-1	7	05/94
Page 2RR16-1	10	04/96
Page 2RR16-2	13	02/98
Page 2RR17-1	10	04/96
Page 2RR17-2	13	02/98
Page 2RR18-1	10	04/96
Page 2RR18-2	. 13	02/98

	Revision	Dated
Page 2RR19-1	13	02/98
Page 2RR20-1	10	04/96
Page 2RR20-2	13	02/98
Page 2RR21-1	10	04/96
Page 2RR22-1	10	04/96
Page 2RR23-1	15	06/01
Page 2RR23-2	15	06/01
Page 2RR23-3	15	06/01
Page 2RR23-4	15	06/01
Page 2RR23-5	15	06/01
Page 2RR23-6	15	06/01
Page 2RR24-1	13	02/98
Page 2RR24-2	13	02/98
Page 2RR25-1	10	04/96
Page 2RR26-1	10	04/96
Page 2RR26-2	13	02/98
Page 2RR27-1	10	04/96
Page 2RR27-2	13	02/98
Page 2RR28-1	10	04/96
Page 2RR28-2	13	02/98
Page 2RR29-1	10	04/96
Page 2RR29-2	13	02/98
Page 2RR30-1	13	02/98
Page 2RR30-2	13	02/98
Page 2RR31-1	10	04/96
Page 2RR31-2	13	02/98
Page 2RR32-1	. 10	04/96

	Revision	Dated
Page 2RR33-1	12	05/96
Page 2RR33-2	12	05/96
Page 2RR33-3	12	05/96
Page 2RR34-1	14	06/99
Page 2RR34-2	14	06/99
Page 2RR34-3	14	06/99

NUCLEAR BOILER M-2141 Sheet 1

Valve Number	P&ID Coordinates	ASME Class	ASME Category	Active/Passive	Valve Size (inches)	Valve Type	Actuator Type	Remote Position Indication	Safety Position	Tests Required	Tests Performed	Test Frequency	CS/RO Justification	Relief Request(s)	Remarks
241F024A	A-5	3	с	А	1	ск	SA		с	FS	FS	RF	RJ05	-	Closure test only.
241F024B	A-5	3	с	A	1	СК	SA	-	с	FS	FS	RF	RJ05	-	Closure test only.
241F024C	A-5	3	С	A	_1	ск	SA	-	с	FS	FS	RF	RJ05	-	Closure test only.
241F024D	A-5	3	С	A	1	СК	SA	-	с	FS	FS	RF	RJ05	-	Closure test only.
241F029A	A-7	3	С	A	1	СК	SA	-	С	FS	FS	RF	RJ05	-	Closure test only.
241F029B	A-7	3	С	A	1	ск_	SA	-	с	FS	FS	RF	RJ05	-	Closure test only.
241F029C	A-7	3	с	A	1	СК	SA	-	с	FS	FS	RF	RJ05	-	Closure test only.
241F029D	A-7	3	с	А	1	СК	SA	-	С	FS	FS	RF	RJ05	-	Closure test only.
241F036A	B-4	3	С	А	1	СК	SA	-	С	FS	FS	RF	RJ06	_	Closure test only.
241F036B	B-4	3	с	А	1	СК	SA	-	с	FS	FS	RF	RJ06	-	Closure test only.
241F036C	B-4	3	С	А	1	ск	SA	-	с	FS	FS	RF	RJ06	-	Closure test only.
241F036D	B-4	3	с	А	1	ск	SA	-	с	FS	FS	RF	RJ06	-	Closure test only.

CONTROL ROD DRIVE M-2147 Sheet 2

Valve Number	P&ID Coordinates	ASME Class	ASME Category	Active/Passive	Valve Size (inches)	Valve Type	Actuator Type	Remote Position Indication	Safety Position	Tests Required	Tests Performed	Test Frequency	CS/RO Justification	Relief Request(s)	Remarks
247114*					214	CK	54			FO	E	DE		DDOG	Onen test enk
24/114*	A-8	5		A	3/4		5A			1-2	15	<u> </u>		KRUO	
247115*	D-8	s	с	Ā	1/2	ск	SA		с	FS	FS	RF		RR06	Closure test only.
															-
247138*	D-4	S	с	A	1/2	ск	SA		с	FS	FS	RF		RR06	Closure test only.
										EQ	EQ	DE		DDOG	Open test only
XV-247126*	D-6	2	В	A	1/2	GB	AO		0	ST				RR06	
XV-247127*	A-6	2	В	A	1/2	GB	AO		0	FS ST	FS 	RF 		RR06 RR06	Open test only.

There is a total of 185 sets of these valves, one for each of the 185 CRD Hydraulic Control Units.

Rev. 15 06/01 *

ISI-T-200.0

				and the second	
HV-249F060	HV-249F059	HV-249F031	HV-249F026	Valve	REACTOR C
G-3	မှ မိ	H-2	G-8	P&ID Coordinates	ORE IS
N	N	N	N	ASME Class.	SOLAT
⊳	⊳	Φ	B	ASME Category	ION CO
≻	A	⊳	⊳	Active/Passive	DOLING
N	10	თ	د	Valve Size (inches)	3 M-214
GB	GT	GT	GB	Valve Type	49 (Con
MO	MO	MO	Q	Actuator Type	tinued)
×	×	×	×	Remote Position Indication	
0/C	0	o/c	0/C	Safety Position	
L P ST	E P ST FS	PI ST	FS ST PI	Tests Required	
L P S FS	S P S FS	P P S FS	FS ST PI	Tests Performed	
22200 22200	aakk	aa⊻ı	2400	Test Frequency	
	1111	111	111	CS/RO Justification	
	111	1 1 1 1	1 1	Relief Request(s)	
		T. S. Approved Amendment #119.			

.....

Rev. 15

Rev. 15

2VT-58

XV-249F044B	XV-249F044A	HV-249F088	HV-249F084	HV-249F062	Valve	REACTOR (
D-4	A-3	င်း	F ن	F-4	P&ID Coordinates	CORE
	<u>→</u>		N	N	ASME Class	ISOLA.
C	n	A	A	Þ	ASME Category	FION C
A	A	⊳	A	A	Active/Passive	OOLIN
<u>د</u>			N	N	Valve Size (inches)	G M-21
Хс	Xc	GB	GT	GT	Valve Type	49 (Co
SA	SA	AO	MO	MO	Actuator Type	ntinued
×	×	×	×	×	Remote Position Indication	
c	C	o/c	C	C	Safety Position	
PI FS	PI FS	E P S FS	E P ST FS	E PI ST	Tests Required	
FS PI	PFS	E P S FS	L P SI S	L P S FS	Tests Performed	
2Y 2Y	RF 2Y	22 Y Y Z Q Q	22200	22200	Test Frequency	
1	11	1111	111	1	CS/RO Justification	
RR23 -	RR23 -		1	1111	Relief Request(s)	
					Remarks	

	and the second				
HIGH PRES	Valve	HV-255F066	HV-255F075	HV-255F079	HV-255F100
SSURE	P&ID Coordinates	ငှ- ပ	F-4	F-3	မာ မာ
000	ASME Class	N	N	N	-
ANT IN.	ASME Category	≻	⊳	Þ	⊳
JECTIO	Active/Passive	>	≻	⊳	⊳
N M-21	Valve Size (inches)	20	ω	ω	د
55 (Co	Valve Type	GT	GT	GT	GB
ntinued	Actuator Type	MO	MO	MO	AO
	Remote Position Indication	×	×	×	×
	Safety Position	0	0	n	0/c
	Tests Required	CPSTS	L P S FS	L P ST	L P ST FS
	Tests Performed	E P S FS	C P S FS	L PI ST	E P ST FS
	Test Frequency	aaxx	aaxx	22200	22200
	CS/RO Justification	-1 - 1 - 1	1 I I I		
	Relief Request(s)	1 8 8 8		1 1 1 1	1 1 1 1
	Remarks				

88-TVS

ISI-T-200.0

REFUELING OUTAGE TEST JUSTIFICATION NUMBER 20

REFUEL TEST JUSTIFICATION HAS BEEN WITHDRAWN

RELIEF REQUEST NUMBER 06

System: Control Rod Drive

P&ID: M-2147

Valves	Category	<u>Class</u>
247114-001 through 247114-185	С	S
247115-001 through 247115-185	С	S
XV-247126-001 through XV-247126-185	В	2
XV-247127-001 through XV-247127-185	В	2
247138-001 through 247138-185	С	S

Function: Control Rod Scram

Impractical Test Requirement: Exercise valves once per 92 days and measure stroke times.

Basis for Relief: These valves, located on the hydraulic control units for the 185 control rod drives, perform the active safety function of rapidly inserting the control rods into the reactor core, upon receipt of a reactor scram signal from the reactor protection system. Exercising these valves quarterly during power operations could result in the rapid insertion of one or more control rods more frequently than desired. Where testing could result in the rapid insertion of control rods, thereby causing rapid reactivity transients and wear of the control rod drive mechanisms, the control rod scram test frequency identified in the Plant Technical Specifications will be utilized as the valve testing frequency.

Normal control rod motion has been shown to be an indicator that the associated cooling water header check valve (247138 -001 through - 185) moves to its safety position (closed). Normal control rod motion may not occur if this check valve were to fail in the open position. An additional positive test of the closure of this valve can be provided by venting of the cooling water header during Primary Containment Integrated Leakage Testing, conducted per TS 5.5.12.

Normal control rod motion does not serve as an indicator that any scram discharge header check valve (247114 -001 through -185) moves to its safety position (open), however. Since this check valve is moved to its open position only by scram exhaust flow, a positive test of the opening of the valve can only be provided by the periodic scram testing and control rod insertion timing specified by SR 3.1.3.4.

Verification that any charging water header check valve (247115 -001 through -185) moves to its safety position (closed), requires that the control rod drive pumps be stopped to depressurize the charging water header. This test cannot be performed during power operations because stopping the pumps would result in loss of cooling water to all control rod drive mechanisms and seal damage could result. This test cannot be performed during each cold shutdown because the control rod drive pumps supply seal water to the reactor recirculation pumps and one of the recirculation pumps might be kept running, thus continuing to need its seal water supply. The HCU accumulator pressure decay test, specified by TRS 3.1.4.3, provides verification of the closure of its charging water header check valve.

The scram inlet valves (XV-247126 -001 through -185) and the scram exhaust valves (XV-247127 -001 through -185) are air operated valves that full-stroke in milliseconds and are not equipped with position indication, thereby rendering measurement of their full-stroke times impractical. Verifying that the control rod associated with each pair of these valves meets the periodic scram testing rod insertion time limits, specified by SR 3.1.3.4, is an acceptable alternate method of detecting degradation of these valves. Since these measurements of control rod insertion times are subject to the conservative limitations of SR 3.1.4.1, 3.1.4.2, 3.1.4.3 and 3.1.4.4, and because these measurements cannot be meaningfully correlated with the full-stroke times of the scram inlet and exhaust valves, trending of these scrams time measurements in any manner comparable to that of valve stroke times is both impractical and unnecessary.

These bases for relief from applicable code testing requirements for these individual control rod scram valves are intended to conform to those provided as guidance by NRC Generic Letter 89-04 (Position #7).

Alternative Testing: Proper functioning of the scram discharge header check valves (247114-XXX), of the scram inlet valves (XV-27126-XXX), and of the scram exhaust valves (XV-247127-XXX) will be verified by periodic scram testing and control rod insertion timing, with reactor pressure \geq 950 psig, conducted per SR 3.1.3.4 and SR's 3.1.4.1, 3.1.4.2, 3.1.4.3 and 3.1.4.4.

- a) For all control rods prior to thermal power exceeding 40% of rated thermal power, following core alternations or after a reactor shutdown that is greater than 120 days.
- b) For specifically affected individual control rods, following maintenance or modification to the control rod or control rod drive system, which could affect the scram insertion time of those specific control rods.
- c) For a representative sample of the control rods, at least once per 120 days of power operation.
- d) For specifically affected individual control rods prior to thermal power exceeding 40% rated thermal power, following maintenance or modification to the control rod or control rod drive system which could affect the scram insertion time of those specific control rods.

Proper closure of the charging water header check valves (247115-XXX) will be verified by the demonstration that each individual accumulator check valve maintains its associated accumulator pressure above the alarm set point for \geq 10 minutes, with no CRD pump operating, at least once per 24 months, conducted per TRS 3.1.4.3.

Proper closure of the cooling water header check valves (247138-XXX) will be verified by venting of the cooling water header during Primary Containment Integrated Leakage Testing, conducted per TS 5.5.12.

ISI-T-200.0

RELIEF REQUEST NUMBER 23

System	P&ID	Valve	System	P&ID Valve
RPV	M-2141	XV-241F009	RPV (continued)	XV-242F051B
Main Steam	M-2141	XV-241F070A		XV-242F051C
		XV-241F070B		XV-242F051D
		XV-241F070C		XV-242F053A
		XV-241F070D		XV-242F053B
		XV-241F071A		XV-242F053C
		XV-241F071B		XV-242F053D
		XV-241F071C		XV-242F055
		XV-241F071D		XV-242F057
		XV-241F072A		XV-242F059A
		XV-241F072B		XV-242F059B
		XV-241F072C		XV-242F059C
		XV-241F072D		XV-242F059D
		XV-241F073A		XV-242F059E
		XV-241F073B		XV-242F059F
· · · · · · · · · · · · · · · · · · ·		XV-241F073C		XV-242F059G
		XV-241F073D		XV-242F059H
RPV	M-2142	XV-24201		XV-242F059L
		XV-24202		XV-242F059M
		XV-242F041		XV-242F059N
······································		XV-242F043A		XV-242F059P
		XV-242F043B		XV-242F059R
		XV-242F045A		XV-242F059S
		XV-242F045B		XV-242F059T
		XV-242F047A		XV-242F059U
		XV-242F047B		XV-242F061
		XV-242F051A		

2RR23-1

ISI-T-200.0

RELIEF REQUEST NUMBER 23 (Cont'd.)

System	P&ID	Valve	System	P&ID	Valve
RXR (cont'd)	M-2143	XV-243F003A	RWCU	M-2144	XV-24411A
		XV-243F003B			XV-24411B
		XV-243F004A			XV-24411C
		XV-243F004B			XV-24411D
		XV-243F009A			XV-244F046
		XV-243F009B	RCIC	M-2149	XV-249F044A
		XV-243F009C			XV-249F044B
		XV-243F009D			XV-249F044C
		XV-243F010A			XV-249F044D
		XV-243F010B	HPCI	M-2155	XV-255F024A
		XV-243F010C			XV-255F024B
		XV-243F010D			XV-255F024C
		XV-243F011A			XV-255F024D
		XV-243F011B	RHR	M-2151	XV-25109A
		XV-243F011C			XV-25109B
		XV-243F011D			XV-25109C
		XV-243F012A			XV-25109D
		XV-243F012B	CORE SPRAY	M-2152	XV-252F018A
		XV-243F012C			XV-252F018B
		XV-243F012D			
		XV-243F040A			
		XV-243F040B			
		XV-243F040C			
		XV-243F040D			
		XV-243F057A			
		XV-243F057B			

Category:	C
Class:	1
Function:	Containment Isolation
Impractical Test Requirement:	 Exercise test valve once per 92 days. (OMa – 1988 Part 10 paragraph 4.3.2)
	 Valve Position Verification once every 2 years (OMa - 1988 Part 10 Paragraph 4.1)
Basis for Deferment:	Excess flow check valves are installed on instrument lines penetrating containment in accordance with Regulatory Guide 1.11. The lines are sized and/or orificed such that off-site doses will be substantially below 10CFR100 limits in the event of a rupture. Therefore, individual leak rate testing of these valves is not required for conformance with 10CFR50, Appendix J requirements.
	The excess flow check valve is a simple device; the major components are a poppet and spring. The spring holds the poppet open under static conditions. The valve will close upon sufficient differential pressure across the poppet. Functional testing of the valve is accomplished by venting the instrument side of the tube. The resultant increase in flow imposes a differential pressure across the poppet, which compresses the spring and decreases flow through the valve. Functional testing is required by Technical Specification SR 3.6.1.3.9. Systems design does not include test taps upstream of the Excess Flow Check Valves. For this reason, the EFCV's cannot be isolated and tested using a pressure source other than reactor pressure.

2RR23-3

Rev. 15 06/01

The testing described above requires the removal of the associated instrument or instruments from service. Since these instruments are in use during plant operation, removal of any of these instruments from service may cause a spurious signal which could result in a plant trip or an unnecessary challenge to safety systems. Additionally, process liquid will be contaminated to some degree, requiring special measures to collect flow from the vented instrument side and also will contribute to an increase in personnel radiation exposure.

Industry experience as documented in NEDO032977-A indicates that EFCVs have a very low failure rate. At Susquehanna the SR failure rate has been approximately 1%. Only half of these SR failures have resulted in replacement of the EFCV. The Susquehanna test history shows no evidence of common mode failure. This Susquehanna test experience is consistent with the findings of the NEDO. The NEDO indicates similarly that many reported test failures at other plants were related to test methodologies and not actual EFCV failures. Thus, the EFCVs at Susquehanna, consistent with the industry, have exhibited a high degree of reliability, availability, and provide an acceptable level of quality and safety.

Therefore, PPL Susquehanna LLC requests relief pursuant to 10CFR50.55a(a)(3)(I) to test excess flow check valves at the frequency specified in the Susquehanna Technical Specifications Surveillance Requirements (SR) 3.6.1.3.9. As discussed in the Technical Specification Bases for this SR, this test provides assurance that each valve actuates to check flow on a simulated instrument line break.

Testing on a Cold Shutdown frequency is impractical considering the large number of valves to be tested and the condition that reactor pressure >500 psig is needed for testing.

Rev. 15 06/01

2RR23-4

NUREG-1482 allows test deferrals to refueling outages if it is impractical to test quarterly or during cold shutdowns. In this instance, considering the large number of valves to be tested and the conditions required for testing (Reactor pressure), it is also a hardship to test all these valves during refueling outages. Recent improvements in Refueling Outage schedules (i.e. shorter outages) minimized the time that is planned for Refueling and testing activities during the outages. The appropriate time for performing these excess flow check valve tests during refueling outages is in conjunction with vessel hydrostatic testing. As a result of shorter outages, decay heat levels during hydrostatic tests are higher than in the past. If the hydrostatic test was extended to test all EFCV's, the vessel could require depressurization several times to avoid exceeding the maximum bulk coolant temperature limit of 212 degrees F. This is an evolution which challenges the reactor operators and thermally cycles the reactor vessel and should be avoided if possible. Also, based on past experience, excess flow check valve testing during hydrostatic testing becomes the outage critical path and could possibly extend the outage by 2 days if all EFCV's were to be tested during this time frame.

A proposed alternative to testing all EFCVs during the refueling outage would be to test certain excess flow check valves immediately preceding the refueling outage while the reactor is at power, while also instituting the appropriate administrative and scheduling controls. This provides the appropriate conditions for testing (Reactor pressure >500 psig), while also providing an acceptable level of quality and safety. Performance of the excess flow check valve testing prior to the outage will be scheduled such that, in the event of a failure, the resulting action statement and limiting condition of operation will encompass the planned shutdown for the refueling outage. Using this strategy, unplanned, unnecessary plant shutdowns as a result of excess flow check valve testing will be avoided.

In summary, considering the extremely low failure rate, personnel and plant safety concerns, the hardship of testing during refueling outages, EFCV testing during refueling outages is impractical and results in a hardship without a compensating increase in the level of safety.

2RR23-5

Rev. 15 06/01

Alternative Testing: Functional testing with verification that flow is checked will be performed per TS 3.6.1.3.9, either immediately preceding a planned Refueling Outage or during the Refueling Outage. For those valves tested prior to the Refueling Outage the appropriate administrative and scheduling controls will be established.

SR 3.6.1.3.9 allows a "representative sample" of EFCVs to be tested every 24 months, such that each EFCV will be tested at least once every 10 years (nominal).

The EFCVs have position indication in the control room. Check valve remote position indication is excluded from Regulatory Guide 1.97 as a required parameter for evaluating containment isolation. The remote position indication will be verified in the closed direction at the same frequency as the exercise test, which will be performed at the frequency prescribed in Technical Specification Surveillance Requirement 3.6.1.3.9. After the close position test, the valves will be reset, and the remote open position indication will be verified. Although inadvertent actuation of an EFCV during operation is highly unlikely due to the spring-poppet design, Susquehanna verifies the EFCVs indicate open in the control room at a frequency greater than once every 2 years.