

November 30, 2001

Mr. Oliver D. Kingsley, President  
and Chief Nuclear Officer  
Exelon Nuclear  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

SUBJECT: OYSTER CREEK NUCLEAR GENERATING STATION - NOTIFICATION OF  
INSERVICE INSPECTION INTERVAL EXTENSION (TAC NO. MB1191)

Dear Mr. Kingsley:

On November 14, 2000, you sent a letter notifying us that the third inservice inspection (ISI) interval for the Oyster Creek Nuclear Generating Station (Oyster Creek) is scheduled to end on March 14, 2002. Amergen Energy Company, LLC (Amergen) is extending the current inspection interval by 7 months in accordance with the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code), Section XI, 1986 Edition, subarticle IWA-2430(d). The new end date of the interval will be October 14, 2002. This extension will not allow any further extension to future 10-year intervals, as the 12-month allowance is cumulative over all intervals unless a future interval is shortened commensurately.

The U.S. Nuclear Regulatory Commission staff has reviewed your letter and has no objection.

Sincerely,

**/RA/**

Helen N. Pastis, Senior Project Manager, Section 1  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-219

cc: See next page

Mr. Oliver D. Kingsley, President  
and Chief Nuclear Officer  
Exelon Nuclear  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

November 30, 2001

SUBJECT: OYSTER CREEK NUCLEAR GENERATING STATION - NOTIFICATION OF  
INSERVICE INSPECTION INTERVAL EXTENSION (TAC NO. MB1191)

Dear Mr. Kingsley:

On November 14, 2000, you sent a letter notifying us that the third inservice inspection (ISI) interval for the Oyster Creek Nuclear Generating Station (Oyster Creek) is scheduled to end on March 14, 2002. Amergen Energy Company, LLC (Amergen) is extending the current inspection interval by 7 months in accordance with the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code), Section XI, 1986 Edition, subarticle IWA-2430(d). The new end date of the interval will be October 14, 2002. This extension will not allow any further extension to future 10-year intervals, as the 12-month allowance is cumulative over all intervals unless a future interval is shortened commensurately.

The U.S. Nuclear Regulatory Commission staff has reviewed your letter and has no objection.

Sincerely,

*/RA/*

Helen N. Pastis, Senior Project Manager, Section 1  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-219

cc: See next page

DISTRIBUTION:

PUBLIC

PD1-1 R/F

RidsOgcMailCenter

RidsAcrsAcnwMailCenter

RidsNrrLASLittle

RidsNrrPMHPastis

RidsNrrDlpmLpdi1 (L. Raghavan)

RidsRgn1MailCenter

Adams Accession No: ML012910628

OFFICE	PD1-1/PM	PD1-1/LA	BC/EMCB	OGC	PD1-1/SC (A)
NAME	HPastis:as	SLittle	TChan	RHoefling	LRaghavan
DATE	11/5/2001	11/29/2001	11/5/2001	11/27/2001	11/30/2001

**OFFICIAL RECORD COPY**

## Oyster Creek Nuclear Generating Station

cc:

John Skolds  
Chief Operating Officer  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

William Bohkle  
Senior Vice President Nuclear Services  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

John B. Cotton  
Senior Vice President - Operations Support  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Joseph J. Hagan  
Senior Vice President -  
Mid Atlantic Regional Operating Group  
Exelon Generation Company, LLC  
200 Exelon Way, Suite 305  
Kennett Square, PA 19348

Jeffrey A. Benjamin  
Vice President -  
Licensing and Regulatory Affairs  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Ron J. DeGregorio  
Vice President  
Oyster Creek Nuclear Generating Station  
AmerGen Energy Company, LLC  
P.O. Box 388  
Forked River, NJ 08731

H. J. Miller  
Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406-1415

Mayor Lacey Township  
818 West Lacey Road  
Forked River, NJ 08731

Senior Resident Inspector (Oyster Creek)  
U.S. Nuclear Regulatory Commission  
P.O. Box 445  
Forked River, NJ 08731

Kent Tosch, Chief  
New Jersey Department of  
Environmental Protection  
Bureau of Nuclear Engineering  
CN 415  
Trenton, NJ 08625

Michael P. Gallagher  
Director - Licensing  
Exelon Generation Company, LLC  
Correspondence Control Desk  
P.O. Box 160  
Kennett Square, PA 19348

Ernest J. Harkness  
Plant Manager  
Oyster Creek Nuclear Generating Station  
AmerGen Energy Company, LLC  
P.O. Box 388  
Forked River, NJ 08731

Kevin P. Gallen, Esquire  
Morgan, Lewis & Bockius LLP  
1800 M Street, NW  
Washington, DC 20036-5869

Manager Regulatory Assurance  
Oyster Creek Nuclear Generating Station  
AmerGen Energy Company, LLC  
P.O. Box 388  
Forked River, NJ 08731

Edward J. Cullen, Jr., Esquire  
Vice President, General Counsel and  
Secretary  
Exelon Generation Company, LLC  
300 Exelon Way  
Kennett Square, PA 19348

J. Rogge, Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406-1415