

August 17, 1995

Mr. John F. Opeka
Executive Vice President, Nuclear
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
P.O. Box 270
Hartford, CT 06141-0270

SUBJECT: CORRECTION TO AMENDMENT NO. 104 - MILLSTONE NUCLEAR POWER STATION,
UNIT 2

Dear Mr. Opeka:

It has come to our attention that page 1-9 of the Millstone 2 Technical Specifications which was amended by Amendment No. 104, issued on September 16, 1985, inadvertently omitted the definition of "P." This definition was submitted in your application of May 29, 1985, and there appears to be no reason for the omission in the amendment. To correct this error, we are enclosing the corrected page.

Sincerely,

Original signed by:

Guy S. Vissing, Senior Project Manager
Project Directorate I-3
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Docket No. 50-336

Enclosure: TS page 1-9

cc w/encl: See next page

Distribution:

Docket File	SNorris	ACRS (4)
PUBLIC	GVissing	LNicholson, RI
PD I-3 Plant	OGC	
SVarga	GHill (2)	
PMcKee	CGrimes	

DOCUMENT NAME: G:\VISSING\CORRECTN

OFFICE	LA:PDI-3	PM:PDI-3	D:PDI-3
NAME	SNorris	GVissing:cn	PMcKee
DATE	08/17/95	08/17/95	08/17/95

OFFICIAL RECORD COPY

9508220292 950817
PDR ADOCK 05000336
PDR

REC FILE CENTER COPY

QF01
111



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

August 17, 1995

Mr. John F. Opeka
Executive Vice President, Nuclear
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
P.O. Box 270
Hartford, CT 06141-0270

SUBJECT: CORRECTION TO AMENDMENT NO. 104 - MILLSTONE NUCLEAR POWER STATION,
UNIT 2

Dear Mr. Opeka:

It has come to our attention that page 1-9 of the Millstone 2 Technical Specifications which was amended by Amendment No. 104, issued on September 16, 1985, inadvertently omitted the definition of "P." This definition was submitted in your application of May 29, 1985, and there appears to be no reason for the omission in the amendment. To correct this error, we are enclosing the corrected page.

Sincerely,

A handwritten signature in cursive script, appearing to read "Guy S. Vissing".

Guy S. Vissing, Senior Project Manager
Project Directorate I-3
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Docket No. 50-336

Enclosure: TS page 1-9

cc w/encl: See next page

J. Opeka
Northeast Nuclear Energy Company

Millstone Nuclear Power Station
Unit 2

cc:

Lillian M. Cuoco, Esq.
Senior Nuclear Counsel
Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06141-0270

F. R. Dacimo, Vice President
Haddam Neck Station
Connecticut Yankee Atomic Power Company
362 Injun Hollow Road
East Hampton, CT 06424-3099

Kevin T. A. McCarthy, Director
Monitoring and Radiation Division
Department of Environmental Protection
79 Elm Street
Hartford, CT 06106-5127

Allan Johanson, Assistant Director
Office of Policy and Management
Policy Development and Planning Division
80 Washington Street
Hartford, CT 06106

S. E. Scace, Vice President
Nuclear Operations Services
Northeast Utilities Service Company
P.O. Box 128
Waterford, CT 06385

Nicholas S. Reynolds
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502

R. M. Kacich, Director
Nuclear Planning, Licensing & Budgeting
Northeast Utilities Service Company
P.O. Box 128
Waterford, CT 06385

J. M. Solymossy, Director
Nuclear Quality and Assessment Services
Northeast Utilities Service Company
P.O. Box 128
Waterford, CT 06385

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

First Selectmen
Town of Waterford
Hall of Records
200 Boston Post Road
Waterford, CT 06385

P. D. Swetland, Resident Inspector
Millstone Nuclear Power Station
c/o U.S. Nuclear Regulatory Commission
P.O. Box 513
Niantic, CT 06357

Donald B. Miller, Jr.
Senior Vice President
Millstone Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385

G. H. Bouchard, Nuclear Unit Director
Millstone Unit No. 2
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385

Charles Brinkman, Manager
Washington Nuclear Operations
ABB Combustion Engineering
12300 Twinbrook Pkwy, Suite 330
Rockville, MD 20852

TABLE 1.2
FREQUENCY NOTATION

<u>NOTATION</u>	<u>FREQUENCY</u>
S	Once per 12 hours.
D	Once per 24 hours.
W	Once per 7 days.
M	Once per 31 days.
Q	Once per 92 days.
SA	Once per 6 months.
R	Once per 18 months.
S/U	Prior to each reactor startup.
P	Prior to each release.
N.A.	Not applicable.