

March 6, 1984

DMB 016

Docket No. 50-321

Mr. J. T. Beckham, Jr.
Vice President - Nuclear Generation
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Dear Mr. Beckham:

The Commission has issued Amendment No. 99 to Facility Operating License No. DPR-57 for the Edwin I. Hatch Nuclear Plant, Unit No. 1. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated April 22, 1983.

The April 22, 1983 application proposed certain changes dealing with the deletion of the drywell to torus differential pressure system. The system was proposed and implemented during the Short-Term Pool Dynamic Loads Program for all Mark I plants pending the results of the long-term program. The reduction of the water leg in the downcomers, using the drywell-torus differential pressure system, was found to successfully mitigate pool swell loads.

In February 1983, you submitted your Plant Unique Analysis Report (PUAR). The PUAR identified the analyses you completed to establish the design basis loads that are appropriate for the anticipated life of the plant. The PUAR analyses did not take credit for operation of the drywell-torus differential pressure system.

Accordingly, you have requested certain changes to the Hatch 1 TSs which delete all operating requirements for the drywell-torus differential pressure system.

By our letter dated January 25, 1984, we informed you that we have reviewed the analyses you performed in the PUAR and found them to be acceptable. Therefore, we agree with your assertion that the drywell-torus differential pressure system is no longer required.

We therefore conclude that the proposed changes to the TSs are acceptable.

We have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR Section 51.5(d)(4) that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

8403260045 840306
PDR ADDCK 05000321
PDR

Mr. J. T. Beckham, Jr.

-2-

We have concluded, based on the considerations discussed above, that:
(1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Notice of Issuance will be included in the Commission's Monthly Notice.

Sincerely,

"ORIGINAL SIGNED BY
JOHN F. STOLZ"

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosure:
Amendment No. 99 to DPR-57

cc w/enclosure:
See next page

DISTRIBUTION:

Docket File

NRC PDR

L PDR

DEisenhut

OELD

CMiles

LHarmon

ACRS-10

TBarnhart-4

EJordan

JTaylor

WJones

DBrinkman

RDiggs

HDenton

EBlackwood

HO rnstein

RI ngram

GRivenbark

Gray File+4

ORB#4:DL
RI ngram
2/16/84

ORB#4:DL
GRivenbark;cf
2/16/84

C-ORB#4:DL
JStolz
2/17/84

AD:OR:DL
GLa nias
3/6/84

OELD
Goodard
2/21/84

Hatch 1/2
Georgia Power Company

50-321/366

cc w/enclosure(s):

G. F. Trowbridge, Esq.
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Ruble A. Thomas
Vice President
P. O. Box 2625
Southern Company Services, Inc.
Birmingham, Alabama 35202

Ozen Batum
Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513

Mr. L. T. Gucwa
Georgia Power Company
Engineering Department
P. O. Box 4545
Atlanta, Georgia 30302

Mr. H. C. Nix, Jr. General Manager
Edwin I. Hatch Nuclear Plant
Georgia Power Company
P. O. Box 442
Baxley, Georgia 31513

Regional Radiation Representative
EPA Region IV
345 Courtland Street, N.E.
Atlanta, Georgia 30308

Resident Inspector
U. S. Nuclear Regulatory Commission
Route 1, P. O. Box 279
Baxley, Georgia 31513

Mr. James P. O'Reilly, Regional
Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, S.W.
Atlanta, Georgia 30334

J. Leonard Ledbetter, Commissioner
Department of Natural Resources
270 Washington Street, N.W.
Atlanta, Georgia 30334



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

GEORGIA POWER COMPANY
OGLETHORPE POWER CORPORATION
MUNICIPAL ELECTRIC AUTHORITY OF GEORGIA
CITY OF DALTON, GEORGIA
DOCKET NO. 50-321
EDWIN I. HATCH NUCLEAR PLANT, UNIT NO. 1
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 99
License No. DPR-57

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Georgia Power Company, et al., (the licensee) dated April 22, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-57 is hereby amended to read as follows:


B40326004B B40306
PDR ADDCK 05000321
P PDR

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 99, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 6, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 99

FACILITY OPERATING LICENSE NO. DPR-57

DOCKET NO. 50-321

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain a vertical line indicating the area of change.

<u>Remove</u>	<u>Insert</u>
3.2-22	3.2-22
3.2-48	3.2-48
3.7-10	3.7-10
3.7-10a	3.7-10a
3.7-33a	3.7-33a
3.7-34	3.7-34

Table 3.2-11

INSTRUMENTATION WHICH PROVIDES SURVEILLANCE INFORMATION

Ref. No. (a)	Instrument (b)	Required Operable Instrument Channels	Type and Range	Action	Remarks
1	Reactor Water Level (GE/HAC)	1 2	Recorder Indicator 0 to 60"	(c) (c)	(d) (d)
2	Shroud Water Level	1 1	Recorder Indicator -317" to -17"	(c) (c)	(d) (d)
3	Reactor Pressure	1 2	Recorder Indicator 0 to 1200 psig	(c) (c)	(d) (d)
4	Drywell Pressure	2	Recorder -5 to +80 psig	(c)	(d)
5	Drywell Temperature	2	Recorder 0 to 500°F	(c)	(d)
6	Suppression Chamber Air Temperature	2	Recorder 0 to 500°F	(c)	(d)
7	Suppression Chamber Water Temperature	2	Recorder 0 to 250°F	(c)	(d)
8	Suppression Chamber Water Level	2 2	Indicator 0 to 300" Recorder 0 to 30"	(c) (c)(e)	(d) (d)
9	Suppression Chamber Pressure	2	Recorder -5 to +80 psig	(c)	(d)
10	Rod Position Information System (RPIS)	1	28 Volt Indicating Lights	(c)	(d)
11	Hydrogen and Oxygen Analyzer	1	Recorder 0 to 52	(c)	(d)
12	Post LOCA Radiation Monitoring System	1	Recorder Indicator 1 to 10 ⁶ R/hr	(c) (c)	(d) (d)
13	a) Safety/Relief Valve Position Primary Indicator	1	Pressure Switch 4-100 psig	(f)	
	b) Safety/Relief Valve Position Secondary Indicator	1	Temperature element 0-600°F	(f)	

Table 4.2-11

Check and Calibration Minimum Frequency for Instrumentation
Which Provides Surveillance Information

Ref. No. (a)	Instrument	Instrument Check Minimum Frequency (b) 1	Instrument Calibration Minimum Frequency (c)
1	Reactor Water Level (GE/MAC)	Each shift	Every 6 months
2	Shroud Water Level	Each shift	Every 6 months
3	Reactor Pressure	Each shift	Every 6 months
4	Drywell Pressure	Each shift	Every 6 months
5	Drywell Temperature	Each shift	Every 6 months
6	Suppression Chamber Air Temperature	Each shift	Every 6 months
7	Suppression Chamber Water Temperature	Each shift	Every 6 months
8	Suppression Chamber Water Level	Each shift	Every 6 months
9	Suppression Chamber Pressure	Each shift	Every 6 months
10	Rod Position Information System (RPIS)	Each shift	N/A
11	Hydrogen and Oxygen Analyzer	Each shift	Every 6 months
12	Post LOCA Radiation	Each shift	Every 6 months
13	a) Safety/Relief Valve Position Pri- mary Indicator	Monthly	Every 18 months
	b) Safety/Relief Valve Position Secondary Indicator	Monthly	Every 18 months

3.7.A.6.c. H₂ and O₂ Analyzer

Whenever the reactor is in power operation, there shall be at least one CAD System H₂ and O₂ analyzer serving the primary containment. If one H₂ and O₂ analyzer is inoperable, the reactor may remain in operation for a period not to exceed seven days.

- d. Post-LOCA Repressurization Limit
The maximum post-LOCA primary containment repressurization limit allowable using the CAD System shall be 30 psig. Venting via the SGTS to the main stack must be initiated at 30 psig following the initial post-LOCA pressure peak.

4.7.A.6.c. H₂ and O₂ Analyzer

Instrumentation surveillance is listed in Table 4.2-11.

7. Shutdown Requirements

If Specification 3.7.A cannot be met, an orderly shutdown shall be initiated and the reactor shall be brought to Hot Shutdown within 12 hours and shall be in the Cold Shutdown condition within the following 24 hours.

B. Standby Gas Treatment System1. Operability Requirements

A minimum of three (2 of 2 in Unit 1 and 1 of 2 in Unit 2) of the four independent standby gas treatment system trains shall be operable at all times when Unit 1 secondary containment integrity is required.

With one of the Unit 1 standby gas treatment systems inoperable, for any reason, Unit 1 reactor operation and fuel-handling and/or handling of casks in the vicinity of the spent fuel pools is permissible for a period of seven (7) days provided that all active components in the remaining standby gas treatment systems in each unit shall be demonstrated to be operable within 4 hours, and daily thereafter.

B. Standby Gas Treatment System1. Surveillance When System Operable

At least once per operating cycle, not to exceed 18 months, the following conditions shall be demonstrated:

- a. Pressure drop across the combined HEPA filters and charcoal absorber banks is less than 6 inches of water at the system design flow rate (+10%, -0%).
- b. Operability of inlet heater at rated power when tested in accordance with ANSI N510-1975.
- c. Air distribution is uniform within 20% across the filter train when tested in accordance with ANSI N510-1975.

This page is left intentionally blank

3.7.A.7. Shutdown Requirements

Bases for shutdown requirements are discussed above in conjunction with the individual requirements for primary containment integrity.

B. Standby Gas Treatment System

The standby gas treatment systems are designed to filter and exhaust the Unit 1 secondary containment atmosphere to the off-gas stack during secondary containment isolation conditions, with a minimum release of radioactive materials from these areas, to the environs. The Unit 1 standby gas treatment system fans are designed to automatically start upon receipt of a high radiation signal from either the Unit 1 or Unit 2 refueling floor ventilation exhaust duct monitors or the Unit 1 reactor building ventilation exhaust duct monitors, or upon receipt of a signal from the Unit 1 primary containment isolation system. The Unit 2 standby gas treatment system fans are designed to automatically start, to assist the Unit 1 fans to exhaust the Unit 1 secondary containment atmosphere upon receipt of a high radiation signal from either the Unit 1 or Unit 2 refueling floor ventilation exhaust duct monitors or the Unit 1 reactor building ventilation exhaust duct monitors, or upon receipt of a signal from the Unit 1 primary containment isolation system. In addition, the systems may also be started manually, from the Main Control Room.

In the case of the Unit 1 standby gas treatment system, upon receipt of any of the isolation signals, both fans start, isolation dampers open and each fan draws air from the isolated Unit 1 secondary containment.

In the case of the Unit 2 standby gas treatment system, upon receipt of an isolation signal from the Unit 1 primary containment isolation system, reactor building ventilation exhaust duct monitors, or the Unit 1 or Unit 2 refueling floor ventilation exhaust duct monitors, both fans start, fan supply and discharge dampers open, and the fans draw air from the isolated Unit 1 secondary containment.

Once the SGTS systems have been initiated automatically, the operator may place any one of the Unit 1 and Unit 2 trains in the standby mode provided the remaining train in each unit is operable. Should a failure occur in the remaining operating trains, resulting in air flow reduction below a preset value, the standby systems will restart automatically.

As a minimum for operation, one of the two Unit 1 standby gas treatment trains and one of the two Unit 2 standby gas treatment trains is required to achieve the design differential pressure, given the design building infiltration rate. Once this design differential pressure is achieved, any leakage past the secondary containment boundary shall be inleakage.

A detailed discussion of the standby gas treatment systems may be found in Section 5.3.3.3 of the Unit 1 FSAR, and in Section 6.2.3 of the Unit 2 FSAR.

Any one of the four filter trains has sufficient absorption capacity to provide for cleanup of the Unit 1 secondary containment atmosphere following containment isolation. Any one of the four available standby gas treatment trains may be considered an installed spare. Therefore, with one of the standby gas treatment trains in each unit inoperable, there is no immediate threat to the Unit 1 containment system performance, and reactor operation or fuel handling operations may continue while repairs are being made. Should either or both of the remaining standby gas treatment trains be found to be inoperable, the Unit 1 plant should be placed in a condition that does not require a standby gas treatment system.