

DISTRIBUTION:

~~Gray File~~

NRC PDR  
L PDR  
TERA-2

NSIC  
BB#4 Rdg  
NRR Rdg  
HDenton  
ECase  
RHartfield  
GBennington  
DEisenhut  
RPurple  
JRoe

REGULATORY DOCKET FILE COPY

INovak  
GLainas  
RReid  
RIngram  
DVerrelli  
OELD  
IE-3  
ACRS-16  
BJones-8  
JMurray  
CMiles  
SECY  
RDiggs  
AEOD  
Gray File-2

OCTOBER 24 1980

celi

Dockets Nos. 50-321  
and 50-366

Mr. William Widner  
Vice President - Engineering  
Georgia Power Company  
P. O. Box 4545  
Atlanta, Georgia 30302

Dear Mr. Widner:

SUBJECT: ORDER FOR MODIFICATION OF LICENSES CONCERNING ENVIRONMENTAL  
QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT

Ref. (a) Commission Memorandum and Order of May 23, 1980 (80-CLI-21)  
Ref. (b) Inspection and Enforcement Bulletin Supplement No. 2 to  
IEB-79-01B, September 30, 1980.

This letter transmits an Order for Modification of Licenses which changes the Technical Specifications for Facility Operating Licenses Nos. DPR-57 and NPF-5 for the Edwin I. Hatch Nuclear Plant, Units Nos. 1 and 2. This change is a result of Ref. (a) which required the staff to codify the documentation requirements for the qualification of safety-related electrical equipment. A copy of the Order is being filed with the Office of the Federal Register for publication.

The deadline of November 1, 1980 for submittal of the qualification information is not changed by this Order. Some additional information regarding the file is contained in Ref. (b). Questions regarding this Order should be directed through your Project Manager.

Sincerely,

Original Signed By

Robert W. Reid, Chief  
Operating Reactors Branch #4  
Division of Licensing

Enclosure:  
Order for Modification  
of Licenses

cc w/enclosure: See next page

8011110 600

59

OFFICE	ORB#4:DL	ORB#4:DL	C-ORB#4:DL	ORB#2:DL	D:DL
SURNAME	RIngram/cb	DVerrelli	RReid	M...ams	DEisenhut
DATE	10/24/80	10/27/80	10/24/80	10/24/80	10/24/80



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

October 24, 1980

Dockets Nos. 50-321  
and 50-366

Mr. William Widner  
Vice President - Engineering  
Georgia Power Company  
P. O. Box 4545  
Atlanta, Georgia 30302

Dear Mr. Widner:

SUBJECT: ORDER FOR MODIFICATION OF LICENSES CONCERNING ENVIRONMENTAL  
QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT

Ref. (a) Commission Memorandum and Order of May 23, 1980 (80-CLI-21)  
Ref. (b) Inspection and Enforcement Bulletin Supplement No. 2 to  
IEB-79-01B, September 30, 1980.

This letter transmits an Order for Modification of Licenses which changes the Technical Specifications for Facility Operating Licenses Nos. DPR-57 and NPF-5 for the Edwin I. Hatch Nuclear Plant, Units Nos. 1 and 2. This change is a result of Ref. (a) which required the staff to codify the documentation requirements for the qualification of safety-related electrical equipment. A copy of the Order is being filed with the Office of the Federal Register for publication.

The deadline of November 1, 1980 for submittal of the qualification information is not changed by this Order. Some additional information regarding the file is contained in Ref. (b). Questions regarding this Order should be directed through your Project Manager.

Sincerely,

Robert W. Reid, Chief  
Operating Reactors Branch #4  
Division of Licensing

Enclosure:  
Order for Modification  
of Licenses

cc w/enclosure: See next page

Hatch 1/2  
Georgia Power Company

50-321/366

cc w/enclosure(s):

G. F. Trowbridge, Esq.  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

Director, Criteria and Standards  
Division  
Office of Radiation Programs (ANR-460)  
U. S. Environmental Protection Agency  
Washington, D. C. 20460

Ruble A. Thomas  
Vice President  
P. O. Box 2625  
Southern Services, Inc.  
Birmingham, Alabama 35202

Ozen Batum  
P. O. Box 2625  
Southern Services, Inc.  
Birmingham, Alabama 35202

Charles H. Badger  
Office of Planning and Budget  
Room 610  
270 Washington Street, S.W.  
Atlanta, Georgia 30334

Mr. H. B. Lee, Chairman  
Appling County Commissioners  
County Courthouse  
Baxley, Georgia 31513

Mr. L. T. Gucwa  
Georgia Power Company  
Engineering Department  
P. O. Box 4545  
Atlanta, Georgia 30302

Mr. Max Manry  
Georgia Power Company  
Edwin I. Hatch Plant  
P. O. Box 442  
Baxley, Georgia 31513

U. S. Environmental Protection Agency  
Region IV Office  
ATTN: EIS COORDINATOR  
345 Courtland Street, N.E.  
Atlanta, Georgia 30308

Appling County Public Library  
Parker Street  
Baxley, Georgia 31513

Mr. R. F. Rodgers  
U.S. Nuclear Regulatory Commission  
Route 1, P. O. Box 279  
Baxley, Georgia 31513

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of  
GEORGIA POWER COMPANY, ET AL  
(Edwin I. Hatch Nuclear Plant,  
Units Nos. 1 and 2)

)  
)  
)  
)

Dockets Nos. 50-321  
and 50-366

ORDER FOR MODIFICATION OF LICENSES

I.

The Georgia Power Company (licensee) and three other co-owners are the holders of Facility Operating Licenses Nos. DPR-57 and NPF-5, which authorize the operation of the Edwin I. Hatch Nuclear Plant, Units Nos. 1 and 2, at steady state reactor power levels not in excess of 2436 megawatts thermal (rated power) for each unit. The facilities consist of boiling water reactors located at the licensee's site in Appling County, Georgia.

II.

On November 4, 1977, the Union of Concerned Scientists (UCS) filed with the Commission a "Petition for Emergency and Remedial Relief." The petition sought action in two areas: fire protection for electrical cables, and environmental qualification of electrical components. By Memorandum and Order dated April 13, 1978 (7 NRC 400), the Commission denied certain aspects of the petition and, with respect to other aspects, ordered the NRC staff to take several related actions. UCS filed a Petition for Reconsideration on May 2, 1978. By Memorandum and Order, dated May 23, 1980, the Commission reaffirmed its April 13, 1978 decision regarding the possible shutdown of operating reactors. However, the Commission's May 23, 1980 decision directed licensees and the NRC staff to undertake certain actions.

- 2 -

With respect to environmental qualification of safety-related electrical equipment, the Commission determined that the provisions of the two staff documents - the Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines) and NUREG-0588, "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment," December 1979 (copies attached) "form the requirements which licensees and applicants must meet in order to satisfy those aspects of 10 CFR Part 50, Appendix A General Design Criterion (GDC-4), which relate to environmental qualifications of safety-related electrical equipment." The Commission directed, for replacement parts in operating plants, "unless there are sound reasons to the contrary, the 1974 standard in NUREG-0588 will apply." The Commission also directed the staff to complete its review of the information sought from licensees by Bulletin 79-01B<sup>1</sup> and to complete its review of environmental qualification of safety-related electrical equipment in all operating plants, including the publication of Safety Evaluation Reports, by February 1, 1981. The Commission imposed a deadline that, "by no later than June 30, 1982 all safety-related electrical equipment in all operating plants shall be qualified to the DOR Guidelines or NUREG-0588."

---

<sup>1</sup> Bulletin 79-01B was not sent to licensees for plants under review as part of the staff's Systematic Evaluation Program. The information sought by Bulletin 79-01B was requested from these licensees by a series of letters and meetings during the months of February and March, 1980.

The Commission requested the staff to, "keep the Commission and the public apprised of any further findings of incomplete environmental qualification of safety-related electrical equipment, along with corrective actions taken or planned," and requested the staff to provide bi-monthly progress reports to the Commission.

The Commission further directed that, "In order to leave no room for doubt on this issue, the staff is to prepare additional Technical Specifications for all operating plants which codify the documentation requirement paragraph of the Guidelines (paragraph 8.0)." The staff was directed to add these documentation requirements to each license after they were approved by the Commission.

The Commission also pointed out that the various deadlines imposed in its Order, "do not excuse a licensee from the obligation to modify or replace inadequate equipment promptly."

### III.

The Commission has approved the Technical Specification provisions set forth in Section IV below which specify documentation requirements and which specifically impose on the licensee the requirement of the Commission's May 23, 1980 Memorandum and Order that by no later than June 30, 1982 all safety-related electrical equipment shall be qualified to the DOR Guidelines or NUREG-0588.

The information developed during the Commission review of the UCS Petition emphasizes the importance of prompt completion of the upgrading of

environmental qualification of safety-related electrical equipment to conform to the DOR Guidelines or NUREG-0588 and of adequate documentation of equipment qualifications. The deadlines set forth in the Commission's Memorandum and Order dated May 23, 1980, assure that such upgrading will be accomplished promptly. In order to assure prompt completion of necessary qualification work or replacement of unqualified components, if necessary, in conformance with the requirements of the Commission's Memorandum and Order dated May 23, 1980, and to provide complete and adequate documentation as promptly as possible, such upgrading and documentation work must commence immediately. Therefore, I have concluded that the public health, safety and interest require this Order for Modification of License to be effective immediately.

#### IV.

Accordingly, pursuant to the Atomic Energy Act of 1954, as amended, and the Commission's Rules and Regulations in 10 CFR Parts 2 and 50, IT IS ORDERED THAT EFFECTIVE IMMEDIATELY Facility Operating Licenses Nos. DPR-57 and NPF-5 are hereby amended to add the following provisions to the Appendix A Technical Specifications.

- (a) "By no later than June 30, 1982, all safety-related electrical equipment in the facilities shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588, "Interim Staff Position on Environmental

Qualification of Safety-Related Electrical Equipment," December 1979. Copies of these documents are attached to Order for Modification of Licenses DPR-57 and NPF-5 dated October 24, 1980.

- (b) "By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified."

To effectuate the foregoing, appropriate pages for incorporation into the Technical Specifications are attached to this Order.

V.


The licensee or any person whose interest may be affected by this Order may request a hearing within 20 days of the date of publication of this Order in the Federal Register. Any request for a hearing will not stay the effective date of this Order. Any request for a hearing shall be addressed to the Director, Office of Nuclear Reactor Regulation, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555. A copy of the request should also be sent to the Executive Legal Director, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, and to G. F. Trowbridge, Esquire, Shaw, Pittman, Potts and Trowbridge, 1800 M Street, NW, Washington, DC 20036, attorney for the licensee.

If a hearing is held concerning this Order, the issues to be considered at the hearing shall be:

- a. whether the licensee should be required to have the environmental qualification records referred to in Section IV, above, available at a central location by no later than December 1, 1980; and
- b. whether all safety-related electrical equipment should be qualified as required in Section IV, above, by no later than June 30, 1982.

Operation of the facility on terms consistent with this Order is not stayed by the pendency of any proceedings on the Order.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Darrell G. Wisenburt, Director  
Division of Licensing  
Office of Nuclear Reactor Regulation

Effective Date: October 24, 1980  
Bethesda, Maryland

Attachments:

1. Technical Specification Pages
2. Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors
3. NUREG-0588, Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment.

## ADMINISTRATIVE CONTROL

### RECORD RETENTION (Continued)

- c. Records of radiation exposure for all individuals entering radiation control areas.
- d. Records of gaseous and liquid radioactive material released to the environs.
- e. Records of transient or operational cycles for those unit components identified in Table 5.7.1-1.
- f. Records of reactor tests and experiments.
- g. Records of training and qualification for current members of the unit staff.
- h. Records of in-service inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities required by the QA Manual.
- j. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10 CFR 50.59.
- k. Records of meetings of the PRB and the SRB.
- l. Records for Environmental Qualification which are covered under the provisions of paragraph 6.15.

### 6.11 RADIATION PROTECTION PROGRAM

Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

### 6.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.203(c)(2) of 10 CFR 20, each high radiation area in which the intensity of radiation is greater than 100 mrem/hr but less than 1000 mrem/hr shall be barricaded and conspicuously posted as a high radiation area and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit\*. Any individual or group of individuals permitted

\*Health Physics personnel, or personnel escorted by Health Physics personnel in accordance with approved emergency procedures, shall be exempt from the RWP issuance requirement during the performance of their assigned radiation protection duties, provided they comply with approved radiation protection procedures for entry into high radiation areas.

HATCH - UNIT 1

- 6-20

Amendment No. 65, Order dtd.  
October 24, 1980

## ADMINISTRATIVE CONTROL

### 6.15 ENVIRONMENTAL QUALIFICATION

6.15.1 By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of Licenses DPR-57 and NPF-5 dated October 24, 1980.

6.15.2 By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.

## ADMINISTRATIVE CONTROL

### RECORD RETENTION (Continued)

- c. Records of radiation exposure for all individuals entering radiation control areas.
- d. Records of gaseous and liquid radioactive material released to the environs.
- e. Records of transient or operational cycles for those unit components identified in Table 5.7.1-1.
- f. Records of reactor tests and experiments.
- g. Records of training and qualification for current members of the unit staff.
- h. Records of in-service inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities required by the QA Manual.
- j. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10 CFR 50.59.
- k. Records of meetings of the PRB and the SRB.
- l. Records for Environmental Qualification which are covered under the provisions of paragraph 6.15.

### 6.11 RADIATION PROTECTION PROGRAM

Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

### 6.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.203(c)(2) of 10 CFR 20, each high radiation area in which the intensity of radiation is greater than 100 mrem/hr but less than 1000 mrem/hr shall be barricaded and conspicuously posted as a high radiation area and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit\*. Any individual or group of individuals permitted

\*Health Physics personnel, or personnel escorted by Health Physics personnel in accordance with approved emergency procedures, shall be exempt from the RWP issuance requirement during the performance of their assigned radiation protection duties, provided they comply with approved radiation protection procedures for entry into high radiation areas.

## ADMINISTRATIVE CONTROL

### 6.15 ENVIRONMENTAL QUALIFICATION

6.15.1 By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of Licenses DPR-57 and NPF-5 dated October 24, 1980.

6.15.2 By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.