

Docket No.: 50-321

Mr. J. T. Beckham, Jr.
Vice President - Nuclear Generation
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

APR 08 1986

Dear Mr. Beckham:

By letter dated January 17, 1986, the Commission issued Amendment No. 121 to Facility Operating License No. DPR-57 for the Edwin I. Hatch Nuclear Plant, Unit No. 1. This amendment revised the Technical Specifications (TSs) related to surveillance frequencies and trip setpoints associated with the ATTS equipment. This amendment inadvertently omitted changes on TS page 3.1-4 which had been made by Amendment Nos. 105 and 113 issued December 31, 1984 and August 27, 1985, respectively. Accordingly, updated TS page 3.1-4 is enclosed. Please incorporate this updated page into your TSs. We apologize for any inconvenience caused by this oversight.

Sincerely,

Original signed by:

George W. Rivenbark, Project Manager
BWR Project Directorate #2
Division of BWR Licensing

Enclosure:
As stated

cc w/enclosures:
See next page

DISTRIBUTION

- Docket File
- NRC PDR
- Local PDR
- RBernero
- SNorris
- GRivenbark
- OELD
- LHarmon
- EJordan
- BGrimes
- JPartlow
- TBarnhardt (4)
- WJones
- FOB, Vasallo
- ACRS (10)

OFFICIAL RECORD COPY

DBL:PD#2
SNorris:mc
4/8/86

DBL:PD#2
GRivenbark
4/8/86

DBL:PD#2:D
DM...
4/15/86

8604210161 860408
PDR ADOCK 05000321
P PDR

Mr. J. T. Beckham, Jr.
Georgia Power Company

Edwin J. Hatch Nuclear Plant,
Units Nos. 1 and 2

cc:

Bruce W. Churchill, Esquire
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

Mr. L. T. Gucwa
Engineering Department
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Mr. H. C. Nix, Jr., General Manager
Edwin J. Hatch Nuclear Plant
Georgia Power Company
P. O. Box 442
Baxley, Georgia 31513

Mr. Louis B. Long
Southern Company Services, Inc.
P. O. Box 2625
Birmingham, Alabama 35202

Resident Inspector
U.S. Nuclear Regulatory Commission
Route 1, P. O. Box 279
Baxley, Georgia 31513

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission,
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Mr. Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, S.W.
Atlanta, Georgia 30334

Mr. J. Leonard Ledbetter, Commissioner
Department of Natural Resources
270 Washington Street, N.W.
Atlanta, Georgia 30334

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513

Amendments Nos. 30, 39, 91, 103, 105, 113, 121
 3.1-4

Table 3.1-1 (Continued)

Scram Number (a)	Source of Scram Trip Signal	Operable Channels Required Per Trip System (b)	Scram Trip Setting	Source of Scram Signal is Required to be Operable Except as Indicated Below
5	High Drywell Pressure	2	≤ 1.92 psig	Not required to be operable when primary containment integrity is not required.
6	Reactor Vessel Water Level (Low) (Level 3)	2	≥ 10.0 inches	
7	Scram Discharge Volume High High Level			Permissible to bypass (initiates control rod block) in order to reset RPS when the Mode Switch is in the REFUEL or SHUTDOWN position.
	a. Float Switches	2	≤ 71 gallons	
	b. Thermal Level Sensors	2	≤ 71 gallons	
8	APRM Flow Referenced Simulated Thermal Power Monitor	2	$S \leq 0.58W+62\%$ (Not to exceed 117%) Tech Spec 2.1.A.1.c(1)	
	Fixed High High Neutron Flux	2	$S \leq 120\%$ Power Tech Spec 2.1.A.1.c(2)	
	Inoperative	2	Not Applicable	An APRM is inoperable if there are less than two LPRM inputs per level or there are less than 11 LPRM inputs to the APRM channel.

8604210164 860408
 PDR ADDCK 05000321
 PDR