

Docket No. 50-321

DISTRIBUTION

JAN 17 1986

Mr. J. T. Beckham, Jr.
Vice President - Nuclear Generation
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Docket File
NRC PDR
L PDR
BWRPD#2
RBernero
OELD
OPA
LHarmon
ACRS-10
TBarnhart-84
EJordan
BGrimes
WJones
FOB, BWR
LFMB
JPartlow
SNorris
GRivenbark
Gray File

Dear Mr. Beckham: *SEE PROPOSED TECH
SPEC'S CHANGES*

The Commission has issued the enclosed Amendment No. 121 to Facility Operating License No. DPR-57 for the Edwin I. Hatch Nuclear Plant, Unit No. 1. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated July 24, 1985.

The amendment revises the TSs for Hatch Unit 1 to support the installation of the analog transmitter trip system (ATTS). It includes changes to the surveillance frequencies and trip setpoints associated with the ATTS equipment.

As discussed with your staff, we have concluded that the existing upper bound pressure limit of 500 psig on the permissive signal for opening the CS and LPCI injection valves must be retained and have, therefore not approved the requested pressure setpoint valve changes for the permissive signals for these valves.

A copy of our Safety Evaluation and Notice of Issuance are also enclosed.

Sincerely,

Original signed by

George W. Rivenbark, Project Manager
BWR Project Directorate #2
Division of BWR Licensing

Enclosures:

- 1. Amendment No. 121
- 2. Safety Evaluation

cc w/enclosures:
See next page

8602120686 860117
PDR ADDCK 05000321
P PDR

BWRPD#2
SNorris
1/16/85

[Signature]
BWRPD#2
GRivenbark:nc
1/16/85

BWRPD#2
DM Ter
1/17/85

Previously concurred in by
OELD
Goddard
1/2/85 86

Mr. J. T. Beckham, Jr.
Georgia Power Company

Edwin J. Hatch Nuclear Plant,
Units Nos. 1 and 2

cc:

G. F. Trowbridge, Esq.
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

Mr. L. T. Gucwa
Engineering Department
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Mr. H. C. Nix, Jr., General Manager
Edwin J. Hatch Nuclear Plant
Georgia Power Company
P. O. Box 442
Baxley, Georgia 31513

Mr. Louis B. Long
Southern Company Services, Inc.
P. O. Box 2625
Birmingham, Alabama 35202

Resident Inspector
U.S. Nuclear Regulatory Commission
Route 1, P. O. Box 279
Baxley, Georgia 31513

Regional Administrator, Region JJ
U.S. Nuclear Regulatory Commission,
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Mr. Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, S.W.
Atlanta, Georgia 30334

Mr. J. Leonard Ledbetter, Commissioner
Department of Natural Resources
270 Washington Street, N.W.
Atlanta, Georgia 30334

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513