December 23,	1985	
Dockets Nos. 50-321	DISTRIBUTION	
and 50-366	Docket File	EJordan
	NRC PDR	BGrimes
	L PDR	WJones
Mr. J. T. Beckham, Jr.	DBLPD#2 Rdg	FOB, BWR
Vice President - Nuclear Generation	RBernero	LFMB
Georgia Power Company	OELD	JPartlow
P. 0. Box 4545	OPA	SNorris
Atlanta, Georgia 30302	LHarmon	GRivenbark
	ACRS-10	Gray File-4
Dear Mr. Beckham:	⊤Barnhart-8	·

December 00 1000

The Commission has issued the enclosed Amendment No.119 to Facility Operating License No. DPR-57 for the Edwin J. Hatch Nuclear Plant, Unit No. 1. The amendment consists of changes to the Technical Specifications (TSs) in partial response to your application dated August 1, 1985.

The amendment revises the TSs for Hatch Unit 1 to update the inservice inspection requirements pursuant to 10 CFR 50.55a(g)(4)(ii). These changes are needed, in part, to help support completion of the first ten-year inservice inspection interval during the Hatch Unit 1 maintenance/refueling outage scheduled to begin November 30, 1985. Other changes requested in your August 1, 1985, application are under review and will be addressed separately.

A copy of our Safety Evaluation and the Notice of Issuance are enclosed.

Sincerely,

Original signed by

George W. Rivenbark, Project Manager Project Directorate #2 Division of BWR Licensing

Enclosures:

1. Amendment No. 119

.

- 2. Safety Evaluation
- 3. Notice

cc w/enclosures: See next page

#### 8401090099 851223 PDR ADOCK 05000321 P PDR

\*See previous white for concurrences.

DBL:PD#2	DBL:PD#2	DBL:PD#2	0ELD
SNorris*	GRivenbark;cr*	DMuller*	Goddard*
11/18/85	11/19/85	11/19/85	11/25/85
12/9/85			

Mr. J. T. Beckham, Jr. Georgia Power Company Edwin J. Hatch Nuclear Plant, Units Nos. 1 and 2

cc: G. F. Trowbridge, Esq. Shaw, Pittman, Potts and Trowbridge 1800 M Street, N.W. Washington, D.C. 20036

Mr. L. T. Gucwa Engineering Department Georgia Power Company P. O. Box 4545 Atlanta, Georgia 30302

Mr. H. C. Nix, Jr., General Manager Edwin J. Hatch Nuclear Plant Georgia Power Company P. O. Box 442 Baxley, Georgia 31513

Mr. Louis B. Long Southern Company Services, Jnc. P. O. Box 2625 Birmingham, Alabama 35202

Resident Inspector U.S. Nuclear Regulatory Commission Route 1, P. O. Box 279 Baxley, Georgia 31513

Regional Administrator, Region JJ U.S. Nuclear Regulatory Commission, 101 Marietta Street, Suite 3100 Atlanta, Georiga 30303

Mr. Charles H. Badger Office of Planning and Budget Room 610 270 Washington Street, S.W. Atlanta, Georgia 30334

Mr. J. Leonard Ledbetter, Commissioner Department of Natural Resources 270 Washington Street, N.W. Atlanta, Georgia 30334

يم الم الم المالية الم مع الم الم

Chairman Appling County Commissioners County Courthouse Baxley, Georgia 31513 ~~



#### UNITED STATES NU^1.EAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

#### GEORGIA POWER COMPANY

#### OGLETHORPE POWER CORPORATION

#### MUNICIPAL ELECTRIC AUTHORITY OF GEORGIA

#### CITY OF DALTON, GEORGIA

#### DOCKET NO. 50-321

#### EDWIN J. HATCH NUCLEAR PLANT, UNIT NO. 1

#### AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 119 License No. DPR-57

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Georgia Power Company, et al., (the licensee) dated August 1, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter J;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-57 is hereby amended to read as follows:

. . .

8601090109 851223 PDR ADUCK 05000321 P PDR

#### Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 119, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION RMM

Daniel R. Muller, Director Project Directorate #2 Division of BWR Licensing

Attachment: Changes to the Technical Specifications

Date of Issuance: December 23, 1985

and a second second

والأجاب والمعقور والمعقور والمراجع المتحد والمراجع والمراجع والمراجع والمراجع والمراجع والمراجع

#### ATTA-IMENT TO LICENSE AMENDMENT NO. 1-3

#### FACILITY OPERATING LICENSE NO. DPR-57

#### DOCKET NO. 50-321

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

Remove	Insert
iv	iv
ix	ix
3.6-9b	3.6-9b
3.6-10	3.6-10
3.6-11	3.6-11 through $3.6-14$ (blank page)
3.6-12	
3.6-13	
3.6-14	
3.6-23	3.6-23
3.6-24	3.6-24 through $3.6-30$ (blank page)
3.6-25	
3.6-26	
3 6-27	
3.6-28	
3 6-29	
3-6-30	

. ....

in the second 

Sect	lion	<u>s</u>	ection	Page
	LIMITING CONDITIONS FOR OPERAT	ION	SURVEILLANCE P	CUIREMENTS
3.6	PRIMAPY SYSTEM BOUNDARY	4	.6 PRIMARY SYSTEM BOUNDAPY	3.6-1
<b>A.</b>	Reactor Coolant Heatup and Cooldown	A	. Reactor Coolant Heatup and Cooldown	3.6-1
в.	Reactor Vessel Temperature and Pressure	Ð.	Reactor vessel Temperature and Pressure	3.6-1
с.	Reactor Vessel Head Stud Tensioning	C.	Reactor Vessel Head Stud Tensioning	3.6-2
D.	Idle Recirculation Loop Startup	D.	Idle Recirculation Loop Startup	3.6-2
E.	Recirculation Pump Start	E.	Recirculation Pump Start	3.6-3
F.	Reactor Coolant Chemistry	F.	Reactor Coolant Chemistry	3.6-4
G.	Reactor Coolant Leakage	G.	Reactor Coolant Leakage	3.6-7
H.	Safety and Relief Valves	H.	Safety and Relief Valves	3.6-9
I.	Jet Pumps	I.	Jet Pumps	3.6-9
J.	Recirculation Pump Speeds	J.	Recirculation Pump Speeds	3.6-10
Κ.	Structural Integrity	ĸ.	Structural Integrity	3.6-10
L.	Snubbers	L.	Snubbers	3.6-10a
3.7	CONTAINMENT SYSTEMS	4.7	CONTAINMENT SYSTEMS	3.7-1
Α.	Primary Containment	A.	Primary Containment	3.7-1
<b>B.</b>	Standby Gas Treatment System	в.	Standby Gas Treatment System	3.7-10
с.	Secondary Containment	c.	Secondary Containment	3.7-12 ·
D.	Frimary Containment Isolation Valves	D.	Primary Containment Isolation Valves	3.7-13
3.8	RADIOACTIVE MATERIALS	4.8	RADIOACTIVE MATERIALS	3.8-1
<b>A.</b>	Miscellaneous Radioactive Materials Sources	<b>A.</b>	Miscellaneous Radioactive Materials Sources	3.8-1
3.9	AUXILIARY ELECTRICAL SYSTEMS	4.9	AUXILIARY ELECTRICAL SYSTEMS	3.9-1
Α.	Requirements for Reactor Startup	<b>A.</b>	Auxiliary Electrical Systems Buigment	3.9-1

.....

iv

Amendment No. 37, 172, 119

۰.

# LIST OF TABLES (Continued)

### <u>Table</u>

### <u>Title</u>

### Page

3.7-1	Primary Containment Isolation Valves	3.7-16
3.7-2	Testable Penetrations with Double O-Ring Seals	3.7-21
3.7-3	Testable Penetrations with Testable Bellows	3.7-22
3.7-4	Primary Containment Testable Isolation Valves	3.7-23
3.13-1	Fire Detectors	3.13-2
3.13-2	Fire Hose Stations	3.13-9
3.14.1-1	Radioactive Liquid Effluent Monitoring Instrumentation	3.14-2
3.14.2-1	Radioactive Gaseous Effluent Monitoring Instrumentation	3.14-7
4.14.1-1	Radioactive Liquid Effluent Monitoring Instrumentation Surveillance Requirements	3.14-4
4.14.2-1	Radioactive Gaseous Effluent Monitoring Instrumentation Surveillance Requirements	3.14-11
4.15.1-1	Radioactive Liquid Effluent Sampling and Analysis Program	3.15-2
4.15.2-1	Radioactive Gaseous Waste Sampling and Analysis Program	3.15-10
3.16.1-1	Radiological Environmental Monitoring Program	3.16-4
<b>3.16.1-2</b>	Reporting Levels for Radioactivity Concentra- tions in Environmental Samples	3.16-7
4.16.1-1	Lower Limit of Detection	3.16-8
6.2.2-1	Minimum Shift Crew Composition	6-4
6.9.1.7-1	Environmental Radiological Monitoring Program Summary	6-18
6.9.2-1	Special Reporting Requirements	6-19

Amendments Nos. \$\$, \$9, 779, 172, 119 ix

and/or the low low set function of more than one c the above required reactor c lant system relief/safety valves inoperable, be in at least HOT SHUTDOWN within 12 hours and in COLD SHUTDOWN within the next 24 hours.

#### 3.6.I Jet Pumps

Whenever the reactor is in the Start & Hot Standby or Run Mode with both recirculating pumps operating, all jet pumps shall be operable. If it is determined that a jet pump is inoperable, an orderly shutdown shall be initiated and the reactor shall be in the Cold Shutdown Condition within 24 hours.

#### 3.5.J. Recirculation Pump Speeds

- 1. Core thermal power shall not exceed 1% of rated thermal power without forced recirculation.
- 2. Operation with a single recirculation pump is permitted for 24 hours unless the recirculation pump is sooner made operable. With one recirculation pump not in operation, initiate action within 15 minutes or continue action to reduce reactor power to or below the limit specified in Figure 3.6-5 within 2 hours. If the pump cannot be made operable or the limit of Figure 3.6-5 cannot be met within the required time, the reactor shall be in cold shutdown within 24 hours.
- 3. Following one pump operation the discharge value of the low speed pump may not be opened unless the speed of the faster pump is less than 50% of its rated speed.

#### 4.6 I. Jet Pumps

Whenever both recirculating pumps are operating with the reactor in the Start & Hot Standby or Run Mode, jet pump operability shall be checked daily by verifying that the following conditions do not occur simultaneously.

- 1. The two recirculation loops have a flow imbalance of 15% or more when the pumps are operated at the same speed.
- 2. The indicated value of core flow rate varies from the value derived from loop flow measurements by more than 10%.
- 3. The diffuser to lower plenum differential pressure reading on an individual jet pump vary from the mean of all jet pump differential pressures by more than 10%.

4.6.J. Recirculation Pump Speeds

Recirculation pump speeds shall be recorded at least once per day.

Amendment No. 105 119

3.6-9b

3.6.K STRUCTURAL INTEGRITY

#### 1. Normal Condition

The structural integrity of ASME Code Class 1, 2, and 3 (equivalent) components shall be maintained in accordance with the Surveillance Requirements of Specification 4.6.K.

#### 2. Off-Normal Conditions

- a. With the structural integrity of any ASME Code Class 1 component not conforming to the above requirements, restore the structural integrity of the affected component(s) to within its limit or isolate the affected component(s) prior to increasing the Reactor Coolant System temperature more than 50°F above the minimum temperature required by NDT considerations.
- b. With the structural integrity of any ASME Code Class 2 component(s) not conforming to the above requirements, restore the structural integrity of the affected component(s) to within its limit or isolate the affected component(s) prior to increasing the Reactor Coolant System temperature above 212°F.
- c. With the structural integrity of any ASME Code Class 3 component(s) not conforming to the above requirements, restore the structural integrity of the affected component(s) to within its limit or isolate the affected component(s) from service.

#### 4.6.K STRUCTURAL INTEGRITY

Surveillance Requirements for in-service inspection and testing of ASME Code Class 1, 2, and 3 (equivalent) components shall be applicable as follows:

- 1. In-service inspection of ASME
  Code Class 1, 2, and 3 (equivalent)
  components and in-service testing
  of ASME Code Class 1, 2, and 3
  (equivalent) pumps and valves shall
  be performed in accordance with
  Section XI of the ASME Boiler and
  Pressure Vessel Code and applicable
  Addenda as required by 10CFR50,
  Section 50.55a(g), except where
  specific relief has been
  granted by the Commission pursuant
  to 10CFR50, Section 50.55a(g)
  (6)(i).
- 2. Performance of the above in-service inspection and testing activities shall be in addition to other specified Surveillance Requirements.
- 3. Nothing in the ASME Boiler and Pressure Vessel Code shall be construed to supersede the requirements of any Technical Specification.

Amendment No. 37, 42, 703, 119

3.6-10

These pages have been left blank.

Amendment No. 84, 119

3.6-11 through 3.6-14

#### 3.6.K STRUCTURAL INTEGRITY

In-service inspection of ASME Code Class 1, 2, and 3 (equivalent) components and in-service testing of ASME Code Class 1, 2, and 3 (equivalent) pumps and valves shall be performed in accordance with a periodically updated version of Section XI of the ASME Boiler and Pressure Vessel Code and Addenda as required by 10CFR50.55a(g). This objective will maintain the structural integrity of safety-related components, pumps, and valves which are necessary to safely shut down the plant or mitigate the consequences of an accident.

Amendment Nô. 119

3.6-23

These pages have been left blank.

Amendment No. 119 3.6-24 through 3.6-30

÷



#### UNITED STATES N\_LEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

## SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

## SUPPORTING AMENDMENT NO. 119 TO FACILITY OPERATING LICENSE NO. DPR-57

GEORGIA POWER COMPANY OGLETHORPE POWER CORPORATION MUNICIPAL ELECTRIC AUTHORITY OF GEORGIA CITY OF DALTON, GEORGIA

## EDWIN J. HATCH NUCLEAR PLANT, UNIT NO. 1

#### DOCKET NO. 50-321

#### 1.0 INTRODUCTION

In the Spring and Fall of 1976, the Nuclear Regulatory Commission sent guidance to power plant licensees regarding the implementation of 10 CFR 50.55a(g) - Inservice Inspection requirements. That guidance directed licensees to submit proposed Technical Specification changes to incorporate standard language referencing 50.55a(g).

In accordance with the provisions of 10 CFR 50.90, as required by 10 CFR 50.59(c), Georgia Power Company (GPC) submitted a request dated August 1, 1985, to amend the Edwin J. Hatch Nuclear Plant, Unit 1, Technical Specifications (Appendix A to Facility Operating License DPR-57) to update the inservice inspection requirements pursuant to 10 CFR 50.55a(g)(4)(ii). The proposed Technical Specification changes are needed, in part, to help support completion of the first ten-year inservice inspection interval during the Hatch Unit 1 maintenance/ refueling outage scheduled to begin November 30, 1985.

#### 2.0 EVALUATION

The August 1, 1985, submittal includes a request for changes to other surveillance requirements in addition to those directed at updating the inservice inspection requirements pursuant to 10 CFR 50.55a(g)(4)(ii). This evaluation concerns only those portions of the submittal related to the 10 CFR 50.55a(g)(4)(ii) inservice inspection update. Specifically, we have reviewed the proposed changes on pages 3.6-10 through 3.6-14 and 3.6-23 through 3.6-30 of the Technical Specifications. The other changes requested by the August 1, 1985, submittal are being handled separately.

The proposed changes replace current requirements which do not specify the Code requirements with new requirements that specifically state that inservice inspection of ASME Code Class 1, 2 and 3 (equivalent) components and inservice testing of ASME Code Class 1, 2 and 3 (equivalent) pump and valves shall be performed in accordance with Section XJ of the ASME Boiler and Pressure Vessel Code and applicable addenda.

8601090127 851223 PDR ADOCK 05000321 P PDR These proposed changes ensure that inservice inspection of components and piping will be performed in accordance with periodically updated editions and addenda of Section XJ of the ASME Boiler and Pressure Vessel Code. The inspection and testing programs include ASME Code Class, 1, 2 and 3 components and piping (including supports) and will provide assurance that the structural integrity of these components and piping will be maintained at an acceptable level throughout the life of the plant.

Based upon the above evaluation, we conclude that the proposed changes represent an increase in the safety of the plant and therefore are acceptable.

#### 3. ENVJRONMENTAL CONSIDERATION

An Environmental Assessment and Finding of No Significant Impact has been issued for this amendment.

#### 4. CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: December 23, 1985

Principal Contributor: B. Turovlin

and the second second

## U.S. NUCLEAR REGULATORY COMMISSION <u>GEORGIA POWER COMPANY, ET AL</u> <u>DOCKET NO. 50-321</u> <u>NOTICE OF ISSUANCE OF AMENDMENT TO</u> FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No.119 to Facility Operating License No. DPR-57, issued to Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority for Georgia, City of Dalton, Georgia (the licensees), which revised the Technical Specifications (TSs) for operation of the Edwin J. Hatch Nuclear Plant, Unit No. 1 (the facility) located in Appling County, Georgia. The amendment is effective as of the date of its issuance and shall be implemented within 30 days.

This amendment revises the TSs for Hatch Unit 1 to update the inservice inspection requirements pursuant to 10 CFR 50.55a(g)(4)(ii). These changes are needed, in part, to help support completion of the first ten-year inservice inspection interval during the Hatch Unit 1 maintenance/refueling outage scheduled to begin November 30, 1985. Other changes requested in the licensee's August 1, 1985, application are being addressed separately.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

8601070130 851223

7590-01

7590-01

Notice of Consideration of Issuance of Amendment and Opportunity for Prior Hearing in connection with this action was published in the FEDERAL REGISTER on August 26, 1985, 50 FR 34560. No request for a hearing or petition for leave to intervene was filed following this notice.

Also, in connection with this action, the Commission prepared an Environmental Assessment and Finding of No Significant Impact which was published in the FEDERAL REGISTER on December 16, 1985 (50FR51315).

For further details with respect to this action, see (1) the application for amendment dated August 1, 1985, (2) Amendment No. 119 to License No. DPR-57, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. 20555, and at the Appling County Public Library, 301 City Hall Drive, Baxley, Georgia 31513. A copy of items (2) and (3) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 23rd day of December 1985.

EOR THE NUCLEAR REGULATORY COMMISSION

Daniel R. Muller, Director Project Directorate #2 Division of BWR Licensing