

October 27, 1986

Docket No. 50-321

Mr. J. T. Beckham, Jr.
Vice President - Nuclear Generation
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Dear Mr. Beckham:

On September 25, 1986, the Commission issued Amendment No. 129 to Facility Operating License No. DPR-57 for the Edwin I. Hatch Nuclear Plant, Unit No. 1. We inadvertently left out revised Technical Specification page 3.17.3 that was changed, as discussed in the associated September 25, 1986 Safety Evaluation for Amendment No. 129, to delete the reference to Table 3.7-1 from Technical Specification Section 3.7.D.1. We are enclosing the revised page 3.7.13 and the revised insertion instructions to reflect this correction.

We regret any inconvenience this omission may have created.

Sincerely,



George W. Rivenbark, Project Manager
BWR Project Directorate #2
Division of BWR Licensing

Enclosure:
As stated

cc w/enclosure:

See next page
Distribution:

Docket File	EJordan
NRC PDR	BGrimes
L PDR	WJones
RBernero	DVassallo
LFMB	SECY
OGC-Beth	JPartlow
OPA	SNorris
LHarmon	GRivenbark
ACRS-10	Gray File
TBarnhart-4	EButcher

BWR:PD#2
SNorris
10/29/86


BWR:PD#2
GRivenbark
10/27/86

BWR:PD#2
DButler
10/27/86

8610300073 861027
PDR ADDOCK 05000321
P PDR

Mr. J. T. Beckham, Jr.
Georgia Power Company

Edwin I. Hatch Nuclear Plant,
Units Nos. 1 and 2

cc:

Bruce W. Chruchill, Esquire
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N.W.
Washington, D.C. 20037

Mr. L. T. Gucwa
Engineering Department
Georgia Power Company
Post Office Box 4545
Atlanta, Georgia 30302

Mr. H. C. Nix, Jr., General Manager
Edwin I. Hatch Nuclear Plant
Georgia Power Company
Post Office Box 442
Baxley, Georgia 31513

Mr. Louis B. Long
Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202

Resident Inspector
U.S. Nuclear Regulatory Commission
Route 1, Post Office Box 279
Baxley, Georgia 31513

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission,
101 Marietta Street, Suite 2900
Atlanta, Georgia 30303

Mr. Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, S.W.
Atlanta, Georgia 30334

Mr. J. Leonard Ledbetter, Commissioner
Department of Natural Resources
270 Washington Street, N.W.
Atlanta, Georgia 30334

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513

ATTACHMENT TO LICENSE AMENDMENT NO. 129

FACILITY OPERATING LICENSE NO. DPR-57

DOCKET NO. 50-321

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised areas are identified by Amendment number and contain a vertical line indicating the area of change.

<u>Remove</u>	<u>Insert</u>
ix	ix
3.7-13	3.7-13
3.7-16	3.7-16
-----	3.7-16a
3.7-17	3.7-17
3.7-18	3.7-18
-----	3.7-18a
-----	3.7-18b
3.7-19	3.7-19
-----	3.7-19a
3.7-23	3.7-23
3.7-24	3.7-24
3.7-25	3.7-25
3.7-26	3.7-26
-----	3.7-26a
-----	3.7-26b
3.7.27	3.7-27

4.7.C.1. Surveillance While Integrity Maintained (Cont'd)

- b. Secondary containment capability to maintain a minimum 1/4-inch of water vacuum under calm wind (5 mph) conditions with each filter train flow rate not more than 4000 cfm shall be demonstrated at each refueling outage, prior to refueling.

3.7.C.2. Violation of Secondary Containment Integrity

- a. Without Hatch-Unit 1 secondary containment integrity, restore Hatch - Unit 1 secondary containment integrity within 4 hours, or perform the following (as applicable):
- (1) Suspend irradiated fuel and/or fuel cask handling in the Hatch-Unit 1 secondary containment.
 - (2) Be in at least Hot Shutdown within the next 12 hours and meet the Conditions of 3.7.C.1.a. within the next 24 hours.
- b. Without Hatch-Unit 1 secondary containment, refer to the following Hatch-Unit 2 Technical Specification, for LCO's to be followed for Hatch-Unit 2:
- (1) Section 3.6.5.1.
 - (2) Section 3.9.5.1.

2. Surveillance After Integrity Violated

After a secondary containment violation is determined the standby gas treatment system will be operated immediately after the affected zones are isolated from the remainder of the secondary containment. The ability to maintain the remainder of the secondary containment at 1/4-inch of water vacuum pressure under calm (5 mph) wind conditions shall be confirmed.

D. Primary Containment Isolation Valves1. Valves Required to be Operable

During reactor power operation, all primary containment isolation valves and all reactor coolant system instrument line excess flow check valves shall be operable except as stated in Specification 3.7.D.2.

D. Primary Containment Isolation Valves1. Surveillance of Operable Valves

Surveillance of the primary containment isolation valves shall be performed as follows:

- a. At least once per operating cycle the operable isolation valves that are power operated and automatically initiated shall be tested for simulated automatic initiation and the closure times.

8610300078 861027
PDR ADDCK 05000321
P PDR