

June 10, 1987

Dockets Nos.: 50-321
and 50-366

Mr. James P. O'Reilly
Senior Vice President - Nuclear Operations
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

SEE PROPOSED CHANGES
TO TECH SPECS

Dear Mr. O'Reilly:

Subject: Issuance of Amendment Nos. 141 and 77 to Facility Operating Licenses
DPR-57 and NPF-5 - Edwin I. Hatch Nuclear Plant, Units 1 and 2
(TACS 61900/61901)

The Commission has issued the enclosed Amendments Nos. 141 and 77 to Facility Operating Licenses DPR-57 and NPF-5, for the Edwin I. Hatch Nuclear Plant, Units 1 and 2. The amendments consist of changes to the Technical Specifications in response to your application dated June 20, 1986, as supplemented by letters dated July 22, 1986, and January 2, 1987.

The amendments modify the Technical Specifications to permit operation with only one recirculation loop in operation and to implement the jet pump surveillance recommendations of NUREG/CR-3052 "BWR Jet Pump Assembly Failure."

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Bi-Weekly Federal Register Notice.

Sincerely,

Lawrence P. Crocker, Project Manager
Project Directorate II-3
Division of Reactor Projects-I/II

Enclosures:

1. Amendment No. 141 to DPR-57
2. Amendment No. 77 to NPF-5
3. Safety Evaluation

cc w/enclosures:
See next page

PD#II-3/DRP-I/II
MDuncan/mac
05/29/87

PD#II-3/DRP-I/II
LCrocker
05/29/87

PD#II-3/DRP-I/II
BJYoungblood
06/9/87

8706170584 870610
PDR ADOCK 05000321
P PDR

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-57 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 141, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

14

B. J. Youngblood, Director
Project Directorate II-3
Division of Reactor Projects-I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 10, 1987

PD#II-3/DRP-I/II
MDuncan/mac
05/29/87

PD#II-3/DRP-I/II
LCrocker
05/29/87

OGC-Bethesda
M. Karhian
06/01/87

PD#II-3/DRP-I/II
B. Youngblood
06/09/87

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-5 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 77, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

151

B. J. Youngblood, Director
Project Directorate II-3
Division of Reactor Projects-I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 10, 1987

PD#II-3/DRP-I/II
MDuncan/mac
05/29/87

PD#II-3/DRP-I/II
LCrocker
05/29/87

OGC-Bethesda
05/ /87

PD#II-3/DRP-I/II
BJYoungblood
06/9/87

see concurrence
on Unit 1 amend.

mal
6/9/87



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 10, 1987

Dockets Nos.: 50-321
and 50-366

Mr. James P. O'Reilly
Senior Vice President - Nuclear Operations
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Dear Mr. O'Reilly:

Subject: Issuance of Amendment Nos. 141 and 77 to Facility Operating Licenses
DPR-57 and NPF-5 - Edwin I. Hatch Nuclear Plant, Units 1 and 2
(TACS 61900/61901)

The Commission has issued the enclosed Amendments Nos. 141 and 77 to Facility Operating Licenses DPR-57 and NPF-5, for the Edwin I. Hatch Nuclear Plant, Units 1 and 2. The amendments consist of changes to the Technical Specifications in response to your application dated June 20, 1986, as supplemented by letters dated July 22, 1986, and January 2, 1987.

The amendments modify the Technical Specifications to permit operation with only one recirculation loop in operation and to implement the jet pump surveillance recommendations of NUREG/CR-3052 "BWR Jet Pump Assembly Failure."

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Bi-Weekly Federal Register Notice.

Sincerely,

A handwritten signature in cursive script that reads "Lawrence P. Crocker".

Lawrence P. Crocker, Project Manager
Project Directorate II-3
Division of Reactor Projects-I/II

Enclosures:

1. Amendment No. 141 to DPR-57
2. Amendment No. 77 to NPF-5
3. Safety Evaluation

cc w/enclosures:
See next page

Mr. J. T. Beckham, Jr.
Georgia Power Company

Edwin I. Hatch Nuclear Plant,
Units Nos. 1 and 2

cc:

G. F. Trowbridge, Esq.
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

Mr. L. T. Gucwa
Engineering Department
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Mr. H. C. Nix, Jr., General Manager
Edwin I. Hatch Nuclear Plant
Georgia Power Company
P. O. Box 442
Baxley, Georgia 31513

Mr. Louis B. Long
Southern Company Services, Inc.
P. O. Box 2625
Birmingham, Alabama 35202

Resident Inspector
U.S. Nuclear Regulatory Commission
Route 1, P. O. Box 279
Baxley, Georgia 31513

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission,
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Mr. Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, S.W.
Atlanta, Georgia 30334

Mr. J. Leonard Ledbetter, Commissioner
Department of Natural Resources
270 Washington Street, N.W.
Atlanta, Georgia 30334

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

GEORGIA POWER COMPANY
OGLETHORPE POWER CORPORATION
MUNICIPAL ELECTRIC AUTHORITY OF GEORGIA
CITY OF DALTON, GEORGIA
DOCKET NO. 50-321
EDWIN I. HATCH NUCLEAR PLANT, UNIT NO. 1
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 141
License No. DPR-57

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Edwin I. Hatch Nuclear Plant, Unit 1 (the facility) Facility Operating License No. DPR-57 filed by Georgia Power Company, acting for itself, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, and City of Dalton, Georgia, (the licensee) dated June 20, 1986, as supplemented by letters dated July 22, 1986, and January 2, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8706170591 870610
PDR ADOCK 05000321
P PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-57 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 141, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



B. J. Youngblood, Director
Project Directorate II-3
Division of Reactor Projects-I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 10, 1987