



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

February 16, 1988

Docket No.: 50-321

MEMORANDUM FOR: Sholly Coordinator

FROM: Lawrence P. Crocker, Project Manager
Project Directorate II-3
Division of Reactor Projects I/II, NRR

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE - NOTICE OF
ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE
(TAC 65997)

Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric

Authority of Georgia, City of Dalton, Georgia, Docket No. 50-321, Edwin I.

Hatch Nuclear Plant, Unit 1, Appling County, Georgia

Date of application for amendment: July 13, 1987

Brief description of amendment: The amendment modified the definition of surveillance frequency in Section 1.II of the Technical Specifications to provide for an 18-month operating cycle instead of the 15 months specified previously.

Date of issuance: February 16, 1988

Effective date: February 16, 1988

Amendment No.: 152

Facility Operating License No. DPR-57. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: January 13, 1988 (53 FR 827)

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated February 16, 1988

No significant hazards consideration comments received: No

8802230229 880216
PDR ADOCK 05000321
P PDR

Sholly Coordinator


- 2 -


Local Public Document Room location: Appling County Public Library,
301 City Hall Drive, Baxley, Georgia 31513

Lawrence P. Crocker, Project Manager
Project Directorate II-3
Division of Reactor Projects I/II, NRR

DISTRIBUTION:
Docket File
Local PDR
NRC PDR
PDII-3 Reading
MRood
LCrocker
LReyes

PDII-3/DRPI/II
MRood/mac
~~12/1/87~~
1/4/88


PDII-3/DRPI/II
LCrocker
~~12/1/87~~
1/4/87


PDII-3/DRPI/II
Acting PD
~~12/1/87~~
2/1/88

Document Name:
HATCH AMENDMENT U1 SHOLLY

Requestor's ID:
CREVISTO

Author's Name:
LCrocker/rad

Document Comments:
Amendment Request date March 27, 1987

Document Name:
HATCH AMENDMENT U1 SHOLLY

Requestor's ID:
CREVISTO

Author's Name:
LCrocker/rad

Document Comments:
Amendment Request date March 27, 1987



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

February 16, 1988

Docket No.: 50-321

MEMORANDUM FOR: Sholly Coordinator

FROM: Lawrence P. Crocker, Project Manager
Project Directorate II-3
Division of Reactor Projects I/II, NRR

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE - NOTICE OF
ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE
(TAC 65997)

Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric
Authority of Georgia, City of Dalton, Georgia, Docket No. 50-321, Edwin I.
Hatch Nuclear Plant, Unit 1, Appling County, Georgia

Date of application for amendment: July 13, 1987

Brief description of amendment: The amendment modified the definition of
surveillance frequency in Section 1.II of the Technical Specifications to
provide for an 18-month operating cycle instead of the 15 months specified
previously.

Date of issuance: February 16, 1988

Effective date: February 16, 1988

Amendment No.: 152

Facility Operating License No. DPR-57. Amendment revised the Technical
Specifications.

Date of initial notice in Federal Register: January 13, 1988 (53 FR 827)

The Commission's related evaluation of the amendment is contained in a
Safety Evaluation dated February 16, 1988

No significant hazards consideration comments received: No

Sholly Coordinator


- 2 -


Local Public Document Room location: Applng County Public Library,
301 City Hall Drive, Baxley, Georgia 31513

Lawrence P. Crocker, Project Manager
Project Directorate II-3
Division of Reactor Projects I/II, NRR

DISTRIBUTION:
Docket File
Local PDR
NRC PDR
PDII-3 Reading
MRood
LCrocker
LReyes

PDII-3/DRPI/II
MRood/mac
~~12/1/87~~
1/4/88


PDII-3/DRPI/II
LCrocker
~~12/1/87~~
1/4/87


PDII-3/DRPI/II
Acting PD
~~12/1/87~~
2/1/88