

January 28, 1992

Docket Nos. 50-321
and 50-366

Mr. W. G. Hairston, III
Senior Vice President -
Nuclear Operations
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

Dear Mr. Hairston:

SUBJECT: HATCH NUCLEAR PLANT, UNIT NO. 2 - CORRECTION TO AMENDMENT NO. 117
(TAC NOS. M69138 AND M69139)

On November 1, 1991, the Nuclear Regulatory Commission issued Amendment Nos. 176 and 117 to Facility Operating Licenses DRP-57 and NPF-5 for the Edwin I. Hatch Nuclear Plant, Units 1 and 2, respectively.

Due to an administrative oversight, Technical Specification (TS) page 3/4 0-2 for Hatch Unit 2 was issued without incorporating the changes approved by Amendment No. 107 dated August 20, 1990. Please replace Unit 2 TS page 3/4 0-2 transmitted with the November 1, 1991, letter, with the enclosed revised page.

Sincerely,

/s/

Kahtan N. Jabbour, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

NRC FILE CENTER COPY

OFC	:LA:PDII-3	:PM:PDII-3	:D:PDII-3	:	:
NAME	:LBerry	:KJabbour:cw	:DMatthews	:	:
DATE	: 1/27/92	: 1/27/92	: 1/28/92	:	:

OFFICIAL RECORD COPY
Document Name: CORRECTION TO AMDT 117/HATCH

9201310270 920128
PDR ADOCK 05000321
P PDR

Handwritten signature/initials

Handwritten number 111

Handwritten "CP"



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555

January 28, 1992

Docket Nos. 50-321
and 50-366

Mr. W. G. Hairston, III
Senior Vice President -
Nuclear Operations
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

Dear Mr. Hairston:

SUBJECT: HATCH NUCLEAR PLANT, UNIT NO. 2 - CORRECTION TO AMENDMENT NO. 117
(TAC NOS. M69138 AND M69139)

On November 1, 1991, the Nuclear Regulatory Commission issued Amendment Nos. 176 and 117 to Facility Operating Licenses DRP-57 and NPF-5 for the Edwin I. Hatch Nuclear Plant, Units 1 and 2, respectively.

Due to an administrative oversight, Technical Specification (TS) page 3/4 0-2 for Hatch Unit 2 was issued without incorporating the changes approved by Amendment No. 107 dated August 20, 1990. Please replace Unit 2 TS page 3/4 0-2 transmitted with the November 1, 1991, letter, with the enclosed revised page.

Sincerely,

A handwritten signature in cursive script that reads "Kahtan N. Jabbour".

Kahtan N. Jabbour, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. W. G. Hairston, III
Georgia Power Company

Edwin I. Hatch Nuclear Plant

cc:

Mr. Ernest L. Blake, Jr.
Shaw, Pittman, Potts and Trowbridge
2300 N Street, NW.
Washington, D.C. 20037

Mr. R. P. McDonald
Executive Vice President -
Nuclear Operations
Georgia Power Company
P.O. Box 1295
Birmingham, Alabama 35201

Mr. J. T. Beckham
Vice President - Plant Hatch
Georgia Power Company
P.O. Box 1295
Birmingham, Alabama 35201

Mr. Alan R. Herdt, Chief
Project Branch #3
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW., Suite 2900
Atlanta, Georgia 30323

Mr. S. J. Bethay
Manager Licensing - Hatch
Georgia Power Company
P.O. Box 1295
Birmingham, Alabama 35201

Mr. Dan Smith
Program Director of
Power Production
Oglethorpe Power Corporation
2100 East Exchange Place
Tucker, Georgia 30085-1349

Mr. L. Sumner
General Manager, Nuclear Plant
Georgia Power Company
Route 1, Box 439
Baxley, Georgia 31513

Charles A. Patrizia, Esq.
Paul, Hastings, Janofsky & Walker
12th Floor
1050 Connecticut Avenue, NW.
Washington, D.C. 20036

Resident Inspector
U.S. Nuclear Regulatory Commission
Route 1, Box 725
Baxley, Georgia 31513

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, Suite 2900
Atlanta, Georgia 30323

Mr. Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, SW.
Atlanta, Georgia 30334

Joe J. Tanner, Commissioner
Department of Natural Resources
205 Butler Street, SE., Suite 1252
Atlanta, Georgia 30334

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513

DATE: January 28, 1992

DISTRIBUTION:

~~Socket File~~

NRC PDR	
Local PDR	
PDII-3 Reading	
Hatch Reading	
SVarga	14E4
GLainas	14H3
DMatthews	
LBerry	
KJabbour	
OGC	15B18
DHagan	MNBB 4702
Ghill (8)	P1-37
WJones	MNBB 4702
CGrimes	11F23
ACRS (10)	P-135
GPA/PA	17F2
OC/LFMB	MNBB 4702

APPLICABILITY

SURVEILLANCE REQUIREMENTS (Continued)

4.0.3 Performance of a Surveillance Requirement within the specified time interval shall constitute compliance with OPERABILITY requirements for a Limiting Condition for Operation and associated ACTION statements unless otherwise required by the specification. Surveillance requirements do not have to be performed on inoperable equipment.

4.0.4 Entry into an OPERATIONAL CONDITION or other specified applicable state shall not be made unless the Surveillance Requirement(s) associated with the Limiting Condition for Operation have been performed within the applicable surveillance interval or as otherwise specified.

4.0.5 Surveillance Requirements for inservice inspection and testing of ASME Code Class 1, 2, & 3 components shall be applicable as follows:

- a. Inservice inspection of ASME Code Class 1, 2, and 3 components and inservice testing of ASME Code Class 1, 2, and 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50, Section XI 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55a(g)(6)(i).
- b. Surveillance intervals specified in Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda for the inservice inspection and testing activities required by the ASME Boiler and Pressure Vessel Code and applicable Addenda shall be applicable as follows in these Technical Specifications:

9201310275 920128
PDR ADDCK 05000321
P PDR