

October 17, 1995

Mr. J. T. Beckham, Jr.  
Vice President - Plant Hatch  
Georgia Power Company  
P. O. Box 1295  
Birmingham, Alabama 35201

SUBJECT: CORRECTION TO LICENSE AMENDMENTS 197 AND 138 TO HATCH UNITS 1 AND 2  
TECHNICAL SPECIFICATIONS (TAC NO. M91078)

Dear Mr. Beckham:

On August 31, 1995, the Nuclear Regulatory Commission issued License Amendments 197 and 138 for the Edwin I. Hatch Nuclear Plant, Units 1 and 2, Technical Specifications (TS) to authorize an increase in the maximum power level. In a discussion with your staff on October 16, 1995, it was brought to our attention that Hatch, Unit 2, TS page 3.4-28 was incorrect. Due to an administrative oversight, LCO 3.4.10 had not been revised as addressed in your January 13, 1995, amendment application.

The revised TS page is enclosed for your use.

Sincerely,

ORIGINAL SIGNED BY:

Kahtan N. Jabbour, Senior Project Manager  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-321 and  
50-366

Enclosure:  
Revised TS page 3.4-28

cc w/encl: See next page

**DISTRIBUTION**

Docket File E.Merschhoff,RII  
PUBLIC R.Crlenjak,RII  
PDII-2 Reading G.Hill (4) T-5 C3  
ACRS T-2 E26 OGC 0-15 B18  
J.Zwolinski S.Varga  
C.Grimes 0-11 E21

DOCUMENT NAME: G:\HATCH\COR91077.LTR

OFFICE	DRPE/PD22/LA	DRPE/PD22/PM	DRPE/PD22/D	
NAME	L. BERRY <i>LB</i>	K. JABBOUR <i>KJS</i>	H. BERKOW <i>H.B.</i>	
DATE	10/17/95	10/17/95	10/17/95	
COPY	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	

OFFICIAL RECORD COPY

200041

9510240073 951017  
PDR ADOCK 05000321  
P PDR

NRC FILE CENTER COPY

DF01

October 17, 1995

Mr. J. T. Beckham, Jr.  
Vice President - Plant Hatch  
Georgia Power Company  
P. O. Box 1295  
Birmingham, Alabama 35201

SUBJECT: CORRECTION TO LICENSE AMENDMENTS 197 AND 138 TO HATCH UNITS 1 AND 2  
TECHNICAL SPECIFICATIONS (TAC NO. M91078)

Dear Mr. Beckham:

On August 31, 1995, the Nuclear Regulatory Commission issued License Amendments 197 and 138 for the Edwin I. Hatch Nuclear Plant, Units 1 and 2, Technical Specifications (TS) to authorize an increase in the maximum power level. In a discussion with your staff on October 16, 1995, it was brought to our attention that Hatch, Unit 2, TS page 3.4-28 was incorrect. Due to an administrative oversight, LCO 3.4.10 had not been revised as addressed in your January 13, 1995, amendment application.

The revised TS page is enclosed for your use.

Sincerely,

ORIGINAL SIGNED BY:

Kahtan N. Jabbour, Senior Project Manager  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-321 and  
50-366

Enclosure:  
Revised TS page 3.4-28

cc w/encl: See next page

**DISTRIBUTION**

Docket File E.Merschhoff,RII  
PUBLIC R.Crlenjak,RII  
PDII-2 Reading G.Hill (4) T-5 C3  
ACRS T-2 E26 OGC 0-15 B18  
J.Zwolinski S.Varga  
C.Grimes 0-11 E21

DOCUMENT NAME: G:\HATCH\COR91077.LTR

OFFICE	DRPE/PD22/LA	DRPE/PD22/PM	DRPE/PD22/D	
NAME	L. BERRY	K. JABBOUR	H. BERKOW	
DATE	10/17/95	10/17/95	10/17/95	
COPY	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	

OFFICIAL RECORD COPY



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

October 17, 1995

Mr. J. T. Beckham, Jr.  
Vice President - Plant Hatch  
Georgia Power Company  
P. O. Box 1295  
Birmingham, Alabama 35201

SUBJECT: CORRECTION TO LICENSE AMENDMENTS 197 AND 138 TO HATCH UNITS 1 AND 2  
TECHNICAL SPECIFICATIONS (TAC NO. M91078)

Dear Mr. Beckham:

On August 31, 1995, the Nuclear Regulatory Commission issued License Amendments 197 and 138 for the Edwin I. Hatch Nuclear Plant, Units 1 and 2, Technical Specifications (TS) to authorize an increase in the maximum power level. In a discussion with your staff on October 16, 1995, it was brought to our attention that Hatch, Unit 2, TS page 3.4-28 was incorrect. Due to an administrative oversight, LCO 3.4.10 had not been revised as addressed in your January 13, 1995, amendment application.

The revised TS page is enclosed for your use.

Sincerely,

*Kahtan N. Jabbour*

Kahtan N. Jabbour, Senior Project Manager  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-321 and  
50-366

Enclosure:  
Revised TS page 3.4-28

cc w/encl: See next page

Mr. J. T. Beckham, Jr.  
Georgia Power Company

Edwin I. Hatch Nuclear Plant

cc:  
Mr. Ernest L. Blake, Jr.  
Shaw, Pittman, Potts and Trowbridge  
2300 N Street, NW.  
Washington, DC 20037

Mr. Ernie Toupin  
Manager of Nuclear Operations  
Oglethorpe Power Corporation  
2100 East Exchange Place  
Tucker, Georgia 30085-1349

Mr. D. M. Crowe  
Manager Licensing - Hatch  
Georgia Power Company  
P. O. Box 1295  
Birmingham, Alabama 35201

Charles A. Patrizia, Esquire  
Paul, Hastings, Janofsky & Walker  
10th Floor  
1299 Pennsylvania Avenue  
Washington, DC 20004-9500

Mr. L. Sumner  
General Manager, Nuclear Plant  
Georgia Power Company  
11030 Hatch Parkway North  
Baxley, Georgia 31513

Mr. Jack D. Woodard  
Senior Vice President  
Georgia Power Company  
P. O. Box 1295  
Birmingham, Alabama 35201

Resident Inspector  
U.S. Nuclear Regulatory Commission  
11030 Hatch Parkway North  
Baxley, Georgia 31513

Chairman  
Appling County Commissioners  
County Courthouse  
Baxley, Georgia 31513

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, NW. Suite 2900  
Atlanta, Georgia 30323

Mr. Charles H. Badger  
Office of Planning and Budget  
Room 610  
270 Washington Street, SW.  
Atlanta, Georgia 30334

Harold Reheis, Director  
Department of Natural Resources  
205 Butler Street, SE., Suite 1252  
Atlanta, Georgia 30334

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.10 Reactor Steam Dome Pressure

LCO 3.4.10 The reactor steam dome pressure shall be  $\leq$  1058 psig. |

APPLICABILITY: MODES 1 and 2.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Reactor steam dome pressure not within limit.	A.1 Restore reactor steam dome pressure to within limit.	15 minutes
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.10.1 Verify reactor steam dome pressure is $\leq$ 1058 psig.	12 hours