

October 17, 1995

Mr. J. T. Beckham, Jr.
Vice President - Plant Hatch
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

SUBJECT: CORRECTION TO LICENSE AMENDMENTS 197 AND 138 TO HATCH UNITS 1 AND 2
TECHNICAL SPECIFICATIONS (TAC NO. M91078)

Dear Mr. Beckham:

On August 31, 1995, the Nuclear Regulatory Commission issued License Amendments 197 and 138 for the Edwin I. Hatch Nuclear Plant, Units 1 and 2, Technical Specifications (TS) to authorize an increase in the maximum power level. In a discussion with your staff on October 16, 1995, it was brought to our attention that Hatch, Unit 2, TS page 3.4-28 was incorrect. Due to an administrative oversight, LCO 3.4.10 had not been revised as addressed in your January 13, 1995, amendment application.

The revised TS page is enclosed for your use.

Sincerely,

ORIGINAL SIGNED BY:

Kahtan N. Jabbour, Senior Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-321 and
50-366

Enclosure:
Revised TS page 3.4-28

cc w/encl: See next page

DISTRIBUTION

Docket File	E. Merschoff, RII
PUBLIC	R. Crljenjak, RII
PDII-2 Reading	G. Hill (4) T-5 C3
ACRS T-2 E26	OGC 0-15 B18
J. Zwolinski	S. Varga
C. Grimes 0-11 E21	

DOCUMENT NAME: G:\HATCH\COR91077.LTR

OFFICE	DRPE/PD22/LA	DRPE/PD22/PM	DRPE/PD22/D	
NAME	L. BERRY	K. JABBOUR	H. BERKOW	
DATE	10/ 17 /95	10/ 17 /95	10/ 17 /95	
COPY	<input checked="" type="radio"/> YES <input type="radio"/> NO	<input checked="" type="radio"/> YES <input type="radio"/> NO	<input checked="" type="radio"/> YES <input type="radio"/> NO	

OFFICIAL RECORD COPY

200041

9510240073 951017
PDR ADOCK 05000321
P PDR

NRC FILE CENTER COPY

DF01

October 17, 1995

Mr. J. T. Beckham, Jr.
Vice President - Plant Hatch
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

SUBJECT: CORRECTION TO LICENSE AMENDMENTS 197 AND 138 TO HATCH UNITS 1 AND 2
TECHNICAL SPECIFICATIONS (TAC NO. M91078)

Dear Mr. Beckham:

On August 31, 1995, the Nuclear Regulatory Commission issued License Amendments 197 and 138 for the Edwin I. Hatch Nuclear Plant, Units 1 and 2, Technical Specifications (TS) to authorize an increase in the maximum power level. In a discussion with your staff on October 16, 1995, it was brought to our attention that Hatch, Unit 2, TS page 3.4-28 was incorrect. Due to an administrative oversight, LCO 3.4.10 had not been revised as addressed in your January 13, 1995, amendment application.

The revised TS page is enclosed for your use.

Sincerely,

ORIGINAL SIGNED BY:

Kahtan N. Jabbour, Senior Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-321 and
50-366

Enclosure:
Revised TS page 3.4-28

cc w/encl: See next page

DISTRIBUTION

Docket File	E. Merschoff, RII
PUBLIC	R. Crljenjak, RII
PDII-2 Reading	G. Hill (4) T-5 C3
ACRS T-2 E26	OGC 0-15 B18
J. Zwolinski	S. Varga
C. Grimes 0-11 E21	

DOCUMENT NAME: G:\HATCH\COR91077.LTR

OFFICE	DRPE/PD22/L	DRPE/PD22/PM	DRPE/PD22/D	
NAME	L. BERRY	K. JABBOUR	H. BERKOW	
DATE	10/17/95	10/17/95	10/17/95	
COPY	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	

OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

October 17, 1995

Mr. J. T. Beckham, Jr.
Vice President - Plant Hatch
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

SUBJECT: CORRECTION TO LICENSE AMENDMENTS 197 AND 138 TO HATCH UNITS 1 AND 2
TECHNICAL SPECIFICATIONS (TAC NO. M91078)

Dear Mr. Beckham:

On August 31, 1995, the Nuclear Regulatory Commission issued License Amendments 197 and 138 for the Edwin I. Hatch Nuclear Plant, Units 1 and 2, Technical Specifications (TS) to authorize an increase in the maximum power level. In a discussion with your staff on October 16, 1995, it was brought to our attention that Hatch, Unit 2, TS page 3.4-28 was incorrect. Due to an administrative oversight, LCO 3.4.10 had not been revised as addressed in your January 13, 1995, amendment application.

The revised TS page is enclosed for your use.

Sincerely,

Kahtan N. Jabbour

Kahtan N. Jabbour, Senior Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-321 and
50-366

Enclosure:
Revised TS page 3.4-28

cc w/encl: See next page

Mr. J. T. Beckham, Jr.
Georgia Power Company

Edwin I. Hatch Nuclear Plant

cc:
Mr. Ernest L. Blake, Jr.
Shaw, Pittman, Potts and Trowbridge
2300 N Street, NW.
Washington, DC 20037

Mr. Ernie Toupin
Manager of Nuclear Operations
Oglethorpe Power Corporation
2100 East Exchange Place
Tucker, Georgia 30085-1349

Mr. D. M. Crowe
Manager Licensing - Hatch
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

Charles A. Patrizia, Esquire
Paul, Hastings, Janofsky & Walker
10th Floor
1299 Pennsylvania Avenue
Washington, DC 20004-9500

Mr. L. Sumner
General Manager, Nuclear Plant
Georgia Power Company
11030 Hatch Parkway North
Baxley, Georgia 31513

Mr. Jack D. Woodard
Senior Vice President
Georgia Power Company
P. O. Box 1295
Birmingham, Alabama 35201

Resident Inspector
U.S. Nuclear Regulatory Commission
11030 Hatch Parkway North
Baxley, Georgia 31513

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Mr. Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, SW.
Atlanta, Georgia 30334

Harold Reheis, Director
Department of Natural Resources
205 Butler Street, SE., Suite 1252
Atlanta, Georgia 30334

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.10 Reactor Steam Dome Pressure

LC0 3.4.10 The reactor steam dome pressure shall be ≤ 1058 psig. |

APPLICABILITY: MODES 1 and 2.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Reactor steam dome pressure not within limit.	A.1 Restore reactor steam dome pressure to within limit.	15 minutes
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.10.1 Verify reactor steam dome pressure is ≤ 1058 psig.	12 hours