September 30, 1986

Docket Nos.: 50-413 and 50-414

> Mr. H. B. Tucker, Vice President Nuclear Production Department Duke Power Company 422 South Church Street Charlotte, North Carolina 28242

Dear Mr. Tucker:

Subject: Issuance of Amendment No. 13 to Facility Operating License NPF-35 and Amendment No. 5 to Facility Operating License NPF-52

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 13 to Facility Operating License NPF-35 and Amendment No. 5 to Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2. These amendments consist of changes to the Technical Specifications in response to your application dated September 10, 1985, and supplemented November 27, 1985, January 7, and July 31, 1986.

These amendments modify Technical Specifications for Catawba Unit 1 to lower the low-low reactor trip signal for the steam generator level when the reactor is operating above 30% power level. The amendments are effective as of their date of issuance. A copy of the related safety evaluation supporting Amendment No. 13 to Facility Operating License NPF-35 and Amendment No. 5 to Facility Operating License NPF-52 is enclosed.

Notice of issuance will be included in the Commission's next bi-weekly Federal Register notice.

Sincerely,

Kahtan Jabbour, Project Manager PWR Project Directorate #4 Division of PWR Licensing-A

8610100612

860930

00413

Enclosures:

- 1. Amendment No. 13 to NPF-35 2. Amendment No. 5 to NPF-52
- Safety Evaluation 3.

cc w/encl: See next page

DISTRIBUTION: See attached page

PWR#A DPWR-A MDuncan/rad 09/()/86

PWR#4/DPWR-A KJabbour 09/10/86

PWR#4/DPWR-A BJYoungblood 09/24/86

Mr. H. B. Tucker Duke Power Company

cc: William L. Porter, Esq. Duke Power Company P.O. Box 33189 Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq. Bishop, Liberman, Cook, Purcell and Reynolds 1200 Seventeenth Street, N.W. Washington, D. C. 20036

North Carolina MPA-1 Suite 600 3100 Smoketree Ct. P.O. Box 29513 Raleigh, North Carolina 27626-0513

Mr. L.L. Williams Power Systems Division Westinghouse Electric Corp. P.O. Box 355 Pittsburgh, Pennsylvania 15230

NUS Corporation 2536 Countryside Boulevard Clearwater, Florida 33515

County Manager of York County York County Courthouse York South Carolina 29745

Richard P. Wilson, Esq. Assistant Attorney General S.C. Attorney General's Office P.O. Box 11549 Columbia, South Carolina 29211

Piedmont Municipal Power Agency 100 Memorial Drive Greer, South Carolina 29651

Mark S. Calvert, Esq. Bishop, Liberman, Cook, Purcell & Reynolds 1200 17th Street, N.W. Washington, D. C. 20036

Brian P. Cassidy, Regional Counsel
Federal Emergency Management Agency, Region I
J. W. McCormach POCH
Boston, Massachusetts 02109 Catawba Nuclear Station

North Carolina Electric Membership Corp. 3333 North Boulevard P.O. Box 27306 Raleigh, North Carolina 27611

Saluda River Electric Cooperative, Inc. P.O. Box 929 Laurens, South Carolina 29360

Senior Resident Inspector Route 2, Box 179N York, South Carolina 29745

Regional Administrator, Region II U.S. Nuclear Regulatory Commission, 101 Marietta Street, NW, Suite 2900 Atlanta, Georgia 30323

Mr. Heyward G. Shealy, Chief Bureau of Radiological Health South Carolina Department of Health and Environmental Control 2600 Bull Street Columbia, South Carolina 29201

Karen E. Long Assistant Attorney General N.C. Department of Justice P.O. Box 629 Raleigh, North Carolina 27602

Spence Perry, Esquire Associate General Counsel Federal Emergency Management Agency Room 840 500 C Street Washington, D. C. 20472

Mr. Michael Hirsch Federal Emergency Management Agency Office of the General Counsel Room 840 500 C Street, S.W. Washington, D. C. 20472

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555



DUKE POWER COMPANY

NORTH CAROLINA ELECTRIC MEMBERSHIP CORPORATION

SALUDA RIVER ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-413

CATAWBA NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 13 License No. NPF-35

860930

8610100522

PDR

ADOCK

- The Nuclear Regulatory Commission (the Commission) has found that: 1.
 - The application for amendment to the Catawba Nuclear Station, Unit 1 Α. (the facility) Facility Operating License No. NPF-35 filed by the Duke Power Company acting for itself, North Carolina Electric Membership Corporation and Saluda River Electric Cooperative, Inc., (licensees) dated September 10, 1985, as supplemented November 27, 1985, January 7, and July 31, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
 - The facility will operate in conformity with the application, as Β. amended, the provisions of the Act, and the regulations of the Commission:
 - There is reasonable assurance: (i) that the activities authorized by С. this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - The issuance of this license amendment will not be inimical to the D. common defense and security or to the health and safety of the public;
 - The issuance of this amendment is in accordance with 10 CFR Part 51 Ε. of the Commission's regulations and all applicable requirements have been satisfied.

- Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-35 is hereby amended to read as follows:
 - (2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 13 and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Duke Power Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

151

Kahtan Jabbour, Project Manager PWR Project Directorate No. 4 Division of PWR Licensing-A

Attachment: Technical Specification Changes

Date of Issuance: September 30, 1986

PWR#4/DPWR-A MDuncan/rad 09/10 /86

PWR#4/DPWR-A KJabbour /86 סנ

OGC-Beth 11th Sav 09/1/ /85

PWR#4/DPWR-A BJYoungblood 09/2/186

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555



DUKE POWER COMPANY

NORTH CAROLINA MUNICIPAL POWER AGENCY NO. 1

PIEDMONT MUNICIPAL POWER AGENCY

DOCKET NO. 50-414

CATAWBA NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. ⁵ License No. NPF-52

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Catawba Nuclear Station, Unit 2 (the facility) Facility Operating License No. NPF-52 filed by the Duke Power Company acting for itself, North Carolina Municipal Power Agency No. 1 and Piedmont Municipal Power Agency, (licensees) dated September 10, 1985, as supplemented November 27, 1985, January 7, and July 31, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public;
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- 2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-52 is hereby amended to read as follows:
 - (2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. ⁵, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Duke Power Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

151

Kahtan Jabbour, Project Manager PWR Project Directorate No. 4 Division of PWR Licensing-A

Attachment: Technical Specification Changes

Date of Issuance: September 30, 1986

PWR#4/D**A**WR-A MDuncan/rad 09//0/86 KN PWR#4/DPWR-A KJabbour 09/10/86



PWR#4/DPWR-A BJYoungblood 09/24/86

- 2 -

ATTACHMENT TO LICENSE AMENDMENT NO. 13

FACILITY OPERATING LICENSE NO. NPF-35

DOCKET NO. 50-413

AND TO

LICENSE AMENDMENT NO. 5

FACILITY OPERATING LICENSE NO. NPF-52

DOCKET NO. 50-414

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change. The corresponding overleaf pages are also provided to maintain document completeness.

Amended Page	<u>Overleaf</u> Page
2-5 3/4 3-8	2-6 3/4 3-7
3/4 3-10	3/4 3-9
3/4 3-12 3/4 3-31	3/4 3-11
	J/+ J-JL

CATAWB			TABLE 2.2-1 (0	Continue	<u>d)</u>			
		REACTOR TRIP	SYSTEM INSTRUM	ENTATION	TRIP SETPOIN	<u>rs</u>		
BA - UN	FUNC	TIONAL UNIT	TOTAL Allowance (ta)	<u>Z</u>	SENSOR ERROR (S)	TRIP SETPOINT	ALLOWABLE VALUE	
LLL2	13.	Steam Generator Water						
1 & 2		a. Unit 1	17	14.2	1.5	>17% of span from 0% to 30% RTP* increasing linearly to > 40.0% of span from 30% to 100% RTP*	>15.3% of span from 0% to 30% RTP* increasing linearly to >38.3% of span from 30% to 100% RTP*	
		b. Unit 2	17	14.2	1.5	≥17% of narrow range span	≥15.3% of narrow range span	
2-5	14.	Undervoltage - Reactor Coolant Pumps	8.57	0	1.0	>77% of bus voltage (5082 volts) with a 0.7s response time	≥76% (5016 volts)	
	15.	Underfrequency - Reactor Coolant Pumps	4.0	0	1.0	>56.4 Hz with a 0.2s response time	≥55.9 Hz	
	16.	Turbine Trip						(
Amen		a.1 Low Control Valve EH Pressure-Low (Unit 1)	N.A.	N.A.	N.A.	<u>≥</u> 550 psig	≥500 psig	
dment		a.2 Stop Valve EH Pressure-Low (Unit 2)	N.A.	N.A.	N.A.	<u>></u> 550 psig	<u>></u> 500 psig	
		b. Turbine Stop Valve Closure	N.A.	N.A.	N.A.	≥1% open	≥1% open	
3(Unit	17.	Safety Injection Input from ESF	N.A.	N. A.	N.A.	N.A.	N.A.	

>

	TABLE 2.2-1 (Continued)									
	REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS									
FUNC	<u>T10N</u>	AL UNIT	<u>(TA)</u>	<u>Z</u>	TOTAL ALLOWANCE (S)	TRIP SETPOINT	SENSOR ERROR ALLOWABLE VALUE			
18.	Rea I	ctor Trip System nterlocks			١					
	a.	Intermediate Range Neutron Flux, P-6	N.A.	N.A.	N.A.	≥1 x 10 ⁻¹⁰ amps	≥6 x 10- ¹¹ amps			
	b.	Low Power Reactor Tr Block, P-7	rips							
	1)	P-10 input	N.A.	N.A.	N.A.	\leq 10% of RTP*	<pre><12.2% of RTP*</pre>			
	2)	P-13 input	N.A.	N.A.	N.A.	<10% RTP* Turbine Impulse Pressure Equivalent	<12.2% RTP* Turbine Impulse Pressure Equivalent			
	c.	Power Range Neutron Flux, P-8	N.A.	N.A.	N.A.	<u><</u> 48% of RTP*	<pre><50.2% of RTP*</pre>			
	d.	Power Range Neutron Flux, P-9	N.A.	N.A.	N.A.	<u><</u> 69% of RTP*	$\leq 70\%$ of RTP*			
	e.	Power Range Neutron Flux, P-10	N.A.	N.A.	N. A	<u>></u> 10% of RTP*	≥7.8% of RTP*			
	f.	Power Range Neutron Flux, Not P-10	N.A.	N.A.	N.A.	\leq 10% of RTP*	<pre>_12.2% of RTP*</pre>			
	g.	Turbine Impulse Cha Pressure, P-13	nber N.A.	N.A.	N.A.	<10% RTP* Turbine Impulse Pressure Equivalent	<12.2% RTP* Turbine Impulse Pressure Equivalent			
19.	Rea	actor Trip Breakers	N.A.	N.A.	N.A	N.A.	N.A.			
20.	Au ^r In	tomatic Trip and terlock Logic	N.A.	N.A.	N.A.	N.A.	N.A.			

1

١

*****RTP = RATED THERMAL POWER

2-6

à

CATAWBA - UNITS 1 &

N

. `

TABLE 3.3-2

REACTOR TRIP SYSTEM INSTRUMENTATION RESPONSE TIMES

FUNC	TIONAL UNIT	RESPONSE TIME
1.	Manual Reactor Trip	N.A.
2.	Power Range, Neutron Flux	\leq 0.5 second*
3.	Power Range, Neutron Flux, High Positive Rate	N.A.
4.	Power Range, Neutron Flux, High Negative Rate	<pre>< 0.5 second*</pre>
5.	Intermediate Range, Neutron Flux	N.A.
6.	Source Range, Neutron Flux	N.A.
7.	Overtemperature ΔT	\leq 4 seconds*
8.	Overpower ∆T	\leq 4 seconds
9.	Pressurizer Pressure-Low	<pre>< 2 seconds</pre>
10.	Pressurizer Pressure-High	<pre>< 2 seconds</pre>
11.	Pressurizer Water Level-High	N.A.

.

١

3/4 3-7

^{*}Neutron detectors are exempt from response time testing. Response time of the neutron flux signal portion of the channel shall be measured from detector output or input of first electronic component in channel.

TABLE 3.3-2 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION RESPONSE TIMES

FUNC	RESPONSE TIME	
12.	Low Reactor Coolant Flow	
	a. Single Loop (Above P-8) b. Two Loops (Above P-7 and below P-8)	<pre>< 1 second < 1 second</pre>
13.	Steam Generator Water Level-Low-Low	
	a. Unit 1 b. Unit 2	\leq 3.5 seconds \leq 2.0 seconds
14.	Undervoltage-Reactor Coolant Pumps	\leq 1.5 seconds
15.	Underfrequency-Reactor Coolant Pumps	<pre>< 0.6 second</pre>
16.	Turbine Trip	
	a.1 Control Valve EH Pressure-Low (Unit 1) a.2 Stop Valve EH Pressure-Low (Unit 2) b. Turbine Stop Valve Closure	N.A. N.A. N.A.
17.	Safety Injection Input from ESF	N.A.
18.	Reactor Trip System Interlocks	N.A.
19.	Reactor Trip Breakers	N.A.
20.	Automatic Trip and Interlock Logic	N.A.

3/4 3-8

CATAWBA - UNITS

1 & 2

Ŷ

TABLE 4.3-1

ŧ

١

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

FUNC	TIONAL UNIT	CHANNEL Check	CHANNEL CALIBRATION	ANALOG CHANNEL OPERATIONAL TEST	TRIP ACTUATING DEVICE OPERATIONAL TEST	ACTUATION LOGIC TEST	MODES FOR WHICH SURVEILLANCE IS REQUIRED
1.	Manual Reactor Trip	N.A.	N.A.	N.A.	R	N.A.	1, 2, 3*, 4*, 5
2.	Power Range, Neutron Flux a. High Setpoint	S	D(2, 4), M(3, 4), Q(4, 6),	Μ	N.A.	N.A.	1, 2
	b. Low Setpoint	S	R(4, 5) R(4)	M	N.A.	N. A.	1###, 2
3.	Power Range, Neutron Flux, High Positive Rate	N.A.	R(4)	М	N.A.	N.A.	1, 2
4.	Power Range, Neutron Flux, High Negative Rate	N.A.	R(4)	M	N.A.	N.A.	1, 2
5.	Intermediate Range, Neutron Flux	S	R(4, 5)	S/U(1),M	N.A.	N. A.	1###, 2
6.	Source Range, Neutron Flux	S	R(4, 5)	S/U(1),M(9)	N.A.	N.A.	2##, 3, 4, 5
7.	Overtemperature ΔT	S	R(12)	М	N.A.	N.A.	1, 2
8.	Overpower ∆T	S	R	M	N.A.	N.A.	1, 2
9.	Pressurizer Pressure-Low	S	R	М	N.A.	N.A.	1
10.	Pressurizer Pressure-High	S	R	М	N.A.	N.A.	1, 2
11.	Pressurizer Water Level-High	Ś	R	M	N.A.	N.A.	1
12.	Reactor Coolant Flow-Low	S	R	м	N.A.	N.A.	1

N

3/4 3-9

TABLE 4.3-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

CATA	REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS										
WBA - UNITS	FUNCTIONAL UNIT		CHANNEL CHECK	CHANNEL CALIBRATION	ANALOG CHANNEL OPERATIONAL TEST	TRIP ACTUATING DEVICE OPERATIONAL TEST	ACTUATION LOGIC TEST	MODES FOR WHICH SURVEILLANCE IS REQUIRED			
1 & 2	13.	Steam Generator Water Level- Low-Low	S	R(13)	М	N.A.	N.A.	1, 2 (
	14.	Undervoltage - Reactor Coolan Pumps	t N.A.	R	N.A.	м	N.A.	1			
	15.	Underfrequency - Reactor Coolant Pumps	N.A.	R	N.A.	м	N.A.	1			
3/4 3	16.	Turbine Trip a.1 Control Valve EH Proscurp - Low (Unit 1)	N.A.	R	N.A.	S/U(1, 10)	N.A.	1#			
-10		a.2 Stop Valve EH Pressure - Low (Unit 2)	N.A.	R	N.A.	S/U(1, 10)	N.A.	1#			
		b. Turbine Stop Valve Closur	e N.A.	R	N.A.	S/U(1, 10)	N.A.	1#			
	17.	Safety Injection Input from ESF	N.A.	N.A.	N.A.	R**	N.A.	1, 2 (
Amer Amer	18.	Reactor Trip System Interlock	S								
ndment ndment		a. Intermediate Range Neutron Flux, P-6	N.A.	R(4)	М	N.A.	N.A.	2##			
No. 1		b. Low Power Reactor Trips Block, P-7	N.A.	R(4)	M(8)	N.A.	N.A.	1			
3(Uni		c. Power Range Neutron Flux, P-8	N.A.	R(4)	M(8)	N.A.	N.A.	1			
t 1) t 2)		Flux, P-9	N.A.	R(4)	M(8)	N.A.	N.A.	1			

^{**} This surveillance need not be performed until prior to entering STARTUP following the Unit 1 first refueling.

TABLE 4.3-1 (Continued)

1

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

FUNC	TIONAL UNIT	CHANNEL Check	CHANNEL CALIBRATION	ANALOG CHANNEL OPERATIONAL TEST	TRIP ACTUATING DEVICE OPERATIONAL TEST	ACTUATION LOGIC TEST	MODES FOR WHICH SURVEILLANCE IS REQUIRED
18.	Reactor Trip System Interlock	ks (Contin	ued)				(₁
	e. Power Range Neutron Flux, P-10	N.A.	R(4)	M(8)	N.A.	N.A.	1
	f. Power Range Neutron Flux, Not P-10	N.A.	R(4)	M(8)	[•] N.A.	N.A.	1, 2
	g. Turbine Impulse Chamber Pressure, P-13	N.A.	R	M(8)	N.A.	N.A.	1
19.	Reactor Trip Breaker	N.A.	N.A.	N.A.	M(7, 11)	N.A.	1, 2, 3*, 4*, 5*
20.	Automatic Trip and Interlock Logic	N.A.	N.A.	N.A.	N.A.	M(7)	1, 2, 3*, 4*, 5*

TABLE 4.3-1 (Continued)

TABLE NOTATIONS

- * Only if the Reactor Trip System breakers happen to be closed and the Control Rod Drive System is capable of rod withdrawal.
- # Above P-9 (Reactor Trip on Turbine Trip Interlock) Setpoint.
- ## Below P-6 (Intermediate Range Neutron Flux Interlock) Setpoint.
- ### Below P-10 (Low Setpoint Power Range Neutron Flux Interlock) Setpoint.
- (1) If not performed in previous 7 days.
- (2) Comparison of calorimetric to excore power indication above 15% of RATED THERMAL POWER. Adjust excore channel gains consistent with calorimetric power if absolute difference is greater than 2%. The provisions of Specification 4.0.4 are not applicable for entry into MODE 2 or 1.
- (3) Single point comparison of incore to excore axial flux difference above 15% of RATED THERMAL POWER. Recalibrate if the absolute difference is greater than or equal to 3%. The provisions of Specification 4.0.4 are not applicable for entry into MODE 2 or 1.
- (4) Neutron detectors may be excluded from CHANNEL CALIBRATION.
- (5) Detector plateau curves shall be obtained, evaluated and compared to manufacturer's data. For the Intermediate Range and Power Range Neutron Flux channels the provisions of Specification 4.0.4 are not applicable for entry into MODE 2 or 1.
- (6) Incore Excore Calibration, above 75% of RATED THERMAL POWER. The provisions of Specification 4.0.4 are not applicable for entry into MODE 2 or 1.
- (7) Each train shall be tested at least every 62 days on a STAGGERED TEST BASIS.
- (8) With power greater than or equal to the interlock setpoint the required ANALOG CHANNEL OPERATIONAL TEST shall consist of verifying that the interlock is in the required state by observing the permissive status light.
- (9) Monthly surveillance in MODES 3*, 4*, and 5* shall also include verification that permissives P-6 and P-10 are in their required state for existing plant conditions by observation of the permissive status light. Monthly surveillance shall include verification of the Boron Dilution
 Alarm Setpoint of less than or equal to one-half decade (square root of 10) above background.
- (10) Setpoint verification is not applicable.
- (11) At least once per 18 months and following maintenance or adjustment of the Reactor trip breakers, the TRIP ACTUATING DEVICE OPERATIONAL TEST shall include independent verification of the Undervoltage and Shunt trips.
- (12) CHANNEL CALIBRATION shall include the RTD bypass loops flow rate.
- (13) For Unit 1, CHANNEL CALIBRATION shall ensure that the filter time constant associated with Steam Generator Water Level Low-Low is adjusted to a value less than or equal to 1.5 seconds.

CATAWBA - UNITS 1 & 2

Amendment No. 13 (Unit 1) Amendment No. 5 (Unit 2)

CA.	ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS							
TAWBA =	NCTIC	NAL UNIT	TOTAL Allowance (TA)	Z	SENSOR ERROR (S)	TRIP SETPOINT	ALLOWABLE VALUE	
₽.	Auxi	liary Feedwater (Continued)			1			
ITS 1	c.	Steam Generator Water Level - Low-Low						
& 2		1) Unit 1	17	14.2	1.5	\geq 17% of span from 0% to 30% RTP increasing linearly to \geq 40.0% of span from 30% to 100% RTP	<pre>> 15.3% of span from 0% to 30% RTP increasing linearly to > 38.3% of span from 30% to 100% RTP</pre>	
3/4 3		2) Unit 2	17	14.2	1.5	≥ 17% of narrow range span	<u>></u> 15.3% of narrow range instrument span	
<u>5</u>	d.	Safety Injection	See Item 1. above for all Safety Injection Setpoints and Allowable Values					
	e.	Loss-of-Offsite Power	N.A.	N.A.	N.A.	> 3500 V	> 3200 V	
	f.	Trip of All Main Feedwater Pumps	N.A.	N.A.	N.A.	– N.A.	N. A.	
	g.	Auxiliary Feedwater Suction Pressure-Low						
Ame Ame		1) CAPS 5220, 5221, 5222	N.A.	N.A.	N.A.	> 10.5 psig	> 9.5 psig	
ndment		2) CAPS 5230, 5231, 5232 a. Unit 1 b. Unit 2	N.A. N.A. N.A.	N.A. N.A. N.A.	N. A. N. A. N. A.	<pre>> 6.2 psig > 6.2 psig > 6.2 psig > 6.0 psig</pre>	<pre>> 5.2 psig > 5.2 psig > 5.2 psig > 5.0 psig</pre>	
No 9.	Cont	ainment Sump Recirculation						
. 13 5 (a.	Automatic Actuation Logic and Actuation Relays	N.A.	N. A.	N.A.	N.A.	N.A.	
Unit 1) Unit 2)	b.	Refueling Water Storage Tank Level-Low Coincident With Safety	N.A.	N.A.	N. A.	≥ 177.15 inches	> 162.4 inches	
		Injection	See Item 1. abo	ve for	all Safety	Injection Setpoi	nts and Allowable Values.	

TABLE 3.3-4 (Continued)

See Item 1. above for all Safety Injection Setpoints and Allowable Values.

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

I.

١

FUNC	TIONA	L UNIT	TOTAL Allowance (TA)	<u>Z</u>	SENSOR ERROR (S)	TRIP SETPOINT	ALLOWABLE VALUE
10.	Loss	of Power					
	a.	4 kV Bus Undervoltage-Loss of Voltage	N.A.	N.A.	N.A.	<u>></u> 3500 V	≥ 3200 V
	b.	4 kV Bus Undervoltage- Grid Degraded Voltage	N.A.	N.A.	N.A.	≥ 3685 V	<u>></u> 3611 V
11.	Cont Oper	crol Room Area Ventilation ration				x.	
	a.	Automatic Actuation Logic and Actuation Relays	N. A.	N.A.	N.A.	N. A.	N.A.
	b.	Loss-of-Offsite Power	N. A.	N.A.	N.A.	≥ 3500 V	\geq 3200 V
	c.	Safety Injection	See Item 1. ab Values.	ove fo	r all Safety	Injection Setpo	oints and Allowable
12.	Cont Hydr	tainment Air Return and rogen Skimmer Operation					
	a.	Manual Initiation	N.A.	N.A.	N.A.	N.A.	N.A.
	b.	Automatic Actuation Logic and Actuation Relays	N. A.	N.A.	N.A.	N.A.	N.A.
	c.	Containment Pressure- High-High	12.7	0.71	1.5	≤ 3 psig	<u><</u> 3.2 psig



SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION RELATED TO AMENDMENT NO. 13TO FACILITY OPERATING LICENSE NPF-35 AND AMENDMENT NO. 5 TO FACILITY OPERATING LICENSE NPF-52 CATAWBA NUCLEAR STATION, UNITS 1 AND 2 DUKE POWER COMPANY, ET AL.

INTRODUCTION

SUCLEAR REGULATO

O3LINT

By letter dated September 10, 1985, Duke Power Company, et al., (the licensee) proposed changes to the Technical Specifications (TS) for Catawba Unit 1 to lower the Low-Low Reactor Trip Signal for the Steam Generator Level when the reactor is operating above 30% power level. These changes pertain to Unit 1 only. However, because Units 1 and 2 TS are combined in one document, certain non-substantive changes in format with respect to Unit 2 are required. Supplemental letters dated November 27, 1985, January 7, 1986, and July 31, 1986, provided revision and clarification to the proposed changes requested in the September 13, 1985, letter.

EVALUATION

The proposed changes to Tables 2.2-1, 3.3-2, 3.3-4 and 4.3-1 would (1) lower the trip setpoint so that instead of increasing linearly from 17 to 54.9% of span, while the reactor is taken from 30 to 100% of rated thermal power, it would increase linearly from 17 to 40%; (2) decrease the minimum permitted trip value (including the setpoint tolerance) at 100% power from 53.2 to 38.3%; and (3) increase the allowable response time for the low-low steam generator reactor trip from 2.0 to 3.5 seconds. The above changes are being proposed to prevent unnecessary reactor trips and auxiliary feedwater initiations due to spurious steam generator low-low level signal fluctuations near the current programmed setpoint.

To support the above changes, the licensee requested that Westinghouse analyze the effect of reduced steam generator inventory on a Feedwater System Pipe Break both with and without offsite power available and on a loss of Non-Emergency AC Power. The Final Safety Analysis Report (FSAR) will be revised to specify a worst case single failure in the auxiliary feedwater system resulting in 491 gpm of auxiliary feedwater delivered to two steam generators. Core residual heat generation was based on ANSI/ANS 5.1-1979, "American National Standard for Decay Heat Power in Light Water Reactors," August 1979. The assumptions of decay heat postulated by the model proposed by the licensee (ANS 5.1-1979) are acceptable. Using these revised assumptions for residual heat in a reanalysis of affected accidents in Chapter 15 of the FSAR indicates that all applicable safety criteria were met at the revised low-low level setpoint. Thus, the staff finds that the proposed revisions to the Catawba Unit 1 TS are acceptable. Furthermore, the proposed revision to the Catawba 1 FSAR is acceptable when 492 gpm on page 15.2-19a is changed to 491 gpm.

8610100632 860930 PDR ADOCK 05000413

PDR

In addition to the setpoint changes, the licensee has added a new filter to the steam generator low-low level channel circuitry to further reduce spurious reactor trips and auxiliary feedwater initiations. The time constant for this filter is adjusted to a value less than or equal to 1.5 seconds. The staff has reviewed the adjustment and finds it acceptable.

ENVIRONMENTAL CONSIDERATION

The amendments involve a change in use of facility components located within the restricted area as defined in 10 CFR Part 20 and changes in surveillance requirements. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational exposures. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there have been no public comments on such finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR Section 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

CONCLUSION

The Commission made a proposed determination that the amendments involve no significant hazards consideration which was published in the Federal Register (51 FR 30564) on August 27, 1986, and consulted with the State of South Carolina, No public comments were received, and the state of South Carolina did not have any comments.

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: Kahtan Jabbour, PWR#4/DPWR-A Rudy Karsch, RSB/DPWR-A

Dated: September 30, 1986

AMENDMENT NO. 13 TO FACILITY OPERATING LICENSE NPF-35 -CATAWBA NUCLEAR POWER STATION, UNIT 1 AMENDMENT NO. 5 TO FACILITY OPERATING LICENSE NPF-52 -CATAWBA NUCLEAR POWER STATION, UNIT 2

DISTRIBUTION: w/enclosures:

Docket No. 50-413 NRC PDR Local PDR NSIC PRC System PWR#4 R/F B. J. Youngblood K. Jabbour M. Duncan OGC/Bethesda R. Diggs, ADM T. Barnhart (8) E. L. Jordan L. J. Harmon B. Grimes J. Partlow ACRS (10) OPA RKarsch NThompson EButcher