Mr. H. L. Sumner, Jr. Vice President - Nuclear Hatch Project Southern Nuclear Operating Company, Inc. Post Office Box 1295 Birmingham, Alabama 35201-1295

EDWIN I. HATCH NUCLEAR PLANT, UNITS 1 AND 2 - ISSUANCE OF SUBJECT: AMENDMENTS RE: INCREASE IN ALLOWABLE VALUE OF REACTOR BUILDING AND REFUELING FLOOR VENTILATION EXHAUST RADIATION MONITORS(TAC NOS. MA2391 AND MA2392)

Dear Mr. Sumner:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 216 to Facility Operating License DPR-57 and Amendment No. 157 to Facility Operating License NPF-5 for the Edwin I. Hatch Nuclear Plant, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated January 21, 1999, which superseded your application dated July 22, 1998. The amendments revise the TS high radiation trip setpoints for the reactor building and the refueling floor ventilation exhaust monitors.

The amendments revise the TS high radiation trip setpoints for the reactor building and the refueling floor ventilation exhaust monitors.

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:

Leonard N. Olshan, Senior Project Manager, Section 1 Project Directorate II **Division of Licensing Project Management** Office of Nuclear Reactor Regulation

Docket Nos. 50-321 and 50-366

Enclosures:

906110202

- 1. Amendment No. 216 to DPR-57
- 2. Amendment No. 157 to NPF-5
- 3. Safety Evaluation

cc w/encls: See next page

GONAN

DISTRIBUTION: Docket File

ACRS PDII-1 R/F GHill(4) PSkinner, RII JZwolinski/SBlack WBeckner, TSB CNorsworthy (e-mail SE only)

OGC

*See previous concurrence

DOCUMENT NAME: G:\HATCH\AMD2391.WPD To receive a copy of this document, indicate in the box C=Copy w/o attachment/enclosure E=Copy with attachment/enclosure N = No copy

RTedesse

PUBLIC

OFFICE	PDII-1/PM	PDII-1/LA E	OGC*	PDII-1/SC	PDII/D_,00	SPSB*
NAME 🗸	LOIshan:cn	CHawes CMN	SHom	REmch RLE	HBerkow	MReinhart
DATE	5 14 199	4 130 199	04/29/99	573 199	514 199	4/14/99
OFFICIAL RECORD COPY * No mayor chop to SE.						

FILF CENTER GO



WASHINGTON, D.C. 20555-0001 June 9, 1999

Mr. H. L. Sumner, Jr. Vice President - Nuclear Hatch Project Southern Nuclear Operating Company, Inc. Post Office Box 1295 Birmingham, Alabama 35201-1295

SUBJECT: EDWIN I. HATCH NUCLEAR PLANT, UNITS 1 AND 2 - ISSUANCE OF AMENDMENTS RE: INCREASE IN ALLOWABLE VALUE OF REACTOR BUILDING AND REFUELING FLOOR VENTILATION EXHAUST RADIATION MONITORS (TAC NOS. MA2391 AND MA2392)

Dear Mr. Sumner:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 216 to Facility Operating License DPR-57 and Amendment No. 157 to Facility Operating License NPF-5 for the Edwin I. Hatch Nuclear Plant, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated January 21, 1999, which superseded your application dated July 22, 1998. The amendments revise the TS high radiation trip setpoints for the reactor building and the refueling floor ventilation exhaust monitors.

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly <u>Federal Register</u> notice.

Sincerely.

Leonard N. Olshan, Senior Project Manager, Section 1 Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket Nos. 50-321 and 50-366

Enclosures:

- 1. Amendment No. 216 to DPR-57
- 2. Amendment No. ¹⁵⁷ to NPF-5
- 3. Safety Evaluation

cc w/encls: See next page

Edwin I. Hatch Nuclear Plant

cc:

Mr. Ernest L. Blake, Jr. Shaw, Pittman, Potts and Trowbridge 2300 N Street, NW. Washington, DC 20037

Mr. D. M. Crowe Manager, Licensing Southern Nuclear Operating Company, Inc. P. O. Box 1295 Birmingham, Alabama 35201-1295

Resident Inspector Plant Hatch 11030 Hatch Parkway N. Baxley, Georgia 31531

Mr. Charles H. Badger Office of Planning and Budget Room 610 270 Washington Street, SW. Atlanta, Georgia 30334

Harold Reheis, Director Department of Natural Resources 205 Butler Street, SE., Suite 1252 Atlanta, Georgia 30334

Steven M. Jackson Senior Engineer - Power Supply Municipal Electric Authority of Georgia 1470 Riveredge Parkway, NW Atlanta, Georgia 30328-4684 Charles A. Patrizia, Esquire Paul, Hastings, Janofsky & Walker 10th Floor 1299 Pennsylvania Avenue Washington, DC 20004-9500

Chairman Appling County Commissioners County Courthouse Baxley, Georgia 31513

Mr. J. D. Woodard Executive Vice President Southern Nuclear Operating Company, Inc. P. O. Box 1295 Birmingham, Alabama 35201-1295

Mr. P. W. Wells General Manager, Edwin I. Hatch Nuclear Plant Southern Nuclear Operating Company, Inc. U.S. Highway 1 North P. O. Box 2010 Baxley, Georgia 31515

Mr. R. D. Barker Program Manager Fossil & Nuclear Operations Oglethorpe Power Corporation 2100 East Exchange Place P. O. Box 1349 Tucker, Georgia 30085-1349



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SOUTHERN NUCLEAR OPERATING COMPANY, INC.

GEORGIA POWER COMPANY

OGLETHORPE POWER CORPORATION

MUNICIPAL ELECTRIC AUTHORITY OF GEORGIA

CITY OF DALTON, GEORGIA

DOCKET NO. 50-321

EDWIN I. HATCH NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 216 License No. DPR-57

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Edwin I. Hatch Nuclear Plant, Unit 1 (the facility) Facility Operating License No. DPR-57 filed by Southern Nuclear Operating Company. Inc. (Southern Nuclear), acting for itself, Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, and City of Dalton, Georgia (the licensees), dated January 21, 1999, which superseded your application dated July 22, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I:
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I:
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-57 is hereby amended to read as follows:
 - (2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 216, are hereby incorporated in the license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Richard L. Emch. S.

Richard L. Emch, Jr., Chief, Section 1 Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Attachment: Technical Specification Changes

Date of Issuance: June 9, 1999

ATTACHMENT TO LICENSE AMENDMENT NO. 216

FACILITY OPERATING LICENSE NO. DPR-57

DOCKET NO. 50-321

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

<u>Remove</u>	Insert
3.3-56	3.3-56
3.3-62	3.3-62

	FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2.	Primary Containment Isolation (continued)					
	c. Drywell Radiation - High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 138 R/hr
	d. Reactor Building Exhaust Radiation — High	1,2,3	2	G	SR 3.3.6.1.1 SR 3.3.6.1.3 SR 3.3.6.1.6	≤ 80 mR/hr
	e. Refueling Floor Exhaust Radiation — High	1,2,3	2	G	SR 3.3.6.1.1 SR 3.3.6.1.3 SR 3.3.6.1.6	≤ 80 mR/hr
3.	High Pressure Coolant Injection (HPCI) System Isolation					
	a. HPCI Steam Line Flow — High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 303% rated steam flow
	b. HPCI Steam Supply Line Pressure - Low	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≥ 100 psig
	c. HPCI Turbine Exhaust Diaphragm Pressure - High	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤20 psig
	d. Drywell Pressure – High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 1.92 psig
	e. HPCI Pipe Penetration Room Temperature — High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 169°F
	f. Suppression Pool Area Ambient Temperature — High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 169°F
						(continued)

Table 3.3.6.1-1 (page 2 of 4) Primary Containment Isolation Instrumentation

1

	FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1.	Reactor Vessel Water Level — Low Low, Level 2	1,2,3, (a)	2	SR 3.3.6.2.1 SR 3.3.6.2.2 SR 3.3.6.2.4 SR 3.3.6.2.5	≥ -47 inches
2.	Drywell Pressure — High	1,2,3	2	SR 3.3.6.2.1 SR 3.3.6.2.2 SR 3.3.6.2.4 SR 3.3.6.2.5	≤ 1.92 psig
5.	Reactor Building Exhaust Radiation — High	1,2,3, (a)	2	SR 3.3.6.2.1 SR 3.3.6.2.3 SR 3.3.6.2.5	≤ 80 mR/hr
	Refueling Floor Exhaust Radiation — High	1,2,3, 5 ^(a) ,(b)	2	SR 3.3.6.2.1 SR 3.3.6.2.3 SR 3.3.6.2.5	≤ 80 mR/hr

Table 3.3.6.2-1 (page 1 of 1) Secondary Containment Isolation Instrumentation

(a) During operations with a potential for draining the reactor vessel.

(b) During CORE ALTERATIONS and during movement of irradiated fuel assemblies in secondary containment.



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SOUTHERN NUCLEAR OPERATING COMPANY, INC.

GEORGIA POWER COMPANY

OGLETHORPE POWER CORPORATION

MUNICIPAL ELECTRIC AUTHORITY OF GEORGIA

CITY OF DALTON, GEORGIA

DOCKET NO. 50-366

EDWIN I. HATCH NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 157 License No. NPF-5

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Edwin I. Hatch Nuclear Plant, Unit 2 (the facility) Facility Operating License No. NPF-5 filed by Southern Nuclear Operating Company, Inc. (Southern Nuclear), acting for itself, Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, and City of Dalton, Georgia (the licensees), dated January 21, 1999, which superseded your application dated July 22, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-5 is hereby amended to read as follows:
 - (2) <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 157 are hereby incorporated in the license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Richard L.Emch. A.

Richard L. Emch, Jr., Chief, Section 1 Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Attachment: Technical Specification Changes

Date of Issuance: June 9, 1999

ATTACHMENT TO LICENSE AMENDMENT NO. 157

FACILITY OPERATING LICENSE NO. NPF-5

DOCKET NO. 50-366

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

<u>Remove</u>	<u>Insert</u>
3.3-57	3.3-57
3.3-63	3.3-63

	FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
2.	Primary Containment Isolation (continued)					
	c. Drywell Radiation-High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 138 R/hr
	d. Reactor Building Exhaust Radiation — High	1,2,3	2	G	SR 3.3.6.1.1 SR 3.3.6.1.3 SR 3.3.6.1.6	≤ 80 maR/h r
	e. Refueling Floor Exhaust Radiation - High	1,2,3	2	G	SR 3.3.6.1.1 SR 3.3.6.1.3 SR 3.3.6.1.6	≤ 80 mR/hr
3.	High Pressure Coolant Injection (HPCI) System Isolation					
	a. HPCI Steam Line Flow — High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 303% rated steam flow
	b. HPCI Steam Supply Line Pressure – Low	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≥ 100 psig
	c. HPCI Turbine Exhaust Diaphragm Pressure - High	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 20 psig
	d. Drywell Pressure — High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 1.92 psig
	e. HPCI Pipe Penetration Room Temperature - High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 169°F
	f. Suppression Pool Area Ambient Temperature - High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 169°F
						(continued)

Table 3.3.6.1-1 (page 2 of 4) Primary Containment Isolation Instrumentation

~

.

.

•

• •

	FUNCTION	APPLICABLE NODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1.	Reactor Vessel Water Level — Low Low, Level 2	1,2,3, (a)	2	SR 3.3.6.2.1 SR 3.3.6.2.2 SR 3.3.6.2.4 SR 3.3.6.2.5	≥ -47 inches
2.	Drywell Pressure — High	1,2,3	2	SR 3.3.6.2.1 SR 3.3.6.2.2 SR 3.3.6.2.4 SR 3.3.6.2.5	≤ 1.92 psig
3.	Reactor Building Exhaust Radiation — High	1,2,3, (a)	2	SR 3.3.6.2.1 SR 3.3.6.2.3 SR 3.3.6.2.5	≤ 80 mR/hr
4.	Refueling Floor Exhaust Rediation — High	1,2,3, 5 ^(a) ,(b)	2	SR 3.3.6.2.1 SR 3.3.6.2.3 SR 3.3.6.2.5	≤ 80 mR/hr

Table 3.3.6.2-1 (page 1 of 1) Secondary Containment Isolation Instrumentation

(a) During operations with a potential for draining the reactor vessel.

(b) During CORE ALTERATIONS and during movement of irradiated fuel assemblies in secondary containment.

.



WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 216 TO FACILITY OPERATING LICENSE DPR-57

AND AMENDMENT NO. 157 TO FACILITY OPERATING LICENSE NPF-5

SOUTHERN NUCLEAR OPERATING COMPANY, INC., ET AL.

EDWIN I. HATCH NUCLEAR PLANT, UNITS 1 AND 2

DOCKET NOS. 50-321 AND 50-366

1.0 INTRODUCTION

By letter dated January 21, 1999, which superseded a letter dated July 22, 1998, Southern Nuclear Operating Company, Inc. (SNC/licensee), proposed license amendments to change the Technical Specifications (TS) for the Edwin I. Hatch Nuclear Plant, Units 1 and 2. The proposed changes would increase the Allowable Values for the high radiation trip for the reactor building and the refueling floor ventilation exhaust monitors to \leq 80 mR/hr for both monitors. The current setpoint for the reactor building ventilation exhaust monitor is \leq 20 mR/hr and the current setpoint for the refueling floor ventilation exhaust monitor is \leq 60 mR/hr.

2.0 BACKGROUND

The function of the reactor building and the refueling floor ventilation exhaust radiation monitors, in combination with other accident mitigation systems, is to limit fission product release during a postulated design basis accident. The monitors automatically initiate closure of the appropriate secondary containment isolation valves and start the standby gas treatment system. Therefore, the Allowable Values for the trip set points are chosen to insure radioactive releases do not exceed offsite dose limits.

3.0 EVALUATION

906110208 990609

In the supporting documentation for the Technical Specifications amendment request, the licensee calculated the radiation field (mR/hr) that would exist at each of the ventilation monitors following a fuel handling accident and the corresponding monitors' response to that field. Using the most conservative radiation monitor response, the license determined that an analytical limit of 340 mR/hr would limit releases such that the resulting offsite doses were well within Title 10 of the <u>Code of Federal Regulations</u> (10 CFR) Section 100.11 acceptance criteria. The licensee concludes that the proposed Allowable Value of \leq 80 mR/hr is well below the analytical limit.

The staff reviewed the licensee's conclusion and performed an independent calculation to verify the acceptability of the licensee's conclusion. The staff determined that changing the alarm set point to \leq 80 mR/hr would not have an adverse impact on the Design Basis Fuel Handling Accident. The staff preformed an independent calculation of the fuel handling accident using

the assumptions of Regulatory Guide 1.25, "Assumptions Used For Evaluation of the Potential Radiological Consequences of a Fuel Handling Accident in the Fuel Handling and Storage Facility for Boiling and Pressurized Water Reactors".

The staff's calculations confirmed that the thyroid doses at the Exclusion Area Boundary (EAB) and Low Population Zone (LPZ) from the fuel handling accident in the auxiliary building meet the acceptance criteria. The parameters which the staff utilized in its assessment are presented in Table 1. For the fuel handling accident in the auxiliary building, the staff calculated a dose of 0.017 rem thyroid at the EAB and at the LPZ. The acceptance criteria at the EAB and LPZ for this accident are contained in Standard Review Plan Section 15.7.4 of NUREG-0800 (75 rem thyroid dose; 25 percent of 10 CFR Part 100 guideline of 300 rem). The staff agrees with the licensee's conclusion that the proposed change will not affect any of the assumptions used to analyze the fuel handling accident. Therefore, the proposed change is acceptable.

Table 1

ASSUMPTION USED FOR CALCULATING RADIOLOGICAL CONSEQUENCES

Parameters	Quantity
Power Level (Mwt) Number of Fuel Rods Damaged Total Number of Fuel Rods	2763 125 34720
Shutdown Time, Hours Power Peaking Factor	24 1.5
Filter Efficiencies (%) elemental organic	95 95
Receptor Point Variables	
Atmosphere Relative Concentration, X/Q (sec/m ³) Exclusion Area Boundary 0-2 hours (1250m) Low Population Zone, duration (1250m)	1.7E-6 1.7E-6

Note: Dose conversion factor from ICRP-30 were utilized for all calculations.

- 2 -

TABLE 2

- 3 -

RADIOLOGICAL CONSEQUENCES PROJECTED BY STAFF, REM

	Thyroid dose	Acceptance Criteria
Exclusion Area Boundary, 0-2 hours	0.017	75
Low Population Zone, duration	0.017	75

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Georgia State official was notified of the proposed issuance of the amendments. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to the installation or use of facility components located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts and no significant change in the types of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (64 FR 24200). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: R. Tadesse

Date: June 9, 1999