

Docket Nos.: 50-413  
and 50-414

September 8, 1986

Mr. H.B. Tucker, Vice President  
Nuclear Production Department  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242

Dear Mr. Tucker:

SUBJECT: ISSUANCE OF AMENDMENT NO. 9 TO FACILITY OPERATING LICENSE NPF-35  
AND AMENDMENT NO. 2 TO FACILITY OPERATING LICENSE NPF-52  
CATAWBA NUCLEAR STATION, UNITS 1 AND 2

The Nuclear Regulatory Commission has issued the enclosed Amendment No.9 to Facility Operating License NPF-35 and Amendment No.2 to Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2. These amendments consist of changes to the Technical Specifications in response to your application dated July 22, 1985, and supplemented September 11, 1985, March 7, 1986, and June 12, 1986.

The amendments change the Technical Specifications to increase the allowed out-of-service times for Reactor Trip System analog channels. The amendments are effective as of their date of issuance.

The changes authorized by these amendments have been accepted on the basis of the staff's Safety Evaluation Report of February 21, 1985, regarding WCAP-10271, "Evaluation of Surveillance Frequencies and Out-of-Service Times for the Reactor Protection Instrumentation System," and Supplement 1 thereto.

A copy of the related safety evaluation supporting Amendment No. 9 to Facility Operating License NPF-35 and Amendment No. 2 to Facility Operating License NPF-52 is enclosed.

Notice of issuance will be included in the Commission's next bi-weekly Federal Register notice.

Sincerely,

151

Kahtan N. Jabbour, Project Manager  
PWR Project Directorate #4  
Division of PWR Licensing-A

Enclosures:

1. Amendment No. 9 to NPF-35
2. Amendment No. 2 to NPF-52
3. Safety Evaluation

cc w/enclosures: See next page

PWR#4/DPWR-A  
MDuncan/rad  
08/25/86

*KNS*  
PWR#4/DPWR-A  
KJabbour  
08/25/86

*BJ Youngblood*  
PWR#4/DPWR-A  
BJYoungblood  
08/ 5/86

8609120249 860908  
PDR ADOCK 05000413  
P PDR

Mr. H. B. Tucker  
Duke Power Company

Catawba Nuclear Station

cc:

William L. Porter, Esq.  
Duke Power Company  
P.O. Box 33189  
Charlotte, North Carolina 28242

North Carolina Electric Membership  
Corp.  
3333 North Boulevard  
P.O. Box 27306  
Raleigh, North Carolina 27611

J. Michael McGarry, III, Esq.  
Bishop, Liberman, Cook, Purcell  
and Reynolds  
1200 Seventeenth Street, N.W.  
Washington, D. C. 20036

Saluda River Electric Cooperative,  
Inc.  
P.O. Box 929  
Laurens, South Carolina 29360

North Carolina MPA-1  
Suite 600  
3100 Smoketree Ct.  
P.O. Box 29513  
Raleigh, North Carolina 27626-0513

Senior Resident Inspector  
Route 2, Box 179N  
York, South Carolina 29745

Mr. C. D. Markham  
Power Systems Division  
Westinghouse Electric Corp.  
P.O. Box 355  
Pittsburgh, Pennsylvania 15230

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission,  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

NUS Corporation  
2536 Countryside Boulevard  
Clearwater, Florida 33515

Mr. Heyward G. Shealy, Chief  
Bureau of Radiological Health  
South Carolina Department of Health  
and Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

County Manager of York County  
York County Courthouse  
York South Carolina 29745

Karen E. Long  
Assistant Attorney General  
N.C. Department of Justice  
P.O. Box 629  
Raleigh, North Carolina 27602

Richard P. Wilson, Esq.  
Assistant Attorney General  
S.C. Attorney General's Office  
P.O. Box 11549  
Columbia, South Carolina 29211

Spence Perry, Esquire  
Associate General Counsel  
Federal Emergency Management Agency  
Room 840  
500 C Street  
Washington, D. C. 20472

Piedmont Municipal Power Agency  
100 Memorial Drive  
Greer, South Carolina 29651

Mark S. Calvert, Esq.  
Bishop, Liberman, Cook,  
Purcell & Reynolds  
1200 17th Street, N.W.  
Washington, D. C. 20036

Mr. Michael Hirsch  
Federal Emergency Management Agency  
Office of the General Counsel  
Room 840  
500 C Street, S.W.  
Washington, D. C. 20472

Brian P. Cassidy, Regional Counsel  
Federal Emergency Management Agency,  
Region I  
J. W. McCormach POCH  
Boston, Massachusetts 02109

AMENDMENT NO. 9 TO FACILITY OPERATING LICENSE NPF-35 -  
CATAWBA NUCLEAR POWER STATION, UNIT 1  
AMENDMENT NO. 2 TO FACILITY OPERATING LICENSE NPF-52 -  
CATAWBA NUCLEAR POWER STATION, UNIT 2

DISTRIBUTION: w/enclosures:

Docket File

NRC PDR  
Local PDR  
NSIC  
PRC System  
PWR#4 R/F  
B. J. Youngblood  
K. Jabbour  
M. Duncan  
OGC/Bethesda  
R. Diggs, ADM  
T. Barnhart (8)  
E. L. Jordan  
L. J. Harmon  
B. Grimes  
J. Partlow  
M. Virgilio  
R. Emch, TOSB  
F. Burrows, EICSB  
ACRS (10)  
OPA



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

DUKE POWER COMPANY

NORTH CAROLINA ELECTRIC MEMBERSHIP CORPORATION

SALUDA RIVER ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-413

CATAWBA NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 9  
License No. NPF-35

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the Catawba Nuclear Station, Unit 1 (the facility) Facility Operating License No. NPF-35 filed by the Duke Power Company acting for itself, North Carolina Electric Membership Corporation, and Saluda River Electric Cooperative, Inc., (the licensee) dated July 22, 1985, and supplemented September 11, 1985 and June 12, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8609120255 860908  
PDR ADOCK 05000413  
P PDR

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-35 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 9, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into the license. Duke Power Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

151

Kahtan N. Jabbour, Project Manager  
PWR Project Directorate #4  
Division of PWR Licensing-A

Attachment:  
Technical Specification  
Changes

Date of Issuance: September 8, 1986

PWR#4/DPWR-A  
MDuncan  
09/25/86

KNT  
PWR#4/DPWR-A  
KJabbour/rad  
08/25/86

81  
Johnson  
OGC-Beth  
09/17/86

DLWalt  
PWR#4/DPWR-A  
BJYoungblood  
09/15/86



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

DUKE POWER COMPANY

NORTH CAROLINA ELECTRIC MEMBERSHIP CORPORATION

PIEDMONT MUNICIPAL POWER AGENCY

DOCKET NO. 50-414

CATAWBA NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 2  
License No. NPF-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the Catawba Nuclear Station, Unit 2 (the facility) Facility Operating License No. NPF-52 filed by the Duke Power Company, acting for itself, North Carolina Electric Membership Corporation, and Piedmont Municipal Power Agency, (the licensee) dated July 22, 1985, and supplemented September 11, 1985, March 7, 1986 and June 12, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-35 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 2, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into the license. Duke Power Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

151

Kahtan N. Jabbour, Project Manager  
PWR Project Directorate #4  
Division of Licensing-A

Attachment:  
Technical Specification  
Changes

Date of Issuance: September 8, 1986

PWR#4/DPWR-A  
MDuncan  
08/25/86

*KNS*  
PWR#4/DPWR-A  
KJabbour/rad  
08/25/86

*Johnson*  
OGC-Beth  
09/2/86

*R. Wait*  
PWR#4/DPWR-A  
BJYoungblood  
09/15/86

ATTACHMENT TO LICENSE AMENDMENT NO. 9

FACILITY OPERATING LICENSE NO. NPF-35

DOCKET NO. 50-413

AND

TO LICENSE AMENDMENT NO. 2

FACILITY OPERATING LICENSE NO. NPF-52

DOCKET NO. 50-414

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change. The corresponding overleaf pages are also provided to maintain document completeness.

Amended  
Page

3/4 3-2

3/4 3-3

3/4 3-5

3/4 3-6

Overleaf  
Page

3/4 3-1

3/4 3-4



### 3/4.3 INSTRUMENTATION

#### 3/4.3.1 REACTOR TRIP SYSTEM INSTRUMENTATION

##### LIMITING CONDITION FOR OPERATION

---

3.3.1 As a minimum, the Reactor Trip System instrumentation channels and interlocks of Table 3.3-1 shall be OPERABLE with RESPONSE TIMES as shown in Table 3.3-2.

APPLICABILITY: As shown in Table 3.3-1.

ACTION:

As shown in Table 3.3-1.

##### SURVEILLANCE REQUIREMENTS

---

4.3.1.1 Each Reactor Trip System instrumentation channel and interlock and the automatic trip logic shall be demonstrated OPERABLE by the performance of the Reactor Trip System Instrumentation Surveillance Requirements specified in Table 4.3-1.

4.3.1.2 The REACTOR TRIP SYSTEM RESPONSE TIME of each Reactor trip function shall be demonstrated to be within its limit at least once per 18 months. Each test shall include at least one train such that both trains are tested at least once per 36 months and one channel per function such that all channels are tested at least once every N times 18 months where N is the total number of redundant channels in a specific reactor trip function as shown in the "Total No. of Channels" column of Table 3.3-1.

TABLE 3.3-1

REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
1. Manual Reactor Trip	2	1	2	1, 2	1
	2	1	2	3*, 4*, 5*	10
2. Power Range, Neutron Flux					
a. High Setpoint	4	2	3	1, 2	2#
b. Low Setpoint	4	2	3	1###, 2	2#
3. Power Range, Neutron Flux High Positive Rate	4	2	3	1, 2	2#
4. Power Range, Neutron Flux, High Negative Rate	4	2	3	1, 2	2#
5. Intermediate Range, Neutron Flux	2	1	2	1###, 2	3
6. Source Range, Neutron Flux					
a. Startup	2	1	2	2##	4
b. Shutdown	2	1	2	3, 4, 5	5
7. Overtemperature $\Delta T$ Four Loop Operation	4	2	3	1, 2	6#
8. Overpower $\Delta T$ Four Loop Operation	4	2	3	1, 2	6#
9. Pressurizer Pressure-Low	4	2	3	1	6#**

CATAMBA - UNITS 1 &amp; 2

3/4 3-2

Amendment No. 9 (Unit 1)  
Amendment No. 2 (Unit 2)

TABLE 3.3-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
10. Pressurizer Pressure-High	4	2	3	1, 2	6#**
11. Pressurizer Water Level-High	3	2	2	1	6#
12. Reactor Coolant Flow-Low					
a. Single Loop (Above P-8)	3/loop	2/loop in any operating loop	2/loop in each operating loop	1	6#
b. Two Loops (Above P-7 and below P-8)	3/loop	2/loop in two operating loops	2/loop each operating loop	1	6#
13. Steam Generator Water Level--Low-Low	4/stm gen	2/stm gen in any operating stm gen	3/stm gen each operating stm gen	1, 2	6#**
14. Undervoltage-Reactor Coolant Pumps (Above P-7)	4-1/bus	2	3	1	6#
15. Underfrequency-Reactor Coolant Pumps (Above P-7)	4-1/bus	2	3	1	6#
16. Turbine Trip					
a.1 Low Control Valve EH Pressure - (Unit 1)	4	2	3	1####	6#
a.2 Stop Valve EH Pressure - Low (Unit 2)	4	2	3	1####	6#
b. Turbine Stop Valve Closure	4	4	1	1####	11#
17. Safety Injection Input from ESF	2	1	2	1, 2	9

CATAWBA - UNITS 1 & 2

3/4 3-3

Amendment No. 9 (Unit 1)  
Amendment No. 2 (Unit 2)

TABLE 3.3-1 (Continued)  
REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
18. Reactor Trip System Interlocks					
a. Intermediate Range Neutron Flux, P-6	2	1	2	2##	8
b. Low Power Reactor Trips Block, P-7					
P-10 Input	4	2	3	1	8
or					
P-13 Input	2	1	2	1	8
c. Power Range Neutron Flux, P-8	4	2	3	1	8
d. Power Range Neutron Flux, P-9	4	2	3	1	8
e. Power Range Neutron Flux, P-10	4	2	3	1	8
f. Power Range Neutron Flux, Not P-10	4	3	4	1, 2	8
g. Turbine Impulse Chamber Pressure, P-13	2	1	2	1	8
19. Reactor Trip Breakers	2	1	2	1, 2	9
	2	1	2	3*, 4*, 5*	10
20. Automatic Trip and Interlock Logic	2	1	2	1, 2	9
	2	1	2	3*, 4*, 5*	10

TABLE 3.3-1 (Continued)

TABLE NOTATIONS

\*Only if the Reactor Trip System breakers happen to be in the closed position and the Control Rod Drive System is capable of rod withdrawal.

\*\*Comply with the provisions of Specification 3.3.2, for any portion of the channel required to be OPERABLE by Specification 3.3.2.

#The provisions of Specification 3.0.4 are not applicable.

##Below the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint.

###Below the P-10 (Low Setpoint Power Range Neutron Flux Interlock) Setpoint.

####Above the P-9 (Reactor Trip on Turbine Trip Interlock) Setpoint.

ACTION STATEMENTS

ACTION 1 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within the next 6 hours.

ACTION 2 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:

- a. The inoperable channel is placed in the tripped condition within 6 hours,
- b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.3.1.1, and
- c. Either, THERMAL POWER is restricted to less than or equal to 75% of RATED THERMAL POWER and the Power Range Neutron Flux trip setpoint is reduced to less than or equal to 85% of RATED THERMAL POWER within 4 hours; or, the QUADRANT POWER TILT RATIO is monitored at least once per 12 hours per Specification 4.2.4.2.

ACTION 3 - With the number of channels OPERABLE one less than the Minimum Channels OPERABLE requirement and with the THERMAL POWER level:

- a. Below the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above the P-6 Setpoint; or
- b. Above the P-6 (Intermediate Range Neutron Flux Interlock) Setpoint but below 10% of RATED THERMAL POWER, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above 10% of RATED THERMAL POWER.

TABLE 3.3-1 (Continued)

ACTION STATEMENTS (Continued)

- ACTION 4 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, suspend all operations involving positive reactivity changes.
- ACTION 5 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 48 hours or open the Reactor trip breakers, suspend all operations involving positive reactivity changes and verify Valves NV-231, NV-237, NV-241, and NV-244 are closed and secured in position within the next hour.
- ACTION 6 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:
- a. The inoperable channel is placed in the tripped condition within 6 hours, and
  - b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 4 hours for surveillance testing of other channels per Specification 4.3.1.1.
- ACTION 7 - Delete
- ACTION 8 - With less than the Minimum Number of Channels OPERABLE, within 1 hour determine by observation of the associated permissive status light(s) that the interlock is in its required state for the existing plant condition, or apply Specification 3.0.3.
- ACTION 9 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, be in at least HOT STANDBY within 6 hours; however, one channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.1.1, provided the other channel is OPERABLE.
- ACTION 10 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 48 hours or open the Reactor trip breakers within the next hour.
- ACTION 11 - With the number of OPERABLE channels less than the Total Number of Channels, operation may continue provided the inoperable channels are placed in the tripped condition within 6 hours.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO.9 TO FACILITY OPERATING LICENSE NPF-35  
AND AMENDMENT NO.2 TO FACILITY OPERATING LICENSE NPF-52

DUKE POWER COMPANY, et al

CATAWBA NUCLEAR STATION, UNITS 1 AND 2

INTRODUCTION

On February 21, 1985, the NRC staff issued its Safety Evaluation Report (SER) on the Westinghouse Technical Specification Optimization Program for increased surveillance intervals and out-of-service times for testing and maintenance of the Reactor Trip System (RTS). The Optimization Program proposal was set forth in WCAP-10271, "Evaluation of Surveillance Frequencies and Out-of-Service Times for Reactor Protection Instrumentation System," and Supplement 1 thereto.

By letter dated July 22, 1986, Duke Power Company, et al., (the licensee) proposed several changes to the Catawba Technical Specifications based on the Optimization Program. One of these proposed changes, which sought to allow RTS analog channel testing in a bypassed condition instead of a tripped condition, was withdrawn by a subsequent letter from the licensee, dated September 11, 1985. The remaining proposed changes have been evaluated by the NRC staff. A March 7, 1986, letter requested that the above changes also be approved for Catawba Unit 2 which received its low power license on February 24, 1986. The June 12, 1986, letter clarified the licensee's request regarding the turbine stop valve closure/turbine trip.

EVALUATION

These amendments increase, from one to six hours, the time during which an inoperable RTS analog channel may be maintained in an untripped condition (See Table 3.3-1, Action Statements 2a and 6a in the revised Technical Specifications). The time an inoperable RTS analog channel may be bypassed to allow testing of another channel in the same function is increased from two to four hours (See Table 3.3-1, Action Statements 2b and 6b in the revised Technical Specifications). A cautionary note is added to the action statements referencing the more stringent requirements for Engineered Safety Feature Actuation System (ESFAS) channels for RTS analog channels common to ESFAS (See Table 3.3-1, Functional Units 9, 10, and 13 and Note \*\*). The time an inoperable turbine stop valve instrument channel (associated with the reactor trip system) may be maintained in an untripped condition is increased from one hour to six hours (See Table 3.3-1, Action Statement 11 in the revised Technical Specifications. We find these changes to be consistent with those which we reviewed and accepted for the Optimization Program proposal. Therefore, the staff finds these changes acceptable on the bases set forth in the staff's February 21, 1985, SER.

8609120264 860908  
PDR ADOCK 05000413  
P PDR

The amendments delete Action Statement 7 and substitute a reference to Action Statement 6 for those reactor trip channels which referenced Action Statement 7 (See Table 3.3-1, Functional Units 11, 12 and 16a in the revised Technical Specifications). This change is discussed in Supplement 1 to WCAP-10271 and results from the similarity and the intent of Action Statements 6 and 7. Further, the staff in a July 24, 1985, letter from Harold R. Denton to L.B. Butterfield identified this to be a specific acceptable revision in the model technical specifications provided to the Westinghouse Owner Group (WOG). On this basis, the staff finds this change acceptable as proposed by the licensee.

#### ENVIRONMENTAL CONSIDERATION

The amendments involve a change in use of facility components located within the restricted area as defined in 10 CFR Part 20 and a change in surveillance requirements. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there have been no public comments on such finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

#### CONCLUSION

The Commission made proposed determinations that the amendments involve no significant hazards consideration which were published in the Federal Register (50 FR 51620) on December 18, 1985, for Catawba Unit 1 and (51 FR 10456) on March 26, 1986, for Catawba Unit 2, and consulted with the state of South Carolina. No public comments were received, and the state of South Carolina did not have any comments.

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: Kahtan Jabbour, PD#4  
Fred Burrows, EISCB  
Richard Emch, TOSB

Dated: September 8, 1986