

April 10, 1997

Mr. H. L. Sumner, Jr.
Vice President
Southern Nuclear Operating
Company, Inc.
Post Office Box 1295
Birmingham, Alabama 35201-1295

SUBJECT: CORRECTED PAGES TO LICENSE TRANSFER AMENDMENTS - EDWIN I. HATCH
NUCLEAR PLANT, UNITS 1 AND 2 (TAC NOS. M84534 AND M84535)

Dear Mr. Sumner:

This letter forwards corrected pages to Amendment No. 203 to Facility Operating License DPR-57 and Amendment No. 144 to Facility Operating License NPF-5 for the Edwin I. Hatch Nuclear Plant, Units 1 and 2, issued on March 17, 1997. The corrected pages are needed to correct errors inadvertently introduced by the staff in the March 17, 1997, license amendments. The errors were introduced when the pages associated with the amendments were retyped. Please replace the following pages with the enclosed corrected pages: Amendment page 2 for Unit 1; Amendment index page for Unit 1; Amendment page 2 for Unit 2; Amendment index page for Unit 2; and Unit 2 license page 4.

Sincerely,

ORIGINAL SIGNED BY H. BERKOW
FOR:

Kahtan N. Jabbour, Senior Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

NRC FILE CENTER COPY

Docket Nos. 50-321 and 50-366

Enclosures: As stated (5)

cc w/encl: See next page

DISTRIBUTION

Docket File J. Johnson, RII
PUBLIC P. Skinner, RII
PDII-2 RF G. Hill (4)
S. Varga ACRS
OGC R. Zimmerman
SCollins/FMiraglia

9704110163 970410
PDR ADOCK 05000321
P PDR

DOCUMENT NAME: G:\HATCH\HAT84534.COR *See previous concurrence
To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PD22*	E	LA:PD22	E	OGC*	D:PD22	E
NAME	KJabbour:cn	LBerry	EHoller	HBerkow			
DATE	4/1/97	4/9/97	4/7/97	4/9/97			

110025

OFFICIAL RECORD COPY

3/20/97
1/1



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

April 10, 1997


Mr. H. L. Sumner, Jr.
Vice President
Southern Nuclear Operating
Company, Inc.
Post Office Box 1295
Birmingham, Alabama 35201-1295

SUBJECT: CORRECTED PAGES TO LICENSE TRANSFER AMENDMENTS - EDWIN I. HATCH
NUCLEAR PLANT, UNITS 1 AND 2 (TAC NOS. M84534 AND M84535)

Dear Mr. Sumner:

This letter forwards corrected pages to Amendment No. 203 to Facility Operating License DPR-57 and Amendment No. 144 to Facility Operating License NPF-5 for the Edwin I. Hatch Nuclear Plant, Units 1 and 2, issued on March 17, 1997. The corrected pages are needed to correct errors inadvertently introduced by the staff in the March 17, 1997, license amendments. The errors were introduced when the pages associated with the amendments were retyped. Please replace the following pages with the enclosed corrected pages: Amendment page 2 for Unit 1; Amendment index page for Unit 1; Amendment page 2 for Unit 2; Amendment index page for Unit 2; and Unit 2 license page 4.

Sincerely,



Kahtan N. Jabbour, Senior Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-321 and 50-366

Enclosures: As stated (5)

cc w/encl: See next page

Edwin I. Hatch Nuclear Plant
Units 1 and 2

cc:

Mr. Ernest L. Blake, Jr.
Shaw, Pittman, Potts and Trowbridge
2300 N Street, NW.
Washington, DC 20037

Mr. D. M. Crowe
Manager, Licensing
Southern Nuclear Operating
Company, Inc.
P. O. Box 1295
Birmingham, Alabama 35201-1295

Resident Inspector
U.S. Nuclear Regulatory Commission
11030 Hatch Parkway North
Baxley, Georgia 31513

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Mr. Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, SW.
Atlanta, Georgia 30334

Harold Reheis, Director
Department of Natural Resources
205 Butler Street, SE., Suite 1252
Atlanta, Georgia 30334

Steven M. Jackson
Senior Engineer - Power Supply
Municipal Electric Authority
of Georgia
1470 Riveredge Parkway, NW
Atlanta, Georgia 30328-4684

Mr. Thomas P. Mazingo
Program Manager
Nuclear Operations
Oglethorpe Power Corporation
2100 East Exchange Place
P. O. Box 1349
Tucker, Georgia 30085-1349

Charles A. Patrizia, Esquire
Paul, Hastings, Janofsky & Walker
10th Floor
1299 Pennsylvania Avenue
Washington, DC 20004-9500

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513

Mr. W. G. Harriston, III
President and Chief Executive
Officer
Southern Nuclear Operating
Company, Inc.
P. O. Box 1295
Birmingham, Alabama 35201-1295

Mr. J. D. Woodard
Executive Vice President
Southern Nuclear Operating
Company, Inc.
P. O. Box 1295
Birmingham, Alabama 35201-1295

Mr. P. W. Wells
General Manager
Edwin I. Hatch Nuclear Plant
Southern Nuclear Operating
Company, Inc.
11030 Hatch Parkway North
Baxley, Georgia 31513

2. Accordingly, Facility Operating License No. DPR-57 is hereby amended by changing the license, Technical Specifications, and Environmental Protection Plan as indicated in the attachment to this license amendment.
3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

ORIGINAL SIGNED BY:

Frank J. Miraglia, Jr., Acting Director
Office of Nuclear Reactor Regulation

Attachments:

1. Facility Operating License
No. DPR-57
2. Technical Specification
changes
3. Environmental Protection Plan
changes

Date of Issuance: March 17, 1997

ATTACHMENT TO LICENSE AMENDMENT NO. 203

FACILITY OPERATING LICENSE NO. DPR-57

DOCKET NO. 50-321

Replace Facility Operating License DPR-57 with the attached revised License No. DPR-57.

Replace the following pages of the Appendix "A" Technical Specifications and Appendix "B" Environmental Protection Plan with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

	<u>Remove Pages</u>	<u>Insert Pages</u>
Appendix A	5.0-17	5.0-17
Appendix B	Cover	Cover
	1-1	1-1
	4-1	4-1

2. Accordingly, Facility Operating License No. NPF-5 is hereby amended by changing the license, Technical Specifications, and Environmental Protection Plan, as indicated in the attachment to this license amendment.
3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

ORIGINAL SIGNED BY:

Frank J. Miraglia, Jr., Acting Director
Office of Nuclear Reactor Regulation

Attachments:

1. Facility Operating License
No. NPF-5
2. Technical Specification
changes
3. Environmental Protection Plan
changes

Date of Issuance: March 17, 1997

ATTACHMENT TO LICENSE AMENDMENT NO. 144

FACILITY OPERATING LICENSE NO. NPF-5

DOCKET NO. 50-366

Replace Facility Operating License No. NPF-5 with the attached revised License No. NPF-5.

Replace the following pages of the Appendix "A" Technical Specifications and Appendix "B" Environmental Protection Plan with the enclosed revised pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

	<u>Remove Pages</u>	<u>Insert Pages</u>
Appendix A	5.0-17	5.0-17
Appendix B	Cover	Cover
	1-1	1-1
	4-1	4-1

- C. This license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I: Part 20, Section 30.34 of Part 30, Section 40.41 of Part 40, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions² specified or incorporated below:

(1) Maximum Power Level

Southern Nuclear is authorized to operate the facility at steady state reactor core power levels not in excess of 2558 megawatts thermal in accordance with the conditions specified herein and in Attachment 2 to this license. Attachment 2 is an integral part of this license.

(2) Technical Specifications

The Technical Specifications in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. are hereby incorporated in the license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

The Surveillance Requirements (SRs) contained in the Appendix A Technical Specifications and listed below are not required to be performed immediately upon implementation of Amendment No. 135. The SRs listed below shall be successfully demonstrated prior to the time and condition specified below for each:

- a) SRs 3.3.2.2.2, 3.3.2.2.3, 3.3.3.2.2, 3.3.8.1.4, 3.6.2.4.2, 3.7.7.2, and 3.7.7.3 shall be successfully demonstrated prior to entering MODE 2 on the first plant startup following the twelfth refueling outage;
- b) SRs 3.8.1.8, 3.8.1.9 (for DG 2C), 3.8.1.10, 3.8.1.12, 3.8.1.13, 3.8.1.17 (for DG 2C), and 3.8.1.18 shall be successfully demonstrated at their next regularly scheduled performance;
- c) SRs 3.6.4.1.3 and 3.6.4.1.4 will be met at implementation for the secondary containment configuration in effect at that time. The SRs shall be successfully demonstrated for the other secondary containment configurations prior to the plant entering the LCO applicability for that configuration.

² The original licensee authorized to possess, use, and operate the facility was Georgia Power Company (GPC). Consequently, certain historical references to GPC remain in the license conditions.