



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

24 APR 1986

Docket No. 50-413

MEMORANDUM FOR: Donna Nottingham, Secretary

FROM: B. J. Youngblood, Director  
PWR Project Directorate #4  
Division of PWR Licensing-A, NRR

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY NOTICE - NOTICE OF  
ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

Duke Power Company, et al., Docket No. 50-413, Catawba Nuclear Station,  
Unit 1, York County, South Carolina

Date of application for amendment: February 12, 1986, as supplemented  
March 3, 4, 11, and 26, and April 9, 1986.

Brief description of amendment: The amendment changes the Technical  
Specifications to extend, on a one-time basis, by a maximum of five  
months those 18-month surveillances associated with the Engineered  
Safety Features which can only be conducted with Unit 1 in cold shut-  
down or refueling.

Date of issuance: April 24, 1986

Effective date: April 24, 1986

Amendment No.: 7

Facility Operating License No. NPF-35: Amendment revised the Technical  
Specifications.

Date of initial notice in Federal Register: March 21, 1986 (51 FR 9905)

The Commission's related evaluation of the amendment is contained in a  
Safety Evaluation dated April 24, 1986

No significant hazards consideration comments received: No

8605050446 860424  
CF ADDCK 05000413  
CF

Local Public Document Room location: York County Library, 138 East Black  
Street, Rock Hill, South Carolina 29730

151

B. J. Youngblood, Director  
PWR Project Directorate #4  
Division of PWR Licensing-A, NRR

DISTRIBUTION:

Docket File

PRC System

PWR#4 R/F

MDuncan

KJabbour

BJYoungblood

DSH in  
PWR#4:DPWR-A  
MDuncan/mac  
04/14/86

KNT  
PWR#4/DPWR-A  
KJabbour  
04/12/86

DSH in  
PWR#4/DPWR-A  
BJYoungblood  
04/14/86